

ADVISORY BOARD CALENDAR

January 11, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50603CO	11A0105CO	A.S.M. Electric & Machine Corp. 333 West 39th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	589 8th Avenue New York NY	Approved	\$0.00
Carry over from April 13, 2011 meeting.						
50874CO2		Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	26th Ward Water Pollution Plant Brooklyn NY	Hold	\$0.00
Carry over from November 9, 2011 meeting. 1) Rear access for switchboard to comply with Table 110.34. 2) Does coordination study reflect fuse size change? Breakers settings to be locked, tamperproof. 3) Generator cut sheets not provided.						
50997CO		Scott Electrical Service, LLC 40 Macon Street Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	80 Wythe Avenue Brooklyn NY	Approved	\$0.00
1) Fire pump emergency feeder to be 2 hour fire rated. 2) Explain 7 sets of 350 MCM steel box on load side of CT. 3) Provide elevations and side view of Con Ed 377 CT cabinet. 4) Show all bus sizes in main distribution board #1. 5) Is a 3 or 4 pole ATS used for EDP life safety board? Job finalized 3/26/12.						
51033		Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	45-35 Van Dam Street Long Island City NY	Hold	\$0.00
Check submitted under wrong Cal. #51014. 1) Size of service entrance conductors not shown. 2) Verify size of emergency conductors for fire pump. 3) Are separate switches used for emergency system? 4) Cut sheets of generator gen set not provided. 5) Provide documentation that 10' tap complies with 240.21(B)(1). MDSB #1A board does not comply with tap rule switches at 80% over 1000 amp, conductor is undersized. 6) Indicate that all emergency feeders comply with 700 for fire protection.						
51034		Kings Electric Company, Inc. 2113 West 6th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	The Edge Williamsburg 34 North 6th Street Brooklyn NY	Approved	\$650.00
New disconnect switch overfused. Job finalized 2/27/12.						

ADVISORY BOARD CALENDAR

January 11, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51035		Commerce Electrical Contracting Corp. 40-12 28th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	PS-1 MOMA 46-01 21st Street Long Island City NY	Hold	\$650.00
1) Verify the size of the second disconnect switch and its fuse size. 2) Verify the size of the tapped conductors. 3) Correct presentation for switch and fuses. 4) Verify the need for 10 sets for the tap. 5) Provide tap details at existing distribution board.						
51036		Royal Electrical & Wiring Corp. 2558 Marion Avenue Bronx NY 10458	Requested approval for the electric service equipment proposed to be installed	23-10 41st Avenue Long Island City NY	Hold	\$650.00
1) Provide size of main bonding jumper in service switches. 2) Service entrance conductors to CT are undersized. 3) bonding and grounding not shown in "1600 sws". 4) Tap lengths not shown. 5) Tapped conductor undersized. 6) Correct designation TDB and TDP.						
51037		RCM Technologies 3020 Westchester Avenue, Suite 401 Purchase NY 10577	Requested approval for the electric service equipment proposed to be installed	Forensic Investigation Division 150-14 Jamaica Avenue Queens NY	Hold	\$650.00
1) Clearance are not shown in the service room ,2 utility sources are feeding one switchboard without tie breakers. Intent to provide two sources and remove the tie. 2) Main service switch to be changed to service switch ground bond. 3) Taps for FA, fire pump change to services switch ground and bonding. 4) Short circuit values incorrect. 5) Provide location (Sections) of service switches to indicate 5' clearance is required(Both service switches do not face each other) 6) Locate CT in correct location.						
51038		Joseph A. Skarulis, Lic. Electl Contr. 245 Wilson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	150-24 Northern Blvd. Flushing NY	Approved	\$650.00
New fire pump meter new conductor is undersized. Job finalized 3/26/12.						
51039		Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Brooklyn College Chiller Plant Brooklyn NY	Ok, but	\$650.00
1) Drawing not in Advisory Board format. 2) No coordination between TRA PRI and main service switch. 3) TRK PRIM size not indicated.						

ADVISORY BOARD CALENDAR

January 11, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51040		Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	201 East 57th Street New York NY	Approved	\$650.00
1) Bus size not shown in DP-2. 2) Service switches not bonded and grounded. 3) Fuses and switches are backwards. Job finalized 6/15/12. 5/13/14 Rejected This drawing already approved Rev 3 shows neutrals I disconnect switches are bonded. 5/19/14 Rejected This drawing already approved, why is a revision 4 being resubmitted? 5/21/14 Swapped A drawing Rev 4.						
51041		E.S.B. Electric Corp. 250 Walton Avenue, Suite 25 Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	463 7th Avenue New York NY	Approved	\$650.00
Feeder is undersized. Job finalized 2/28/12.						
51042		FSM Electrical Corp. 36-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	960 Sixth Avenue New York NY	Approved	\$650.00
Emergency side fire pump under fused. 9/12/13 job finalized. 1/9/14 Swapped Rev 2.						
51043		Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	307 West 37th Street New York NY	Approved	\$650.00
51044		Allstate Electric Corp. 555 Eighth Avenue, Suite 809 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	600 Third Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 11, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51045		Horsepower Electric 4109 Forth Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	2182 3rd Avenue New York NY	Approved	\$650.00
51046		OHM Electrical Corp. 39-40 21st Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Eatly 200 Fifth Avenue New York NY	Approved	\$650.00
Length of tap not shown. Job finalized 3/26/12.						
51047		Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Time Life 1271 6th Avenue New York NY	Approved	\$650.00
51048		J.M. Electrical Corporation 122 East 42nd Street New York NY 10168	Requested approval for the electric service equipment proposed to be installed	Sony Corporation of America 550 Madison Avenue New York NY	Hold	\$650.00
Are any of the loads connected to the emergency feeder feeding life safety loads?						
51049		Metro Electrical Contractors, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Bronx Court House 878 Brook Avenue Bronx NY	Approved	\$650.00
1) Emergency side fire pump fuse undersized. 2) Provide neutral in fire alarm service switch and disconnect switches. 3) Remove bond in fire alarm emergency switch. Job finalized 3/7/12.						

ADVISORY BOARD CALENDAR

January 11, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51050		A. Ferry Electrical 217A Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	260 West 26th Street New York NY	Approved	\$650.00
1) Equipment grounding conductors undersized. 2) Confirm that service bus has a barrier separating line and load. Job finalized 3/27/12.						
51051		A. Ferry Electrical 217A Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	Elliot Chelsea Houses 401 West 25th Street New York NY	Approved	\$650.00
Service switches, 1,2,4 are overfused. Job finalized 3/27/12.						
51052		Tarasis Electric Corp. 45-48 51st Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Lehman H.S. 3000 East Tremont Avenue Bronx NY	Approved	\$650.00
1) How does 2" conduit enter and leave the fire alarm cutout? How is 1/0 connect to FA terminals? 2) Switch to be installed on fire alarm emergency side, not cutout. 3) Verify that neutrals is not being switched on fire alarm system. Job finalized 3/7/12.						
51053		Stanco Systems Electrical Contracting Inc. 4061 Victory Boulevard Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	SL Green 100 Park Avenue New York NY	Approved	\$650.00
51054		LFG Landmark Facilities Group, Inc. 252 East Avenue Norwalk CT 06855	Requested approval for the electric service equipment proposed to be installed	GVM 145 East 57th Street New York NY	Ok, but	\$650.00
1) Service bus line side of CT undersized. 2) Based on the 2008 building code, are the pumps on the roof fire pumps on limited service fire pumps?						

ADVISORY BOARD CALENDAR

January 11, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51055		Bigman Brothers, Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Methodist Hospital 506 Sixth Street Brooklyn NY	Approved	\$650.00
51056		Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU Book Store 726 Broadway, 1st Floor New York NY	Approved	\$650.00
51057		Sterling Electric Inc. 863 Sterling Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	Trey Whitefield School 17 Hinsdale Street Brooklyn NY	Approved	\$650.00
51058		Brandl Electric Inc. 1927 Mott Avenue Far Rockaway NY 11691	Requested approval for the electric service equipment proposed to be installed	Citizen Hotel 218 West 50th Street New York NY	Ok, but	\$650.00
1) Verify fuse sizing for the fire pump on emergency side. 2) Verify if loads other than the fire pump are connected to the emergency system.						
51059		Madison Electric Inc. 123-07 20th Avenue College Point NY 11356	Requesting permission to leave as installed AC cable that does not contain an insulated equipment grounding conductor as a wiring method in a place of assembly	Shree Maha Kali Temple 110-43 155th Street Jamaica ny	Approved	\$0.00
Code: 518.4						

ADVISORY BOARD CALENDAR

January 11, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51060		Purcell Electrical Contractors, Ltd. 138-30 241st Street Rosedale NY 11422	Requesting permission to install overhead service entrance conductors in nonmetallic rigid conduit in a corrosive area Far Rockaway, Queens	6227 and 6229 Almeda Avenue Far Rockaway NY	Approved	\$0.00
Code: 230.43						
51061		B & S Electrical Contracting Co. Inc. 4317 15th Avenue Brooklyn NY 11219	Requesting permission to leave as installed AC cable that does not contain an insulated grounding conductor as a wiring method in a place of assembly	5224 15th Avenue Brooklyn NY	Approved	\$350.00
Code: 518.4						
51062		Safeway Construction Inc. 25 Crescent Street Brooklyn NY 11208	Requesting permission to install overhead service entrance conductors in nonmetallic rigid conduit in a corrosive area, Broad Channel, Queens	18-18 Crossbay Blvd. Broad Channel NY	Approved	\$0.00
Code: 230.43 With the stipulation that Schedule 80 rigid non metallic conduit is used.						
51063		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to wrap emergency conductors in glass cloth electrical tape to separate emergency and normal conductors that share a common pull box	DEP Croton Water Treatment 3701 Jerome Avenue Bronx NY	Denied	\$0.00
Code: 700.9(B). Designated emergency systems and normal power cannot be shared in the same pull box on raceways.						
51064		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requesting permission to leave a new section of switgear installed with a rear clearance of 16 inches obstructed by an existing door frame on an Advisory Board submission in "ok, but" status	NYU Langone Medical Center 323 East 29th Street New York NY	Void	\$0.00
Provide copy of original drawing showing the existing switchboard line up that was originally approved. /void 51064 as per 51144.						

ADVISORY BOARD CALENDAR

January 11, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51065		RJ Electrical Contractor 201-11 Linden Blvd. St. Albans NY 11412	Requesting permission to leave as installed, the service switch installed on the outside of the building	239 East 51st Street Brooklyn NY	Denied	\$350.00