

ADVISORY BOARD CALENDAR

January 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45920CO	04A0409CO	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	410 West 24th Street New York NY	Approved	\$0.00
Carry over from September 15, 2004 meeting.						
45921CO	04A0408CO	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	405 West 23rd Street New York NY	Approved	\$0.00
Carry over from September 15, 2004 meeting.						
46090CO	04A0557CO	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Marriot Time Square Hotel 1021-1029 Avenue of the Americas New York NY	Approved	\$0.00
Carry over from December 15, 2004 meeting. Verify if emergency panel is feeding automatic transfer switches or not.. Job finalized 2/8/07.						
46107	04A0561	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	800 Second Avenue New York NY	Hold	\$650.00
1) Relocate service switch inside service room. 2) Show detail of new tap with all existing connections. 3) Show 2000A switch correctly (not service switch?).						
46108	05A0002	Joseph A. Skarulis, Licensed Electrician 245 Wilson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	70 New Lane Staten Island NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46109	04A0564	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	270 Nostrand Avenue Brooklyn NY	Approved	\$650.00
46110	04A0559	Folks Electrical, Inc. 670 Broadway New York NY 10012	Requested approval for the electric service equipment proposed to be installed	300 East 71st Street New York NY	Approved	\$650.00
46111	04A0560	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	LIU Athletic Rec. & Wellness 153 Ashland Place Brooklyn NY	Approved	\$650.00
46112	04A0562	Bernardi Electric Co. 996 Coney Island Avenue Brooklyn NY 11230	Requested approval for the electric service equipment proposed to be installed	1901 Emmons Avenue Brooklyn NY	Approved	\$650.00
Show bonding and grounding of service switches. Show system ground connection. 1/13/05-Item finalized.						
46113	05A0001	Hylan Electrical Contracting, Inc. 1150 South Avenue, Corporate Park Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Staten Island Mall 2655 Richmond Avenue Staten Island NY	Approved	\$650.00
Provide 11 service conduits to accept additional 3 sets of service cables in future if required. Finalized on February 3, 2005.						

ADVISORY BOARD CALENDAR

January 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46114	05A0004	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	New High School 20 Thomson Ave. 4th, 5th & 8th Flo Queens NY	Approved	\$650.00
46115	05A0005	Dean Electric Co., Inc. 7909 Third Avenue Brooklyn NY 11209	Requested approval for the electric service equipment proposed to be installed	Maimonides Hospital 4801 Tenth Avenue Brooklyn NY	Approved	#Error
46116	05A0006	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	715 Lexington Avenue New York NY	Approved	\$650.00
Indicate available short circuit current at panel "PP-B1". Justify 100 KA panel rating. 1/13/05 - Item finalized.						
46117	05A0007	I.S.M. Electric, Inc. 512 73rd Street Brooklyn NY 11209	Requested approval for the electric service equipment proposed to be installed	Civil Term Supreme Court 141 Livingston Street Brooklyn NY	Approved	\$650.00
46118	05A0008	Evergreen Electrical Construction, Inc. 40-22 College Point Blvd., 2nd Floor Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	Prince Tower 133-53 37th Street Flushing NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46119	05A0009	Pabst Electric Company Inc. 45-48 51st Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	City Center Theater HVAC 130 West 56th Street New York NY	Approved	\$650.00
46120	05A0010	Kings Electric Co., Inc. 2113 West 6th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	195 Bowery New York NY	Hold	\$650.00
Clarify fire pump ATS sources, not in accord with Article 695 for alternate source.						
46121	05A0011	Schlesinger Electrical Contractors, Inc. 664 Bergen Street Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	347 West 36th Street New York NY	Approved	\$650.00
1) New 3000A fuse too large for cubic inch distribution section (2-5 x 1/4) copper bus. 2) Rectifier feeding new DC panel requires secondary protection. 1/13/05-Item finalized.						
46122	05A0012	Concorde Electrical Services, Inc. 6701 8th Avenue Brooklyn NY 11228	Requested approval for the electric service equipment proposed to be installed	40 East 78th Street New York NY	Approved	\$650.00
46123	05A0014	Dal Electrical Corporation 5910 11th Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Verizon 608 West 176th Street New York NY	Denied	\$650.00
Fire alarm connection shall be a cutout type for 120/208 volt system.						

ADVISORY BOARD CALENDAR

January 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46124	05A0029	L.E.A. Electric Corp. 2112 Broadway, Suite 204 New York NY 10023	Requested approval for the electric service equipment proposed to be installed	Sher Institute 425 5th Avenue New York NY	Approved	\$650.00
46125	05A0030	DM Electric Corporation 150 Mada Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Exxon Mobil Terminal 4101 Arthur Kill Road Staten Island NY	Hold	\$650.00
1) Provide equipment submittals. 2) Provide 5KV relay curves for feeders #3 and #4. 3) Provide loading summary on 5KV overhead feeders.						
46126	05A0032	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	CBRE 200 Park Avenue New York NY	Approved	\$650.00
46127	05A0035	Up Town Electric, Inc. 5-26 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Pergament Properties Richmond Ave. & Platinum Avenue Staten Island NY	Approved	\$650.00
46128	05A0031	Rigid Electric Inc. 336 37th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	NY University-Cancer Center 550 1st Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46129	05A0028	Compsec Electric Corporation 31-54 12th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	70 Washington Street Brooklyn NY	Ok, but	\$650.00
1) Provide bus sizing for service switches #1, #2. 2) Show series rating of garage panel. 3) Provide neutral calculation for feeders from service switch #1 to main distribution board "A".						
46130	05A0013	A/C Electric of New York, Inc. 32 Union Square East New York NY 10003	Requested approval for the electric service equipment proposed to be installed	Urban Outfitters 999 Third Ave .aka 205 E. 59th St. New York NY	Approved	\$650.00
46131	05A0003	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	130 West 30th Street New York NY	Approved	\$650.00
1) Provide cut sheets of circuit breaker panel. 2) Check series rating of circuit breakers with type of circuit breakers. Item finalized 2/28/05.						
46132	05A0015	RCM Power Systems Services 2500 McClellan Avenue Pennsauken NJ 08109	Requested approval for the electric service equipment proposed to be installed	850 3rd Avenue New York NY	Approved	\$650.00
1) Emergency fuse cut-out to be on line side of the main generator circuit breaker. 2) Show series rating of panel EDP-L. 3) State location of automatic transfer switches. Finalized 1/25/05.						
46133	05A0016	MSM Electric, Inc. 3089 Brighton 6th Street Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	485 Madison Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46134	05A0017	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	155 Canal Street New York NY	Approved	\$650.00
46135	05A0018	Scientific Electric Company, Inc. 900 Edgewater Road Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	279 West 117th Street New York NY	Approved	\$650.00
46136	05A0020	Alom Electric LLC 148 22nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	2567 Broadway New York NY	Approved	\$650.00
46137	05A0021	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Teachers Coll. @ Columbia Un 517 West 121st Street New York NY	Approved	\$650.00
46138	05A0022	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	207 E. 57th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46139	05A0023	Livingston Electrical Associates, Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	410 East 92nd Street New York NY	Approved	\$650.00
46140	05A0024	Livingston Electrical Associates, Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	212 East 57th Street New York NY	Approved	\$650.00
46141	05A0025	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	800 Avenue of the Americas New York NY	Approved	\$650.00
46142	05A0026	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	347 West 36th Street New York NY	Approved	\$650.00
46143	05A0027	Dola Electrica Co., Inc. 3044 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	North General Hospital 1979 Madison Avenue New York NY	Hold	\$650.00
1) 1200 amp switches shall be GFCI type. 2) Increase conductors or lower fusing. 3) Show existing MCC fusing. 4) Existing service room should be mechanically ventilated.						

ADVISORY BOARD CALENDAR

January 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46144	05A0034	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	84 Front Street Brooklyn NY	Hold	\$650.00
1) Show type of 2nd fusing on meter banks. 2) Change fusing on fire pump switch to 600%. 3) No coordination between 1200 amp HCP service switch and panel distribution board. 4) Provide neutral disconnect link closer to the bond and grounding. 5) Con-Ed AIC.						
46145	05A0019	Jeco Electrical Service Corp. 1162 Intervale Avenue Bronx NY 10459	Requested approval for the electric service equipment proposed to be installed	15 West 45th Street New York NY	Approved	\$650.00
46146	-	Alom Electric LLC 148 22nd Street Brooklyn NY 11232	Requesting special permission to leave as installed a 100 ampere Retail tap off existing 2000 ampere Retail Tenant Box. Tap is less than 10% of existing service switch.	2567 Broadway New York NY	Approved	\$0.00
46147	---	Tesla Electric Corp. 23-18 Steinway Street Astoria NY 11105	Requesting permission to install dimmer boards that will be mounted facing each other with front clearances of 33 inches.	2458 National Drive Brooklyn NY	Approved	\$0.00
46148	----	New York City Housing Authority 23-02 49th Avenue Long Island City NY 11101	Requesting permission to install 24 volt CCTV cabling and conduit inside a elevator shaft to provide power to a camera on the roof to monitor the elevator motor rooms and roof areas.	82 Dwight Street Brooklyn NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

January 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46149	----- --	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requesting permission one time location to install approximately for one year a custom non-listed lighting fixture made of approved listed components.	731 Lexington Avenue New York NY	Approved	\$0.00
With the stipulation						
46150	04A0563	LED Effects, Inc. 11390 Sunrise Gold Circle #800 Rancho Cordova CA 95742	Requested approval for use in New York City of your Decorative LED Light.		Denied	\$200.00
Luminaire must be listed. Not recognized. Terminations must meet the New York City Electrical Code.						
46151	05A0033	Teknion, LLC 12000 Horizon Way Mount Laurel NY 08054	Requested approval for use in New York City of your Teknion "ie" Modular Furniture. Model/Series Numbers: JEBH, JEBB, JECF, JEBF, JEPD, JEPB, JEDB, JEPP, JSU, TUI and TYI.		Approved	\$200.00
With the stipulation that the base feed and all other components used to make connection to the source of supply must comply with the New York City Code, Section 605.6.						