

# ADVISORY BOARD CALENDAR

**January 13, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49686CO	09A0378CO	Quenzer Electric Systems, Inc. 11 West 25th Street, 9th Floor New York NY 10010	Requested approval for the electric service equipment proposed to be installed	6100 Francis Lewis Blvd. Queens NY	Approved	\$0.00
Carry over from September 16, 2009 meeting.						
49690CO	09A0382CO	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Coney Island Hospital Brooklyn NY	Hold	\$0.00
Carry over from September 16, 2009 meeting. 1) Change trip on G2 breaker to allow coordination with HI (1600A breaker). 2) Fire pumps fire alarm feeds to be tapped ahead of generator breaker.						
49808CO	09A0466CO	GTS Electrical 218-14 Northern Blvd. Bayside NY 1136	Requested approval for the electric service equipment proposed to be installed	7 Bushwick Place Brooklyn NY	Approved	\$0.00
Carry over from November 18, 2009 meeting. 1) 2 sets 4/0 fused at 600 amps and markings fuse and switch size are reversed. 2) #1 above not explained. 3) Provide warning label on 2500A switch "fuses may be energized by backfeed". 4) 208V side of Y-Y transformer shall not have neutral ground. 5) Barrier off rear of existing service switchboard. Job finalized 4/9/10.						
49849CO	09A0490CO	A.L.P. Lighting Components 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your High Bay Fluorescent Lighting Fixture. Model/Series Numbers: HBT5-446, 646, 346, 846, 546 - HBT8-448, 648, 348, 548 and 848.		Hold	\$0.00
Carry over from November 18, 2009 meeting. Product is acceptable if it is listed and bears the mark.						
49850CO	09A0491CO	A.L.P. Lighting Components 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your Surface/Pendent Mounted Fluorescent Wrap Fixtures. Model Series/Numbers: 300-220, 300-220TAN, 300-230, 300-240, 300-240TAN, 300-420, 300-440, 300-272, and 300-296		Hold	\$0.00
Carry over from November 18, 2009 meeting. Product is acceptable if it is listed and bears the mark.						

# ADVISORY BOARD CALENDAR

January 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49851CO	09A0492CO	A.L.P. Lighting Components 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your Fluorescent Surface/Pendent Mount Wrap Fixtures. Model/Series Numbers: 390-220 and 390-240.		Hold	\$0.00
Carry over from November 18, 2009 meeting. Product is acceptable if it is listed and bears the mark.						
49852CO	09A0493CO	A.L.P. Lighting Components 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your Fluorescent Surface/Pendent Mount Wrap Fixtures. Model/Series Numbers: RDIALP-2X2, 2X4 T5/T8 LAMPS.		Hold	\$0.00
Carry over from November 18, 2009 meeting. Product is acceptable if it is listed and bears the mark.						
49853CO	09A0494CO	A.L.P. Lighting Components 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your Recessed Fluorescent Troffer Lighting Fixture. Model/Series Numbers: EL-1x2, EL-1x4, EL-2x2, EL-2x4.		Hold	\$0.00
Carry over from November 18, 2009 meeting. Product is acceptable if it is listed and bears the mark.						
49883CO	09A0524CO	Fas Electrical Contractors, Inc. 90-61 Pitkin Avenue Ozone park NY 11417	Requested approval for the electric service equipment proposed to be installed	Van Blarcom Closures, Inc. 156 Stanford Street Brooklyn NY	Approved	\$0.00
Carry over from December 16, 2009 meeting. Verify that fire pump circuit conductor are fire rated. Job finalized 3/19/10.						
49893	10A0001	Douglas Paskor, Inc. 248 Nassau Avenue Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	12 East 14th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**January 13, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49894	10A0002	Royal Electrical & Wiring Corp. 27-07 BQE West Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	100 Jay Street Brooklyn NY	Approved	\$650.00
49895	10A0003	Tower Electric Inc. 21-19 40th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	3050 Corlear Avenue Bronx NY	Approved	\$650.00
1) Commercial wireway should be rated 1600A. 2) Feeder sizes missing from m.8. line troughs. Job finalized 2/16/10.						
49896	10A0004	Taft Electric Co., Inc. 31-31 123rd Street Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	Ormonde 10 Broadway aka 154 West 70th St New York NY	Approved	\$650.00
49897	10A0005	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	11 Park Place aka #8-10 Murray St. New York NY	Approved	\$650.00
49898	10A0006	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bronx Comm. Coll. N. Instruct 200 Hall of Fame Terrace Bronx NY	Approved	\$650.00
1) Disconnect switch to be 30 amps on normal and emergency sides FCO from generator must be disconnect switch. 2) Show grounding terminals in service switch. 3) Service room to be mechanically ventilated. 4) Confirm 480V switchboard provided with barriers between sections. Job finalized 6/22/10.						

# ADVISORY BOARD CALENDAR

**January 13, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49899	10A0007	Arc Electl & Mechanical Contrs, Corp. 28 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Harlem Hospital 512 Lenox Avenue New York NY	Hold	\$650.00
1) Emergency room disconnects marked as service switches in ESB.B and ESB.C. 2) Show front of ATS. 3) Service room show fronts of 400 amp disconnect switches. 4) Install barriers on side of switchboards less than 3' from wall. 5) Secondary of FP transformer not bonded and grounded. 6) Verify that there are no splices in FP controller. 7) Verify 4/0 conductors feeding jockey pump. 8) FACO and fire pump emergency feed shall be ahead of 1st fuse off the generator. 9) Explain how conductors will terminate on switches.(2 sets of 500 or 600 amps sw ect.). 10) Bond neutral in FCO. 11) 2 fuses installed a FACO panel. 11) Feeder conductors oversized. 12) Generator neutral to be connected to water main on building steel. 13) Paralleling bus undersized. 14) Provide coordination study.						
49900	10A0008	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1285 Avenue of the Americas New York NY	Approved	\$650.00
49902	10A0010	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Verizon 71-40 164th Street Fresh Meadows NY	Approved	\$650.00
1) Is generator pak listed as a complete assembly? 2) Show key intlk on portable generator breaker. 3) Show generator breaker bus size. Job finalized 2/22/10.						
49903	10A0011	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Pet Smart 632 Broadway New York NY	Approved	\$650.00
New 1600A service switch on load side of Con ED CT to be bottom feed. Job finalized 10/25/10.						
49904	10A0012	Lina Electric Corp. 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	300 West 128th Street New York	Approved	\$650.00
1) Service bus feeding 2400 amps of service switches is undersized. 2) Show selectivity between 800 amp service switch and circuit breakers and verify breakers AIC. 3) Fire pump feeder taken off of through bus. Job finalized 2/22/10.						

# ADVISORY BOARD CALENDAR

**January 13, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49905	10A0013	Naber Electric Corp, N.Y. 350 Fifth Avenue, Suite 3304 New York NY 10118	Requested approval for the electric service equipment proposed to be installed	Carnasie Plaza Avenue D & East 89th Street Brooklyn NY	Hold	\$650.00
1) Provide conductor sizes in outdoor switchgear. 2) Conductors on load side of 5000 amp switch are undersized. 3) Show grounding to watermain. 4) Verify 13000 amp switch size. 5) Provide detailed outdoor layout, fencing and grounding. 6) Show Con-Ed's point of entry outside. 7) Clarify future section of switchboard 2.						
49906	10A0014	A.S.R. Electrical Contracting, Inc. 845 Lexington Avenue, Suite 3R New York NY 10021	Requested approval for the electric service equipment proposed to be installed	Gotham Center-Building B2 42-09 28th Street Long Island City NY	Approved	\$650.00
1) Future board to be relocated to provide access around the board. 2) Conductor off of ATS #2 is undersized. 3) Verify that 1600 amp emergency board loads are feeding 3 or 4 pole ATS' Job finalized 2/16/10.						
49907	10A0015	Integral Electrical Power & Control Corp. 307 7th Avenue, Suite 507 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	240 Central Park South New York NY	Approved	\$650.00
49908	10A0016	New Phase Electrical Contractors, Inc. 725 East 136th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	401 East 74th Street New York NY	Approved	\$650.00
49909	10A0017	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	311 West 127th Street New York NY	Approved	\$650.00
1) #2 and #6 tap conductors undersized for 1200 amp fuses. 2) 1st and 2nd point of fusings cannot be series rated. 3) Provide physical side views. 4) Provide signage on service rooms. 5) Verify that service entrance are concrete encased. Job finalized 3/19/10.						

# ADVISORY BOARD CALENDAR

**January 13, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49910	10A0018	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New York Hospital Queens 56-45 Main Street Flushing NY	Hold	\$650.00
1) Generator room layout not provided. 2) Where is generator located in conjunction with emergency gear? Show complete layout. 3) Verify if 3 or 4 pole ATS' are being used. 4) Provide coordination study. 5) Fire pump emergency branch circuit not fire rated. 6) Someone who knows job to appear at next meeting.						
49911	10A0019	Building Management System Elec, LLC 33-13 58th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1 Hanson Place Brooklyn NY	Approved	\$650.00
49912	10A0020	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Equity Office 1095 Avenue of the Americas New York NY	Approved	\$650.00
49913	10A0021	Mari Electric Contractors Inc. 463 Wild Avenue Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	557 Atlantic Avenue Brooklyn NY	Approved	\$650.00
New 600 amp service switch is overfused. Job finalized 2/22/10.						
49914	10A0022	Corporate Electrical Tech, Inc. 2719 Grand Avenue Bellmore NY 11710	Requested approval for the electric service equipment proposed to be installed	20 University Place New York NY	Approved	\$650.00
Bonding and grounding of existing equipment not shown. Job finalized 3/19/10.						

# ADVISORY BOARD CALENDAR

**January 13, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49915	10A0023	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Stop & Shop Supermarket 70-20 Rockaway Beach Blvd. Rockaway NY	Approved	\$650.00
49916	10A0024	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	627 West 165th Street New York NY	Approved	\$650.00
49917	10A0025	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	530 West 120th Street New York NY	Hold	\$650.00
Some who knows job to appear at next meeting.						
49918	10A0026	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Gowanus Facility 201 Douglass Street Brooklyn NY	Ok, but	\$650.00
1) Service cables undersized. 2) Cables feeding 1000 KVA transformer undersized. 3) Cables on load side of 1000KVA transformer undersized. 4) Provide scale drawing for plan view.						
49919		United Electrical Contracting Corp. 69 Ludlow Street New York NY 10002	Requesting permission to leave as installed a 200 amp feeder with a reduced neutral.	310 Wild Avenue Staten Island NY	Denied	\$350.00

# ADVISORY BOARD CALENDAR

**January 13, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49920		Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requesting permission to leave as installed a 3000 amp service switch where the door of the service switch will not be allowed to open to 90 degrees due to a C.T. cabinet overlapping into the front clearance area.	40 Worth Street New York NY	Approved	\$0.00
With the stipulation that insulating material is installed on the outside side and back of the 1600 amp C.T. cabinet where it overlaps into the width area of the new 3000 amp service switch and C.T.						
49921		Warren Ostroff Electric 102-15 159th Road Howard Beach NY 11414	Requesting permission to leave as installed a kitchen countertop more than 12" wide were a receptacle outlet was not installed.	14 Horatio Street New York NY	Denied	\$350.00
With permission to install receptacle outlet in the cabinet below the countertop so its face will be flush with the front of the cabinet.						
49922		Guggenheim Museum 1071 Fifth Avenue New York NY 10128	Requesting permission to install additional non life safety loads to an existing emergency distribution panel in lieu of installing a separate automatic transfer switch.	Solomon R. Guggenheim Museum 1071 Fifth Avenue New York NY	Approved	\$0.00
49923		Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission to install emergency and normal feeders inside of 2 hour fire rated enclosure where all feeders will be installed in rigid galvanized steel conduits containing THHN conductors.	One Centre Street New York NY	Denied	\$0.00
49924		KNC Electric Inc. 187-27 Linden Blvd. St. Albans NY 11412	Requesting permission to install underground concrete encased service entrance conductors in non metallic conduit in a corrosive area, Far Rockaway Queens.	120 Beach 26th Street Queens NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

January 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49925		Wank Adams Slavin Associates LLP 740 Broadway New York NY 10003	Requesting permission to add an additional 400 amp service switch without filing Advisory Board drawings, there are 2 existing 1000 amp service switches fused at 700 amps and one existing 400 amp service switch fused at 400 amps where a peak documented load over the past three years is 275KW.	IS 117 300 Willoughby Avenue Brooklyn NY	Denied	\$0.00