

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48300CO	07A0545CO	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYPH 523 East 70th Street New York NY	Approved	\$0.00
Carry over from November 14, 2007 meeting.						
48359CO	07A0567CO	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	East River Science Park 450 East 29th Street New York NY	Approved	\$0.00
Need side of ATS. Job finalized 2/25/08.						
48395CO	07A0650CO	Connectrac 163 Leslie Street Dallas TX 75207	Requested approval for use in New York City of your Steel Receptacle and Cover, 8-Wire, 4-Circuit power jumper and infeed, and floor-mounted raceway components Connectrac U Series		Approved	\$0.00
Carry over from December 12, 2007 meeting.						
48396CO	07A0651CO	Connectrac 163 Leslie Street Dallas TX 75207	Requested approval for the use in New York City of your Duplex Receptacle System with 24' flex conduit and floor-mounted raceway Components. Connectrac I Series.		Approved	\$0.00
Carry over from December 12, 2007 meeting.						
48397CO	07A0652CO	Connectrac 163 Leslie Street Dallas TX 75207	Requested approval for use in New York City of Steel Junction Box with 24' flex conduit and floor-mounted raceway components. Connectrac M Series.		Approved	\$0.00
Carry over from December 12, 2007 meeting.						

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48401CO		Quantum Electric Corporation 30-30 Northern Blvd. Long Island City NY 11101	Requesting permission not to file full Advisory Board drawings for the addition of a new 200 amp service switch that will provide power to a limited service fire pump	Community Service 105 22nd Street New York NY	Approved	\$0.00
Carry over from December 12, 2007 meeting.						
48403	08A0001	Campell and Dawes Ltd. Electl Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	HSBC-Cooling Tower 119 West 39th Street New York NY	Approved	\$650.00
48404	08A0002	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Beacon Capital 1211 6th Avenue New York NY	Hold	\$650.00
1) Provide paralleling switchgear in Advisory Board SDS(i.e. bus dimensions etc). 2) Provide GFP on paralleling switchgear breakers. 3) Indicate generator neutral/ground point.						
48405	08A0003	Red Wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	90-10 Grand Central Parkway East Elmhurst NY	Ok, but	\$650.00
1) Explain ground on 200 amp disconnect switch. 2) 4 conductors shall feed the 400 amp service switch. 3) Fuse type not provided.						
48406	08A0004	Red wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	27-02 1st Avenue Astoria NY	Ok, but	\$650.00
1) Service entrance conductor size from meter to service switch not shown. 2) 2nd fusing not shown.						

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48407	08A0005	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	AOL 770 Broadway New York NY	Approved	\$650.00
48408	08A0006	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	315 West 57th Street New York NY	Approved	\$650.00
Confirm primary switch and fuse of 500 KVA transformer can handle transformer in rush. Job finalized 2/25/08.						
48409	08A0007	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	30 Adam C. Powell Jr. & 127th Stre New York NY	Approved	\$650.00
48410	08A0008	Innovative Electric of New York, Inc. 2056 Cross Bronx Expressway Bronx NY 10472	Requested approval for the electric service equipment proposed to be installed	Prospect Avenue Apartments 890 Prospect Avenue Bronx NY	Approved	\$650.00
48411	08A0009	Techno-Volt Electric, Inc. 28-31 119th Street Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	31-00 Vernon Boulevard Long Island City NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48412	08A0010	Matros Automated Electl Constn Corp. 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	25 Broad Street New York NY	Approved	\$650.00
48413	08A0011	L.E.A. Electric Corp. 1006 Sixth Avenue, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	15 Union Square West New York NY	Approved	\$650.00
48414	08A0012	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	805 Columbus Avenue New York NY	Approved	\$650.00
48415	08A0013	Kew Electric Inc. 1428 Hylan Blvd. Staten Island NY 10305	Requested approval for the electric service equipment proposed to be installed	785 Eighth Avenue New York NY	Approved	\$650.00
3/26/14 Swapped A-Rev 3 and B-Rev 4. 3/24/15 Swapped A-Revision 4 and B Revision 5. 8/17/15 Swapped drawing B-Revision 6. No more as built swaps for this job.						
48416	08A0014	Del Power & Light Electrical Contractors, I 32 East 31st Street, Suite 805 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	325 East 101st Street New York NY	Approved	\$650.00
1) Provide coordination per 620.62 for elevator disconnects. 2) Provide coordination for service switch #2 and tenant DP. Job finalized 7/1/08.						

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48417	08A0015	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	One Hunters Point 5-49 Borden Avenue Long Island City NY	Approved	\$650.00
1) How is life safety metered. 2) Fire pump has 2 800 fused switch, only 1 allowed. 3) Indicate neutral term and ground connector for FP service switch. Job finalized 4/7/09.						
48418	08A0016	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	FedEX Distribution Center 670 East 132nd Street Bronx NY	Hold	\$650.00
1) Verify if Con-ED is feeding the CT. 2) FCO switches to be lockable and identified. 3) Provide bus size from service switch to panel. 4) FCO to be connected before neutral line. 5) FA ATS being fed at 460V on generator side. 6) Identify if generator neutral is grounded. 7) confirm generator is adequately sized to operate FP. 8) FCO not permitted at 460V. 9) Indicate clearance from disconnect switch adjacent to FP disconnect.						
48419	08A0017	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	801 Amsterdam Avenue New York NY	Approved	\$650.00
1) Verify that copper conductors are being used between 2000 amp switch to detail trough. 2) Show tap detail in trough. 3) FP feeder to be rated. 4) Provide second door. Job finalized 5/15/08.						
48420	08A0018	June Electric Corp. 2025 Continental Avenue, Suite 5E Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	47-49 East 34th Street New York NY	Approved	\$650.00
1) 2500 amp fire pump service switch is not located 12" from the switchboard. 2) Switch for manual fire pump is undersized, should be 400 amps. 3) Feed to manual fire pump not fire rated. 4) Fusing per DP-C does not coordinate with service switch fuse. Job finalized 3/3/08. 11/18/14 Swapped 1 of 1 Revision 2.						
48421	08A0019	alvatore Campisi & Sons Electl Contrs, Inc 453 Onderdonk Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	519 8th Avenue New York NY	Approved	\$650.00
Tap bus to vertical section of new distribution section undersized. Job finalized 2/27/08						

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48422	08A0020	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metro PCS 29 West 47th Street New York NY	Approved	\$650.00
48423	08A0021	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Sprint Wireless Broadband 425 East 25th Street New York NY	Approved	\$650.00
48424	08A0022	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Rockefeller Group 1271 6th Avenue New York NY	Hold	\$650.00
1) Show tap details of bus duct on 10th and C1 levels. 2) How long are taps to panels off of bus duct tap. 3) Clarify DP concourse and distribution switchboard on 10th floor with physical drawings from Galaxy and show interlock buses. 4) Remove neutral bond in panel DPH-RP-1. 5) Bus feeding 2 2000 amp service switches undersized.						
48425	08A0023	Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Grand Hyatt Hotel 109 East 42nd Street New York NY	Approved	\$650.00
48426	08A0024	Red Wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	114-02 15th Avenue College Point NY	Ok, but	\$650.00
1) Second fusing not shown, short circuit calculations. 2) Cut sheet of service switch not provided. 3) Supplemental ground not provided. 4) Clarify neutral in service switch.						

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48427	08A0025	Red Wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	175-15 Rockaway Blvd. Jamaica NY	Ok, but	\$650.00
1) Remove neutral bond and supplemental ground in 200 amp disconnect switch. 2) Show tap detail in trough after the new 800 amp service switch.						
48428	08A0026	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Advanced Realty 235-239 West 23rd Street New York NY	Approved	\$650.00
The total fusing cannot exceed the rating of the 500 MCM conductor. Job finalized 2/16/10.						
48429	08A0027	Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	FDNY LIC Shop 48-67 34th Street Long Island City NY	Approved	\$650.00
48430	08A0028	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	300 East 42nd Street New York NY	Approved	\$650.00
48431	08A0029	Seong Jin Electric Inc. 37-12 58th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	83-30 Kew Gardens Road Queens NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48432	08A0030	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Sheraton Hotel 222 Duffield Street Brooklyn NY	Approved	\$650.00
48433	08A0031	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens Family Courthouse Apts 89-14 Parsons Blvd. Jamaica NY	Approved	\$650.00
48434	08A0032	J.G. Electrical Installations, Inc. 66-05 60th Place Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	NY Downtown Hospital 170 Williams Street New York NY	Approved	\$650.00
48435	08A0033	Dooley Electric Company, Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Salvation Army 120 West 14th Street New York NY	Approved	\$650.00
1) Change existing 2500 amp fuses in service switch #2 to 2000 amps with signage. 2) Provide control on generator board to trip open load band in emergency mode. Job finalized 2/25/08.						
48436	08A0034	A & M Electrical Service, Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	215 West 88th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48437	08A0035	A & M Electrical Service, Inc. 5309 3rd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	55 John Street New York NY	Approved	\$650.00
48438	08A0036	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Weill Cornell 407 East 61th Street New York NY	Hold	\$650.00
Emergency feeds for life safety not tapped from line side of emergency generators switchboard.						
48439	08A0037	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	360 Furman Street Brooklyn NY	Approved	\$650.00
1) Show service entrance to switchboards, bus on sets. 2) 4000 amp fuse in Board A oversized. 3) Fire pump service switch not remote from the switchboard. Job finalized 2/25/08.						
48440	08A0038	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	15 Broad Street New York NY	Hold	\$650.00
1) Fire pump switch feed tapped from switchboard section that contains a switch. 2) Fire pump circuit not shown on drawing. 3) Fire pump circuit not shown must be fire rated. 4) Note on drawing must indicate fire pump and painted red. 5) Fire pump metered twice.						
48441	08A0039	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	P.S. 142M 100 Attorney Street New York NY	Approved	\$650.00
Show short circuit curves. Job finalized 5/19/08.						

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48442	08A0040	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	Marymount Manhattan College 221 East 71st Street New York NY	Approved	\$650.00
48443	08A0041	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metro PCS-Hunter College 450 West 41st Street New York NY	Approved	\$650.00
Relocate 200 amp service switch above meter pan. Job finalized 2/27/08.						
48444	08A0042	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Sprint Wireless Broadband 333 East 66th Street New York NY	Ok, but	\$650.00
Conductor size on load side of meter and 200 amp disconnect switch not shown.						
48445	08A0043	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Bell Atlantic 1633 Broadway New York NY	Approved	\$650.00
48446		M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requesting permission due to lack of room inside of the existing service room to install a new service switch in an adjacent room, where signage will be provided.	315 West 57th Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48447		Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requesting permission to install a seventh service in a building where the switch will supply power to a sprinkler booster pump.	300 East 42nd Street New York NY	Approved	\$0.00
48448		Kew Electric Inc. 1428 Hylan Blvd. Staten Island NY 10305	Requesting permission to install concrete encased service entrance conductors in Schedule 80 rigid non-metallic PVC conduits.	785 Eighth Avenue New York NY	Approved	\$0.00
48449		DVL Consulting Engineers Inc. 137 Fifth Avenue New York NY 10010	Requesting permission to install concrete encased service laterals and service entrance conductors in rigid non metallic PVC conduits.	PS 829R 98 Grant Street Tompkinsville NY	Approved	\$0.00
48450		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to install concrete encased service entrance conductors in non metallic fiberglass reinforced epoxy conduits.	805 Columbus Avenue New York NY	Approved	\$0.00
48451		ACP Electrical Contracting, Inc. 412 West 48th Street New York NY 10036	Requesting permission to install bayonet type overcurrent protective devices rated 3 to 5 amps inside of the dwelling unit circuit breaker panels to provide untamperable power for submetering.	65 West 90th Street New York NY	Approved	\$0.00
with the stipulation that the rating of the enclosed fuse is rated 2 amperes or less.						

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48452		A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requesting permission to install life safety automatic transfer switches inside of a fire pump room.	55 John Street New York NY	Approved	\$0.00
48453		Stanco Systems Electrical Contracting 4061 Victory Boulevard Staten Island NY 10314	Requesting permission to tap temporary power from the load side of a 3000 amp service switch to feed a temporary 400 amp second fusing that will provide power to scaffolding that will be in use less than one year	Empire State Building 34th Street & Fifth Avenue New York NY	Approved	\$0.00
48454		Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requesting permission to tap power to supply a fire pump from the load side of a CT that is located in the same switchboard section that contains a service switch.		Denied	\$0.00
48455		Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requesting permission due to existing commercial building condition problems, to allow the new service equipment to be installed on the exterior of the building supplied by underground rigid non-metallic PVC conduits.	1081 Leggett Avenue Bronx NY	Approved	\$0.00
48456		Excel Electric Co., Inc. 207 West 25th Street, 9th Floor New York NY	Requesting permission due to creating an extreme financial distress to leave as installed 23 three family homes that are wired without the common area's branch circuits being supplied by a separate public, light and power meter and panelboard	Crystal St, Flatlands Ave., Montauk Brooklyn NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

January 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48457	08A0044	Janmar Lighting 730 W. Golden Grove Way Convina GA 91722	Requested approval for use in New York City of your Luminescent T Ceramic Metal Halide (CMH) portable track fixtures. Model/Series Numbers: 736, 737, 738, 739, 740, 741, 744, 752, 756, 756SL and 757		Approved	\$0.00
With the stipulation that Model						
48458	08A0045	Illumivision Inc. 7224 50th Str. Edmonton Alberta, Canada T6B2J1	Requested approval for use in New York City of your LED Lighting Fixtures. Model/Series Numbers: LX White/RGB, Highlite, Lightwave Bar White/RGB, Mini White/RGB, Smartflo, Power supplies		Approved	\$200.00
48459	08A0046	Thomas & Betts Corp. 8155 T & B Blvd. Memphis TN 38125	Requested approval for use in New York City of your Conduit Expansion Coupling. Model/Series Numbers: XJG-Series ½" to 5" Trade Sizes		Approved	\$200.00