

# ADVISORY BOARD CALENDAR

**January 17, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47285CO2	06A0341CO2	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	23-45 Caton Place New York NY	Ok, but	\$0.00
Carry over from December 13, 2006 meeting. Show selectivity or request special permission.						
47400CO	06A0452CO	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Memorial Sloan-Kettering 300 East 66th Street New York NY	Approved	\$0.00
Carry over from September 13, 2006 meeting.						
47468CO	06A0465CO	Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	25 Fifth Avenue New York NY	Approved	\$0.00
Carry over from October 25, 2006 meeting.						
47525CO2	06A0554CO2	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	The Plaza Hotel Fifth Avenue at Central Park South New York NY	Approved	\$0.00
Carry over December 13, 2006 meeting.						
47533CO	06A0534CO	Levest Electric Corp. 325 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	275 7th Avenue New York NY	Approved	\$0.00
Carry over November 15, 2006 meeting.						

# ADVISORY BOARD CALENDAR

**January 17, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47575CO	06A0586CO	Dal Electrical Corp. 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	157 Chambers Street New York NY	Approved	\$0.00
Carry over from December 13, 2006 meeting.						
47577CO	06A0570CO	Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Peter Cooper Village/Stuyvesa 280 First Avenue New York NY	Approved	\$0.00
Carry over from December 13, 2006 meeting.						
47588CO	06A0584CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	NY Mets New Stadium Queens NY	Approved	\$0.00
Carry over December 13, 2006 meeting. Increase size of transformer feeding fire pump. Job finalized 3/22/07.						
47591CO	!	Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requesting permission on drawing 47468 presently on hold to leave the service room with one door of egress	25 Fifth Avenue New York NY	Denied	\$0.00
Carry over from December 13, 2006 meeting. As per field inspection a second means of egress must be provided. ( Calendar #47468).						
47610	07A0002	J.H. Electric of New York, Inc. 59-01 Grand Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	Dept. of Sanitation District M 650 West 57th Street New York NY	Approved	\$650.00
"mssa Sect #2" bus undersized for 3000A and 4000A switches. (need 800A/Sq. in). Job finalized 2/22/07.						

# ADVISORY BOARD CALENDAR

**January 17, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47611	07A0003	Flack + Kurtz Consulting Engs, LLP 475 Fifth Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Long Island Jewish Hospital 265-25 76th Avenue New Hyde Park NY	Ok, but	\$650.00
1) Provide 7ft between emergency and cogenerator switchboard. 2) Provide 1-Line and floor plan in Advisory Board format. 3) Provide bus bar sizing and section views for Asco switchboards. 4) Update drawings w/changes discussed by Flack and Kurtz. 5) Provide coordination study.						
47612	07A0004	Heso Electrical Inc. 33-06 Ditmars Blvd. Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Hill County Restaurant 30 West 26th Street New York NY	Approved	\$650.00
New equipment not shown on floor plan. New tap 10ft max. Job finalized 4/25/07.						
47613	07A0005	A & M Electrical Service, Inc. 76 Bathgate Street Staten Island NY	Requested approval for the electric service equipment proposed to be installed	55 John Street New York NY	Approved	\$650.00
47614	07A0006	Interphase Electric Corp. 5304 Seventh Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Museum of the City of NY 1220 Fifth Avenue New York NY	Approved	\$650.00
Service cables to "MSB-2" undersized. Job finalized 1/17/07.						
47615	07A0007	Community Electric Inc. 124 Granite Avenue Staten Island NY 10303	Requested approval for the electric service equipment proposed to be installed	NYC Public Health Lab 455 First Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**January 17, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47616	07A0008	Samson Electric Corp. 33-00 Northern Blvd-6th Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Chelsea Market 75 9th Avenue New York NY	Approved	\$650.00
Show Con Ed P.O.E. on floor plan w/location of SEB. Indicate distance from SEB to service switch. Job finalized 2/9/07.						
47617	07A0009	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 5th Avenue New York NY	Approved	\$650.00
47618	07A0010	Walsh Electrical Contracting Inc. 76 Midland Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	Hampton Inn and Suites 1112 South Avenue Staten Island NY	Approved	\$650.00
47619	07A0011	Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	Sutter Ave. a.k.a 340 Pennsylvania St Brooklyn NY	Approved	\$650.00
47620	07A0012	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Clarett Brooklyn Tower 230 Ashland Place Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**January 17, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47621	07A0013	Elco Electrical Contracting Corp. 35-43 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Furman Residence 1060 Fifth Avenue, Apt 11A New York NY	Approved	\$650.00
47622	07A0014	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Guggenheim Museum 1071 Fifth Avenue New York NY	Approved	\$650.00
47623	07A0015	Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Brookfield Properties One Liberty Plaza New York NY	Approved	\$650.00
47624	07A0016	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Qwest Communication 32 Avenue of the Americas New York NY	Approved	\$650.00
47625	07A0017	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Kepco Bldg. 4 131-40 Maple Avenue Flushing NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						

# ADVISORY BOARD CALENDAR

January 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47626	07A0018	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Corcon 361 Manhattan Avenue Brooklyn NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47627	07A0019	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Approval Concept	Billie Ann Plastics 360 Troutman Street Brooklyn NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47628	07A0020	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Habana Outpost 757 Fulton Street Brooklyn NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47629	07A0021	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Jamaica Bay Wildlife Refuge 175-10 Cross Bay Blvd. Broad Channel NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47630	07A0022	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Big Sue 925 Bergen Street Brooklyn NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						

# ADVISORY BOARD CALENDAR

**January 17, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47631	07A0023	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Davidson Pipe 5002 Second Avenue Brooklyn NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47632	07A0024	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Marjam Supply Company 20 Rewe Street Brooklyn NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47633	07A0025	Frank Pugliese Electric Contracting Corp. 141-18 Holly Avenue Flushing NY 11355	Requested approval for the electric service equipment proposed to be installed	144-02 158th Street Jamaica NY	Hold	\$650.00
Bus undersized after 3000 amp service switch.						
47634	07A0026	John J. Guth Engineering, P.C. 242 West 30th Street, 8th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sprint PCS 3250 Hunterspoint Avenue Long Island City NY	Approved	\$650.00
47635	07A0027	Tom Fitzpatrick Electrical Contg Corp. 1643 Utica Avenue Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	International Affairs Building 416-430 W. 118th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

January 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47636	07A0001	Electric Corp. d/b/a Mage Electrical Contr 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	450 West 15 Street New York NY	Approved	\$650.00
47637	07A0028	OHM Electrical Corp. 39-40 21st Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Times Square Tower 7 Times Square New York NY	Approved	\$650.00
47638	07A0029	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Avalon Cooper Square 22 East First Street New York NY	Approved	\$650.00
47639	07A0030	Robert Garcia Electrical Contracting Corp. 500 Trinity Avenue, Suite 1-B Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	119-121 West 28th Street New York NY	Approved	\$650.00
47640	07A0031	Gessin Electrical Contractors, Inc. 791 East 139th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	67 Wall Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**January 17, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47641	07A0032	Woodland Electrical Contracting Corp. 4601 White Plains Road Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	The Slane 840 Westchester Avenue New York NY	Approved	\$650.00
47642	07A0033	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requested approval for the electric service equipment proposed to be installed	666 Fifth Avenue New York NY	Approved	\$650.00
47643	07A0034	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	787 7th Avenue New York NY	Approved	\$650.00
Verify grounding scheme of generator are 3 or 4 pole ATS being used. Job finalized 2/9/07.						
47644	07A0035	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	25 Broadway New York NY	Approved	\$650.00
Verify length of tap. Is it 5' or 25' tap. If tap is 5' or 25' bring up to 2500 amps. Job finalized 2/9/07.						
47645	07A0036	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Linda Koenig 24 Morrison Avenue Staten Island NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						

# ADVISORY BOARD CALENDAR

January 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47646	07A0037	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Adrian Grenier 430 Grand Avenue Brooklyn NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47647	07A0038	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Kevin Buckley 211-60 Breezy Point Blvd. Rockaway Pt. NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47648	07A0039	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Roy Frasier 325 Park Place Brooklyn NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47649	07A0040	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Spindelman 106 Clay Street Brooklyn NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47650	07A0041	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Steven Trevor 48 West 88th Street New York NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						

# ADVISORY BOARD CALENDAR

**January 17, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47651	07A0042	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Royal Baltic 9829 Ditmas Avenue Brooklyn NY	Approved	\$0.00
<p>With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.</p>						
47652	07A0043	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Royal Plastics 2840 Atlantic Avenue Brooklyn NY	Approved	\$0.00
<p>With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.</p>						
47653	07A0046	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested Concept Approval	Kepco Building 1 131-38 Sanford Avenue Flushing NY	Approved	\$0.00
<p>With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.</p>						
47654	07A0044	L.E.A. Electric Corp. 1001 Sixth Avenue New York NY 10018	Requested approval for the electric service equipment proposed to be installed	25 Chapel Street Brooklyn NY	Approved	\$650.00
47655	07A0045	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Tishman-Speyer Properties 50 Rockefeller Plaza New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**January 17, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47656	07A0047	Power Masters Electrical Contracting, Inc. 37-23 27th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	400 East 57th Street New York NY	Approved	\$650.00
47657	(	D & S Electrical Corporation 450 Beach 48th Street Far Rockaway NY 11691	Requesting permission to install Schedule 80 non metallic service entrance standpipes on 8, 2 family buildings located in a corrosive area Far Rockaway, Queens	70&172 Marvin St, 193,95&199 Bch Far Rockaway NY	Approved	\$0.00
47658	((	Mari Electric 535 Wild Avenue Staten Island NY 10314	Requesting permission to install Schedule 80 non metallic conduit outdoor underground to extend 13,800 volt service laterals 400 feet to the property line.	100 Windward Court Staten Island NY	Approved	\$0.00
47659	(((	Hirschel Electrical, Inc. 411 Beach 30th Street Far Rockaway NY 11691	Requesting permission due to the commercial building having no common areas to install service switches on the outside of each building.	2002 Cornaga Avenue Queens NY	Denied	\$0.00
Contractor did not provide sketch of job that was requested by the Advisory Board prior to the 1/17/07 meeting.						
47660	(((	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to utilize the old New York City Electrical code to reconfigure clearances inside of existing electrical closets where the bus ducts, panels and feeders are being replaced and to also waive requirements related to foreign systems in dedicated equipment space.	425 Park Avenue New York NY	Approved	\$0.00

With the stipulation that: 1) a sketch is submitted for special permission showing the final layout of the electric closets affected. 2) That all clearance issues inside of the electrical closets can not be less than 36 inches. 3) The telephone risers running through the electrical closets must be boxed in.

# ADVISORY BOARD CALENDAR

**January 17, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47661	(((	Kleinknecht Electric Company, Inc. 940 Eighth Avenue New York NY 11019	Request permission to keep the feeder cables grouped together by phase instead of phase and neutrals in a metallic wireway.	Pierpoint Morgan Library 29 East 36th Street New York NY	Denied	\$350.00
47662	(((	Levest Electric Corp. 325 West 37th Street New York NY 10018	Requesting permission to install a 2000 amp service switch with a front clearance of four feet on a 1000 KVA service.(Calendar # 47586).	Amalgamated Bank 275 7th Avenue New York NY	Approved	\$0.00
47663	((((	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requesting permission to leave as fabricated and installed service switchgear where the fire pump service switch is installed in the middle of the switchboard. (Calendar #47565 Ok, but).	1510 2nd Avenue New York NY	Approved	\$0.00
47664	((((	Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356	Requesting permission to leave as installed a 3000 amp service switch with a front clearance of 39 inches on a 1000 KVA service.		Approved	\$0.00
47665	07A0048	Teknion, LLC 12000 Horizon Way Mount Laurel NY 08054	Requested approval for use in New York City of your B3 Boulevard Teknion Modular Furniture Systems.		Approved	\$200.00