

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
44658CO-	03A0061CO-	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	325 Hudson Street(FOCAL) New York NY	Hold	\$250.00
Carried over from February 26, 2003 meeting. 2/18/04-Provide information and justify use of 3 4/O per pahse in free air. What is the termination of breaker rated for 75% or 90 degrees?						
44892CO	03A0259	Arc Electrical & Mechanical Contrs Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	359 Greenpoint Avenue Brooklyn NY	Hold	\$250.00
Carry over from May 14, 2003 meeting.						
45217CO	03A0546	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Aqueduct Racetrack 110-00 Rockaway Blvd. Queens NY	Approved	\$250.00
Carried over from September 17, 2003 meeting.						
45260CO-	03A0580CO-	Livingston Electrical Associates, Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	New Fire Alarm System 9 West 57th Street New York NY	Hold	\$250.00
2/18/04-Hold for new drawings. -Tap in ATS, KFMR size (95 KVA), Rule 12-01						
45300CO	03A0609CO	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	92-59 59th Avenue Queens NY	Approved	\$250.00
Carried over from November 19, 2003 meeting.						

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45317CO	03A0635CO	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	1095 Park Avenue New York NY	Ok, but	\$250.00
How far is the tap?						
45356CO	03A0652CO	Qnce Electrical Contracting Corp. 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Jacobi Medical Center Bronx NY	Hold	\$250.00
Carried over from December 17, 2003 meeting. 1) Ground lug & ground strap in para. switchgear must be on source side of disc. link. 2) Provide section views for SQ D & GE switchboards. 3) Verify clearance around paralleling switchboard. 4) Provide submittal on general circuit breakers. 5) Provide details on switchgear #1 & switchgear #2.						
45389CO	03A0684	Olympic Electrical Wiring Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	310 East 102nd Street New York NY	Approved	\$0.00
Carried over from December 17, 2003 meeting.						
45429CO	04A0007CO	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	New York Life 51 Madison Avenue New York NY	Ok, but	\$250.00
Carried over from January 14, 2004 meeting. 1. Clarify feed to panel is there a neutral? 2. Splice box to ATS #6 shows 600 MCM-should be 500 MCM.						
45441	04A0023	Hugh O Kane Electric Co., LLC 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYC Housing Authority 90 Church Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45442	04A0024	Electric Light & Power, Inc. 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Atlantic Terminal 139 Flatbush Avenue Brooklyn NY	Hold	\$650.00
1) Submit in Advisory Board format. 2) Need coordination study, available short circuit, general voltage, general grounding, system 1-Line with bus sizes, compliance with rule 12-01, show 2nd level overcurrent equipment.						
45443	04A0025	Flemington Electrical Maintenance Inc. 207 West 25th Street-7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Ultra Flex Packaging Corp. 494 Wortman Avenue Brooklyn NY	Hold	\$650.00
1) Service bus 4-1/4 x6" for 4000A. 2) Plan drawing to indicate all equipment w/I.D. and dimensions. 3) Provide details for 2nd fusing switchboard.						
45444	04A0026	Mechanical Electrical Corp. 876 Jamaica Avenue Brooklyn NY 11208	Requested approval for the electric service equipment proposed to be installed	IS-44 100 West 77th Street New York NY	Approved	\$650.00
45445	04A0027	Dean Electric Co., Inc. 7909 Third Avenue Brooklyn NY 11209	Requested approval for the electric service equipment proposed to be installed	Maimonides Medical Center 4802 Tenth Avenue Brooklyn NY	Approved	\$650.00
45446	04A0028	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Automobile Dealership of America 20th Avenue & 141 Street Whitestone NY	Hold	\$650.00

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45447	04A0029	Sage Electrical Contracting 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	430 Park Avenue New York NY	Approved	\$650.00
45448	04A0030	D & D Electrical Enterprises Inc. 3505 E. Tremont Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	2500 Halsey Street Bronx NY	Approved	\$650.00
45449	04A0031	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	191 Bradley Avenue Staten Island NY	Ok, but	\$650.00
Provide reduced neutral justification.						
45450	04A0032	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	160 West End Avenue New York NY	Ok, but	\$650.00
1. Provide cuts on auto-transformers. 2. Provide reduced neutral calculations.						
45451	04A0033	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requested approval for the electric service equipment proposed to be installed	Atlantic Terminal 139 Flatbush Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45452	04A0034	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	The Rockefeller University 1230 York Avenue New York NY	Hold	\$650.00
1. New generator MCB submittal. 2. Short circuit and coordinate study. 3. Provide disconnects where power enters other buildings.						
45453	04A0035	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requested approval for the electric service equipment proposed to be installed	Atlantic Terminal/Bank of NY 139 Flatbush Avenue Brooklyn NY	Hold	\$650.00
1) Show ATS info on riser (3-Pole/4-pole?). 2) Furnish short circuit and coordinate study. 3) Furnish submittal on general main breakers. 4) Verify generator grounding.						
45454	04A0036	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	New York Life 51 Madison Avenue New York NY	Ok, but	\$650.00
1) Change main fuse to 5000 a lower 3000 to 2500. 2) Provide 2 lugs for grounding.						
45455	04A0037	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Frank Sinatra High School 20-30 Thomson Avenue Long Island City NY	Approved	\$650.00
45456	04A0038	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	215 West 90th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45457	04A0039	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1415 Richmond Avenue Staten Island NY	Ok, but	\$650.00
1. Point A must show short circuit. 2. Show supplemental ground on service switch #7.						
45458	04A0040	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	370 Ocean Parkway Brooklyn NY	Approved	\$650.00
45459	04A0041	Marcel Electrical Contracting Corp. 1406 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	19-23 St. Marks Place New York NY	Approved	\$650.00
45460	04A0042	Alco Electric, LLC 5790 Broadway Bronx NY	Requested approval for the electric service equipment proposed to be installed	172 West 79th Street New York NY	Approved	\$650.00
45461	04A0043	Barbaro Electric Co., Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	8-10 Murray Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45462	04A0044	Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bellevue Hospital First Avenue & 27th Street New York NY	Approved	\$650.00
45463	04A0045	Izzo Electric Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Taino Plaza 488 East 164th Street Bronx NY	Approved	\$650.00
45464	04A0046	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	11 West 42nd Street New York NY	Approved	\$650.00
45465	04A0047	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	150 Varick Street New York NY	Approved	\$650.00
45466	04A0048	Elmac Electric, Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	45-15 Colden Street Flushing NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45467	04A0049	A & A New York Electric Corp. 5224 3rd Avenue Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	215 West 23rd Street New York NY	Approved	\$650.00
45468	04A0050	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	90 West Street New York NY	Approved	\$650.00
45469	04A0051	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	405 Park Avenue South New York NY	Approved	\$650.00
45470	04A0052	Atlas Electric Contractors, Inc. 87-12 113th Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Port Richmond H.S. St. Joseph Avenue & Innis Street Staten Island NY	Approved	\$650.00
45471	04A0053	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens Vocational H.S. 37-02 47th Street Long Island City NY	Hold	\$650.00
1) Need supplemental ground point. 2) Increase bus on load side and line side of both 3000A service switch. 3) Fire pump need 4 1/0 conductors to feed fire pump and show bond and ground of fire pump.						

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45472	04A0054	Mechanical Electrical Corp. 876 Jamaica Avenue Brooklyn NY 11208	Requested approval for the electric service equipment proposed to be installed	JHS 60 420 East 12th Street New York NY	Approved	\$650.00
45473	04A0055	Falcon Electrical Contracting Corp. 159 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	CVS Store 2465 Richmond Avenue Staten Island NY	Approved	\$650.00
1) Add supplemental ground. 2) Mismarked 3-500 MCM instead of 4-500 feeding 400A service switch.- 9/20/04- finalized.						
45474	04A0056	Pulsar Electric Inc. 51 Atlantic Avenue Floral Park NY 11101	Requested approval for the electric service equipment proposed to be installed	3 UN Plaza New York NY	Approved	\$650.00
45475	04A0057	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	111 8th Avenue New York NY	Approved	\$650.00
45476	04A0058	CMS Electrical Service Co., Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	395 Hudson Street New York, NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45477	04A0059	Intrepid Electrical Contracting Co., Inc. 149 Waterbury Avenue Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Allen Stevenson School 132 East 78th Street New York NY	Approved	\$650.00
45478	04A0060	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University 80 Claremont Avenue New York NY	Hold	\$650.00
<p>1) Increase copper to 1200A service switch or decrease fusing on line and load. 2) All feeds to service switch must be terminated at load side of 3000A service switch. 3. Show bonding and grounding on existing 3000A service switch. 4) 1200 amp disc. Switch marked as service switch.</p>						
45479	04A0061	The Sound Beyond Electrical Corp. 134 West 29th Street-11th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	310 West Service Road Staten Island NY	Approved	\$650.00
45480	04A0062	Big Shot Electric Corp. 710 East 135th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Ritz Tower 101 East 57th Street New York NY	Approved	\$650.00
45481	04A0063	R & L Systems 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	8-12 West 14th Street New York NY	Ok, but	\$650.00
<p>1) 5 sets fo 500 MCM must terminate to fuses.</p>						

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45482	04A0064	R & L Systems 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1710 Broadway New York NY	Approved	\$650.00
45483	04A0065	C.M.Richey, Inc. Electrical Contractors 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Clove Lake Nursing Home 25 Fanning Street Staten Island NY	Approved	\$650.00
This installation is subject to other agencies having jurisdiction.						
45484	04A0066	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	116 John Street New York NY	Approved	\$650.00
45485	04A0067	Twins Electric Corp. 460 Austin Place Bronx NY 10455	Requested approval for the electric service equipment proposed to be installed	178-10 Wexford Terrace Queens NY	Approved	\$650.00
45486	04A0068	Axcel Electric Company 287 Tenth Avenue, Suite 2N New York NY 10001	Requested approval for the electric service equipment proposed to be installed	31 West 21st Street New York NY	Approved	\$125.00

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45487	04A0069	Harry Dorowski Electric 516 West 25th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	199 Bowery New York NY	Approved	\$650.00
45488	none	Lizardos Engineering Associates, P.C. 200 Old Country Road Mineola NY 11501	Requesting permission to design electrical wiring under the old New York City Electrical Code in a building that was filed with the New York City Building Department in October of 2000 (BIS #200613531).	Highbridge Senior Housing 1420 Plimpton Avenue Bronx NY	Approved	\$0.00
45489	-	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requesting permission to omit the one foot separation between service and distribution equipment on service switchboards on a previous approved drawing (Cal. #45366 old code). The service switch is equipped with ground fault protection.	7 World Trade Center New York NY	Approved	\$0.00
45490	--	Mechanical Electrical Corp. 876 Jamaica Avenue Brooklyn NY 11208	Requesting permission to allow a 18' tap in lieu of 10' for the installation of a 200 amp switch inside of a 1000 KVA service room.	JHS 60 420 East 12th Street New York NY	Approved	\$0.00
45491	---	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to not provide full selective coordination with the installation of 1200 amp Class "L" current limiting fuses which will feed a 800 amp circuit breakers.	Associated Press 450 West 33rd Street New York NY	Denied	\$0.00

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45492	--	Classic Electric, Inc. 29-05 21 Avenue Astoria NY 11105	Requesting permission not to file Advisory Board drawings on an 1000 KVA service where an existing 500 KVA 120/208V Y to 480 V Delta was replaced with a 500 KVA 208V Delta to 277/480V Y type with the addition of a 600 amp fused disconnect switch on the secondary.	10 West 66th Street New York NY	Approved	\$0.00
45493	---	Call Electric Co. 35-21 Ninth Street Long Island City NY 11106	Requesting permission to allow a 120/208V 200 amp disconnect switch to be installed in the service room with a front clearance of 32". This 200A switch will replace an existing 100 amp switch.	1700 Broadway New York NY	Approved	\$0.00
45494	----	Klear Electrical Corp. 40-21 24th Street Long Island City NY 11101	Requesting blanket approval to install 30 amp single phase service rated switches that will supply power to Time Warner power packs for cable TV. The load is 720 watts and many of the buildings encountered will have existing 1000 KVA services.	Citywide New York NY	Approved	\$0.00
45495	-----	New York City Housing Authority 23-02 49th Avenue Long Island City NY 11101	Requesting permission to install new feeders inside of elevator shafts that will provide power for elevator pit, cab and control room lighting, in four (4) buildings.	Walk, 133 Navy Walk and 719 King Brooklyn NY	Approved	\$0.00
45496	-----	New York City Housing Authority 23-02 49th Avenue Long Island City NY 11101	Requesting permission to install CCTV cabling and conduits inside of elevator shaftways that will be used to provide cameras in the elevator cars in 7 buildings.	7 Buildings	Approved	\$0.00

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45497	-----	Flack & Kurtz Inc. 475 Fifth Avenue New York Ny 10017	Requesting permission to install fiber and copper conductors that will enter an electrical room and terminate in a transition box that will change over the wiring method from outside to inside plant type. The wiring method from the transition box will be conduit and interduct that will run through the electric room to the PBX room.	North Shore-LIJ Med. Ctr. Queens NY	Hold	\$0.00
45498	-----	Electric Light & Power, Inc. 463 Wild Avenue Staten Island NY 10314	Requesting permission to install arc proof tape as barriers to isolate conductors energized from different 460 volt service switchboards.	Atlantic Term. Office Tower 139 Flatbush Avenue Brooklyn NY	Approved	\$0.00
45499	04A0070	The Durham Company 722 Durham Road Lebanon MO 65536	Requested approval for use in New York City of your Electrical Meter Socketss		Approved	\$200.00
45500	04A0071	Prescolite, Inc. 101 Corporate Drive, Suite L Spartanburg SC 29303	Requested approval for use in New York City of your Incandescent Recessed Lighting Fire Classified. Model/Series Nos. FT6, FT5, FT4 and FT4LV.		Approved	\$200.00
45501	04A0072	Prescolite, Inc. 101 Corporate Drive, Suite L Spartanburg SC 29303	Requested approval for use in New York City of your Incandescent Recessed Lighting Fire Classified Model/Series No. FT6CF.		Approved	\$200.00

ADVISORY BOARD CALENDAR

February 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45502	04A0073	Prescolite, Inc. 101 Corporate Drive, Suite L Spartanburg SC 29303	Requested approval for use in New York City of your Incandescent Recessed Lighting Fire Classified. Model/Series Nos. P63-FB, P63EBFB, P63-277FB, P66-FB, P66-EBFB, P66-277FB, P68-FB, P68-EBFB, P68-277EB, P69-FB and P69-277FB.		Approved	\$200.00
45503	04A0074	Prescolite, Inc. 101 Corporate Drive, Suite L Spartanburg SC 29303	Requested approval for use in New York City of your Incandescent Recessed Lighting Fire Classified. Model/Series Nos. P821-FB, P821-FBT, P821-FBFC, P85-FB, P831-FB and P817-FB.		Approved	\$200.00