

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49829CO3	09A0487CO3	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Jacobi Medical Center 1400 Pelham Parkway South Bronx NY	Approved	\$0.00
Carry over from September 15, 2010 meeting. 1) Portable generator switch to be a fused type. 2) Show conductors to portable generator switch. 3) Omit generator ground from grounding collector bar. Job finalized 3/23/11.						
50203CO2	10A0245CO2	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	11 Fifth Avenue New York NY	Hold	\$0.00
Carry over from October 13, 2010 meeting.						
50242CO	10A0280CO	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Lehman College 2990 Goulden Avenue Bronx NY	Hold	\$0.00
Carry over from August 11, 2010 meeting.						
50344CO2	10A0365CO2	Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Tallman Island WPCP 127-01 Powells Cove Boulevard College Point NY	Hold	\$0.00
Carry over from January 19, 2011 meeting.						
50382CO2	10A0400CO2	Jordan Daniels Electrical Contractors, Inc. 151 West 25th Street, 7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sprint 60 Hudson Street New York NY	Hold	\$0.00
Carry over from January 19, 2011 meeting.						

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50385CO2	10A0403CO2	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Madison Square Garden 4 Penn Plaza New York NY	Approved	\$0.00
Carry over from January 19, 2011 meeting. Provide coordination curves for new gen. distribution. Job finalized 3/28/11. 9/16/14 Swapped A1-Rev 5, B1-Rev 6, B2-Rev 6.						
50407CO	10A0425CO	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	18 Richmond Terrace Staten Island NY	Hold	\$0.00
Carry over from December 22, 2010 meeting. 1) No coordination between 3000A and 1200A cb's curve plotted wrong for 3000A CB. 2) Gen coord curves plotted wrong 1000A CB. 3) Fire Alarm ATS cannot be in a service room. 4) show ATSS on 1-line.						
50415CO2	10A0433CO2	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mt Sinai Ctr for Science and Med 1470 Madison Avenue New York NY	Hold	\$0.00
Carry over from January 19, 2011 meeting.						
50522	11A0038	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	ABC-TV 125 West End Avenue New York NY	Approved	\$650.00
50523	11A0039	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	431 West 37th Street New York NY	Approved	\$650.00
Job finalized 3/2/11.						

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50524	11A0040	Arcadia Electrical Co., Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	I.S. 117K 300 Willoughby Street Brooklyn NY	Ok, but	\$650.00
Relocate new service switch to wall or add additional door to service room						
50525	11A0041	Jeminis Electrical Contractors, Inc. 22-42 129th Street, 2nd Floor College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Con Edison Emergency Gen. 30 Flatbush Avenue Brooklyn NY	Denied	\$650.00
This is not a 1000 KVA service.						
50526	11A0042	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1271 6th Avenue New York NY	Approved	\$650.00
50527	11A0043	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Lowe's South Staten Island Staten Island NY	Denied	\$650.00
Not Advisory Board issue.						
50528	11A0044	Centrum Electric Corp. 12 Lombardy Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	33 West End Avenue New York NY	Approved	\$650.00
7/9/14 Swapped Revision 1.						

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50529	11A0045	Carl & Mark Electric Corp. 214-75 Jamaica Avenue Queens Village NY 11428	Requested approval for the electric service equipment proposed to be installed	900 Broadway New York NY	Approved	\$650.00
50530	11A0046	Urban Tech Electric Inc 108-02 Rockaway Beach Blvd., 2nd Floor Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	300 East 93rd Street New York NY	Approved	\$650.00
50531	11A0047	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	1212 Fifth Avenue New York NY	Approved	\$650.00
Why two normal feed from same P.O.E.? Job finalized 03/28/11						
50532	11A0048	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	NYU-Langone Med. Ctr. 550 First Avenue, 3rd Floor Lab New York NY	Approved	\$650.00
50533	11A0049	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S. 331K 7002 Fourth Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50534	11A0050	Heller Electric, Inc. 620 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	100 Henry Street Brooklyn NY	Approved	\$650.00
50535	11A0051	M.R. Electrical Service LLC 115 Heyward Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	2-25 50th Avenue Long Island City NY	Approved	\$650.00
1) Show cu detail in new terminal cabinet. 2) Who will be installing new cu bus detail? Job finalized 3/28/11.						
50536	11A0052	Power Distribution Electrical Contracting 1107 43rd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	3339 Park Avenue Bronx NY	Approved	\$650.00
50537	11A0053	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	Bush Terminal 4302 First Avenue Brooklyn NY	Hold	\$1,300.00
50538	11A0054	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Metropolitan Museum of Art 1000 Fifth Avenue New York NY	Hold	#Error
1) Existing service bus undersized for new switchboard E. 2) Show clearances in front of switchgear. 3) How are rear covers attached to the switchboard. 4) Show bus sizing in Switchboard "E", "H" and "F". 5) Provide transformer cut sheets. 6) Provide cut sheet of GF switch for transformer. 7) Provide coordination study.						

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50539	11A0055	Twins Electric Corporation 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	27--03 42nd Road Queens NY	Approved	\$650.00
1) Service switches drawn backwards. 2) Fire pump feed taken from through bus. 3) Fire pump branch circuit undersized. 4) Feeder to panel not identified. 5) Provide barrier at end of switchboard. 6) Show short circuit calculations for 200 amp panel. Job finalized 8/3/11. 6/28/13-Received letter requesting job address correction. Address corrected on 7/1/13.						
50540	11A0056	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	DEP 1801 Richmond Terrace Staten Island NY	Approved	\$650.00
Provide proof that bus modifications are being installed by a listed shop. Job finalized 3/23/11.						
50541	11A0057	Royal Electrical & Wiring Corp. 27-07 BQE West Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	East New York Apartments 805 East New York Avenue Brooklyn NY	Approved	\$650.00
1) P5 panel not bonded and grounded. 2) Fire pump conductors undersized. Job finalized 3/28/11.						
50542	11A0058	Levinson & Santoro Electric Corp. 18-20 130th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Morris High School 1110 Boston Road Bronx NY	Approved	\$650.00
Provide bus sizing of Siemens switchboard. Job finalized 4/19/11.						
50543	11A0059	Shelter Electric 53-01 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Animal Medical Center 510 East 62nd Street New York NY	Ok, but	\$650.00
1) Tap conductor undersized. 2) What is the length of the tapped conductor? 3) Neutral in 200 amp disconnect switch is bonded. 4) Bubble all new work.						

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50544	11A0060	J.R.D. Electric Corp. 67-11 79th Street Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	Ruben & Company 600 Madison Avenue New York NY	Approved	\$650.00
1) Where is new trough located? 2) #2 tap conductor is undersized. 3) Equipment grounding conductors undersized. Job finalized 6/30/11.						
50545	11A0061	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	236 Livingston Street Brooklyn NY	Approved	\$650.00
1) Neutral not bonded and grounded in service switch. 2) Neutrals in disconnect switches are bonded. 3) Verify if switchboards are existing. Job finalized 4/19/11.						
50546	11A0062	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Con Edison 1610 Matthews Avenue Bronx NY	Approved	\$650.00
Verify that new service equipment is not subject to mechanical injury. Provide site plan. Job finalized 6/28/11.						
50547	11A0063	Litespeed Electric, Inc. 135 West 29th Street, Suite 301 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1385 Broadway New York NY	Approved	\$650.00
Fuses are not coordinated. Job finalized 3/29/11.						
50548	11A0064	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	The Ciena 314 East 100th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50549	11A0065	Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requested approval for the electric service equipment proposed to be installed	408 Broadway New York NY	Approved	\$650.00
50550	11A0066	Selectric Electrical Contracting Co., Inc. 78-14 46th Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	IS 232 1700 Macombs Road Bronx NY	Approved	\$650.00
50551	11A0067	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Verizon 50 Varick Street New York NY	Approved	\$650.00
50552	11A0068	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S. 310K 942 62nd Street Brooklyn NY	Approved	\$650.00
50553	11A0069	Tesla Electric Corp 23-18 Steinway Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	400 Broome Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50554	11A0070	zardos Mechanical & Electrical Engineeri 240 West 35th Street, Suite 304 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	New York Hospital Queens 56-45 Main Street Flushing NY	Approved	\$650.00
50555	11A0071	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	St. Mary's Hospital for Children 29-01 216th Street Bayside NY	Denied	\$650.00
1) Verify that Con-Ed is bringing in the 9 sets of 500MCM. 2 Section bus size not shown. 3) Equipment grounding conductors undersized. 4) Neutral in FP emergency switch bonded to enclosure. 5) Transformer tap lengths not shown 6) TVSS service switch not bonded and grounded. 7) Generator room layout not provided. 8) Verify that emergency feeders are not ran through service room. 9) Line and emergency side FA switch feed not taken from line side of main switches. 10) Provide coordination study for new work for correct job. (11) Review not complete.						
50556	11A0072	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Verizon-Network Separation 227 East 30th Street New York NY	Approved	\$650.00
50557		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Permission for an installation of equipment of equipment operating in excess of 600 volts.	Fordham Preparatory School 441 East Fordham Road Bronx NY	Denied	\$0.00
With the stipulation: 1) Transformer shall be delta primary and Y secondary. 2) Show grounding scheme.						
50558		New York City Housing Authority 90 Church Street New York NY 10007	Requesting permission to install new unspliced elevator feeder conductors inside of 23 existing elevator shaftways where the old elevators are being replaced	Astoria Houses oria Blvd., 8th St., 27th Ave. and 1st Queens NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50559		Heller Electric, Inc. 620 Coney Island Avenue Brooklyn NY 11218	Requesting permission to leave as installed on a 1000 KVA service without filing drawings the replacement of a defective 1600 amp service switch.	9 Hall Street Brooklyn NY	Denied	\$350.00
50560		Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requesting permission due to lack of space inside of the building to install new service equipment outside of a commercial building	Van Nest Server Room 1610 Mathews Avenue Bronx NY	Approved	\$0.00
50561		Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requesting permission to install underground concrete encased service entrance conductors in nonmetallic rigid conduit where one of the conduits will power a fire pump.	456 West 19th Street New York NY	Approved	\$0.00
With the stipulation that Schedule 80 pvc is installed.						
50562		J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requesting permission due to lack of space inside of the service room to leave as installed new service equipment installed in the adjacent room with signage.	5730 Mosholu Avenue Bronx NY	Approved	\$350.00
50563		Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Permission on the coordination between the 1200A over current protective devices and distribution panel EDP11 be accepted at .10 seconds.	PS 59 and H.S. Arts/Science 250 East 57th Street New York NY	Denied	\$0.00

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50564		Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requesting permission to tap power for a fire pump in the CT cabinet that contains a service switch	227 East 30th Street New York NY	Approved	\$0.00
50565		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission for a variance from the requirements of the NYC Electrical Code Amendment Section 408.51, (c), (2). This code section creates a hardship because the GE Switchgear is not Density rated under UL 1558 testing procedures but carries a continuous 5000Amp heat rise rating[Data previously submitted]. By accepting the request to use the breaker trip rating, under Article 240.6, (c), (1), which can allow the ampere rating of the breaker frame to equal the adjusted current setting, than the proposed equipment would meet the condition of 408.51, (c), (1) where bus bars shall be sized at 800Amps per square inch. The current density of the proposed Switchgear with the breaker's Long Item Pick-up Setting, at 4750Amps is 791.66 Amps per square inch, based on 6 Sq. Inches of Bus [2-8x3/8]. The Pickup setting will be secured, on the frame itself, with a tamperproof guard and a seal over the adjusting means with appropriate nameplate designations.	Mt. Sinai School of Medicine 101st Street and Madison Avenue New York NY	Hold	\$0.00
50566	11A0073	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	360 Lexington Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 18, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50567	11A0074	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Long Island Jewish 75-59 263rd Street Glen Oaks NY	Hold	\$650.00
1) Correct title box to correct address. 2) Show 2nd level GF protection and coordination study.						