

# ADVISORY BOARD CALENDAR

**March 12, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52208	13A0130CO2	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Public Safety Answering Ctr II 350 Marconi Street Bronx NY	Approved	\$0.00
Carry over from August 14, 2013 meeting.						
52209	13A0396	Anthony G. Ferry Inc. 1916 Park Avenue New NY 10037	Requested approval for the electric service equipment proposed to be installed	111 Lawrence Street Brooklyn NY	Approved	\$650.00
52286	13A0593CO	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Target Throgs Neck 815 Hutchinson River Parkway Bronx NY	Approved	\$0.00
Carry over from November 20, 2013 meeting. Show length of tap conductor. 4/17//14 Job finalized. 7/28/14 Rejected #3 was approved.4/17/14. 1/12/15 Swapped 1 of 1, Revision 4.						
52239	13A0697CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	99 Church Street New York NY	Approved	\$0.00
Carry over from February 12, 2014 meeting. Provide documentation from a mechanical engineer that proper ventilation is installed in the service room. 3/21/14 Job finalized.						
52295	13A0719CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Cobble Hill Health Center 380 Henry Street Brooklyn NY	Approved	\$0.00
Carry over from January 15, 2014 meeting. 1) Provide DLO cut that provides 70% ampacity for cable. 2) Correct service designation "new". All Service equipment are existing , verify.						

# ADVISORY BOARD CALENDAR

**March 12, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0039CO	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	605 West 42nd Street New York NY	On Hold	\$0.00
Carry over from February 12, 2014 meeting. 1) Item #5 not addressed tap length not shown and conductors to be derated 310.15 B4C, neutral counted as current carrying conductor. 2) Provide detailed load calculations showing neutral reduction non linear loads.						
	14A0040	Horsepower Electric 188 21st Street, 2nd Floor Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	98 Montague Street New York NY	Pending	\$650.00
1) Which listed switchboard shop will be performing the bus work in the switchgear. 2) Vertical bus in Section MDP-1 sec 3 undersized. 3) Size and main bonding jumper not shown on drawing.						
52483	14A0045	Right Away Electric, LLC 56-15 Andrews Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	490 Myrtle Avenue Brooklyn NY	Approved	\$650.00
1) Incoming AIC not shown. 2) Service entrance conductors to ss #3 undersized. 3) Size of feeder conductors to ODB not shown. 4) Short circuit study not provided by a P.E. 5) Fire pump must not be shared with other OCPD. 8/21/14 Job finalized.						
52532	14A0053	Abstract Electrical Contractors, Inc. 18--60 45th Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	395 Flatbush Extension Brooklyn NY	Approved	\$650.00
1) Clarify number of cables in existing wireway, 4 sets of #2 not shown on 1 line. 2) 1 line shows 36 conductors in wireway. 3) Conductors must be derated. 4) Length of new taps not shown. 7/18/14 Rejected 1) Existing under floor wireway, 1 line does not match Note; 1Line show 44 conductors and note says 30 conductors. 2) Tap conductors to new switches to be 600 KCM. 9/17/14 Job finalized.						
52223	14A0056CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	85 Broad Street New York NY	Approved	\$0.00
Carry over from February 12, 2014 meeting.						

# ADVISORY BOARD CALENDAR

**March 12, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52274	14A0058	Heller Electric Co., Inc. 620 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	421 Hudson Street New York NY	Approved	\$650.00
Verify who will be performing the bus work in the existing 4000 amp service switch and who will be testing it. 4/14/14 Approved with the stipulation that the testing report is submitted after testing is performed,						
52210	14A0060	Reliable Electrical Contractors 41 Clinton Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	339 Greene Avenue Brooklyn NY	Approved	\$650.00
	14A0084	Altman Electric 94 East 4th Street New York NY 10003	Requested approval for the electric service equipment proposed to be installed	43 West 23rd Street New York NY	Pending	\$650.00
Provide short circuit curves service switch fuses to panel.						
52211	14A0088	AMC Electrical Services 140 18th Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Qwest Relocation 60 Hudson Street New York NY	Approved	\$650.00
12/16/14 Swapped Revision 1						
52232	14A0092	YS Electric 39-39 63rd Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	196 East 75th Street New York NY	Approved	\$650.00
Service switch reversed. 3/19/14 Job finalized.						

# ADVISORY BOARD CALENDAR

**March 12, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52212	14A0093	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Proctor & Gamble-3rd Floor 120 West 45th Street New York NY	Approved	\$650.00
<p>1) Show clearances in service room. 2) Load side of fire pump circuit conductors not fire rated where is the pull box located. 3) Size of vertical bus to 2000 amp service switch not shown, 4/16/14 Rejected 1) Show clearances in front of PPH and PPH-1 panels. 2) There are changes on drawings 1 of 5 and 5 of 5 Revision 1. Please describe the changes on drawings 2,3 and 4 of 5 Revision 1. If no changes were made to these drawings, they shall not be marked at Revision 1's, All that is needed are the corrected drawings. 5/15/14 Rejected 1) Drawing 1 of 5 shows Rev 1. 2) Drawings 2,3,4 and 5 of 5 show Rev 0 with changes not reviewed. 5/21/14 Job finalized.</p>						
52352	14A0095	First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	408 West 52nd Street New York NY	Approved	\$650.00
<p>1) New drawings cannot be marked Rev 5 showing revisions on 1st submittal. 2) Fire pump circuit conductors not fire rated. 3) Provide cut sheet for 1200A trans-s CT. 4/15/14 Job finalized.</p>						
52278	14A0096	First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	40 North 4th Street Brooklyn NY	Approved	\$650.00
<p>1) This drawing shows 3rd fusing Advisory Board approval not required see rule 1RCNY 34-05. 2) Drawing not in Advisory Board format.</p>						
	14A0098	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Presbyterian Hospital New York NY	On Hold	\$650.00
52357	14A0099	Re-Con Electric Inc. 1090 Leggett Avenue Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	135 West 52nd Street New York NY	Approved	\$650.00
<p>1) Provide 2nd copy of drawing. 2) Service room to be mechanically ventilated, door to open outwards. 5/22/14 Job finalized.</p>						

# ADVISORY BOARD CALENDAR

**March 12, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52282	14A0101	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	11 Times Square New York NY	Approved	\$650.00
Bubble new work only, Why are existing boards bubbled? 4/17/14 Job finalized.						
52398	14A0103	Strand Electric Co., Inc. 160 Eleventh Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Ocean Park Apartments 125 Beach 17th Street Far Rockaway NY	Approved	\$0.00
SANDY 1) 3000 amp service switch 13 to have 5' clearance in front of it. 2) Section bus undersized both boards. 3) Tap conductor undersized to 30 amp switch. 4) 30 amp disconnect switch not shown on room layout drawing. 6/25/14 Rejected Verify that fire standing switchboard complies with 408.60(F).. 3/4/15 Swapped FP50-01 Rev 2, AB20-01 Rev1, SB30--01 Rev 1 and SB30-02 Rev 1.						
52794	14A0104	Strand Electric Co., Inc. 160 Eleventh Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Ocean Park Apartments 120 Beach 19th Street Far Rockaway NY	Approved	\$0.00
SANDY 1) Tap conductor to 30 amp switch undersized. 2) Section bus in both boards undersized. 3) New panel DPHPD requires 3' clearance. 6/25/14 Rejected Verify that rear of switchboard complies with 408.60(F). 3/4/15 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52397	14A0105	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	Brookfield-Concourse Project 1 New York Plaza New York NY	Approved	\$650.00
Show selectivity. 6/25/14 Job finalized.						
52213	14A0106	M & M Control Wiring and Electrical, Inc. 2952/2954 Richmond Terrace Staten Island NY 10303	Requesting permission due to lack of space inside of the building to leave as installed service equipment installed on the outside wall where the service switches will not be grouped together.	62 Van Duzer Street Staten Island NY	Approved	\$0.00
Code: 230.70(A)(1) and 230.72(A). With the stipulation that the installation meets the requirements of Section 110.26 and signage is installed at each service location indicating where the other service is located.						

# ADVISORY BOARD CALENDAR

**March 12, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0107	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Health and Hospital Corporation 55 Water Street, 24, 25 and 26 Floors New York NY	Rejected	\$650.00
1) Neutral in 400 amp trans "3" bonded and grounded after service switch. 2) Bonding conductor is undersized. 3/25/14 Job finalized. 6/19/14 Relocate service equipment to allow access around the sides of the switchboards. 3/24/15 6-10 comment not addressed. New submittal required. 12/2/15 New submittal required.						
52214	14A0109	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Queens Ciollege-Kiely Hall 65-30 Kissena Blvd. Queens NY	Approved	\$650.00
52285	14A0110	Rainbow Electric Co. Inc. 76-18 Rockaway Blvd. Woodhaven NY 11421	Requested approval for the electric service equipment proposed to be installed	200 East 27th Street New York NY	Approved	\$650.00
Verify coordination between 2000A and 1200A fuses. 4/17/14 Job finalized.						
52235	14A0111	Allstate Electric Corp. 555 8th Avenue, Suite 809 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	500 Eighth Avenue, 4th Floor New York NY	Approved	\$650.00
Block space next to the new 800 AM s.s. 3/20/14 Job finalized.						
52519	14A0112	A.L. Electrical Corp. 307 7th Avenue, Suite 404 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	31 East 74th Street New York NY	Approved	\$650.00
1) 5' clearance required in front of service switches. 2) Correct size of fire pump service switch on room layout drawing. 3) Verify that emergency feeders do not run through service room. 4) Show AIC rating for normal side of the ATS'. 5) Provide cut sheet of emergency generator panel and method of termination, and feeder size to emergency panel. 9/15/14 Job finalized. 9/23/16 Swapped drawing 1 and 2-Revision 2.						

# ADVISORY BOARD CALENDAR

**March 12, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52346	14A0113	J.A. Lee Electric, Inc. 23-55 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	333 Hudson Street New York NY	Approved	\$650.00
1) Provide OCPD for the temp gen. 2) Correct point of short circuit calc to point A. 3) Indicate if the ATS and gen are separately derived system. 4/21/14 Rejected Item #1 not addressed fused disconnect switch required. 5/15/14 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/25/16 Swapped drawing 1-Revision 2.						
52445	14A0114	Power Masters Electrical Contracting Inc. 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	1191 Boston Road Bronx NY	Approved	\$650.00
1) How long are tapped conductors to panel PPLD? EGC undersized. 2) Fire alarm switch to comply with 110.26(3). 3) Where is switchboard MSWBD #1 with 800 amp switch feeding emergency. 7/24/14 Job finalized. 5/23/16 Swapped drawings 1 and 2-Revision 1.						
52460	14A0121	Sheridan Electric, LTD. 197 Grand Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	18-22 West 56th Street New York NY	Approved	\$650.00
1) Fire pump circuit conductors undersized and emergency fusing undersized. 2) Verify that emergency feeders are not run through the service room. 8/8/14 Job finalized.						
52215	14A0122	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	NBC Data Center 30 Rockefeller Plaza, 7th Floor New York NY	Approved	\$650.00
52248	14A0123	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Whitney Museum 945 Madison Avenue New York NY	Approved	\$650.00
1) Neutral in 800 amp disconnect switch bonded after service switch. 2) 2nd fuse does not coordinate. 4/10/14 Job finalized.						

# ADVISORY BOARD CALENDAR

**March 12, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52229	14A0124	Star Delta Electric, LLC 17 Battery Place, Suite 203 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	The Trump International Hotel One Central Park West New York NY	Approved	\$650.00
Power study shows no coordination between 1600 and 1200 amp fuses. 3/17/14 Job finalized. 8/11/14 Swapped A drawing Revision 2.						
52216	14A0125	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	33-06 88th aka 87-02 Northern Blvd. Queens NY	Approved	\$650.00
4/17/14 Swapped 1-1 Rev 1.						
52272	14A0126	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	136-140 West 42nd Street New York NY	Approved	\$650.00
1) 2500 amp fuse to 1500 amp fuse does not coordinate. 2) Service room to open outwards. 4/14/14 Job finalized.						
52284	14A0127	Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	1293 Broadway New York NY	Approved	\$650.00
Service room door to open outwards. 4/17/14 Job finalized. 4/21/16 Swap drawing, 1 and 2-Revision 4.						
52217	14A0128	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	360 West 31st Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**March 12, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52273	14A0129	NJS Electrical Service Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	1065 Avenue of the Americas New York NY	Approved	\$650.00
Provide metering equipment. 4/14/14 Job finalized. 3/30/15 Swapped 1 and 2, Revision 2s.						
52247	14A0130	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	75 Clinton Street Brooklyn NY	Approved	\$650.00
1) Missing coordination information at 10KA breaker panels. 2) Need available fault current at 10KA breaker panels. 4/10/14 Job finalized.						
52218	14A0131	J.J. Rosenberg Electrical Contrs, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	Valentino 693 Fifth Avenue New York NY	Approved	\$650.00
10/5/15 Rejected. New changes don't comply with 110.26(A)(2), and are not shown on 1 Line drawing. 9/22/16 Swapped drawing B-Revision 2.						
52219	14A0132	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requesting permission on a Hurricane Sandy recovery installation where the service will be located to a higher location to utilize MC cable as a wiring method for service entrance conductors in a five foot high area between the top of the end boxes and the service room floor where flexibility is required where new building steel must be installed to support the new service room.	Waterside Plaza 10, 20, 25, 30 and 40 Waterside Plz New York NY	Approved	\$0.00
Code: 230.43. With the stipulation that construction containing the service entrance conductors, and Con ED boxes complies with Section 230.6(5) of the New York City Amendments. *Confirm this installation with Con-Edison.						

# ADVISORY BOARD CALENDAR

**March 12, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0136	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	75 Broad Street New York NY	Rejected	\$650.00
<p>1) New drawings cannot be marked Revision 1. 2) Service rooms to be mechanically ventilated. 3) Service switchboards to comply with 230.64(B)(4) on 408.60(F). 4) Show elevation drawing of existing service entrance boxes 4 &amp; 5 and show clearances. 5) Show clearances in service room. 6) Identify on all 1 line drawings where SEBS are located. 7) Is Con ED installing service entrance conductors to service equipment as stated on 1 line drawing? 8) Verify that existing service entrance conductors were not water damaged. 9) Fire pump circuit conductors not fire rated. 10) Vertical bus on load side of 2000 amp main #2 distribution B #2c undersized drawing 1 of 20. 11) Vertical bus in Distribution #3B undersized drawing 4 of 20. 12) Drawing 7 of 20 is ATS 3 or 4 pole type. 13) Drawing 9 of 20 indicate which drawing is supplying DP-6A and show OCPD size. 14) Drawing 12 of 20 which drawing supplies 2000 amp disconnect switch and show OCPD, and where is load side supplying? 15) Drawing 7, 8, 12, 13 take off bus sizes supplying disconnect switches not shown. 16) Coordination study not provided. Review not completed. 9/18/14 1) Item #9, 16 not addressed. 2) Bus in service entrance box undersized drawing 1, 9. 3) Feeders undersized for special service fire pump drawing 7, 4) Physicals of end boxes don't match 1 line drawing.</p>						
52220	14A0137	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requesting permission to utilize an underground sprinkler water pipe as a supplemental grounding electrode in a non steel structured building where a vapor barrier that can't be punctured is installed under the building.	5-11 47th Avenue Queens NY	Approved	\$0.00
Code: 250.53(D)(2), 250, 52(A)(8).						
	14A0139	Roma Electric Corp. 30-75 14th Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	505 West 19th Street New York NY	Rejected	\$650.00
<p>1) Tap conductors to 400 amp disconnect switches undersized. 2) EGC to 400 amp disconnect switch undersized. 3) Bus sizes of switches not shown on 1 line drawing. 4) Bonding and grounding to be installed on line side of neutral link. 4/14/14 Rejected 1) Do not bubble corrections or changes, use delta symbol. 2) Item #3 not addressed in Delta board. 3) Neutral to be bonded to enclosures in remote service switches. 4) 2 copies of corrected drawings to be submitted. 5/15/14 Job finalized. 10/5/15 Rejected. New submittal required installation changed from original submission.</p>						
52221	14A0141	Jun Safety Electrical Inc. 1801 86th Street Brooklyn NY 11204	Requesting permission to leave as installed due to lack of space in the service room to allow new additional service equipment in the adjacent room.	245 West 51st Street New York NY	Approved	\$0.00
With the stipulation that the installation meets the requirements of Section 110.26 and signage is installed at each service location indicating where the other service is located.						

# ADVISORY BOARD CALENDAR

**March 12, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0143	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to leave medium voltage bus density at 1000 amps per square inch instead of 700 amps per square inch as per ANSI/IEEE heat run tested ratings for application special to this project.	17-19 Hazen Street Bronx NY	On Hold	\$0.00
Code: 230,42(A). Provided listing documentation for the medium voltage equipment.						