

ADVISORY BOARD CALENDAR

March 13, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51588	12A0144CO	Top Shelf Electric Corporation 463 Wild Avenue Staten Island NY 10314	Requesting permission to feed 4 separate lots with two service points where the service equipment for two buildings will be installed on the outside of commercial buildings where there is no space to install the equipment indoors.	32, 4384, 4386 and 4388 Victory Blv Staten Island NY	Approved	\$0.00
Carry over from July 18, 2012 meeting.						
	13A0051	Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	Throgs Neck Shopping Center 815 Hutchinson River Parkway Bronx NY	On Hold	\$650.00
1) Main bonding jumper not shown on drawing for s.s. 2) Verify incoming service ent. Conductors are Edison. 3) Feeder to PNL HDP-1 not shown, bus size in panel not shown. 4) Grounding electrode not shown on drawing for F.A. 5) Tap conductors size and length not shown on drawing for trans S combo 1 sw. 6) Tap conductors on loadside of 2000A disc. Switch length not shown. 7) Mechanical ventilation not provide for service room.						
	13A0052	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	IS 297Q 74-03 34th Avenue Queens NY	On Hold	\$650.00
1) 2000 amps s.s. and 1200 amps disc. Sw. are reversed. 2) S.S.WB and RDB physical different from one line. 3) Buss to 2000 am service switch undersized. 4) Provide AIC. 5) Provide larger text(readable). 6) Show 2						
51693	13A0053	Electrical Design Management, LLC 939 Eighth Avenue, Suite 301 New York NY 10019	Requested approval for the electric service equipment proposed to be installed	300 East 23rd Street New York NY	Approved	\$650.00
Short circuit study to comply with Section 3018(L). Job finalized 7/3/13,						
	13A0054	Cobex Inc. 74-16 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	6209 11th Avenue Brooklyn NY	On Hold	\$650.00
1) Drawing submitted, not Advisory Board format. 2) SWBD bus and section bus size not shown on drawing. 3) Equipment manufacture cut sheets not provided. 4) Main and supplemental grounding electrodes not shown on drawing. 5) Fuse type and fuse coordination not provided. 6) Main bonding jumpers not shown on drawing. 7) Measurement not provided for SWBD in service room.						

ADVISORY BOARD CALENDAR

March 13, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	13A0055	Testa Electric Company, Inc. 1435 65th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	503 Fulton Street Brooklyn NY	On Hold	\$650.00
1) Drawing submitted not Advisory Board format. 2) SWBD bus size not shown on drawing. 3) Equipment manufacture cut-sheets, not provided. 4) Main water pipe and supplemental grounding electrode not shown on drawing. 5) Fuses type and fuse coordination not provided. 6) Main bonding jumpers and size not shown on drawing.						
51630	13A0058CO	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	120 Wall Street New York NY	Approved	\$0.00
SANDY Carry over from February 20, 2013 meeting. 1) Show cable tray run and how building conductors will be installed in the trays and not interfering with switch operation, how will DLO cables enter the trays. 2) Emergency lighting inverter to be removed from service room. 3) Verify that the doors for the fire rated room need to open 180 degree or move room closet to the door. Job finalized 4/19/13.						
51589	13A0068	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	645 10th Avenue New York NY	Approved	\$650.00
51655	13A0069	Joseph Weinstein Electric Corp. 94-24 88th Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Staples Store 699 6th Avenue New York NY	Approved	\$650.00
Verify min 1/0 install to building steel for supp gnd. Job finalized 5/10/13.						
52067	13A0070	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	529 West 29th Street New York NY	Approved	\$650.00
1) ATS room to be fire rated. 2) Provide mechanical ventilation in service room. 3) Provide length of taps and comply with tap rules. 4) Verify load calculations for apartments. 5) Verify reduced neutral calculations. 10/18/13 Item #3 not addressed, main disconnect switches required at each meter. 12/31/13 job finalized. 6/23/14 Rejected 1. New revisions marked Revision 4 when revision 4s were approved already. 2) Tap conductors undersized and weren't marked as changes. 3) Old Revision 4 note removed from drawings, meter bands. New work marked as Rev 4 when it should be Rev 5. 4) Fire alarm has two 60 amp service switches on normal side, emergency FA switch is located in gen set. 5) Special service fire pump underfused on normal and emergency side. 6) Provide listing for gen set as a complete assembly.						

ADVISORY BOARD CALENDAR

March 13, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51637	13A0071	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	55 West 25th Street New York NY	Approved	\$650.00
1) Service switch to comply with 250.64(D)(2). 2) Verify that service room is fire rated. Job finalized 4/29/13.						
51661	13A0072	Gold Star Electrical 59-24 57th Street Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	364 6th Avenue New York NY	Approved	\$650.00
Grounding electrode not provide at service switches. Article 250.64(D)(2). Job finalized 5/21/13.						
51612	13A0073	USA Electrical Services 77-08 21st Avenue East Elmhurst NY 11370	Requested approval for the electric service equipment proposed to be installed	540 Main Street New York NY	Approved	\$650.00
1) Provide listing documentation for co-gen. 2) Sequence of operation not provided. 3) Provide A/C. Job finalized 4/4/12.						
51636	13A0074	Megan Electrical Enterprises 36-51 Bell Boulevard, Suite #208 Bayside ny 11361	Requested approval for the electric service equipment proposed to be installed	Avantus Dialysis Center 315 East 62nd Street New York NY	Approved	\$650.00
Main and a supplemental grounding electrode not provide Art 250.64(D). Job finalized 4/24/13.						
51656	13A0075	OM Electric, Inc. 262 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	301 West 125th Street New York NY	Approved	\$650.00
Remove service switch to be grounded 250.64(D) 2. Job finalized 5/10/13.						

ADVISORY BOARD CALENDAR

March 13, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51657	13A0076	Samson Electric Corp. 825 8th Avenue New York NY 10019	Requested approval for the electric service equipment proposed to be installed	825 8th Avenue New York NY	Approved	\$650.00
1) Neutral in generator disconnect switch not bonded to enclosure. 2) Verify that normal supplies to ATS' are 3rd fusing. Job finalized 5/10/13.						
51602	13A0077	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	510 West 42nd Street New York NY	Approved	\$650.00
51772	13A0078	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	436 East 149th Street Bronx NY	Approved	\$650.00
Remove service switches to be grounded 250.64(D)2. 7/29/13 job finalized.						
51689	13A0079	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	136-140 West 42nd Street New York NY	Approved	\$650.00
Fire pump service switches to comply with 250.64(D)2. Job finalized 6/19/13						
51774	13A0080	V-Mar Electric Ltd. 408 Grand Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	401 Park Avenue South New York NY	Approved	\$650.00
Remote service switch to be grounded 250.64(D)2. 7/29/13 job finalized.						

ADVISORY BOARD CALENDAR

March 13, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52718	13A0081	Dooley Electric Co., Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	34 East 51st Street New York NY	Approved	\$650.00
<p>1) Show what the clearance is in front of the end box on Level C. 2) Verify that Con Ed is supplying end box with 8 sets of 500 MCM. 3) Service entrance conductors and service bus undersized. 4) Feeders to fire pump undersized. 5) F.P. emergency fusing undersized. 6) Neutral in generator switch to be bonded and grounded supplying 4 pole ATS. 7) Provide separate enclosures for f.p. and 1600 c.b. taps at the generator. 4/16/14 1) No note at load side of generator indicating whether 3 or 4 pole ATS will be used downstream. 2) Are separate enclosures installed for generator disconnect switches? 1/6/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
51658	13A0082	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	Cambria Gardens 738 Albany Avenue Brooklyn NY	Approved	\$650.00
<p>1) Fire rated RHH cable to be installed in a 2 hour fire rated enclosure for the fire pump feeder. 2) Remote fire pump service switch and remote solar photovoltaic service switch to comply with 250.64(D)2. Job finalized 5/10/13.</p>						
51659	13A0083	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	Cambria Gardens 690 Albany Avenue Brooklyn NY	Approved	\$650.00
<p>1) Fire rated RHH cable to be installed in a 2 hour fire rated enclosure for the fire pump feeder. 2) Remote fire pump service switch and remote service switch for solar photovoltaic system to comply with 250.64(D)2. Job finalized 5/10/13.</p>						
51663	13A0084	Cabin Electric Inc. 77 Commerce Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Greystone Management 7 West 22nd Street New York NY	Approved	\$650.00
<p>1) Verify that there is 5' of clearance in front of the service switch. 2) Verify that switchboard has rear doors or block off rear of switchboard. 3) Verify that the clearance in front of the c.t. cabinet complies with 110.26(A)12. And Table 110.26. 4) Verify the number of grounding lugs and indicate whether building steel is present and bonded. 5) Provide size of main bonding jumper. 6) List fuse types. 7) Provide manufacturer's equipment cuts. 5/13/13- #6 and #4 not addressed. Job finalized 5/23/13.</p>						

ADVISORY BOARD CALENDAR

March 13, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51666	13A0085	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	850 3rd Avenue Brooklyn NY	Approved	\$650.00
1) Verify refurbishing of existing circuit breakers in existing switchboard was done by original manufacture. 2) GFP not provide at 1200 amps bus duct switches. 3) Provide cuts on the satin trip units and verify they are UL listed. 5/21/13- New Elemco test reports not sign by tester and P.E. that witness test. #1, #2 & #3 not address. Job finalized 6/13/13.						
51631	13A0086	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	2 Metrotech Center Brooklyn NY	Approved	\$650.00
1) Existing switchboard service bus under size. 2) Verify that ATS w/stand rating is 55 KAIC or more. Job finalized 4/22/13. Address correction from letter received on 4/8/13.						
52231	13A0087	Fred Geller Electrical, Inc. 37-32 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	550 1st Avenue New York NY	Approved	\$650.00
1) Verify by note what the size of the overcurrent devices are at generator 1 MCC-CG1-EB-4 and MCC-CG2-EB-7. 2) Equipment grounding conductor to ATS 112 undersized. 3) Provide secondary F.A. switch. 4) Verify that the ATS's have withstanding or provide operating of ATS/series rating with upstream rc.p. 12/18/13 Rejected 1) Item 1 not addressed. 2) Item #2 addressed, now other EGC's are undersized. 3) Drawing went from Revision 1 to 4 with customer comments without first correcting original comments. 4) Drawings 2,3 & 4 of 4 show Revision 4 but no changes have been identified. 2/26/14 Rejected 1) Item #1 not addressed. 2) Fire alarm EGC undersized. 3) Fire alarm transformer to be bonded and grounded at 1 location. 4) Item #4 not addressed. Drawings are marked Revision 4. 3/17/14 Job finalized. 2/6/17 Swapped drawings. Drawing 1-Revision4 and Drawing 3-Revision 3.						
	13A0088	Contact Plus Electrical Corp. 247 Van Brunt Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	50 Varick Street New York NY	On Hold	\$650.00
1) 4000A s.s. shown incorrectly on drawing. 2) Provide physical of 4000 amp service switch modifications. 3) Show how bus will be extended.						
51697	13A0089	Hal Electrical Contractors Inc. 32 East 31st Street, Suite 812 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	240 West 167th Street Bronx NY	Approved	\$650.00
1) Verify grounding electrode collector bus inside service room for s.s. for 250. 64(D)3 compliance. 2) One line diagram for fire alarm not shown on drawing. 3) Verify type of fire rated conductor for fire pump. Job finalized 7/11/13.						

ADVISORY BOARD CALENDAR

March 13, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51893	13A0090	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	PS 70Q 30-45 42nd Street Queens NY	Approved	\$650.00
1) Fire pump service ent. and circuit conductor undersize, line side not fire rated. 2) Fire pump emergency feeder under fused. 3) Show size of vertical bus to 2500 and 1600 amp disconnect switches. 4) Provide withstand ratings for ATS' 9/20/13 job finalized.						
51734	13A0091	M.R. Electrical Service LLC 115 Heyward Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	146 South 4th Street Brooklyn NY	Approved	\$650.00
1) Service grounding electrode conductors to 600 amps comb. Pal. undersize. 2) Provide w/stand (110.9) for s.s. 2,3,4, 5. Job finalized 7/19/13						
	13A0092	Broadway Electric LLC 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Cogeneration Project 55 Church Street New York NY	Denied	\$650.00
1) Drawings submitted are not in Advisory Board format. 2) Submit cut sheets and listing for Co-gen unit.						
	13A0093	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	180 Orchard Street New York NY	On Hold	\$650.00
Not Reviewed						
	13A0138	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	90 Broad Street New York NY	On Hold	\$0.00
SANDY 1) Was any of the existing equipment and underground feeders, if any ,submerged? Provide explanation of what work is being installed. 2) Provide FLA for fire pumps. 3) Is any of the existing equipment energized? 4) Is the service equipment new or existing? 5) Fuse types not provided. 6) Bus sizes and equipment physicals not provided. 7) Drawing not in Advisory Board format.						

ADVISORY BOARD CALENDAR

March 13, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51664	13A0139	Stasi/Dallas Electrical Contracting, Inc. 6908 Eighth Avenue Brooklyn NY 11228	Requested approval for the electric service equipment proposed to be installed	3405-3415 Neptune Avenue Brooklyn NY	Approved	\$0.00
SANDY 1) Secondary of transformers to be bonded to building steel or water main. 2) Fire pump h.p. not shown. 3) Verify transformer tap rules apply or install main in panelboard. 4) Verify that service room is mechanically ventilated. 5) Verify voltage and AIC. 6) Verify that system. Is coordinated. Job finalized 5/15/13. 11/23/15 Swapped drawings A-Revision 2; B-Revision 3						
51690	13A0140	Stasi/Dallas Electrical Contracting, Inc. 6908 Eighth Avenue Brooklyn NY 11228	Requested approval for the electric service equipment proposed to be installed	2750-3325 Neptune Avenue Brooklyn NY	Approved	\$0.00
SANDY Verify correct voltage and short circuit values. Finalized and swapped 6/19/13. 6/25/14 Swapped A-Rev 2 and B-Rev 3 address correction. 11/23/15 Drawing swapped A, Revision 3, B, Revision 4.						
51591	13A0141	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	85 Broad Street New York NY	Approved	\$0.00
SANDY 4/18/14 Swapped A-Rev 1 and B-Rev 1.						
51896	13A0142	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	199 Water Street New York NY	Approved	\$0.00
SANDY 1) Why are there 16-500 MCM lugs to TSB-1 temporary? 2) Was the other equipment water damaged. 3) Provide details of the work that will be installed. 4/24/13 -Main grounding electrode not provided at multiple s.s. enclosures. 2) S.S. vertical bus size not shown on drawing. 9/23/13 job finalized.						
51735	13A0143	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	17 State Street New York NY	Approved	\$0.00
SANDY 1) Transformer secondary to be bonded and grounded at only 1 point. 2) Generator to have main breaker. Provide generator and emergency board cut sheets 3) Show MI transition boxes. 4) Fire pump service switch to be grounded as per 250.64(D)(2). 5) Coordination study to be provided by a PE. Job finalized 7/19/13.						

ADVISORY BOARD CALENDAR

March 13, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51700	13A0144	AKF 1501 Broadway, Suite 700 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	1 New York Plaza New York NY	Approved	\$0.00
SANDY 1) Provide AIC. 2) Provide coordination study from P.E. 3) Provide distance of service entrance conductors 180'. 4) Rear door? 5) Verify with DOB construction division to whether or not emergency back up is required for the fire pumps and other jurisdiction that may apply. 6) Fire pump and fire alarm service switches to comply with 250.64(D)(2). 7) Provide scope of what will be installed. Job finalized 7/15/13.						
51603	13A0145	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	DC 37 125 Barclay Street New York NY	Approved	\$0.00
SANDY 1) Show where and how service entrance is feeding the new switchboards. 2) Show entire service room layout. 3) Give complete scope of what work is being installed. 4) Show what is new and what is existing. 5) 240 volt fuse on 208 system coordination. Job finalized 3/25/13.						
	13A0146	KD Electric, Inc. 39 West 14th Street, Suite 502 New York NY 10011	Requested approval for the electric service equipment proposed to be installed	100 Wall Street New York NY	On Hold	\$0.00
SANDY 1) Provide cutsheets of service bus by Galaxy show compliance with 368.119, and Eaton equipment. 2) Provide size of main bonding jumper. 3) Verify fire alarm emergency feeder size. 4) F.A. and F.P. emergency feeders reversed on drawing. 5) Verify fusing to emergency panel, overfused at 2000 amps. 6) Show P.O.E. accurate locations. 7) Provide accurate cross section and match bus location. 8) Provide EM board info, room location, etc. 9) Provide location of EM switches (unprotected taps). 11) Verify bus sizes on all vertical sections.						
	13A0147	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	180 Maiden Lane New York NY	On Hold	\$0.00
SANDY 1) Signage to be provided on rear of switchboards stating do not remove covers or work on while live. 2) Verify that existing service equipment wasn't storm damages. 3) Service entrance conductors and service bus undersized. 4) Verify bus sizes on all vertical sections.						
	13A0148	Top Shelf Electric Corporation 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	80 Broad Street New York NY	On Hold	\$0.00
SANDY 1) Provide signage on rear of switchboard stating do not remove covers-do not work live. 2) Provide sizes of main bonding jumpers. 3) Verify sections and horizontal and vertical bus locations. 4) Indicate all c.b. devices, do not include qualities only. 5) C.B. rated for 65 KAIC when short circuit at board is 88 KAIC. 6) Provide FEO CAT cut sheets.						

ADVISORY BOARD CALENDAR

March 13, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	13A0149	Zwicker Electric Co., Inc. 360 Park Avenue, South 4th Floor New York NY 10010	Requested approval for the electric service equipment proposed to be installed	60 Broad Street New York NY	On Hold	\$0.00
SANDY 1) Provide size of main bonding jumpers. 2) Fire pump service switches and splice boxes not shown on drawing. 3) Equipment grounding conductors to booster pump service switch undersized. 4) Verify conductors in conduit to fire alarm service switch and system. 5) Explain tap method in fire alarm disconnect switch. 6) Secondary of transformer not bonded and grounded. 7) F.A. EM feeder shall be a tap of gen. 8) Verify distance between gen and f.p. EM switch. 9) Verify bus sizes. 10) Verify elevation sections.						
51604	13A0150	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Coler Nursing Facility 900 Main Street Roosevelt Island NY	Approved	\$0.00
SANDY Job finalized 3/25/13.						
51590	13A0157	Flack and Kurtz 475 Fifth Avenue New York NY 10017	Requesting permission to install jacketed shielded liquidtight conduit for LED lighting 9on the Empire State building antenna structure	Empire State Building 350 Fifth Avenue New York NY	Approved	\$0.00
Code: 225.10 With the stipulation that documentation is provided that the wiring method is listed for the purpose intended, and the installation complies with the NYC Energy Code						
	13A0158	Cosentini Associates Two Pennsylvania Plaza New York NY 10121	Requesting permission to omit the use of ground fault protection on a 3000 amp 480/277 volt replacement service switch where it is felt that the downstream overcurrent protection can possibly trip for incidental faults and de energize the entire life safety distribution system	Solow 9 West 57th Street New York NY	Denied	\$0.00
Code: 240.12.						