

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
43744CO	02A0116CO	Consolidated Electric Construction Co. 205 East 42nd Street New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Emergency Generator 501 W. 26th Street-34rd & 4th Floors New York NY	Hold	\$0.00
Carryover from March 13, 2002 meeting. Submit drawings in Advisory Board format.						
44892CO2	03A0259CO2	Arc Electrical & Mechanical Cont. Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	359 Greenpoint Avenue Brooklyn NY	Ok, but	\$0.00
Carryover from May 14, 2003 meeting. 1.Submit revised s.c. and coordination study. 2. Submit bus sizes.						
45260CO2	03A0580CO2	Livingston Electrical Associates, Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	New Fire Alarm System 9 West 57th Street New York NY	Approved	\$0.00
Carryover from October 15, 2003 meeting.						
45357CO	03A0653CO	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	K-Mart Service 770 Broadway New York NY	Ok, but	\$0.00
Carryover from December 17, 2003 meeting. Bus undersized use new code sizes 700 A/se in.						
45396CO	03A0691CO	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	491-497 Greenwich Street New York NY	Approved	\$0.00
Carryover from December 17, 2003 meeting.						

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45419CO	04A0017CO	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Random House 235 West 55th Street New York NY	Hold	\$0.00
Carryover January 14, 2004 meeting. Is it all new? Scope?						
45422CO	03A0703CO	Ideal Electric & HVAC Co., Inc. 235 India Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Pagano Residence 1060 5th Avenue-Apt. 11C-11D New York NY	Approved	\$0.00
Carryover from January 14, 2004 meeting. 1) Subject to 1st elect. violation. 2) New drawings must be submitted. Job finalized 5/1/06.						
45442CO	04A0024CO	Electric Light & Power, Inc. 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Atlantic Terminal 139 Flatbush Avenue Brooklyn NY	Hold	\$0.00
Carryover from February 18, 2004 meeting. 1) Provide 2nd egress from generator enclosure. 2) ATS-6-1 undersized. 3) Show fire pump information. 4) FCO not permitted at 480V. 5) Switch and fuse required for fire alarm FBR, not circuit breaker. 6) Generator breakers should not have GFP. 7) Short circuit calculations.						
45453CO	04A0035CO	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requested approval for the electric service equipment proposed to be installed	Atlantic Terminal/Bank of NY 139 Flatbush Avenue Brooklyn NY	Approved	\$0.00
Carryover from February 18, 2004 meeting.						
45471CO	04A0053CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens Vocational H.S. 37-02 47th Street Long Island City NY	Approved	\$0.00
Carryover from February 18, 2004 meeting.						

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45478CO	04A0060CO	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University 80 Claremont Avenue New York NY	Approved	\$0.00
Carryover from February 18, 2004 meeting. 1) Increase copper to 1200 amp service switch or decrease fusing on line and load. 2) All feeds to service switch must be terminated at load side of 3000 amp. 3) Show bonding and grounding on existing 3000 amp service switch. 4) 1200 amp disc. switch marked as service switch. Originally, this item was "Denied" . The decision was reversed to "approved" in April 2004.						
45497CO	--	Flack & Kurtz Inc. 475 Fifth Avenue New York Ny 10017	Requesting permission to install fiber and copper conductors that will enter an electrical room and terminate in a transition box that will change over the wiring method from outside to inside plant type. The wiring method from the transition box will be conduit and interduct that will run through the electric room to the PBX room.	LIJ Medical Center New Hyde Park NY	Approved	\$0.00
Carryover from February 18, 2004 meeting.						
45504	04A0075	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requested approval for the electric service equipment proposed to be installed	7 World Trade Center New York NY	Hold	\$650.00
1) Available short circuit current? Furnish short circuit study with 2 gens in parallel. 2. Show gen. neutral grounding.						
45505	04A0076	Terraferma Electrical Construction Co., Inc 19-51 37th Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Hunts Point WPCP Project Bronx, NY	Approved	#Error
1) Comply with code bus sizing for 4000A 1000% rated device. Job finalized June 8, 2004.						
45506	04A0077	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Advanced Radiology 89-40 56th Avenue Elmhurst NY	Approved	\$650.00
1) The 1000 amp feeder is undersized. 4/14/04 Feeders change to 3 sets of 500 MCM. 2) Is 1000 amp circuit breaker being removed? No. 3) The bus bars are undersized. Existing. 4) Inadequate access to equipment in the switchboard room. Existing. 5) Review suspended pending resubmission. Job re-examined on 4/14/04 and approved.						

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45507	04A0078	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Citigroup 111 Wall Street New York NY	Approved	\$650.00
45508	04A0079	Hugh O Kane Electric Co., LLC 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1290 Avenue of Americas New York NY	Hold	\$650.00
1) Furnish DLO cable sizes from generator to generator breakers indicate wiring method. 2) Short circuit rating of generator? 3) AIC rating of generator breakers? 4) Feeder from 3000A generator breaker undersized. 5) Floor plan clearance beside generator breaker enclosure.						
45509	04A0080	Qncc Electrical Contracting Corp. 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Kings County Hospital Brooklyn NY	Hold	\$650.00
1) Show bonding jumper size. 2. Clarify Con Ed short circuit current and impedance. 3. Indicate available short circuit current at Square D switchboards. 4. Bus sizes for Square D switchboards. 5. Section view for Square D switchboards.						
45510	04A0081	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	NYU School of Medicine Joan & Joel Smilow Research Ctr. New York NY	Hold	\$650.00
1) Show bonding jumper sizes. 2) Clarify bus sizing. 3) Short circuit calculations for generator system, coordination curves. 4) AIC ratings of generator breakers. 5) Clarify location of A/C-G-1 in switchboard room. 6) Provide 2 means of egress in generator room.						
45511	04A0082	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	685 Third Avenue New York NY	Ok, but	\$650.00
1) Conduit size inadequate. 2) Safety switch must be service rated. 3) Mark fire pump info and type.(sp. svc).						

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45512	04A0083	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Pizzeria Uno 65 Metropolitan Oval Bronx NY	Approved	\$650.00
45513	04A0084	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New York University 25 Waverly Place New York NY	Approved	\$650.00
45514	04A0085	Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	146 West 29th Street New York NY	Hold	\$650.00
1-Trough to be removed and replaced with conduit w/encasement. 2. Or locate 800A service switch outside of room						
45515	04A0086	Douglas Paskor, Inc. 248 Nassau Avenue Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	303 Louisiana Avenue Brooklyn NY	Approved	\$650.00
45516	04A0087	A A Reale Electric Inc. 4223 1st Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	42 Bridgewater Street Brooklyn NY	Hold	\$650.00
Scope of work changed prior to meeting.						

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45517	04A0088	Platinum Electrical Contracting Inc. 360 Industrial Loop Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Sprint 111 8th Avenue New York NY	Approved	\$650.00
45518	04A0089	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	Yankee Stadium Bronx NY	Approved	\$650.00
45519	04A0090	A.M.C. Electrical Services, Inc. 3819 Fort Hamilton Parkway Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	401 5th Avenue New York NY	Approved	\$650.00
45520	04A0091	Kew Electric Inc. 1428 Hylan Blvd. Staten Island NY 10305	Requested approval for the electric service equipment proposed to be installed	1749-53 1st Avenue New York NY	Approved	\$650.00
45521	04A0092	Douglas Paskor, Inc. 248 Nassau Avenue Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	12 East 14th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45522	04A0093	BLZ Electric, Inc. 620 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	Boulevard ALP 71-61 159th Street Flushing NY	Approved	\$650.00
45523	04A0094	BLZ Electric, Inc. 620 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	159-10 71st Avenue Flushing NY	Approved	\$650.00
45524	04A0095	Arc Electrical & Mechanical Cont. Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Hunter College 71 East 94th Street New York NY	Denied	\$650.00
<p>1) The bus sizes of existing switchboard was not provided. 2) The bonding, grounding, supplemental ground of the new and existing service switches not shown.. 3) The physical on the end box not shown. 4) The physical of the new equipment not provided.</p>						
45525	04A0096	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Astor Place 445 Lafayette Street New York NY	Approved	\$650.00
45526	04A0097	R & L Systems 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	145 Hudson Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45527	04A0098	R & L Systems 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	180 West 58th Street New York NY	Approved	\$650.00
45528	04A0099	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	247 Chrystie Street New York NY	Approved	\$650.00
45529	04A0100	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	780 8th Avenue New York NY	Approved	\$650.00
45530	04A0101	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	385 First Avenue New York NY	Approved	\$650.00
45531	04A0102	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	63 Wall Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45532	04A0103	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Trump F 140 Riverside Boulevard New York NY	Approved	\$650.00
45533	04A0104	R. Donovan & Son Electric Co., Inc. 198-08 33rd Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	55 West 26th Street New York NY	Approved	\$650.00
45534	04A0105	Star-Delta Electric Inc. 17 Battery Place-Suite 701 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	75 Broad Street New York NY	Approved	\$650.00
45535	04A0106	Diane Electric, Inc. 1371 Seabury Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Verizon 210 West 18th Street New York NY	Approved	\$650.00
45536	04A0107	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	165 Charles Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45537	04A0108	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	Verizon Antenna 120 Greenwich Street New York NY	Approved	\$650.00
45538	04A0109	Associated Electrical Contractors of NY Cor 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	90-10 Grand Central Parkway Queens NY	Approved	\$650.00
45539	04A0110	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	23-35 Broadway Long Island City NY	Approved	\$650.00
45540	04A0111	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	64-56 Kissena Blvd. Queens NY	Approved	\$650.00
45541	04A0112	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	999 Forest Avenue Staten Island NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45542	04A0113	Nead Electric Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Dodger Stages World Wide Plz 340 West 50th Street New York NY	Approved	\$650.00
45543	04A0114	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	629 West 54th Street New York NY	Approved	\$650.00
45544	04A0115	Barth-Gross Electric Co., Inc. 110 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	145 West 30th Street New York NY	Approved	\$650.00
45545	04A0116	Dynamic Electric Service Inc. 14-17 110th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	720 Park Avenue New York NY	Approved	\$650.00
45546	04A0117	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	655 Park Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45547	04A0118	Cy Electrical Corp. 23-92 23rd Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	828 Broadway New York NY	Approved	\$650.00
45548	04A0119	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	85 10th Avenue New York NY	Approved	\$650.00
45549	04A00120	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	264 West 40th Street New York NY	Approved	\$650.00
45550	04A0121	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	300 Madison Avenue New York NY	Approved	\$650.00
45551	04A0122	Elco Electrical Contracting Corp. 35-43 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1060 Fifth Avenue-Apt. 9C/D New York NY	Approved	\$650.00
1. Subject to 1st electric to remove violation. 2. New drawings must be submitted. Job finalized July 20, 2006.						

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45552	04A0123	BLZ Electric Inc. 620 Coney Island Avenue New York NY 11218	Requested approval for the electric service equipment proposed to be installed	The Gretch Building 60 Broadway Brooklyn NY	Denied	\$650.00
<p>1) The drawings are too small and not legible. 2) The fire pump service switch must be in a separate enclosure. 3) The wiring method from the fire pump controller does not have to be encased in concrete. 4) Is the manufacturer current systems a U.L. shop? 5) You are still using the old Advisory Board notes for copper bus. 6) The 600 FRN must be changed to the correct type fuse. 7) The supplemental ground not provided in 4000 amp service switch. 8) The switchboard with back access doors is installed against the wall. 9) Show 3rd fusing in panels NBP-1 and NBP-2. 10) Correct the standard notes.</p>						
45553	04A0124	Cobra Electric Corp. 18-17 42nd Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Rosa Park Condominium 163 St. Nicholas Avenue New York	Denied	\$650.00
<p>1) The fire pump service switch has to be installed in a separate cabinet barriered on both sides. 2) The 600 amp TR fuses do not coordinate with the 2000 amp fuse. 3) The supplemental ground was not provided. 4) Correct notes as per new Advisory Board rules. 5. The line side bus of the 2000 amp service switch is not rated at 800 amps per square inch.</p>						
45554	04A0125	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Dept. of Environmental Protection 432 East 110th Street New York NY	Denied	\$650.00
<p>1) Show coordination between LCG circuit breakers and 2nd fusing. 2) Short circuit calculations were not provided. 3) Overlay curves were not provided. 4) Bus sizes were inadequate.</p>						
45555	04A0126	L.T.C. Electric, Inc. 47-10 104th Street Corona NY 11368	Requested approval for the electric service equipment proposed to be installed	38-11 108th Street Corona NY	Approved	\$650.00
<p> </p>						
45556	04A0127	Cobra Electric Corp. 18-17 42nd Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Manhattan Town House Equity 309 West 118th Street New York NY	Denied	\$650.00
<p>1. The vertical bus is undersized in service switchboard. 2. The FRN fuses do not coordinate with the 1600 A4BY and 1200 A4BY fuses. 3. The bonding and grounding of service switches was not shown on the drawing. 4. The neutral conductor is bonded in distribution after the service switch. 5. Neutral conductor must terminate in fire pump service switch. 6. Remove notation for concrete encasement on the load side of the fire pump controller. 7. Revise standard termination notes.</p>						

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45557	04A0128	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Dept. of Environmental Protection 593 East 132nd Street New York NY	Denied	\$650.00
1) Coordination studies were not provided. 2) Short circuit calculations were not provided. 3) Overlay curves were not provided.						
45558	--	Lektric Installations Corp. 3802 Church Avenue Brooklyn NY 11203	Requested permission to leave as installed service equipment on the outside of a building that consists of one dwelling and one commercial space.	94-33 Corona Avenue Elmhurst NY	Hold	\$0.00
45559	-----	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requesting permission to leave as installed service entrance conductors in trough that is encased in concrete inside of a garage parking area.	345 West 42nd Street New York NY	Approved	\$0.00
With the stipulation that the conductor terminations are not covered with concrete.						
45560	----- -	Proscia Electrical Contracting Inc. 141-07 20th Avenue Whitestone NY 11357	Requesting permission not to file Advisory Board drawings on a service totaling 2800 amps, where the existing DC service will be eliminated.	38 West 21st Street New York NY	Denied	\$0.00
Full Advisory Board submittals are required for any addition to an existing service which would bring the total to 1000 KVA or larger.						
45561	-----	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requesting permission to install PVC conduit with galvanized elbows and stub-ups below grade to provide power to distribution equipment.	26 Astor Place New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45562	-----	Classic Electric, Inc. 29-05 21 Avenue Astoria NY 11105	Requesting permission not to file Advisory Board drawings for the installation of a 600 amp disconnect switch that is 2nd fusing fed from a 2000 amp service switch on a 1000 KVA service.	1730 Mulford Avenue Bronx NY	Denied	\$0.00
Full Advisory Board submittals are required for any change in the service equipment with a rating of 1000 KVA or larger, up to and including second level overcurrent protection.						
45563	-----	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requesting permission to install PVC conduit with galvanized elbows and stub-ups embedded in 2 inches of concrete for service and branch circuit wiring throughout a building.	3-7 Wooster Street New York NY	Approved	\$0.00
45564	-----	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requesting permission to utilize a building's steel columns with ground rods to ground service equipment in two buildings that have no water service.	387 Johnson Ave. and 132 Bogart St. Brooklyn NY	Approved	\$0.00
With the stipulation that the installation is in compliance with Article 250.56 of the 2002 National Electrical Code.						
45565	-----	Sambar Electric Corp. 314 Nelson Avenue Staten Island NY 10308	Requesting permission to install new elevator feeder conduits inside of the elevator shaftway in a building where the elevators are being modernized.	215 Hart Blvd. Staten Island NY	Approved	\$0.00
45566	----- ---	New York City Housing Authority 23-02 49th Avenue Long Island City NY 11101	Requesting permission to install CCTV cabling and conduit in an elevator shaft to supply power to cameras inside of the cars.	419 East 93rd Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45567	----- -	Amp-Lite Electric Co., Inc. 1535 Broadway New York NY 10036	Requesting permission not to group together service equipment in a building that does not have a common space.	1606 Richmond Avenue Staten Island NY	Approved	\$0.00
With the stipulation that signage is provided at each service switch indicating where the other service switch is located.						
45568	----- -	Matthew K. Bendix (MKB) 519 Eighth Avenue-20th Floor New York NY 10016	Requesting concept approval for the installation of a 6000 amp service switch and CT that will be behind a wire mesh gate that when opened the front clearance of the electrical equipment will be greater than 5 feet but less than 5 feet when the gate is closed.	19 Union Square West New York NY	Approved	\$0.00
45569	----- ----	Atkinson Koven Feinberg Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting permission due to space restrictions on an existing service room to install a new 600 amp service switch in a room outside of the existing service room.	French Institute Alliance Franchise 22 East 60th Street New York NY	Approved	\$0.00
With the stipulation that signage is provided at each service indicating where the other service is located.						
45570	----- ----	Amber Lite Electrical Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requesting permission to feed service entrance conductors that enter a 4 gang meter pan on the side of one building and feeds 3 other buildings by underground conduit in 4 groups of attached buildings.	; thru 28 Tone Lane and 30 Tone Lar Staten Island NY	Approved	\$0.00
45571	----- ----	Dean Electric Co., Inc. 7909 Third Avenue Brooklyn NY 11209	Requesting permission to run a temporary feeder from an emergency generator temporarily installed in the street in front of a building. The feeder will run up a wall to the roof, along the roof perimeter wall mounted and protected by corded off barriers to pick up existing loads.	Maimonides Medical Center Brooklyn NY	Denied	\$0.00

Article 517.12, Health Care Facilities states that the wiring method shall comply with the applicable requirements of Chapters 1 through 4 of the National Electrical Code.

ADVISORY BOARD CALENDAR

March 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45572	04A0129	Cooper Lighting 1101 Southerfield Road Americas GA 31729	Requested approval for use in New York City of your Fluorescent Lighting. Model/Series Numbers: 2G Troffers 2x4 & 2x2		Approved	\$200.00
Providing the fixture metal is 20 U.S.S.G.						
45573	04A0130	Kinetics Industries, Inc. 1101 Southerfield Road Americus GA 31719	Requested approval for use in New York City of your DC Power Rectifier. Model/Series Numbers: GVR005M22-002CUL, GVR010M22-005CUL, GVR015M22-005CUL, GVR020M22-005CUL, GVR025M22-010CUL, GVR050M22-015CUL, GVR075M22-020CUL, GVR0100M22-025CUL, GVR125M22-025CUL, GVR150M22-030CUL.		Hold	\$200.00

Pending Testing Report.