

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46046CO	04A0509CO	Encore Lighting LLC 57-10 49th Place Maspeth NY 11378	Requested approval for use in New York City of yourr Exit & Emergency Lighting. Model/Series Nos. 6EB/12EB/Endurance/LSE/LC8 Series.		Approved	\$0.00
Carry over from November 17, 2004 meeting.						
49328CO	09A0115CO	Team Electric, Inc. 20 West 36th Street, 702 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	129 West 29th Street New York NY	Ok, but	\$0.00
Carry over from March 18, 2009 meeting. 1) Emergency side fire pump branch circuit to be fused at 150%. 2) Provide drip pan under piping in service room. 3) Show tap detail to 400A switches. 4) Explain front view of Con-ED SEB.						
49831CO	09A0489CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Lowe's Kings Plaza 5100 Kings Plaza Brooklyn NY	Denied	\$0.00
Carry over from November 18, 2009 meeting. Incomplete submittal, details not provided.						
49871CO	09A0512CO	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Gourveneur Health Services 277 Madison Street New York NY	Hold	\$0.00
Carry over from December 16, 2009 meeting. 1) Bus ducts to be rerouted outside of emergency room. 2) Neutrals on load side of transformers bonded twice. 3) Neutral in generator board to be bonded.						
49899CO	10A0007CO	Arc Electl & Mechanical Contrs, Corp. 28 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Harlem Hospital 512 Lenox Avenue New York NY	Approved	\$0.00
Carry over from January 13, 2010 meeting. 1) ESB-A: No coordination main 400A -branch 400A not required for Advisory Board, but is required for hospital emergency. 2) Submit drawings for service switchboards. Job finalized 3/28/12.						

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49958CO	10A0059CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	106-21 Beach Channel Drive Rockaway NY	Hold	\$0.00
Carry over from February 10, 2010 meeting. 1) Show coordination between 1600 amp main and 1600 amp secondary breakers. 2) Ground fault not provided on new 1600 amp breaker. 3) Key interlock scheme not complete, 2-1600 amp main and tie in MCC-T. 4) Bus sizes not provided in MCC-T board.						
49980	10A0064	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	Harlem Village Academy HS 35 West 124th Street New York NY	Ok, but	\$650.00
Verify that installation complies with technical policy and procedure notice # 1/07.						
49981	10A0065	Linphill Electrical Contractors, Inc. 4850 White Plains Road, 2nd Fl. Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	19 Hyatt Street Staten Island NY	Ok, but	\$650.00
No coordination 800A A4BQ and 400A TR fuses.						
49982	10A0066	ECS Electrical Contracting Services, Inc. 351 Kent Avenue Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	221 Canal Street New York NY	Approved	\$650.00
1) Service entrance feeding 1600 amp service switch undersized. 2) Fuses in 1600 amp service switch oversized. 3) Verify clearance behind existing SS#4. Front of new 12x12 trough. Job finalized 6/4/10.						
49983	10A0067	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	8 West 40th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49984	10A0068	Queens Electrical Contractors, Inc. 34-05 34th Street Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	Newtown Apartments 30-15 Newtown Avenue Astoria NY	Approved	\$650.00
49985	10A0069	June Electric Corp. 2025 Continental Avenue, Suite 5E Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	850 Jennings Street Bronx NY	Approved	\$650.00
49986	10A0070	Star Electric 494 Greenwich Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	110 East 40th Street New York NY	Approved	\$650.00
49987	10A0071	V-Mar Electric Ltd. 408 Grand Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	411 Lafayette Street New York NY	Approved	\$650.00
Service room door to open outwards. Job finalized 4/29/10.						
49988	10A0072	New Wave Electrical Contracting Corp. 439 Port Richmond Avenue Staten Island NY 10302	Requested approval for the electric service equipment proposed to be installed	1490 Boston Road Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49989	10A0073	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Museum for African Art 1780 Fifth Avenue New York NY	Approved	\$650.00
49990	10A0074	Global Electrical Contracting Westchester, Inc. 4065 Boston Road Bronx NY 10466	Requested Concept Approval:	DSNY Salt Storage Fac. 80-45 Winchester Blvd. Queens NY	Approved	\$650.00
49991	10A0075	B & G Electrical Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Bob's Furniture Store 517 East 117th Street New York NY	Approved	\$650.00
49992	10A0076	BLZ Electric, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	229-231 Duffield Street Brooklyn NY	Approved	\$650.00
49993	10A0077	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	177 Ninth Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49994	10A0078	Bigman Brothers, Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Continuum Health Partners 2771-2773 Frederick Douglass Blvd. New York NY	Approved	\$650.00
49995	10A0079	RCM Electric Corp. 1915 McDonald Avenue Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	160 Columbus Avenue New York NY	Ok, but	\$650.00
1) Neutral bonded after service switch. 2) Equipment grounding conductor undersized for tapped feeder. 3) How long is tap?						
49996	10A0080	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Time Life 1271 Sixth Avenue New York NY	Approved	\$650.00
Provide supplemental ground. Job finalized 9/24/10.						
49997	10A0081	Lippolis Electric, Inc. 3396 Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Clearwire Site ID 5160 127 West 43rd Street New York NY	Hold	\$650.00
1) More than six service switches not allowed. 2) Which listed manufacturer will be upgrading the end box, provide cut sheets?						
49998	10A0082	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Cabrini Terrace Apartments 900 West 190th Street New York	Approved	\$650.00
Verify grounding of synchron. Gen. (3p or 4p ATS?) Job finalized 4/5/10.						

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49999	10A0083	Broadway Electric 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Winoker Realty 229 West 28th Street New York NY	Approved	\$650.00
Service room to be mechanically ventilated. Job finalized 6/3/10.						
50000	10A0084	R. Donovan & Son Electric Co., Inc. 198-08 33rd Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	151East 80th Street New York NY	Approved	\$650.00
1) Provide cut sheets of listed end box. 2) Show how many sets of new conductors are feeding new switchboard and the wiring method used. 3) Is trap in floor covered? Job finalized 4/29/10.						
50001	10A0085	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	5030 Broadway New York NY	Approved	\$650.00
50002	10A0086	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	133 East 58th Street New York NY	Approved	\$650.00
50003	10A0087	Samson Electric Corp. 3300 Northern Blvd - Basement Level Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	31-00 47th Avenue Long Island City NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50004	10A0088	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	225 Varick Street New York NY	Approved	\$650.00
50005	10A0089	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	Love Lane Mews 1-23 College Place Brooklyn Heights NY	Approved	\$650.00
50006	10A0090	Rigid Electric Inc. 336 37th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Hospital for Special Surgery 535 East 70th Street New York NY	Approved	\$650.00
50007	10A0091	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	The Lambs Club 130 West 44th Street New York NY	Approved	\$650.00
50008	10A0092	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Hahn Kook Chiller 460 Park Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50009	10A0093	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	205 West 76th Street New York NY	Ok, but	\$650.00
1) AIC not provided. 2) Retail switch #3 not completely drawn, and shown in room layout.						
50010	10A0094	Capitol Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Time Warner Cable 350 Broadway New York NY	Approved	\$650.00
50011	10A0095	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	1490 Dumont Avenue Brooklyn NY	Approved	\$650.00
50012	10A0096	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Maspeth Campus IS/HS 585Q 54-70 74th Street Queens NY	Approved	\$650.00
50013	10A0097	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mt. Sinai School of Medicine 1470 Madison Avenue New York NY	Ok, but	\$650.00
1) Temp wiring methods to comply with Article 590.4. 2) Neutral to be bonded and grounded on transformer secondary on switchboard not both. 3) Locomotive conductor to be listed for use in conduits and show type of connectors being used.						

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50014	10A0098	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Lincoln Medical Center 234 East 149th Street Bronx NY	Hold	\$650.00
1) Provide generator cuts. 2) Verify what emergency loads being served. 3) Show bus sizes on switchboards. 4) Show bonding and grounding of generator. 5) Special permission required for non coordination.						
50015	10A0099	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	PS 264 371 89th Street Brooklyn NY	Approved	\$650.00
Service bus feeding 1200 and 400 amp service switches undersized. Job finalized 3/23/10.						
50016	10A0100	Crana Electric Inc. 600A East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Best Buy Kings Plaza Mall Brooklyn NY	Approved	\$650.00
1) Feeders undersized on load side of new 1200/3 breakers. 2) Addition of equipment beyond new 1200/3 breakers must be submitted to Advisory Board. Job finalized 6/29/11.						
50017		Purcell Electrical Contractors, Ltd. 138-30 241st Street Rosedale NY 11422	Requesting permission to install overhead service conductors in non metallic conduit in a corrosive area.	6233 and 6235 Almeda Avenue Far Rockaway NY	Approved	\$0.00
50018		DVL Consulting Engineers Inc. 137 Fifth Avenue New York NY 10010	Requesting permission to install underground concrete encased service entrance conductors in rigid nonmetallic conduit	New School-PS/IS 71R 1050 Targee Street Staten Island NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50019		ATN Electric Corp. 240-19 Jamaica Avenue Bellerose NY 11426	Requesting permission to install underground concrete encased service lateral conductors in nonmetallic conduit	Natuzzi Bros. Ice Co., Inc. 121-60 Farmers Blvd. Springfield Garden NY	Approved	\$0.00
50020		Amboy Electric Inc. 6523 Amboy Road Staten Island NY 10216	Requesting permission to utilize Section 518.4 of the 2008 NEC and install A/C cable that does not contain an insulated grounding conductor.	655 Rossville Avenue Staten Island NY	Approved	\$0.00
50021		New York City Housing Authority 90 Church Street New York NY 10007	Requesting permission on a job site where an existing elevator is being upgraded to allow existing on new conduit with a new unsplined feeder inside of the elevator shaftway	Manhattanville Rehab 529 West 133rd Street New York NY	Approved	\$0.00
50022		Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requesting permission to allow 4'9" clearance in front of a service switch on a 1000 KVA service	PTC Trinity Real Estate 205 Hudson Street New York NY	Approved	\$0.00
50023		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to refeed an existing panel with a new feeder where the existing panel has a front clearance of 31 inches.	CBS 524 West 57th Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50024		Emerson Climate Technologies One Independence Way Princeton NJ 08540	Requesting permission to install manufactured wiring systems for general lighting circuits in an exposed truss ceiling, 604.1(A)(5).	Lowe's Kings Plaza 5100 Kings Plaza Brooklyn NY	Approved	\$0.00
With the stipulation that the installation complies with the rest of NYC Amendments 604.1(A) (1),(2),(3),(4),(6),(7, and(8).						
50025		Team Electric, Inc. 20 West 36th Street, Suite 702 New York NY 10018	Requesting permission to install c seventh service switch that will power a fire pump	129 West 29th Street New York NY	Approved	\$0.00
50026		Douglas Electrical Contracting Corp. 87-25 78th Street Woodhaven NY 11421	Requesting permission to use one nationally recongnized testing laboratory report for two additional jobs that were installed exactly the same	Bklyn, 327 W. 112th St., NY, 83--27 Various boros NY	Approved	\$0.00
With the stipulation that all components are exactly the same.						
50027		S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requesting permission to leave as installed meterbank terminal boxes and meterbanks with front clearances less than three feet for 15 locations throughout the building.	111 Lawrence Street Brooklyn NY	Denied	\$350.00
50028		Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requesting permission to leave as installed 3000 amp fused feeders ran in metallic and nonmetallic conduits with 1/0 equipment grounding conductors where it will be a tremendous hardship to shut down the building to replace equipment grounding conductors	80 DeKalb Avenue Brooklyn NY	Denied	\$350.00

ADVISORY BOARD CALENDAR

March 17, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50029		Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requesting permission to leave as installed due to financial and economic hardship to correct to apply 215.2(A)(1) Exception #2 for the commercial wiring portion of a residential building.	440 West 42nd Street New York NY	Denied	\$0.00
50030		NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requesting permission to approve for use a circuit breaker panel with aluminum back box, cover and internal supports that was specially designed by a listed switchboard manufacturer, tested for use in a MRI/OR but is not listed to UL standards.	1275 York Avenue New York NY	Denied	\$0.00
50031	10A0101	Suntech America, Inc. 71 Stevenson Street, 10th Floor San Francisco CA 94105	Requested approval for use in New York City of your Custom Monocrystalline Photovoltaic Module. Model/Series Numbers: Suntech Power LT 705x1740-V8(custom version of Light Thru)	DDC-DEP Yard Reconstruction 855 Remsen Avenue Brooklyn NY	Approved	\$200.00
With the stipulation that this approval is for one time one location only.						
50032	10A0102	Louvers International, Inc. 849 Church Street Elmhurst IL 60126	Requested approval for use in New York City of your Enclosed and gasketed vaportight lighting fixture(2 lamp T8 setup). Model/Series Numbers: ADV4-P-2T8-20.		Approved	\$200.00
50033	10A0103	Integrated Metering Systems, Inc. 11701 S. Belcher Road, Ste 123 Largo FL 33773	Requested approval for use in New York City of your Electric Submeter. Model/Series Numbers: Mini Meter kWh meter. Model MMD-PKG-IF or model MD240F01S0021.		Approved	\$200.00