

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52814	13A0599CO	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	455 Madison Avenue New York NY	Approved	\$0.00
Carry over from January 15, 2014 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52813	14A0594CO	ATJ Electrical Inc. 33-61 55th Street Woodside NY 11377	Requesting permission to leave as installed due to a hardship to replace, an open bottomed 3000 amp fused switch feeding an open bottomed 3000 amp switchboard with 11-4 inch conduits containing 5-500 KCM conductors with 1-500 KCM as an equipment grounding conductor connected directly to the enclosures on each side, where 3/0 equipment bonding jumpers are installed on the conduit bonding bushings to the enclosures.	NYC 1 City Hall New York NY	Approved	\$0.00
Carry over from December 17, 2014 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53002	14A0670	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	615 West 131st Street New York NY	Approved	\$650.00
<p>1) Provide short circuit and coordination study. 2) Provide site/key plan to indicate the location on Gen Set to the switchgear 3) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/24/15 Job finalized. With the stipulation as follows: 1) Relays setting to be as per recommendation of coordinatin study. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	14A0675CO	Robert Magoolaghan, Inc. 240 Beach 116th Street Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	220 5th Avenue New York NY	Denied	\$0.00
<p>Carry over from December 17, 2014 meeting. Fuse type, circuit breaker type not shown, short circuit curve to be provided. 2/19/16 Denied 1) Show fuse types on 1 Line drawing. 2) Show fault current at new circuit breaker panel. 3 Neutral in service switch to be bonded and grounded. 4) Why is cut sheet of 3000 amp fuse attached. 5) Provide full size drawings. 6) Fuse type not shwon, short circuit cuve to be provided.</p>						
	14A0680	Fellnzer Engineering LLP 22 Mulberry Street, Suite 2A Middletown NY 10940	Requesting permission to utilize various lengths of tray cable for the installation of motorized electrical shades	Columbia University New York NY	Denied	\$0.00
<p>1) Manufacturer's installation instructions for this installation not provided. 2) Electrical material used is not suitable for the purpose intended 110.2.</p>						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52796	14A0698	J.R.D. Electric Corp. 67-11 79th Street Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	280 Park Avenue, 11th Floor New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53100	14A0705	& D Electrical Construction Company Inc 18 West 27th Street, 12th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	23-01 42nd Rd. Long Island City NY	Approved	\$650.00
1) 500 KVA transformer not shown in service room. How long are transformer secondary taps? 6/19/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/25/16 Swapped drawing 4-Revision 1.						
53152	14A0726CO	azen and Sawyer Environ. Eng's & Scientists 498 Seventh Avenue, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Coney Island Wastwater Pollution Control Plant Brooklyn NY	Approved	\$0.00
Carry over from December 17, 2014 meeting. Requires short circuit and coordination study submittal and review. 8/5/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52815	15A0016CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Cornell NYC Tech Campus 1 Main Street Roosevelt Island NY	Approved	\$0.00
Carry over from February 18, 2015 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/18/15 Rejected. Show doors on chain link fence. 10/30/15 Swapped drawings 1,2 and 3, Revision 3s. 7/25/16 Swapped drawings 1,2. 7/25/16 Swapped drawings 1,2 & 3-Revision 4s.						
53114	15A0027	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	68-74 Charlton Street New York NY	Approved	\$650.00
1) Provide signage for the location of service. 2) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/26/15. Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/30/15 Swapped drawings 1,2,3-Revision 5.						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52816	15A0036CO	Cosentini Associates Two Pennsylvania Plaza New York NY 10121	Requesting permission to install manufactured wiring systems for receptacles below an accessible hung ceiling or where no finished ceilings exists	Jane Street Group 250 Vesey Street New York NY	Approved	\$0.00
Carry over from January 7, 2015 meeting. With the stipulation that communication cables and the MC cables are installed as per code and this approval is subject to field inspection. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0044	Campbell and Dawes Ltd. Electl Contrs. 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	1221 Avenue of the Americas New York NY	On Hold	\$650.00
1) Verify there are neutral conductors feeding paralleling switchboards from the generators. 2) Be bus duct shows between paralleling boards show 3-6"x1/4" on one side and 4-5"x1/4" on the other side. 3) Show where neutral is bonded in paralleling boards as note says above generators. 4) Remove typo for feeder size to swbd-62 off of generator 2 set 500. 5) Provide interlock between the pair breakers. 6) Provide short circuit/coordination study.. Verify that normal main CBS have GFCl upstream. 7) Provide gen room layout.						
	15A0046	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	50 West Street New York NY	On Hold	\$650.00
1) Verify that switchboards comply with 230.64(B)(4) or 408.60(F). 2) Where is the end box located? Show incoming room. 3) EGCs in service entrance conduits not required but neutral is to be bonded to enclosure in the end boxes 250.4(A)(4). 4) Provide ground fault protection on disconnect switch feeding panel PP-H63. 5) AB50-1, and 2 of 3, show splicing or copper detail of how taps will be made in splice-tap boxes and verify compliance with 250.122(B). 6) Transformers T, 3 and 4 show length of secondary conductors. 7) Transformer T7, secondary conductors not protected exceeds tap rules. 8) Show conductors connecting Sections in DP-H6en. 9)Emergency side 2 fusing ahead of fire alarm transformer. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.The other option is for equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE:Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10) Disc link must be relocated after the f.p. tap.						
52797	15A0047	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	405 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/21/16 Swapped drawing FP,AB-Revision 1.						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0049	FSM Electrical Corp. 36-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	118 East 40th Street New York NY	On Hold	\$650.00
<p>1) Verify feeder connection to 1-1/4"x2" bus in 1200 amp pnl "RDB" and show conductor size for connection between panels. 2) Show fuse type in Navtech 800 amp Trans s. 3) Remove neutral bond and ground in fire alarm emergency disconnect switch. 4) Show lengths of taps feeding 4-60 amp circuit breaker panels, show feeder size to pnl "EM-LP-9". 5) Show method of tapping in the trough. 6) Show type of fire rated assembly that will be installed for the fire pump. 7) General notes and incoming fault current not shown. 8) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52817	15A0050	Anthony G. Ferry, Inc. 1916 Park Avenue, Suite 520 New York NY 10037	Requested approval for the electric service equipment proposed to be installed	240 Manhattan Avenue New York NY	Approved	\$650.00
<p>This submittal supercedes Approval #51500. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52963	15A0051	Intelogic Electric, Inc. 254 40th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	44 West 29th Street New York NY	Approved	\$650.00
<p>Verify neutral connection in c.t. cabinet connect to phase log. 4/7/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
52818	15A0053	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	The Astor 235 West 75th Street New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53105	15A0067	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	225 Broadway New York NY	Approved	\$650.00
<p>Show full electrical room layout including egress 6/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/26/16 Drawing swap Drawing 1, 2-Revision 3.</p>						
	15A0068	A to Z Electl Maint. & Service Corp. 307 Seventh Avenue, Suite 403 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	500 Metropolitan Avenue Brooklyn NY	Pending	\$650.00
<p>1) Incoming fault current not shown. 2) Fire pump feeder not fire rated, correct FLA.</p>						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52988	15A0075	J & D Electrical Construction Company Inc 18 West 27th Street, 12th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	237 West 54th Street New York NY	Approved	\$650.00
<p>1) Fire pump service switch and 800A transformer secondary switch #1 to have proper front clearances. 2) Show service bus size feeding 2000 amp service switches. 3) Show lengths of transformer secondary taps on 1 line. 4) Verify HP size of limited service fire pump. 5) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 4/21/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 6/23/15 Swapped drawing 1, Revision #2. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 8/24/15 Swapped Drawing 3-Revision 3. 						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52800	15A0082	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	240 East 38th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52897	15A0084	Anthony G. Ferry Inc. 1916 Park Avenue New NY 10037	Requested approval for the electric service equipment proposed to be installed	132 West 27th Street New York NY	Approved	\$650.00
<p>1) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2) Relocate neutral disconnect link after all taps. 3/27/15 With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/11/16 Sw0 drawing 1 and 2, Revision 1</p>						
52819	15A0086CO	A & M Electrical Service Inc. 617 Johnson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	507-515 West 28th Street New York NY	Approved	\$0.00
Carry over from February 18, 2015 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/27/16 Swapped drawing A-Revision 2; Drawing D-Revision 2; Drawing F-Revision 1; Drawing H-Revision 1 and Drawing I-Revision 1.						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52795	15A0091	Chaim Electric 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	431 West 37th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53060	15A0104	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	135 West 45th Street New York NY	Approved	\$650.00
<p>1)With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Fire Rated Enclosure's must comply with the following:</p> <p>1)A P.E. or R.A. must file a PW1 as an ALT 3. 2)A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3)The fire proofing must be performed by a certified fire proofing installer. 2) Coordination study not submitted. 6/1/15 Job finalized. Drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Fire Rated Enclosure's must comply with the following:</p> <p>1)A P.E. or R.A. must file a PW1 as an ALT 3. 2)A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3)The fire proofing must be performed by a certified fire proofing installer. 9/21/15 Swapped drawings 1, 2, 3 and 4, Revision 6's. 2/17/16 Swapped drawings 1,2,3 and 4, Revision 7s. 6/20/16 Swapped drawings 1,2,3 and 4-Revision 8s. No more swaps for this submittal.</p>						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53063	15A0111	A & R Electrical Maintenance, Inc. 85-47 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Prospect Plaza 1765 Prospect Place Brooklyn NY	Approved	\$650.00
1) Service rooms in both building marked 1B. 2) 1200 amp feeder requires a main disconnect switch at point of entry to building and supplemental ground to enclosure. 3) Grounding electrode conductors for fire pump 1A not ran with service entrance conductors to remote Building, GEC to be brought back to building where the service entrance conductors come in. 6/1/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/21/16 Swapped drawings 1,2 and 3-Revision 2s.						
52820	15A0114	Maximum Electric Corp. 65-19 Metropolitan Avenue Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	1158 5th Avenue New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0119	Jaros Baum & Bolles Consulting Engs 80 Pine Street New York NY 10005	Requesting permission to allow the primary feeders on the load side of the micro grid breakers to be run in R65 conduit.	Hudson Yards & Towers 500 West 33rd Street New York NY	On Hold	\$350.00
1) Clarify interim system and how it will be protected. 2) Spliced service entrance conductors not allowed. 3) Protection scheme and sequence of operation to be submitted. 4) Provide the length of time the temp will be in service. 5) Review color scheme provided on the drawings.						
53056	15A0124	A & R Electrical Maintenance, Inc. 85-44 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	500 Union Avenue Bronx	Approved	\$650.00
Tap conductors to (2) 200A meters are undersized. 5/29/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 Swapped Drawing 1-Revision 2						
52821	15A0125	Patriot Electric Corp. 96-06 220th Street Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	1000 6th Avenue New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/14/16 Swapped Drawing 1-Revision 1.						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52822	15A0126	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Hudson Yards Tower C 501 West 30th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52961	15A0127	Facility Solutions Group 236 West 30th Street New York NY	Requested approval for the electric service equipment proposed to be installed	101 Warren Street New York NY	Approved	\$650.00
aka 270 Greenwich Street Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/23/15 Swapped drawing B & C, Revision 1s.						
52823	15A0128	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Flushing Commons 38-18 Union Street Flushing NY	Approved	\$650.00
This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/1/16 Swapped Drawings A, B, & F-Revision 2 and drawing E-Revision 1.						
52824	15A0129	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	225 Liberty Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52964	15A0130	Spirelli Electric, Inc. 1901 Amethyst Street Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	260 East 161st Street Bronx NY	Approved	\$650.00
Parallel conductors to comply with 310.4(B). 4/7/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52825	15A0131	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	250 Vesey Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/30/15 Swapped drawing 1-Revision 1, Drawing A-Revision D, Sheet 1 and 2 normal, Drawing A-Revision D, Sheet 1 and 2 Gen. 9/1/16 Swapped drawings AB50-01-Revision 2., A Gen Sh 1 and 2 -Revision E; A Normal SH 1 and 2-Revision E.						
52826	15A0132	Metro Electrical Contractors, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	5700 Avenue D Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0133	Lens Electric, Inc. 2802 Avenue Y Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	P.S. M460 40 Irving Place New York NY	Denied	\$650.00
Tap of a tap not permittd						
	15A0136	Delco Electrical Corp. 241 West 37th Street, Suite 700 Brooklyn NY 10018	Requested approval for the electric service equipment proposed to be installed	261 Hudson Street New York NY	Rejected	\$650.00
<p>1) Show how generator and co-gen systems are grounded. 2) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/29/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/5/16 Rejected Provide new coordination study.</p>						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52827	15A0137	Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	1625 Forest Avenue Staten Island NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0138	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	The Hub 333 Schermerhorn Street Brooklyn NY	Denied	\$650.00
<p>1) Electrical room off of electrical room 1 to have ventilation and compliance with 110.26(A)(3), What does this room serve? 2) How will 6 sets of 750 KCM conductors terminate to 800 amp switches.(Switch typo). 3) Show length of transformer secondary conductors off or 300 KVA transformer, secondary conductors overfused. 4) Show fuse types, meter banks, fire pump and 400 Trans s. 5) Service board 'MS-B' - 200 amp service switch to be bonded and grounded. 6) Feeders off of generator not protected. 7) Verify feeder size to fire alarm service switch. Bond and ground switch. 8) Equipment grounding conductors undersized -2-400 amp disconnect switches tapped off of 3000 amp fuses. 9) 3 and 4 pole ATS mixed. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
52987	15A0139	Jorob Contracting and Electrical Co. Inc. 040 Avenue of the Americas, Lower Level New York NY 10001	Requested approval for the electric service equipment proposed to be installed	84 William Street New York Ny	Approved	\$650.00
<p>1) Neutral bonded and grounded on load side of neutral link. 2) Equipment grounding conductor on load side of fire pump service switch undersized. 3) Correct contractors name and address in title block. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/21/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/26/16 1) Fire pump circuit conductor to fire pump undersized. 2) Equipment grounding conductor to 400 amp CT undersized. 10/26/16 Swapped drawing 1-Revision 3.</p>						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0140	Brandl Electric Inc. 250 Greenpoint Avenue, 4th Fl Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	110 Wall Street New York NY	Denied	\$650.00
<p>1) Correct contractors name in title block. 2) Service room, verify that switches above trough comply with 110.26(A)(3). 3) Service equipment on room layout does not indicate switches or distribution equipment, incoming not shown, Is there an overhead trough running across the room? 4) Verify service entrance conductors to fire pump, neutral conductor required. Why MI cable?. Where is the service switch located? Why run EGC's with MI cable? EGC on load side of FP switch undersized. 5) MS-A- bus sizes feeding 2000, 2-1200 and 1600 amp switches not shown. 6) Tap conductors off of 1200 amp feeder undersized. 7) EGC from MS-A to "P65" undersized, where is P65 located? Review stopped. MSB not reviewed.</p>						
52812	15A0144	Bigman Brothers, Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bloomingdales 1000 3rd Avenue New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52828	15A0145	Glo Electric LLC 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	149 Kent Avenue Brooklyn NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52829	15A0146	AMA Consulting Engineers, P.C. 250 West 39th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	31-00 47th Street Queens NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52830	15A0149	NJD Wiring & Electric, Inc. 213-08 99th Avenue Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	Elmhurst Hospital 79-01 Broadway Elmhurst NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/11/16 Swapped AB50-01 Revision 2 With the stipulation: Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer.</p>						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0150	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Magnum Apartment Conversion 140 West Street New York NY	On Hold	\$650.00
1) Fire pump emergency side, feeder undersized, underfused. 2) New 75KVA transformer not shown in service room. 3) Gen DLO cable installed as a service conductor (not protected) required to be concrete incased DLO is not an approved wiring method.						
52799	15A0151	Centrum Electric Corporation 12 Lombardy Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	89-14 Parsons Blvd. Jamaica NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52801	15A0152	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Chelsea Market 75 9th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52802	15A0153	Qncc Electric 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	1160 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52798	15A0154	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Rentar Plaza 66-26 Metropolitan Avenue Queens NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52831	15A0155	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU Dibner Library 5 Metrotech Center Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0156	Demand Electric, Inc. 230 49th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Brooklyn Army Terminal 80 58th Street Brooklyn NY	On Hold	\$650.00
1) New service switch #4 not shown on room layout drawing. 2) Show listing of rotary docking station. 3) Where will rotary docking station be installed, 700.6(G)? 4) Wrong fuse show on the T.C-C.						
52832	15A0157	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	65 Central Park West New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52803	15A0158	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	Stevenson Medical Health Ctr. 731 White Plains Road Bronx NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52804	15A0159	Antonio Ceriello Electric Inc. 15 Carroll Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	84 3rd Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/24/15 Swapped Revision 1. 6/19/15 Swapped Revision 2.						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0160	Regional Electrical Voice & Data Inc. 111-08 101st Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	130 West 42nd Street New York NY	Pending	\$650.00
1) Grounded conductors to supply service switches 250.24(c). 2) Cut sheet of 30 HP fire pump not provided. 3) Show short circuit current at 30 HP fire pump controller.						
52982	15A0161	Beacon Electric Corp. 266 Jericho Turnpike Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	270 Madison Avenue New York NY	Approved	\$650.00
1) Fire pump service switch to be bonded and grounded. 2) Verify if fire pumps are new or existing dotted line. 3) Verify if service entrance conductors to fire pump service switch are new or existing dotted line with relocated switch. 4) Scope of new work not clear. 4/20/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53203	15A0162	John Stassi, Licensed Electrician 4347 Hylan Boulevard Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	Parc East Towers Apartments 240 East 27th Street New York NY	Approved	\$650.00
1) Equipment grounding conductor on transformer secondary conductors undersized. 2) Provide spec for VFD cables. 3) Provide listing information. 6/18/15 Transformer secondary and equipment grounding conductors undersized as per tap rules 400 KCM rated 335 amps fused at 350 amps. 2) Co-gen to be hard wired. 8/25/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/20/16 Swapped drawings A021501-Revision 3 and A021502-Revision 1. 8/25/16 Swapped 1 Line drawing Revision 4.						
	15A0163	John Stassi, Licensed Electrician 4347 Hylan Boulevard Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	235 East 22nd Street New York NY	On Hold	\$650.00
1) Show service room verify fire rating, clearances in front of new equipment. 2) Listing documentation for co-gen not provided. 3) 1/0 fused at 250 amps. 4) Transformer secondary not bonded and grounded. 5) Disconnect switches reversed. 6) Equipment grounding conductor undersized from 1500 amp panel to 600 amp disconnect switch. 7) Single line is not consistent with manufacturer's diagram.						
	15A0165	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	31-57 31st Street Astoria NY	Rejected	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/23/16 1) Maintain the clear working 5ft. (50") in front at ss #5. 2) Maintain the working width in front of "200A F.P. MTR".(working width is 2ft from side of is "distribution section 1 and F.A. switch")						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52834	15A0166	Allcom Electric Corp. 121-13 14th Road College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	The Brill Building 1619 Broadway New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52805	15A0168	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	340 Madison Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52807	15A0171	NJS Electrical Service Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	1095 6th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52835	15A0172	New Century Electrical Contractors 105-15 Jamaica Avenue Queens NY 11418	Requested approval for the electric service equipment proposed to be installed	Hurricane Sandy Repair 2650 Ocean Parkway Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52809	15A0173	Jeco Electrical Service Corp. 1162 Intervale Avenue Bronx NY 10459	Requested approval for the electric service equipment proposed to be installed	635 6th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52836	15A0174	Dooley Electric Co., Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Harness Eye Institute 635 West 165th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/1/17swap dwg 1 pf 2						
52837	15A0175	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	33-06 88th Street Queens NY	Approved	\$650.00
aka 87-02 Northern Blvd.-Queens Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52810	15A0176	E.S.B. Electric Corp. 250 Walton Avenue, Suite 25 Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	29 Broadway New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/30/16 Swapped drawing 1-Revision 1						
52838	15A0177	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1140 Broadway New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52839	15A0178	Response Electric Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	3 Hanover Square New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52808	15A0179	Allstate Electrical Group 120 West 31st Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	The Union Club 101 East 69th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52840	15A0180	Didonato and Sons Electl Contg 85 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	55-27 Myrtle Avenue Queens NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52811	15A0181	FSM Electrical Corp. 38-06 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Marmara Park Avenue Hotel 114 East 32nd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52983	15A0182	Jacoby Electric Corp. 10-40 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	60 Hudson Street New York NY	Approved	\$650.00
1) Bus feeding 2000 amp circuit breaker load side of 1250 KVA transformer undersized. 2) Ground fault protection of equipment not shown on 1 Line drawing. 3) Provide 2nd copy of short circuit study. 4/20/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52806	15A0183	Eastern Electrical Construction Inc. 149-07 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	230-79 Rockaway Blvd. Springfield NY 11413	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53602	15A0184	Eastern Electrical Construction Inc. 11-12 Clintonville Street Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	132-34 32nd Avenue Flushing NY	Approved	\$650.00
1) Bus feeding service switches 2, 3, and 4 undersized. 2) Service switches 2 and 3 to have neutral disconnect link. 3) Neutral not bonded and grounded in service equipment. 4) 1 line does not match physical. 5) 1000 KVA service room to be 2 hour fire rated. 3/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52841	15A0186	Radix Wire 26000 Lakeland Blvd. Cleveland CA 44132	Requested approval for use in New York City of your 2 hour fire rated FPL , UL (FHIT) System 28A.		Approved	\$200.00
With the stipulation that the Radix Wire Fire Resistive cable is installed as per system 28A in entirety. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52843	15A0187	Qncc Electric 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	315 East 68th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/6/17 Swapped drawing #B-Revision 6 and drawing A-Revision 3						
	15A0188	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	3270 Hylan Blvd. Staten Island NY	Rejected	\$650.00
1) Show doors on chain link fences and height. 2 Neutral disconnect link to be relocated to load side of bonding and grounding. 3) Verify what(not in Easton contract) means. Is the equipment being installed or not? 4) Verify that manhole rings are bonded with the 3/0 EGC. 5) Provide coordination study. 4/23/15 Rejected. 1) Clearances of service equipment to comply with Table 110.26(A), show complete chain link fence that encloses equipment, not clear on drawing. show all fences, drawing too light to read, show height of fence. 2) Item #4 not addressed. 4/27/15 Rejected. 1) Clearances of service equipment to comply with Table 110.26(A), show complete chain link fence that encloses equipment, not clear on drawing show all fences, drawing too light to read, show height of fence. 2) Item #4 not addressed..						
52876	15A0206	ECNY Electric 12 West 32nd Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	PS 69 144 Keating Place Staten Island NY	Approved	\$650.00
3/24/15 Expedited Review. 4/20/15 Swapped Revision 2.						