

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52288	13A0151CO2	Fletcher Thompson Architecture Eng. 345 Seventh Avenue, Suite 15N New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Fort Totten Building 102 102 Duane Road Queens NY	Approved	\$0.00
Carry over from January 15, 2014 meeting. Not Reviewed expedite for NYFD commissioner. 4/18/14 Job finalized.						
52249	13A0578CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	201 Pearl Street New York NY	Approved	\$0.00
Carry over from January 15, 2014 meeting. 3/30/15 Swapped Drawing 1, Revision 3.						
	13A0712CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Telx 32 Avenue of the Americas New York NY	On Hold	\$0.00
Carry over from December 11, 2013 meeting. 1) Coordination study to be performed by a P.E. and stamped, not complete. 2) Show bonding and grounding of existing service switch and generators. 3) Switches to be labeled to match Sequence of Operation on 1 Line drawing. 4) Show elevation drawing of feeders entering and in the service room. 5) Do service switchboards rear doors? 6) 1 Line and room layout don't match. 7) Someone who knows job to appear at the meeting when new drawings are submitted.						
52381	13A0715	First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	297 North 7th Street Brooklyn NY	Approved	\$650.00
1) Show size of service bus feeding the 1600 amp service switches. 2) Provide manufacturer's cut sheet of generator and switchboard with documentation show that the generator and panel are listed as a complete assembly. 5/13/14 Rejected 1) Item #2 partially addressed. 2) Corrected drawings show Rev 0. 6/18/14 Job finalized. 9/22/14 Swapped 1 and 2, Revision 2.						
	14A0039CO2	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	605 West 42nd Street New York NY	On Hold	\$0.00
Carry over from March 12, 2014 meeting. 1) Drawings -N-10' tap conductors in panels DP-33E, DP-45 feeding last sections 1240 amps of conductors feeding 1400 amp of fusing. Item two (listed from previous meeting) not addressed.						

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52350	14A0097	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	PS 35Q 90-11 191st Street Queens NY	Approved	\$650.00
1) Change normal fire pump fuse to 1200A. 2) Remove "Exit" sign. 3) Telephone service room shouldn't be accessed through the main service room. 5/19/14 1) Service switch #2 overfused. 2) Drawing "B" shows Revision 1, there appears to be no changes, nothing indicated. 5/21/14 Job finalized. 8/8/14 Swapped A, B & C, Rev 2.						
	14A0100	E D Electrical Inc. 5402 7th Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	503 Canal Street New York NY	Administrative Closure	\$650.00
1) Provide manufacturer's cut sheet of generator and switchgear showing listing as a complete assembly. 2) Verify that Con-ED box is directly below CT cabinet and service entrance conductors are installed in a fire rate area, show elevation drawing. 3) Provide coordination study between service switch #1 and DPK panel, and Bussman and little fuses. 5/22/14 Job finalized.						
52345	14A0108	NYC Electrical Contracting Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	17 Monitor Street Brooklyn NY	Approved	\$650.00
1-800 s.s. mislabeled and fuse in reverse. 5/15/14 Job finalized.						
52250	14A0134	Bestco General Electrical Inc. 922 East 233rd Street Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	299 Meserole Street Brooklyn NY	Approved	\$650.00
12/19/14 Swapped 2, Revision 2.						
	14A0142	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	NYU Smilow Emer. Pwr Sys 522 First Avenue New York NY	Rejected	\$650.00
1) Submittal not in Advisory Board format. 2) What is the scope of work? 3) Coordination study required. 5/19/14 Rejected Items #1 and 2 not addressed. 9/22/14 Rejected Item #1 not addressed.						

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52387	14A0145	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	200 Lafayette Street New York NY	Approved	\$650.00
1) 5' clearance required in front of fire pump service switch 10 point meter in way. 2) Show size of main bonding jumper. 3) How do 1/0 conductors terminate in 60 amp disconnect switch? 4) Equipment grounding conductors undersized load side of lockable trough, and tap conductors fed from 400 amp switch to 200 amp switch, and load side trough fed from 1600 amp switch. 5) Provide cut sheet for generator and switchgear showing that it is listed as a complete assembly. 5/16/14 Rejected 1) Revised drawings show Rev 1 when Rev 1's were originally submitted. 2) Item #4 partially addressed. 3) Item #5 not addressed. 6/19/14 Job finalized.						
52251	14A0146	Michael Schondorf, Inc. 545 West 45th Street, Suite 6F New York NY 10036	Requested approval for the electric service equipment proposed to be installed	32 West 33rd Street New York NY	Approved	\$650.00
OR 5/13/14 Swapped Rev 1.						
	14A0147	James F. Volpe Electl Contrg Corp. 81Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	16-16 Whitestone Expressway Queens NY	Administrative Closure	\$650.00
5/13/14 Swapped "A" drawing Rev 1. 8/7/14 Void as per Cal. #52418.						
52253	14A0148	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	90 Park Avenue New York NY	Approved	\$650.00
6/19/14 Swapped Rev 3.						
52254	14A0149	JSP Electrical Contracting Corp. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	H & M Store 111 Fifth Avenue New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/27/16 Swapped drawing B-Revision 1. 9/23/16 Bus feeding sections 5, undersized drawing AB-1.						

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52336	14A0151	Glo Electric LLC 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Soundview 1711 Lacombe Avenue Bronx NY	Approved	\$650.00
1) Service lateral undersized for 4000 amp service, what is the length of service laterals? 2) Short circuit calculations not complete. 5/13/14 Job finalized. 6/23/15 Swapped drawings A, Revision 1 and B, Revision 2.						
52255	14A0155	Barth-Gross Electric Co., Inc. 46-02 37th Avenue Long Island City NY 10001	Requested approval for the electric service equipment proposed to be installed	450 Park Avenue New York NY	Approved	\$650.00
7/23/14 Swapped -01 Revision 2.						
52256	14A0156	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Citibank 390 Greenwich Street, 9th Floor New York NY	Approved	\$650.00
52257	14A0157	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	East River Science Hotel 430 East 29th Street New York NY	Approved	\$650.00
52293	14A0158	Innovative Electric of New York, Inc. 4351 White Plains Road Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	Pepsico Phase II 112-02 15th Avenue College Point NY	Approved	\$650.00
Verify s.s. designation and location of new fuse on single line. 4/21/14 Job finalized. 3/24/15 Swapped 1 and 2 Revision 1s. 6/19/15 Swapped drawings 1, Revision 3 and 2, Revision 2.						

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52539	14A0159	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Scotia Bank 250 Vesey St., 23rd and 24th Floors New York NY	Approved	\$650.00
Address is aka Four World Financial Center Provide short circuit calculations to circuit breaker panels. 9/24/14 Job finalized. 12/28/15 Swapped drawing 1-Revision 1.						
52258	14A0160	Campbell and Dawes Ltd. Electrical Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	Mount Kellet 280 Park Avenue, 4th Floor New York NY	Approved	\$650.00
3/21/16 Swapped Drawing 1, Revision 1.						
52296	14A0162	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Hudson Yards Tower 501 West 30th Street New York NY	Approved	\$650.00
1) Physical for TC-SS-4/TC-DS-4-6(B) shows. 2) Service switches #2 instead of SS 1 and SS2. 3) Service switch #4 in TC-SS-4-3/TC-D5-4-3(B) board overfused drawing AB-E1. 4) Physical for TC-SS-4-5/TC-D5-4-5-(B) show 2 service switches #3 instead of SS 3 and 4. 5) Show cable support boxes for service entrance conductors and provide physicals, concrete encasement with signage, distance of vertical runs. Voltage drop. 6) Generator cables are under sized, generator gives out about 4500A. 4/21/14 Job finalized.						
52294	14A0165	New Phase Electrical Contractors, Inc. 725 East 136th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	230 Fifth Avenue New York NY	Approved	\$650.00
Confirm 3' clearance in front of disconnect switch. 4/21/14 Job finalized. 12/5/14 Swapped Revision 2.						
54187	14A0166	New Phase Electrical Contractors, Inc. 725 East 136th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	515 Madison Avenue New York NY	Approved	\$650.00
1) Verify size of fuses in s.s. #3. 2) Verify equipment grounding conductor is being installed with fire pump feeder. 3) Show conductor support boxes and take pictures of completed support boxes for inspection purposes. 10/6/15 Rejected. 1) Item 1 explain how equipment grounding conductors are being installed with MI cable. MI cable can't be installed in conduit. Explain cable support boxes. 2) Equipment grounding conductor undersized. 11/3/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52349	14A0167	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	GM Building 767 5th Avenue New York NY	Approved	\$650.00
1 Distribution switchboard PP-EM bus to be rated at 700 amps sq". 2) Coordination study to be performed and stamped by a P.E. 3) Provide listing documentation from a NRTL for generator and switchgear as a complete assembly. 5/21/14 Job finalized. 3/31/15 Called contractor. Need full size drawings. 4/21/15 Swapped Drawing B, Revision 2. 6/4/15 Swapped Drawing B, Revision 3.						
	14A0169	A.T.J. Electrical Inc. 122-13 15th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	150 First Avenue New York NY	Denied	\$650.00
1) Verify 3' clearance in front of FAP tap. 2) Verify that emergency conductors are not installed in the service room unless they are fire rated. 3) Equipment grounding conductors for fire pump system undersized, feeders to fire pump not fire rated. 4) Equipment grounding conductors for feeders to life safety panel undersized, show conductors and conduits on load side of ATS and verify amount of sets of conductors. 5) Generator feeders not shown. 6) 1000 amp fuse protecting 400 amp ATS, provide size of life safety panel. 7) 3000 amp breaker to 800 amp fuse does not coordinate. 7/14 No good for carry over. 1) Items 1,2,3,4 and 7 not addressed. 2) Fire pump feeders undersized. 3) Provide listing from NRTL showing that the gen set is listed as a complete assembly. 11/12/14 Denied 1) Item #2 not addressed. 2) Fire pump emergency feeders not fire rated. 3) Item #5 not addressed. 4) Item #7 not addressed 5) With the stipulation: Fire Rated Enclosure's must comply with the following: 1.A P.E. or R.A. must file a PW1 as an ALT 3. 2.A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer.						
52520	14A0170	Prince Electrical Contracting Corp. 1406 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Homewood Suites 312 West 37th Street New York NY	Approved	\$650.00
1) Rear of switchboard to be blocked off. 2) Verify disconnect link on service entrance bus and show sizing of take off bus feeding service switches. Provide neutral link for 1200 amp service switch. 3) Show size of take off bus supplying disconnect switches. 4) Emergency fire alarm disconnect switch bonded and grounded. 5) Verify what type of fire pump is being installed. 6) Emergency fire pump circuit changes wiring methods. 9/15/14 Job finalized. 4/1/15 As per contractor MI cable was installed not fire rated enclosure.						
	14A0171	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	20 Waterside Plaza New York NY	On Hold	\$0.00
SANDY 1) Add note to drawing indicating special permission 52219 to use MC cable for service entrance. 2) Note fire pump sizes. 3) Provide manufacturers cut sheet for 550 KCM conductor. 4) How do you go from 11 sets to 12 sets of MC cable. 5) Will MC cable for service and feeders be bundled together or separated on rack. 6) Provide transformer secondary tap lengths. 7) Splice for fire pump to be located in fire pump room						

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0172	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	40 Waterside Plaza New York NY	On Hold	\$0.00
SANDY 1) Add note to drawing indicating that special permission 52219 was approved to use MC cable for service entrance. 2) P-1, P-2 bus undersized to 2000 amp service switch. 3) Provide manufacturer's cut sheet for 550 MCM conductor. 4) Note the sizes (HPIFLA) for the fire pumps. 5) How do you go from 11 sets to 12 of MC cable?. 6) Will MC cable for service entrance and feeders be bundled together or separated on a rack? 7) P.1. Feeder over fused at 2000 amps. 8) Splice box for fire pump to be located in fire pump room. 9) Show the lengths of transformer secondary						
52259	14A0173	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Ft. Washington Armory 216 Fort Washington Avenue New York NY	Approved	\$650.00
OR						
52260	14A0174	First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	85 Flatbush Avenue Extension Brooklyn NY	Approved	\$650.00
8/27/14 Swapped drawings 1 & 2, Rev 1.						
52343	14A0175	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	100 Willoughby Square Brooklyn NY	Approved	\$650.00
1) Bus undersized in TDP-3W, TDP-18-Eand DP-C section vertical bus. 2) Reduced neutral calculations not provided. 3) 1600 A4BQ to 1200 A4BQ don't coordinate. 5/15/14 Job finalized. 6/23/14 Swapped 1,2,3 & 4 Rev 4, 6/23/16 Swapped 1,2, 3 and 4-Revision 4.						
52342	14A0176	Horsepower Electric 188 21st Street, 2nd Floor Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	22-22 Jackson Avenue Long Island City NY	Approved	\$650.00
Fire pump feeder to be fire rated. 5/15/14 Ok, with the stipulation that UL listed 2 hour rated assembly complies with the following: 1) Have a P.E. or R.A. file a PW1 as an ALT 3. 2) Have a Special Inspection TR1 form submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3) Have the fire proofing performed by a certified fire proofer installer. 4/29/15 Swapped drawings 1 and 2, Revision 2.						

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52340	14A0177	Power Tech Electric Corp. 7 Penn Plaza New York NY 10001	Requested approval for the electric service equipment proposed to be installed	370 Seventh Avenue New York NY	Approved	\$650.00
OR Through bus undersized to last distribution section. 5/15/14 Job finalized.						
52391	14A0178	Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	60 East 8th Street New York NY	Approved	\$650.00
1) Provide sequence of operation. 2) Co-Gen trans. are bonded on the utility side. 6/20/14 Job finalized.						
52261	14A0179	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	300 East 40th Street New York NY	Approved	\$650.00
OR						
52262	14A0180	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	63 East 9th Street New York NY	Approved	\$650.00
OR 8//27/14 Swapped 1, Rev 1.						
52263	14A0181	Cedar Electrical Contractors, Inc. 64 Fulton Street, Suite 602 New York NY	Requested approval for the electric service equipment proposed to be installed	St. John's Building 330 West Street New York NY	Approved	\$650.00
OR 7/23/14 Swapped Revision 1. 11/1/16 Swapped Drawing1-Revision 2.						

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52344	14A0182	Cedar Electrical Contractors, Inc. 64 Fulton Street, Suite 602 New York NY	Requested approval for the electric service equipment proposed to be installed	249 West 17th Street New York NY	Approved	\$650.00
52339	14A0183	Techno-Volt Electric, Inc. 28-29 119th Street Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	1201 Findlay Avenue Bronx NY	Approved	\$650.00
52264	14A0184	E. Fitzgerald Electric Co. 98-16 Rockaway Beach Blvd. Rockaway NY 11694	Requested approval for the electric service equipment proposed to be installed	733 Amsterdam Avenue New York NY	Approved	\$650.00
OR						
52265	14A0185	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	79 Madison Avenue New York NY	Approved	\$650.00
52266	14A0186	OM Electric, Inc. 262 West 38th Street, Suite 1202 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	5 West 125th Street New York NY	Approved	\$650.00
9/28/16 Swapped drawings. 1 and2- Revision 1s						

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0187	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to leave as installed undersized tap conductors where 1 set of #2's and 1 set of 3/0's were tapped on the load side of 3000 amp fuses.	2 Gold Street New York NY	Denied	\$0.00
SANDY Code: 240.21						
	14A0188	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to leave as installed undersized tap conductors where #2 copper taps were installed on the load side of 2000 amp fuses.	201 Pearl Street New York NY	Denied	\$0.00
SANDY Code: 240.21						
52267	14A0189	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to leave as installed a 400 amp ATS with a front clearance of 31".	201 Pearl Street New York NY	Approved	\$0.00
SANDY						
52268	14A0190	Horsepower Electric 188 21st Street Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	50-01 2nd Street Long Island City NY	Approved	\$650.00
OR						
52394	14A0192	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Mt. Sinai 1180 5th Avenue New York NY	Approved	\$650.00
1) Provide documentation showing that the Shaffner mtc transformer are listed. 2) Service switch notation is reversed. 5/19/14 Rejected 1) Drawings 2,3, & 4 of 4 are marked Revision 1 and there are no indications of any revisions. 2) Item #1 not addressed, no documentation provided by a NRTL. 6/23/14 Job finalized.						

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0193	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	625 West 57th Street New York NY	On Hold	\$650.00
<p>1) Drawings 4 of 6 25 of 6 physicals don't match, number of switches don't match. 2) Show where Con Ed enters the service room, does Con ED enter on 1st floor or basement? 3) Show size of service bus feeding the service switches. 4) Where are the step down transformers located in relation with the distribution boards, How long are the transformer taps? 5) Equipment grounding conductors for fire pump undersized 250.122. 6) MSWB-2 1600 amp feeder, equipment grounding conductor undersized. 7) Equipment grounding conductors supplied from 2000 amp bus trough undersized should be 4/0. 8) Show fuse types on generator disconnect switches. 9) Generator bonded and grounded and 3 and pole ATS switches are mixed to panels EMLT and EMDS. 10) Provide documentation that the ENER-6 RVDOX generator and switchgear is listed as a complete assembly. 6/11/14 1) Transformer secondary taps to comply with 240.21 C-6. 2) RB-LE switchboard to be 700 amps per square inch. 3) Item #3 not addressed.</p>						
	14A0194	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1535 Broadway New York NY	Rejected	\$650.00
<p>11/30/15 Rejected. Disconnect link should be located as previous location after CT or 4000A switch.</p>						
52482	14A0195	PJS Electric, Inc. 10 43rd Street, Box #L15 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Bush Terminal Piers Open Space 4300 First Avenue Brooklyn	Approved	\$650.00
<p>1) 3' clearance required on the side of the switchboard. 2) What fuse level is feeding MVA-1 and provide OCPD size of feeder. 3) Short circuit study to be provided by a P.E. and stamped. 4) Drawing to be larger scale. 7/23/14 Rejected 1) Item #4 not addressed, 8"x11" drawings not acceptable. 2) Verify that switchgear has rear hinged doors drawing FP changed. 8/21/14 Job finalized.</p>						
52859	14A0196	Roz-A-Lite Electrical Contracting, Inc. 159 20th Street, Suite 401 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	LIC Marriott Hotel & Residence 29-07 Queens Plaza North Long Island City NY	Approved	\$650.00
<p>1) Correctly indicate whether aluminum or copper feeder conductors are being installed, and type of conduit being installed. 2) Fire alarm utility disconnect switch overfused, and not bonded and grounded. 3) Fire pump feeders to be fire rated. 4) Verify ampere rating of panel EMDP-3-1. 5) Provide short circuit study. 6) Generator is separately derived system provide bonded and grounding. 12/2/14 Rejected Item #3 partially addressed. 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/16/16 Swapped Drawing 1 and 2-Revision 3. 10/3/16 Swapped drawing 1-Revision 4.</p>						

ADVISORY BOARD CALENDAR

April 9, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52270	14A0197	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	JHS 291 231 Palmetto Street Brooklyn NY	Approved	\$650.00
3/30/15 Swapped 1 of 1, Revision 2.						