

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49103CO	08A0558CO	Murray Diamond, Licensed Electrician 35-05 169th Street Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	Highland Care Center 91-31 175th Street Jamaica NY	Ok, but	\$0.00
Carry over from November 12, 2008 meeting. Verify if 3 or 4 pole ATS are used.						
49184CO	08A0626CO	JMC Electric Corp. 172-02 39th Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	370 Park Avenue New York NY	Approved	\$0.00
Carry over from December 10, 2008 meeting.						
49254CO2	09A0051CO2	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	125 Park Avenue New York NY	Approved	\$0.00
Carry over from February 11, 2009 meeting.						
49275CO	09A0072CO	High Beam Electric Corp. 37 Kinsey Place Staten Island NY 10303	Requested approval for the electric service equipment proposed to be installed	1545 Atlantic Avenue Brooklyn NY	Hold	\$0.00
Carry over from February 11, 2009 meeting. 1) 12 sets 4/0 fused at 5000 amps. 2) Show selectivity between service switch #3 and 2000 amp distribution switch.						
49296CO	09A0083CO	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	23-31 Grand Street New York NY	Approved	\$0.00
Carry over from March 18, 2009 meeting.						

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49319CO	09A0106CO	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University 530 West 120th Street New York NY	Approved	\$0.00
Carry over from March 18, 2009 meeting. 1) Install barriers on sides of columns to switchgear that are less than 3". 2) Provide rear hinged doors on the switchgear. Job finalized 7/9/09.						
49320CO	09A0107CO	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Goldman Sachs 77 Water Street New York NY	Approved	\$0.00
Carry over from March 18, 2009 meeting. 1) Equipment grounding conductor undersized on load side of 1200 amp service switch. 2) Ground lug to be indicated. 3) Provide supplemental ground. Job finalized 6/2/09.						
49349CO	09A0136CO	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Verizon 240 East 38th Street New York NY	Hold	\$0.00
Carry over from March 18, 2009 meeting. 1) Load shedding sequence not provided. 2) Provide ground fault protection or all non-life safety loads. 3) The emergency loads must comply with the current codes.						
49382	09A0141	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 1 New York Plaza New York NY	Hold	\$650.00
1) Show details for terminating 20 sets in switchboard and ATS. 2) Provide complete submissions for Siemens switchboards. Include bus sizing. 3) Provide short circuit and coordination study.						
49383	09A0142	Schlesinger Electrical Contractors, Inc. 664 Bergen Street Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	1751 Park Avenue New York NY	Ok, but	\$650.00
Grounding electrode conductor for SS#2 to connect to grounding collector bus or direct to water service.						

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49384	09A0143	Jemco Electrical Contractors, Inc. 92-13 180th Street Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	Queensborough Comm. College Springfield Blvd. & 56th Street Bayside NY	Approved	\$650.00
1) Verify available short circuit current at Panel 'A'. 2) Provide cuts on grounding res., GF CT and GF relay. 3) Provide gate in fence near SS#2. 4) Confirm tie switch in 5KV switchgear in N.O. 5) Show existing 5KV loads on 1-Line. 6) Correct key interlock scheme on 1-Line. 7) Maintain max 25ft on length of secondary 5KV feeders from transformers to 5KV switchgear. Job finalized 7/8/09.						
49385	09A0144	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	St. John's University 80-40 Utopia Parkway Queens NY	Hold	\$650.00
1) Describe how medium voltage feeders will be run and what type wiring method will be used. 2) Provide cut sheet of type medium voltage conductor will be used. 3) 1- 1/4x2" undersized for 600 amp medium voltage switch and distribution board. 4) Provide size of neutral bond. 5) Conductors on load side of generator not shown. 6) Describe which type of MI will be used multi conductor or single and how it will be installed triplexed or singular. 7) Neutral bonded on primary side of transformer instead of secondary. 8) FACO 480 volt sides shall be a switch. 9) Jockey pump connection to be made external to fire pump controller. 10) Provide barrier behind SS#1 and 2 and distribution. 11) Line side FACO not bonded.						
49386	09A0145	Amko Electrical Construction & Maint. Inc 32-17 College Point Blvd. Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	425 Main Street New York NY	Approved	\$650.00
49387	09A0146	JMC Electric Corp. 172-02 39th Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	10 Monroe Street New York NY	Hold	\$650.00
1) Service bus too small as shown to accommodate existing loads. 2) Verify new feeder length within tap rules.						
49388	09A0147	Egg Electric Inc. 24 West 25th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Faculty House 400 West 117th Street New York NY	Ok, but	\$650.00
1) Service switches remote from the switchboard must be grounded 250.64(D). 2) Provide ground electrode connection for fire pump switch.						

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49389	09A0148	United Electrical Contracting Corp. 69 Ludlow Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	132 4th Avenue New York NY	Ok, but	\$650.00
Fire pump service switch to be grounded.						
49390	09A0149	Prince Electric Corporation 130-07 26th Avenue College Point NY 11354	Requested approval for the electric service equipment proposed to be installed	P.S. 202 138-30 Lafayette Street Ozone Park NY	Approved	\$650.00
49391	09A0150	Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	2131 Frederick Douglas Blvd. New York NY	Approved	\$650.00
49392	09A0151	Pulsar Electric, Inc. 51 Atlantic Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	Courtyard Marriott 3 East 40th Street New York NY	Ok, but	\$650.00
1) 400 amp service switch must be grounded. 2) Cable size too small from 400A generator circuit breaker. 3) Verify generator grounding and 3W/4W for 100A ATS.						
49393	09A0152	Borowide Electrical Contractors, Inc. 36-07 20th Avenue Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	70 West 36th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49394	09A0153	Maximum Electrical Contracting Corp. 708 Mace Avenue Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	128 West 29th Street New York NY	Approved	\$650.00
49395	09A0154	All-Star Electrical Services, Inc. 35 West 31st Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	545 5th Avenue New York NY	Approved	\$650.00
1) Provide bus size on line side of 4000A service switch. 2) Verify that transformer room is mechanically vented. 3) Provide data on transformer. Show winding connection (delta-Y); grounding. 4) Verify fuse size for transformer inrush. Job finalized 7/29/09.						
49396	09A0155	Axcel Electric Co. Inc. 535 West 46th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	330 Wilson Avenue Brooklyn NY	Approved	\$650.00
1) Special permission required to add a 7th service switch. 2) Provide short circuit calculations and curves. 3) Details not provided on drawing. Job finalized 9/16/09.						
49397	09A0156	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	247 West 30th Street New York NY	Approved	\$650.00
49398	09A0157	erified Electrical & Technical Services, In 27 Williams Street, Suite 409 New York NY 10005	Requested approval for the electric service equipment proposed to be installed	15 West 65th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49399	09A0158	Hugh O kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	N.Y.U. Co. Gen Expansion 725 Broadway New York NY	Hold	\$650.00
<p>1) Verify what work is new, what work is existing, and what work will be future. 2) 1 line does not match room layout. 3) What work is electrician who filed drawing doing? 4) Verify 3' clearance in front of FACO box. 5) Provide cope compliant schematic for equipment grounding system for multiple buildings. 6) Locate new fuse cutout in 725 Broadway. 7) Correct Con-Ed service voltage for existing service(typo). 8) Confirm new 4160V generator system is compliant emergency source. 9) key interlocks must be installed.</p>						
49400	09A0159	L & B Electrical International, Inc. 2063 Atlantic Avenue Brooklyn NY 11233	Requested approval for the electric service equipment proposed to be installed	School of Visual Arts 225 West 16th Street New York NY	Approved	\$650.00
49401	09A0160	Crana Electric Inc. 600A East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	The Bank Note 1201 Lafayette Avenue Bronx NY	Approved	\$650.00
49402	09A0161	Morales Electrical Contracting, Inc. 4601 Avenue N Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	P.S. 125M 425 West 123rd Street New York NY	Approved	\$650.00
49403	09A0162	C.M. Richey Electrical Contractors, Inc. 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Pratt Institute 524 Myrtle Avenue Brooklyn NY	Approved	\$650.00
<p>1) Drawing not in Advisory Board format. Breaker info, bus sizes. 2) Someone who knows job to appear at next meeting. Job finalized 5/13/09.</p>						

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49404	09A0163	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2nd Avenue Subway 1858 2nd Avenue New York NY	Approved	\$650.00
1) Drawing not in Advisory Board format. Breaker info, bus size. Job finalized 6/23/09.						
49405	09A0164	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	NY Aquarium 502 Surf Avenue Brooklyn NY	Hold	\$650.00
1) Clarify new and existing equipment. 2) Coordinate contract drawings and Eaton drawings.						
49406	09A0165	Jata Electrical Construction Corp. 16 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	183-11 Hillside Avenue Jamaica NY	Ok, but	\$650.00
1) Only generator frame to be grounded. 2) Generator feeder undersized.						
49407	09A0166	alvatore Campisi & Sons Electl Contrs, Inc 453 Onderdonk Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	11 West 19th Street New York NY	Hold	\$650.00
1) Verify who will be performing the box bar work inside of the switchgear contractor or switchboard company. 2) Bus additions must be all copper or aluminum.						
49408	09A0167	B & G Electrical Contractors of New York 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	East River Plaza 536 East 116th St. & F.D.R. Dr. New York NY	Approved	\$650.00
Show fire pump branch circuits and fire pump detail. Job finalized 5/13/09.						

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49409	09A0168	Global Electl Contracting of Westchester, Inc. 4065 Boston Road Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	Jacobi Medical Data Ctr 1400 Pelham Parkway Bronx NY	Hold	\$650.00
1) Ground bus to be continuous to all sections of switchboard in MDP-data. 2) Generator feeders undersized to paralleling gear. 3) Secondary of transformers not grounded. 4) Neutrals bonded to enclosure in 30 amp disconnect switches. 5) 480 volt switches to be ground fault protected. 6) Show second fusing off of paralleling gear. 7) Submitted curves do not show selectivity.						
49410	09A0169	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Courtlandt Corners I 870 Courtlandt Avenue Bronx NY	Approved	\$650.00
1) #1 copper service entrance conductor requires #8 ground. 2) 600 amp fusing requires #1 equipment grounding conductor. 3) Remote service switches to be grounded. Job finalized 5/13/09.						
49411	09A0170	JMC Electric Corp. 172-02 39th Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	500 19th Street Brooklyn NY	Ok, but	\$650.00
1) Show where existing 3/0 service entrance conductors terminate to. 2) Show where #3 ground terminates to. 3) Remote service switches require grounding conductor. 4) Provide supplemental ground.						
49412	09A0171	JMC Electric Corp. 172-02 39th Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	64-11 Beach Channel Drive Far Rockaway NY	Approved	\$650.00
1) A neutral conductor must be installed in each service switch. 2) Where is ground terminated without a neutral? 3) Explain grounding of service switch. Job finalized 6/2/09.						
49413	09A0172	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	730 Park Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49414	09A0173	Riverdale Electric Corp. 131 Walnut Avenue, 3rd Floor Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	47 West 57th Street New York NY	Ok, but	\$650.00
Remote service switches shall be connected to grounding electrode conductor.						
49415	09A0174	DNR Electric, Inc. 1338 Morrison Avenue Bronx NY 10472	Requested approval for the electric service equipment proposed to be installed	115 West 45th Street New York NY	Approved	\$650.00
49416	09A0175	Klear Electrical Corp. 31-00 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Holiday Inn 440 West 57th Street New York NY	Approved	\$650.00
49417	09A0176	Modern Trend Electrical Contracting Corp 45-06 108th Street Corona NY 11368	Requested approval for the electric service equipment proposed to be installed	521 Park Avenue New York NY	Approved	\$650.00
49418	09A0177	Warren Ostroff Electric Inc. 102-15 159th Road Howard Beach NY 11414	Requested approval for the electric service equipment proposed to be installed	Moinian 655 Park Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49419	09A0178	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	235 Gold Street Brooklyn NY	Approved	\$650.00
1) Ground bus not shown on drawing. 2) Tap conductor to 200 amp disconnect switch is undersized. 3) Service switch remote from switchboard. 4) CT bus feeding fire pump and 2000 amp switch undersized. 5) Bus sizes omitted on drawing . 6) Show clearances in front of switchboard. Job finalized 11/3/10.						
49420	09A0179	Global Electl Contracting of Westchester, Inc. 4065 Boston Road Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	York College Academic Core 94-20 Guy Brewer Blvd. Jamaica NY	Approved	\$650.00
Bus sizes not provided for some switches in 3 new distribution boards. Job finalized 6/22/09.						
49421	09A0180	Pinto & Teger Electric Corp. 14-14 123rd Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Verizon 208 East 79th Street New York NY	Ok, but	\$650.00
Fire alarm service switch to be fused cutout.						
49422	09A0181	Department of Environmental Protection 59-17 Junction Boulevard Flushing NY 11373	Requested approval for the electric service equipment proposed to be installed	Throgs Neck Pumping Station 2421 Lafayette Avenue Bronx NY	Approved	\$650.00
49423	09A0182	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	400 Broome Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49424	09A0183	CMS Electrical Services Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Equity Office Properties 717 Fifth Avenue New York NY	Hold	\$650.00
1) Advisory Board submittal on generator switchboard. 2) GFP on generator breakers non-life safety, 1000A and above.						
49425	09A0184	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Crown Heights Charter HS 1485 Pacific Street Brooklyn NY	Approved	\$650.00
49426	09A0185	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requested approval for the electric service equipment proposed to be installed	Randall Island Field Develop Randall's Island park Randall's Island NY	Hold	\$650.00
1) Provide manufacturer's 1-line of 13KV switchgear (PACS). 2) Add fire-rated doors between transformer vaults for 2nd egress.						
49427	09A0186	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	400 5th Avenue New York NY	Approved	\$650.00
1) Verify front clearance in front of service switch #6 in switchboard C. 2) Special permission needed to install a 7th service switch in switchboard A. 3) Bus undersized for 4000 amp service switch in switchboard B. 4) Provide GFP on 480V switches 1000A plus. 5) Generator neutral to terminate on building steel on water main electrode. 6) Branch circuit to chiller transformer is undersized service A. 7) Verify that ATS room and doors are 2 hour fire rated. 8) Verify that emergency feeders aren't running through the service room. 9) Fire pump branch circuit undersized and conduit undersized. Ok with special permission.						
49428	09A0187	Tap Electrical Contracting Service Inc. 37-20 58th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	DEP WP-103 Wards Island New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49429		Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requesting permission due to lack of space in the service room, to install a 1600 amp service switch in a remote restaurant service room that will provide access to the restaurant for their electrical distribution equipment.	22-31 Grand Street New York NY	Approved	\$0.00
With the stipulation that signage is provided on each service room door indicating where the other service is located.						
49430		Crana Electric Inc. 600A East 132nd Street Bronx NY 10454	Requesting permission to install a switchboard with a side clearance of 2 feet on a 1000 KVA service.	The Bank Note 1201 Lafayette Avenue Bronx NY	Approved	\$0.00
49431		Maximum Electrical Contracting Corp. 708 Mace Avenue Bronx NY 10467	Requesting permission to install a service switch with a front clearance of 57 inches on a 1000 KVA service.	128 West 29th Street New York NY	Approved	\$0.00
49432		Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requesting permission to install 2-60 amp service switches in lieu of a fuse cutout for a fire alarm service one on the normal side and one 20 and one 60 amp off of the paralleling switchgear on a 1000 KVA service.	125 Worth Street New York NY	Denied	\$0.00
Due to installation of a FACO installed on the 120/208 volt side and FA disconnect switch installed on the 277/480V emergency side.						
49433		Dorion Norton Electrical Contracting Corp 112-33 Guy R. Brewer Blvd. Jamaica NY 11433	Requesting permission to leave as installed due to a hardship to replace AC cable that does not contain an insulated equipment grounding conductor.	1033 Glenmore Avenue Brooklyn NY	Approved	\$350.00

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49434		ATN Electric Corp. 240-19 Jamaica Avenue Bellerose NY 11426	Requesting permission due to a hardship to replace, to leave as installed in a place of assembly AC cable that does not contain an insulated equipment grounding conductor as a wiring method.	319 East 53rd Street New York NY	Approved	\$350.00
49435		Fresh Meadow Electrical Contractors, LLC 65-01 Fresh Meadow Lane Fresh Meadows NY 11365	Requesting permission to utilize non-metallic conduit as a wiring method for concrete encased service entrance conductors that will power 6 park houses and outdoor lighting poles throughout a park located above 2 piers in a corrosive area.	Brooklyn Bridge Park Project New York NY	Approved	\$0.00
49436		W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requesting permission to use a metal water sprinkler pipe located next to the service equipment as grounding electrode instead of the metal domestic water pipe located 300' away from the service equipment.	Mobile Gas Station 1132 York Avenue New York NY	Denied	\$0.00
49437		Samco Electric Corp. 39-08 24th Street Long Island City NY 11101	Requesting permission due to a water damage to replace a defective CT and 1600 amp service switch fused at 1200 amps, and also replace 3-400 amp and 1-100 amp service switches on a 1000 KVA service without filing Advisory Board drawings.	PS 221K 791 Empire Blvd. Brooklyn NY	Denied	\$0.00
49438		Reiter Electric, Inc. 533 West 47th Street New York NY 10036	Requesting permission to utilize an existing water pipe riser to ground the secondary of a transformer on the 50th floor of a building that does not have building steel.	265 East 66th Street New York NY	Approved	\$0.00
With the stipulation that pumps, valves, and water meters are effectively bonded around any equipment likely to be disconnected for repairs or replacement. A 3/0 grounding jumper shall be installed from the line side of the metal underground water pipe's main valve to the water pipe riser being utilized as the grounding electrode.						

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49439		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission due to lack of space in a 21st floor electrical closet, to allow a one for one replacement of a defective 200 amp, 480 volt disconnect switch that will have a front clearance of 28 inches instead of 36 inches.	299 Park Avenue, 21st Floor New York NY	Approved	\$0.00
With the stipulation that insulated material is installed on the wall adjacent to the disconnect switch.						
49440		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission due to lack of space in a 14th floor electrical closet, to allow a one for one replacement of a defective 200 amp, 480 volt disconnect switch that will have a front clearance of 26 inches instead of 36 inches.	299 Park Avenue, 14th Floor New York NY	Approved	\$0.00
With the stipulation that insulated material is installed on the wall adjacent to the disconnect switch.						
49441		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to install submersible luminaires that operate on 120 volt supply circuits where the luminaires contain in-line 120/12 volt step down transformers for fountain lighting.	140 West 65th Street New York NY	Denied	\$0.00
49442		Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10003	Requesting permission due to rigid metal conduits already installed in 10" concrete slabs to allow 3-400 MCM SIMpull THHN conductors to be installed in 2 inch conduits that will result in the conduit having a 46% fill.	400 5th Avenue New York NY	Approved	\$0.00
49443		Denmar Electric Corp. 47-40 48th Street Woodside NY 11377	Requesting permission to replace one for one a 4000 amp service switch without filing full Advisory Board drawings on a 1000 KVA service	Prospect Park Zoo 450 Flatbush Avenue Brooklyn NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

April 15, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49444	09A0188	Fab*Am Electric, Inc. 1243 Oakpoint Avenue Bronx NY 10474	Requested approval for use in New York City of your Consolidated Edison CT Cabinet Spec 142: CT-36 and CT-44.		Approved	\$200.00
49445	09A0189	Fab*Am Electric, Inc. 1243 Oakpoint Avenue Bronx NY 10474	Requested approval for use in New York City of your Con Edison Endboxes Spec #: F-205, F-215, F-484		Approved	\$200.00