

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47684CO	07A0067CO	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Barclays Capital (Thor Project) 200 Park Avenue New York NY	Approved	\$0.00
Carry over from February 14, 2007 meeting. 1) Show system ground on gen. neutral. 2) Provide Asco bus sizing on Asco drawings. Job finalized 6/7/07.						
47691CO	07A0073CO	Fas Electrical Contractors, Inc. 90-61 Pitkin Avenue Ozone park NY 11417	Requested approval for the electric service equipment proposed to be installed	Ultra Flex Packaging 975 Essex Street Brooklyn NY	Ok, but	\$0.00
Carry over from February 14, 2007 meeting. !) Conductors feeding the transformer are undersized. 2) How far is the run from the transformer to the new panel, should be within 10 feet.						
47739CO	07A0106CO	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Citigroup 44-47 23rd Street Long Island City NY	Approved	\$0.00
Carry over from March 14, 2007 meeting. Provide complete generator room layout. Job finalized 8/10/07.						
47740CO	07A0105CO	Star-Delta Electric Inc. 17 Battery Place-Suite 701 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	40 Wall Street New York NY	Approved	\$0.00
Carry over from March 14, 2007 meeting.						
47750CO	07A0142CO	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Atria Assisted Living 3718-3726 Henry Hudson Parkway Bronx NY	Approved	\$0.00
Carry over from March 14, 2007 meeting.						

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47762CO	07A0103CO	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Henry Miller Theater 1111 6th Avenue New York NY	Approved	\$0.00
Carry over from March 14, 2007 meeting.						
47765CO	07A0137CO	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Towers at Hutchinson Metro Ctr 1250 Waters Place Bronx NY	Hold	\$0.00
Carry over from March 14, 2007 meeting. 1) Verify if 10 HP motor is a fire pump, if it is service switch is undersized and conductors must be fire rated. 2) Generator neutral must be bonded properly 4 pole ATS is used.						
47776CO	07A0100CO	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1211 Southern Blvd. Bronx NY	Hold	\$0.00
Carry over from March 14, 2007 meeting. Tap for fire pump made in same switch section.						
47781CO	07A0134CO	Washington Electric Co., Inc. 140 58th Street, Suite 8F Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	B & H Photo 420 9th Avenue New York NY	Hold	\$0.00
Carry over from March 14, 2007 meeting. Washington Electric filed Advisory Board drawings and Action, Light and Power is listed as the contractor on the drawing . 2) The installation does not comply with Article 250.30. (A)(I).						
47805	07A0152	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Metro Office Supply 345 Park Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47806	07A0197	C.M.S. Electrical Services Co., Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	325 Hudson Street New York NY	Approved	\$650.00
Comply with art 40% current density for bus on load side of 3000A switch. Job finalized June 7, 2007.						
47807	07A0202	Jen Electrical Contractors, Inc. 7812 New Utrecht Avenue Brooklyn NY 11214	Requested approval for the electric service equipment proposed to be installed	276 Stagg Street Brooklyn NY	Approved	\$650.00
Comply with art 40% current density for bus on load side of 3000A switch. Job finalized June 7, 2007.						
47808	07A0198	BRG Electric Inc. 88-26 Winchester Blvd. Queens Village NY 11427	Requested approval for the electric service equipment proposed to be installed	Time Warner 59-81 Paidge Avenue Brooklyn NY	Hold	\$650.00
1) Verify that ATS in service room is not feeding life safety equipment. 2) Indicate which equipment is new or existing. 3) Fuse types not provide. 4) Feeders to ATS are undersized line, load and generator. 5) Provide generator room layout. 6) Verify if generator neutral is bonded. If yes, need 4P ATS.						
47809	07A0189	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	111 Fifth Avenue New York NY	Approved	\$650.00
1) Service entrance conductors can not be spliced. 2) 400A 2nd fusing must be RK1 for coordination. Job finalized June 7, 2007.						
47810	07A0158	Jata Electrical Construction Corp. 16 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	90-30 Metropolitan Avenue Queens NY	Approved	\$650.00
1) Indicate the size and number of sets feeding the service. 2) Show dims on floor plan. 3) Maintain grounding continuity with underground pull box. Job finalized May 20, 2008.						

# ADVISORY BOARD CALENDAR

April 18, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47811	07A0154	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Samuel Gompers Voc. Tech H.S. 455 Southern Boulevard Bronx NY	Approved	\$650.00
Provide access to overhead utility trough. Job finalized 4/25/07.						
47812	07A0153	Angel Power & Light Electl Contrs, LLC 32 East Street, Suite 805 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Manhattan Mini Storage Fac. 401 East 110th Street New York NY	Approved	\$650.00
47813	07A0204	B & G Electrical Contractors of NY Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Target Fit-Out Project 2201Nostrand Avenue Brooklyn NY	Hold	\$650.00
1) Indicate the sets and wire size on load side of termination box. 2) Provide selective coordination between distribution breakers and service fuse. 3) Confirm adequacy of s.c. rating of MDS.						
47814	07A0206	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	MS 114 91st Street and First Avenue New York NY	Approved	\$650.00
1) Service room doors to open out with panic hardware. 2) F.P. switch must be 12" from service. 3) 2nd means of egress required. 4) Emergency feeder to F.P. to be fire rated. Job finalized 8/2/07.						
47815	07A0208	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Gregorio Luperon H.S. 516 West 181st Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47816	07A0195	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2025 Seward Avenue Bronx NY	Approved	\$650.00
Confirm clearance around new service switch. Job finalized 12/14/07						
47817	07A0196	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2675 W. 36th Street Brooklyn NY	Approved	\$650.00
47818	07A0192	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	220 South Street New York NY	Approved	\$650.00
47819	07A0175	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	600 West 42nd Street New York NY	Approved	\$650.00
47820	07A0174	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	246 Spring Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47821	07A0171	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	515 West 52nd Street New York NY	Approved	\$650.00
47822	07A0170	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	3260 Henry Hudson Parkway Riverdale NY	Approved	\$650.00
47823	07A0168	MF Electrical Service Co., Inc. 3323 Merritt Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	550 Brush Avenue Bronx NY	Ok, but	\$650.00
Confirm guard rail is in accordance with prior approvals.						
47824	07A0165	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	20 East 23rd Street New York NY	Approved	\$650.00
47825	07A0185	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Bradford House Apartments 1210 Croes Avenue Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47826	07A0184	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	65 36 Avenue P Brooklyn NY	Approved	\$650.00
Confirm service entrance configuration approved by Con-Ed. Job finalized 12/17/07.						
47827	07A0176	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Nextel 10101 Foster Avenue Brooklyn NY	Approved	\$650.00
Transformer neutral ground in 1 location only. Job finalized 4/25/07.						
47828	07A0177	Chapman &n Chapman Electl Contrs, Inc. 64-17 Grand Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	GHI Data Center-2nd Floor 441 Ninth Avenue New York NY	Approved	\$650.00
New tap 10ft max. Job finalized 4/25/07.						
47829	07A0178	Stanco Systems Electrical Contracting Inc. 4061 Victory Boulevard Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	P.S. 156X/151X 750 Concourse Village West Bronx NY	Approved	\$650.00
New tap undersized cable must be 600A.(Svc B). Job finlized 4/25/07.						
47830	07A0179	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Frank Sinatra School of Arts 32-12 35th Street Queens NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

April 18, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47831	07A0160	MDM Consulting Engineers 65 Bleecker Street New York NY 10012	Requested concept approval	Empire State Building 350 Fifth Avenue New York NY	Approved	\$650.00
47832	07A0212	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Sephora 300 Madison Avenue New York NY	Approved	\$650.00
47833	07A0215	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested concept approval	The New Yankee Stadium 1 Yankee Stadium Way Bronx NY	Ok, but	\$0.00
Comply with clearance of Art. 110.						
47834	07A0210	Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Flushing Meadows Crotona Park Queens NY	Ok, but	\$650.00
Provide coordination study.						
47835	07A0201	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Long Island Jewish Med. Ctr. 75-59 263rd Street Glen Oaks NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47836	07A0199	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	SAC Capital Management 540 Madison Avenue New York NY	Approved	\$650.00
Feeder to existing 1600 amp switch is undersized.						
47837	07A0180	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Jamaica Nursing Home 39-22/52 135th Street @90th Avenue Jamaica NY	Approved	\$650.00
Show correct AIC. Job finalized 4/25/07						
47838	07A0181	Arch Electric, Inc. 4244 Crescent Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	37 West 47th Street New York NY	Ok, but	\$650.00
Remove bonding off of disconnect switch.						
47839	07A0182	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	590 Madison Avenue New York NY	Approved	\$650.00
Remove neutral to chiller. Job finalized 8/1/07.						
47840	07A0188	D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	377 Greenwich Street New York NY	Ok, but	\$650.00
1) Door next to new work to open out. 2) Move new equipment over to the left as much as possible.						

# ADVISORY BOARD CALENDAR

April 18, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47841	07A0187	L.E.A. Electric Corp. 1001 Sixth Avenue, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	15 Union Square New York NY	Approved	\$650.00
47842	07A0186	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	33 West 56th Street New York NY	Ok, but	\$650.00
Fire pump service switch located in middle of through bus.						
47843	07A0166	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	788 Columbus Avenue New York NY	Approved	\$650.00
47844	07A0173	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	510 West 52nd Street New York NY	Approved	\$650.00
47845	07A0172	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	1930 Broadway New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47846	07A0169	M.&R. Electl Contrg and Repair Serv. Inc. 149 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	100 Lafayette Street New York NY	Approved	\$650.00
47847	07A0167	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	32 Old Slip New York NY	Approved	\$650.00
Provide contractors 1997 application #. For generator work. Job finalized 4/24/07.						
47848	07A0164	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	100 Park Avenue New York NY	Ok, but	\$650.00
Service entrance conductor for services B1 to B2 concrete encased.						
47849	07A0214	Norway Electrical Corp. 1205 Jerome Avenue Bronx NY 10452	Requested approval for the electric service equipment proposed to be installed	804 East 138th Street Bronx NY	Approved	\$650.00
47850	07A0161	SMC Electrical Contracting, Inc. 126-12 18th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	HS of Telecommunications 350 67th Street Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47851	07A0162	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New York Hilton 1335 Avenue of the Americas New York NY	Ok, but	\$650.00
Remove copper grounds from conduit.						
47852	07A0163	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	1230 York Avenue New York NY	Approved	\$650.00
47853	07A0194	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	21 Dominick Street New York NY	Approved	\$650.00
47854	07A0200	Deltex Electrical Contracting, Inc. 1027 McDonald Avenue Brooklyn NY 11230	Requested approval for the electric service equipment proposed to be installed	120 West 44th Street New York NY	Approved	\$650.00
47855	07A0193	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2411 Frederick Douglas Blvd. New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

April 18, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47856	07A0191	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1415 Richmond Avenue Staten Island NY	Approved	\$650.00
47857	07A0209	BLH Electrical Contractors, Inc. 535 Coster Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	Jefferson Towers 700 Columbus Avenue New York NY	Ok, but	\$650.00
1) Change 600 amp switch to 400 amps. 2) Change fuses in 1200 amp switch for 750 MCM.						
47858	07A0205	Levinson & Santoro Electric Corp. 20-16 130th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	J. Browne High School 63-25 Main Street Flushing NY	Approved	\$650.00
47859	07A0207	J.H. Electric of New York, Inc. 708-12 133rd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Department of Sanitation 780-786 12th Avenue New York NY	Ok, but	\$650.00
1) Show location of service end boxes. 2) Show selectivity between 6000 and 4000 amp fuses.						
47860	07A0156	Arcardia Electrical Company, Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	Walgreens Coney Island 532 Neptune Avenue Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47861	07A0155	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	National Sports Museum 26 Broadway New York NY	Approved	\$650.00
1) What do the load side of ATS feed. 2) Show bus sizes on the line side of service switches 1 and 2. Job finalized 4/26/07.						
47862	07A0157	Jata Electrical Construction Corp. 16 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	421 West 54th Street New York NY	Approved	\$650.00
47863	07A0183	Judd Electric, Inc. 41-41 38th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	201 East 17th Street New York NY	Approved	\$650.00
47864	07A0203	Quest Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	462 West 58th Street New York NY	Approved	\$650.00
1) Show size of service bus. 2) Show selectivity between 1200 amp and 400 amp fuses. 3) Verify that fire pump service switch has neutral conductor, where is fire pump located. Job finalized June 7, 2007.						
47865	07A0159	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	650 6th Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47866	07A0190	GTS Electrical Corp. 218-14 Northern Blvd. Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	112-02 15th Avenue College Point NY	Hold	\$650.00
1) Someone who know job to walk us through installation and drawings. 2) Drawings not in Advisory Board format.						
47867	07A0211	Dal Electrical Corp. 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	150 East 42nd Street New York NY	Approved	\$650.00
47868	07A0213	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	1 Metro Tech Center Brooklyn NY	Approved	\$650.00
Show wire size on load side of ATS to panelboard. Job finalized June 7, 2007.						
47869	=	Raptor Electrical Construction Corp. 205-07 Hillside Avenue, Suite 27 Hollis NY 11423	Requesting permission to leave as installed fenced in service equipment outside of a building.	340 Baychester Avenue Bronx NY	Approved	\$350.00
47870	-	ISM Electric Contractor Inc. 512 73rd Street Brooklyn NY 11209	Requesting permission to install two recessed circuit breaker panels that will face each other with a front clearance of 27 inches.	163 Charles Street New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**April 18, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47871	--	Mari Electric Contractors Inc. 535 Wild Avenue Staten Island NY 10314	Requesting permissions due to no common area inside the building to install service equipment for multiple stores outdoors	1071 Bay Street Staten Island NY	Approved	\$0.00
With the stipulation that raintight equipment is installed outdoors.						
47872	---	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requesting permission to install service equipment for a cell site on the outside of a commercial building where signage will be provided as per 230.2(E).	Sprint 138-01 Springfield Blvd. Queens NY	Approved	\$0.00
47873	----	RHR Electric Co., Inc. 135 West 29th Street, Suite 1202 New York NY 10001	Requesting permission to install a new circuit breaker panel on the front of a column inside of a walk-in clothes closet.	435 East 52nd Street, Apt 6C New York NY	Approved	\$0.00
With the stipulation that the circuit breaker panel is not installed in the vicinity of easily ignitable material.						
47874	-----	Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456	Requesting permission due to lack of space inside of the existing service room to install a new service switch in the adjacent room.	412 West 110th Street New York NY	Approved	\$0.00
With the stipulation that signage is provided as per Article 2302(E) of the NEC.						
47875	-----	James Walters Electrical Contractors, Inc. 110-09 Liberty Avenue Richmond Hill NY 11419	Requesting permission due to lack of room inside of the building's service area, to install a new service switch on the outside of the building that will feed the existing meters where Con-Edison's underground service lateral is defective.	52-27 69th Street Queens NY	Approved	\$0.00
With the stipulation that the new service switch is properly bonded and grounded and the bonding and grounding is removed from the disconnect switches.						