

ADVISORY BOARD CALENDAR

May 2, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50906CO		Nead Electric Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	240 East 38th Street New York NY	Hold	\$0.00
Carry over from October 19, 2011 meeting. 1) GFI Should be located at generator breaker (alarm only) 2) Bond neutral at generator only(not two locations).						
50911CO2		Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	rth River WWTP, 135th and 12th Str New York NY	Approved	\$0.00
Carry over from February 15, 2012 meeting.						
51033CO2		Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	45-35 Van Dam Street Queens NY	Denied	\$0.00
Carry over from April 18, 2012 meeting. 1) Tap conductors undersized. 2) No main in panel MDSB #1A.						
51036CO		Royal Electrical & Wiring Corp. 2558 Marion Avenue Bronx NY 10458	Requested approval for the electric service equipment proposed to be installed	23-10 41st Avenue Long Island City NY	Hold	\$0.00
Carry over from January 11, 2012 meeting.						
51125CO		N.J.D. Wiring & Electric, Inc. 55 Huron Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	1050 Targee Street Staten Island NY	Approved	\$0.00
Carry over from March 14, 2012 meeting.						

ADVISORY BOARD CALENDAR

May 2, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51137CO		Hugh O Kane Electric Company, Inc. 90 White Street New York NY 11101	Requested approval for the electric service equipment proposed to be installed	85 St. Nicholas Terrace New York NY	Hold	\$0.00
Carry over from March 14, 2012 meeting. 1) Verify that 5" conduits are stubbing up into the bottom of the switchgear on drawing 7 of 13, 2) Verify that metal grating on drawing 7 is picked up in the grounding system and provide grounding grid drawing. 3) Explain conductors ran in open air off of generators ASCO drawing 1 and provide generator cut sheets. 4) Provide room layout for generator G1. 5) Explain locomotive cables from generator to main breakers. 6) Verify that conduits running underground contain conductors listed for wet location. 7) Someone with knowledge of this installation to appear at next meeting.						
51177CO		Liphill Electrical Contractors Inc. 4850 White Plains Road, 2nd Floor Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	Kings Hotel 2416 Atlantic Avenue Brooklyn NY	Hold	\$0.00
Carry over from April 18, 2012 meeting. Comments are not corrected need 5' clearance, and wider door.						
51194CO		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Brooklyn Army Terminal 5803 1st Avenue Brooklyn NY	Approved	\$0.00
Carry over from April 18, 2012 meeting. 1) Provide physicals of all equipment in Advisory Board format showing side views. 2) Someone who knows job to appear next meeting 3) Verify that all clearances comply with 110.34. 4) Transformer to have DOE energy efficiency indicate concrete encased service for Con ED service conductors. Job finalized 8/2/12. 9/26/14 Swapped 1 and 2, Rev 1.						
51221CO		NJS Electrical Service Corp. 36-16 13th Street Long Island City NY 11106	Requesting permission to use a second utility source as alternate power source in lieu of a generator to supply power to a limited service fire pump.	555 5th Avenue New York NY	Hold	\$0.00
Carry over from April 18, 2012 meeting. DOB inspector to visit the job site to determine that there is lack of space to install a new service switch.						
51226		P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	New York University 21 Washington Place New York NY	Hold	\$650.00
1) Fire pump emergency disconnect switch to be grouped together with the other transformer disconnect switches. 2) Transformer on MDB-CG board neutral not grounded to building steel on system grounding electrode. 3) Verify that ATS 2 does not feed life safety. 4) Secondary devices rating (Total) are not in compliance with 450 requirement including fire pump load (secondary OCPD).						

ADVISORY BOARD CALENDAR

May 2, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51227		Accurate Electrical Corp. 4319 18th Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	Paramount Hotel 235 West 46th Street New York NY	Approved	\$650.00
1) Verify that the neutral is bonded to the enclosure of the 3000 amp service switch. 2) Vertical bus in section containing 1-800 and 2-400 switches is undersized. 3) Correct job address in title block. 12/20/13 3rd drawing submitted with address as 235 West 46th Street. Called contractor and requested correct address and letter if required. Googled address is 235. 1/21/14 Address correction to 235 West 46th Street, Manhattan. 4/16/14 Revision 4 Swapped 4 Swapped. Revision 3 was for address correction.						
51228		Big Shot Electric Corp. 710 East 135th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	St. Hilda's & St. Hugh's 619 West 114th Street New York NY	Approved	\$650.00
Verify that new section has rear doors. Job finalized 6/18/12.						
51229		Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Vasinee Food Corporation 1247 Grand Street Brooklyn NY	Approved	\$650.00
51230		Kramer Electric, LLC 336 West 37th Street, Suite 510 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	The Puck Building 295 Lafayette Street New York NY	Denied	\$650.00
1) All new work to be bubbled on drawings, including feeders and service entrance. 2) Provide cut sheet of new Con Ed end box. 3) Are feeders new or existing to existing service? 4) Existing feeder sizes not provided. 5) Lengths of taps not provided, wire size of taps not provided. 6) Switch sizes not provided in SS-3A and SS 4A. 7) Show clearances between service end box and new CT to elevator panel.						
51231		Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	NYU/Bellevue Hospital Center 462 First Avenue New York NY	Approved	\$650.00
Feeder to new ATS undersized. Job finalized 7/31/12.						

ADVISORY BOARD CALENDAR

May 2, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51232		Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	Van Cortlandt Park 5900 Broadway Bronx NY	Approved	\$650.00
1) Is service enclosed by a fence? If so show entire fence with clearance dimensions. 2) Verify that Con ED is bringing in the service lateral conductors to the CT. 3) Vertical bus feeding 2-1200 amp service switches is undersized. Job finalized 11/21/12.						
51233		Rigid Electric, Inc. 336 37th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	HSS 525 East 71st Street New York NY	Approved	\$650.00
51234		BT Electrical, Inc. 85-02 67th Drive Rego Park NY 11374	Requested approval for the electric service equipment proposed to be installed	235 West 71st Street New York NY	Approved	\$650.00
51235		Avalon Electric Corp. 3632 Kingsbridge Avenue Bronx NY 10463	Requested approval for the electric service equipment proposed to be installed	770 Garrison Avenue Bronx NY	Approved	\$650.00
Verify that installation complies with 690.64(B)(2) requirement. Job finalized 8/3/12.						
51236		Cedar Electrical Contractors, Inc. 64 Fulton Street, Suite 692 New York NY 10038	Requested approval for the electric service equipment proposed to be installed	26 Little West 12th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 2, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51237		Cedar Electrical Contractors, Inc. 60 Fulton Street, Suite 602 New York NY 10038	Requested approval for the electric service equipment proposed to be installed	641 6th Avenue New York NY	Approved	\$650.00
51238		Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Rockefeller University 1230 York Avenue New York NY	Hold	\$650.00
Prior submittal 50068 showing original installation is not approved by the Advisory Board. Once approved this installation will be reviewed by the board but the coordination study must include these new switches.						
51239		P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	New York University 111 Second Avenue New York NY	Approved	\$650.00
Neutral conductor in fire pump service switch to be bonded to the enclosure. Job finalized 5/8/12.						
51240		Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	The Laurel 400 East 67th Street New York NY	Approved	\$650.00
Verify clearances in front of AP-C3-5 and AP-C3 or relocate them. Job finalized 5/8/12.						
51241		Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	NYU-Steinhardt-Cellar 35 West 4th Street New York NY	Approved	\$650.00
4 pole ATS required. Job finalized 9/18/12.						

ADVISORY BOARD CALENDAR

May 2, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51242		C.M. Richey Electrical Contractors 57-10 65th Street Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	One Fordham Plaza Bronx NY	Approved	\$650.00
1) Service entrance conductors feeding new service switch not shown. 2) Fire alarm feed tapped after service switch. 3) Verify that 2000 amp service switch has rear doors. Job finalized 6/4/12.						
51243		Stanco Systems Electrical Contracting Inc. 4061 Victory Boulevard Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	220 East 42nd Street New York NY	Approved	\$650.00
51244		JSP Electrical Contracting Corp. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Kips Bay 542 Second Avenue New York NY	Approved	\$650.00
Service switch 6B not shown on drawing. Job finalized 6/4/12.						
51245		H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Isreal Discount Bank 511 Fifth Avenue New York NY	Denied	\$650.00
Through bus phase and neutral undersized.						
51246		Hatzel & Buehler, Inc. 45 Broadway, Suite 1240 New York NY 10006	Requested approval for the electric service equipment proposed to be installed	820 Washington Street New York NY	Approved	\$650.00
Service entrance conductors undersized, verify 16 conductors are supplied by Con-Ed. Job finalized 6/4/12.						

ADVISORY BOARD CALENDAR

May 2, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51247		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	388 Bridge Street Brooklyn NY	Approved	\$650.00
1) Show sized of service bus in Switchboard "A". 2) Verify 5' clearance in front of service switch 1A. 3) Provide neutral disconnect link on 480 volt board. 4) 'show size of bonding jumper on secondary of transformer. Job finalized 6/4/12.						
51248		DeFalco Electric 32-26 Greenpoint Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	450 West 14th Street New York NY	Approved	\$650.00
Verify that new distribution board has rear doors. Job finalized 6/21/12.						
51249		Tanachion Electrical Contracting, Inc. 1562 Richmond Road, Suite 2B Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Amboy Road Strip Mall 4366 Amboy Road Staten Island NY	Approved	\$650.00
3 sets of 300 MCM overfused. Job finalized 6/21/12.						
51250		Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Solow 9 West 57th Street, 4th Floor New York NY	Approved	\$650.00
1) 6 sets of 700 MCM feeders overfused. 2) Verify life safety disconnects are not in same section as non life safety. Job finalized 9/18/12.						
51251		QEC Electrical Service Corp. 1394 Ogden Avenue Bronx NY 10452	Requesting permission to leave a new service switch installed on the wall outside of the service room due to lack of space inside of the existing service room with signage installed indicating where the other service is located	464 Saint Marks Avenue Brooklyn NY	Approved	\$350.00
Code: 230.72(A).						

ADVISORY BOARD CALENDAR

May 2, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51252		Kenneth Fisk Electric Corporation 72-02 Cooper Avenue Glendale NY 11385	Requesting permission to install outdoor branch circuits and control wiring for split system air conditioning in non metallic rigid conduit on a 2 family dwelling unit.	179 DeGraw Street Brooklyn NY	Approved	\$0.00
Code: 225.10.						
51253		Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requesting permission due to hardship to correct to tap power for the fire alarm feeder on the load side of the generator fuse and permit the tap to be made on the line side of the emergency switchboard disconnect switch.	NYU Langone Medical Center 240 East 38th Street New York NY	Denied	\$0.00
51254		Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requesting permission to replace 2 defective CTs and 5000 amp service switches without filing Advisory Board drawings.	Beth Israel Medical Center 10 Nathan D Pearlman Place New York NY	Approved	\$0.00
Code: 110.2(B). With the stipulation that supplemental grounds are installed.						
51255		AKF Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to leave as installed as per the approved drawing, campus style distribution system where a feeder enters a remote building and the fire alarm and fire pump taps are made on the line side of the buildings main disconnect switch.	Brooklyn Navy Yard 62 Flushing Avenue Brooklyn NY	Approved	\$0.00
Code: 90.2(c) Re: 50807. With the stipulation that the installation complies with Section 230.2(E) of the NYC Electrical Code. It is recommended that the 1200 amp switch located in building 30 is locked in the on position.						