

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	13A0636CO	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	371 Broadway New York NY	On Hold	\$0.00
Carry over from November 20, 2013 meeting. 1) Coordination study to be performed by a PE and stamped. 2) Who will be installing future meter bank? If by others, state if on the drawing.						
52299	13A0717CO	Net Power Electric Corp. 370 19th Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	92 Morningside Avenue New York NY	Approved	\$0.00
Carry over from January 15, 2014 meeting. 6/22/15 Swapped Drawings and coordination study 1 and 2, Rev 3s.						
52404	14A0031	C.M. Richey Electrical Contractors, Inc. 347 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	145-155 West 18th Street New York NY	Approved	\$650.00
1) 2 pole ATS used on 4 wire system. 2) Provide tap lengths. 3) ATS to be rated at 200 amps.(Typo). 7/15/14 Job finalized. 1/20/16 Swapped Drawings A-Revision 1, B-Revision-2 and C-Revision 1.						
	14A0033	Walsh Electrical Contracting Inc. 1363 North Railroad Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	L.A. Fitness Staten Island 3231 Richmond Avenue Staten Island NY	On Hold	\$650.00
1) Bonding and grounding not shown in service switch #3. 2) New feeders overfused. 3) Coordination study not provided not provided 240.12A,.						
	14A0034	EDM Electric 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1414 6th Avenue New York NY	Administrative Closure	\$650.00
1) Room layout shows 2-800 amp service switches #2. 2) Verify that emergency feeders are not installed in the service room. 3) Service switches to have 5' front clearance. 4) Fire pump equipment grounding conductors undersized line and load. 5) Verify feeder sizes to Jockey pump. 6) S.S. #1 not bonded and grounded. 7) Emergency side fire alarm switch bonded and grounded on a non separately derived systems. 8) Tap lengths off of s.s. #2 not shown, equipment grounding conductors for tapped conductors undersized. 9) Feeder sizes on load side of s.s. #4 not shown. 10) Provide main overcurrent device for panel DP-R1. 11) How will 8 sets of 600MCM terminate in 1600 amp ATS? 12) Review not complete. 7/25/14 Rejected 1) Show tap method in trough. 2) Show length of transformer tap. 3) Short circuit study to be stamped by a P.E. Note: Fire Rated Enclosures must comply with the following: 1) A.P.E. or R.A. must file a PW1 as an Alt 3. 2) A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3) The fire proofing must be performed by a certified fire proofing installer. 9/4/14 Received letter dated July 31, 2014 requesting Submission #14A0034 be rescinded immediately.						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0035	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Battery Maritime Building 10 South Street New York NY	On Hold	\$650.00
1) Show front clearances of all service equipment and verify that service room is mechanically ventilated. 2) Vertical bus in MDP-GHK board undersized and MDP-C. 3) Follow transformer secondary tap rules. 4) EGC's undersized throughout. 5) Feeders overfused throughout. 6) MDP-GIPEC and MDP-DOT require main OCPD. 7) ESSB panel overfused. 8) Where is FP transformer located? 9) Coordination study not provided. 10) Review not complete.						
52301	14A0090	Surge Suppression Inc. 10 Melvin Street Destin FL 32541	Requested approval for use in New York City of your Surge Protection Devices		Approved	\$200.00
	14A0115	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Stapleton Waterfront 8 Navy Pier Court Staten Island NY	On Hold	\$650.00
1) Service room doors to open outwards w/panic hardware. 2) MDB-1 SS#2 overfused and equipment grounding conductors are undersized; tap lengths not shown and may be undersized. 3) Fire alarm feeder conductors misidentified, remove 30 amp FA switch on load side of ATS, remove neutral bonds on 30 amp switches on load side of transformer, secondary show lengths of transformer secondary taps. 5) Note says generator "Not a separately derived system" but neutrals are bonded to enclosure. 6) Equipment grounding conductors undersized throughout drawing 1 of 9. 7) Drawing 2 of 9 EGC's undersized. 8) Tap lengths not shown. 9) 800 amp service switch #1 not bonded or grounded. 10) Length of transformer taps not shown and supply more than 6 OCPD's. 11) Panel RDB-E has no main. 12) Drawing 3 of 9 generator same as comment #5 above. 13) Same as comment #4 above. 14) Coordination study not provided. 15) All future submittals to be reviewed by submitter prior to submitting to Advisory Board. 16) Review not complete.						
	14A0116	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	245 West 17th Street New York NY	Rejected	\$650.00
1) New tap conductors are undersized and length of tap is not shown. 2) Beyond 2nd fuse. Outgoing feeder from new 1200A switch undersized. 6/19/14 Job finalized. 9/16/14 Swapped drawings 1 and 3, Rev 1. 1/30/15 Rejected. Equipment grounding conductors on line and load side of 1200 amp switch are undersized, tap length not shown.						
52334	14A0135	R.C.M. Electric Corp. 1915 McDonald Avenue Brooklyn NY 11223	Requesting permission due to lack of space inside of the building to leave as installed service equipment installed on the outside wall where the service switches will not be grouped together.	Crafthouse 60 Van Duzer Street Staten Island NY	Approved	\$0.00
With the stipulation that signage is provided at each service location indicating where the other service is located.						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52302	14A0140	Megaris Electrical Contracting Corp. 10-01 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	40-22 College Point Blvd. College Point NY	Approved	\$650.00
<p>1) Correct address, there is no 133-40 79th Street in Brooklyn. 2) Verify 36 sets of service entrance conductors. 3) Provide neutral links in service switches. 4) Provide bus sizes in service switches over 1200 amps. 5) Fire pump feeder undersized. 6) Provide supplemental ground. 7) Provide details 11,000 SEB. 9/8/14 Rejected for 9/10/14 carryover. 1) Service entrance conductors undersized. 2) Explain next to Con Ed manhole M14 feeding adjacent building? 11/6/14 Job finalized. 4/7/15 Swapped Drawing 1, Revision 3. 6/23/15 Swapped Revision 5. 8/18/15 Swapped drawing 1, Revision 6. Next change will require a new submittal.</p>						
52610	14A0153	Jay Helfgott Electric Corp. 220 Ashford Street Brooklyn NY 11207	Requested approval for the electric service equipment proposed to be installed	78-04 South Conduit Avenue Queens NY	Approved	\$650.00
<p>1) Correct address, there is no 133-40 79th Street in Brooklyn. 2) Verify 36 sets of service entrance conductors. 3) Provide neutral links in service switches. 4) Provide bus sizes in service switches over 1200 amps. 5) Fire pump feeder undersized. 6) Provide supplemental ground. 7) Provide details of 11,000A SEB. 9/8/14 Rejected for 9/10/14 carryover. 1) Item #7 not addressed, cut sheet for SEB does not match 1 Line. 2) Bus in 2000 amp service switch #5 undersized. 3) Item #5 not addressed. 4) Item #6 not addressed. 5) Verify 16 sets of service entrance conductors. 11/6/14 Carry no good for 11/19/14 meeting for the following reasons: 1) Service entrance conductors undersized. 2) Tap conductors to 400 and 800 trans S switches undersized. 3) Verify 4-1/4x4 bus size in 1600 amp service switch #2.</p>						
	14A0154	Jay Helfgott Electric Corp. 220 Ashford Street Brooklyn NY 11207	Requested approval for the electric service equipment proposed to be installed	79-60 South Conduit Avenue Queens NY	Rejected	\$650.00
<p>1) Correct address, there is no 133-40 79th Street in Brooklyn. 2) Verify 36 sets of service entrance conductors. 3) Provide neutral links in service switches. 4) Provide bus sizes in service switches over 1200 amps. 5) Fire pump feeder undersized. 6) Provide supplemental ground. 7) Provide details of 11,000A SEB. 9/8/14 Rejected for 9/10/14 carryover. 1) Item #7 not addressed, cut sheet for SEB does not match 1 Line. 2) Bus in 2000 amp service switch #5 undersized. 3) Item #5 not addressed. 4) Item #6 not addressed. 5) Verify 16 sets of service entrance conductors. 11/6/14 Carry no good for 11/19/14 meeting for the following reasons: 1) Service entrance conductors undersized. 2) Tap conductors to 400 and 800 trans S switches undersized. 3) Verify 4-1/4x4 bus size in 1600 amp service switch #2.</p>						
	14A0163	Team Electric, Inc. 20 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Gods Love We Deliver 166 Avenue of the Americas New York NY	On Hold	\$650.00
<p>1) Coordination study not provided. 2) Show type of ATS being installed. 3) Equipment grounding conductors undersized. 4) Fire pump emergency feeder to be fire rated. 5) Emergency feed to fire pump to be ahead of generator main. 6) No emergency source for fire alarm. 7) Fuse too large in normal feed to fire pump.. 8) Jockey pump tap cannot be in controller, 9) On floor plan f.p. switch shown as 600A. One line show 1200A.</p>						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0164	Interphase Electrical Corp. 5304 Seventh Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Pier 40 353 West Street New York NY	Denied	\$650.00
1) 1 Line does not match room layout, no FP tap section taps made in CT's. 2) Fire pump feeder conductors to be fire rated. 3) Remove FA switch off load side of ATS. 4) Main switchboard bus density to comply with 110.2B and Table 230.42, show bus size in generator 2000 amp switch and 2000 amp switch in main switchboard. 5) Coordination study not provided by a PE and stamped. 6) Sequence of Operation not provided. 7) Block off rear of switchgear. 8) F.A. ATS cannot be located in service room. 9) Generator disconnect switch to comply with 700.6F. 10) Verify clearances between transformers for ventilation.						
52534	14A0168	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	121-16 Roosevelt Avenue Flushing NY	Approved	\$650.00
Equipment grounding conductor undersized for new feeder to new panel. 6/19/14 Drawing 1 of 2 not corrected. 9/22/14 Job finalized.						
52353	14A0191	Arch Electric Inc. 42-44 Crescent Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	333 West 52nd Street New York NY	Approved	\$650.00
1) Verify that fuses for the elevator systems are coordinated. 2) Verify that all remote service switches are bonded and grounded. 3) New service switch be relocated to end of distribution equipment or to outside of the service room. 5/22/14 Job finalized.						
52348	14A0199	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	PS 320Q 360 Seneca Avenue Queens NY	Approved	\$650.00
Verify sizes of vertical bus in MDB. 5/19/14 Job finalized.						
52733	14A0200	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	11-05 30th Road Queens NY	Approved	\$650.00
1) Incoming AIC not shown. 2) Show short circuit current at meter banks. 3) 800 to 200 amp fuse don't coordinate. 11/24/14 Rejected Item #3 not addressed. 1/9/14 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/15/15 Swapped drawings 1 and 2, Revision 4s.						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52440	14A0202	Einstein Electrical Corporation 42-16 28th Avenue Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	Birchwood Apartments 102-10 66th Road Queens NY	Approved	\$650.00
1) Verify with utility the installation of CT in the end box of provide documentation. 2) Provide cut sheet of end box w/CT and listing by NRTL. 3) Provide cut sheet of cogen showing its listing. 7/22/14 Job finalized. 9/10/15 Swapped Drawing 1-Revision 2.						
52439	14A0203	Einstein Electrical Corporation 42-16 28th Avenue Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	Birchwood Apartments 102-30 66th Road Queens NY	Approved	\$650.00
1) Verify with utility the installation of CT in the end box of provide documentation. 2) Provide cut sheet of end box w/CT and listing by NRTL. 3) Provide cut sheet of cogen showing its listing. 7/22/14 Job finalized.						
52351	14A0204	Dooley Electric Co., Inc. 4014 Third Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Lenox Hill Hospital 100 East 77th Street New York NY	Approved	\$650.00
1) 2nd level of ground fault protection required on bus duct. 2) Verify that trough is bonded on each side. 5/21/14 Job finalized.						
52303	14A0205	AMA Consulting Engineers, P.C. 250 West 39th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Lobster Place 75 Ninth Avenue New York NY	Approved	\$650.00
OR						
52304	14A0206	Inner City Electrical Contractors, Inc. 160 21st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	366 5th Avenue New York NY	Approved	\$650.00
OR						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52305	14A0208	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	ABC-TV 330 West 66th Street New York NY	Approved	\$650.00
OR						
	14A0209	Top Shelf Electric Corporation 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Brooklyn Bridge Pier House 90 Ferman Street Brooklyn NY	On Hold	\$650.00
<p>1) Incoming AIC not shown. 2) Show bus sizes in service switches and distribution panels. 3) Bonding and grounding not shown. 4) Neutral links not shown. 5) 2nd fusing to be shown unless work will be done by others must be noted on drawing. 6) Fire pump emergency feeder overfused and fire rated. 7) Equipment ground conductors undersized. 8) Fire alarm emergency supply to be separated from other OCPD's. 9) Provide cutsheet for generator and distribution panel showing it is listed as a complete assembly. 10) Show sizes of main bonding jumpers in switchboards. 11) Provide coordination study from a PE with stamp. 12) Garage panel not shown. 13) Review stopped.</p>						
52306	14A0210	Konsker Electric Corp. 35-40 36th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Fendi 598 Madison Avenue New York NY	Approved	\$650.00
OR						
52307	14A0211	NY Electric 1370 Broadway, Suite 820 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 Fifth Avenue New York NY	Approved	\$650.00
OR 7/31/14 Swapped A-Revision 1.						
52308	14A0212	JMC Electrical Corp. 172-02 39th Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	827 East 92nd Street New York NY	Approved	\$650.00
OR						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52309	14A0213	Lilker Associates Consulting Engs, PC 1001 Avenue of the Americas New York NY 10018	Requesting permission to install a replacement 800 amp service switch that will have a front clearance of 4 feet.	608 5th Avenue New York NY	Approved	\$350.00
Code: 230.64(B)(1).						
52727	14A0214	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	10 Waterside Plaza New York NY	Approved	\$0.00
SANDY 1) Verify that all service equipment has rear doors. 2) Provide cut sheet for 550 KCM conductor showing it is listed for dual rating to be installed in conduits. 3) Show FLA of fire pump. 4) Explain how one transformer can be used while the other is not. 1/8/15 Job finalized. 9/15/15 Swapped drawings AB40 1 of 3, Revision 4; AB40 2 & 3, Revision 2s; SB41-1, Revision 1; SB40 1,2 and 3, Revision 2s.						
52741	14A0215	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	30 Waterside Plaza New York NY	Approved	\$0.00
SANDYSANDY 1) Provide cut sheet for 550 KCM conductor showing it is dual rated to install in conduit. 2) Block off rear of switchboards.. 4) Explain how one transformer can be used while the other is not. 1/12/15 Job finalized.. Note: Electrical contractor to size bonding jumpers on feeders as per Table 250.122 on open bottom switchboards. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/14/15 Rejected drawing AB40 1 of 3. 1) Wiring method not shown, size of conduit. 2) Transformer overfused length of secondary tap not shown. 3) 200 amp switch reversed. 2/16/16 Item #2 not addressed, 75KVA transformer. 5/23/16 Swapped drawings AB 1 of 3-Revision 5, AB 2 of 3-Revision 3, AB 3 of 3-Revision 2. 1/4/17 Swapped drawings FP-1-Revision 3, AB1-Revision 7 and AB3-Revision 3.						
52521	14A0216	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	55 Water Street New York NY	Approved	\$650.00
1) 2000 amp service switch are overfused. 2) Elevator OCPD's to be selectivity coordinated, show fuse types in panelboards. 9/15/14 Job finalized.						
52920	14A0217	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	250 Vesey Street New York NY	Approved	\$650.00
Fuses do not coordinate.3/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52384	14A0218	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	19 Park Place New York NY	Approved	\$650.00
Show short circuit current at meter banks. 6/19/14 Job finalized.						
	14A0219	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	961 First Avenue New York NY	On Hold	\$650.00
1) Show the front of 400 amp trans S and its front clearance. 2) Electrical equipment in service room not identified. 3) 1200 amp s.s. not identified in service room and 1 line. 4) Length of taps off of 1200 amp s.s. not shown. Where are the disconnect switches located? 5) Provide length of transformer secondary tap. 6) Provide cut sheet and listing of generator and its switchboard, frame to be grounded. 7) 4 pole ATS used on a non separately derived system. 8) Review not complete.						
52310	14A0221	GRX Electric Corporation 8 West 38th Street, Suite 804 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	33-10 Woodside Avenue Queens NY	Approved	\$650.00
9/16/14 Swapped Drawing 1, Revision 1.						
52311	14A0223	Team Electric, Inc. 20 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Xavier High School 30 West 16th Street New York NY	Approved	\$650.00
OR 2/22/16 Swapped drawing 1 of 2, Revision 1.						
52312	14A0224	Bay Electric Inc. 876 Jamaica Avenue Brooklyn NY 11208	Requested approval for the electric service equipment proposed to be installed	Albert Einstein College of Med. 1300 Morris Park Avenue Bronx NY	Approved	\$650.00
OR						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52313	14A0225	Hatzel & Buehler, Inc. 230 Park Avenue, Suite 925 New York NY 10169	Requested approval for the electric service equipment proposed to be installed	200 Vesey Street New York NY	Approved	\$650.00
52314	14A0226	Polo Electric Corp. 497 Canal Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	180 Maiden Lane New York NY	Approved	\$0.00
SANDY 3/24/15 Swapped Drawing 1 of 2, Revision 1.						
52315	14A0228	A & R Electrical Maintenance, Inc. 85-47 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	36-29 White Plains Road Bronx NY	Approved	\$650.00
3/30/15 Swapped drawing 1 of 3, Revision 2.						
52385	14A0229	& D Electrical Construction Company, In 31 Beadl Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	117-129 East 85th Street New York NY	Approved	\$650.00
1) Verify that new service room is fire rated. 2) 5' clearance required in front of service switch. 6/19/14 Job finalized. 9/14/15 Rejected 1) New work is not bubbled as original submission. 2) Neutral link is in wrong location. 3) Provide short circuit curves for fuse changes by a P.E. bearing the stamp. 4) Show changes on drawing 2 of 3. 9/26/16 Swapped drawings 1,2 and 3-Revision 3.						
52316	14A0232	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	350 Park Avenue New York NY	Approved	\$650.00
OR						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52317	14A0233	Rockmor Electric Enterprise, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Megar Evers 1650 Bedford Avenue Brooklyn NY	Approved	\$650.00
OR						
52318	14A0234	Forest Brook Electrical Contractor, Inc. 2217 Avenue X Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	1535 3rd Avenue New York NY	Approved	\$650.00
	14A0235	Demand Electric, Inc. 230 49th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	The Arthur Avenue Residence 600 East 181st Street Bronx NY	Rejected	\$650.00
Fuse too large feeding fire pump. 5/22/14 Job finalized. 7/23/14 Rejected Drawing 16269-2 shows Revision 2 but there are no changes noted in the title block.						
52390	14A0236	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New York Times College Point Facility College Point NY	Approved	\$650.00
Coordination study to be performed and stamped by a PE. 6/20/14 Job finalized.						
	14A0239	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	NYU Infrastructure Project 435 East 30th Street New York NY	Pending	\$0.00
SANDY Verify new work on 1 Line drawings, there are feeders out of the new switchgear with notes stating "under separate contracts" and some feeders without notes, clarify.						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52319	14A0240	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Magnum Real Estate 140 West Street New York NY	Approved	\$650.00
	14A0241	Fresh Meadow Electrical Contractors, LLC 65-01 Fresh Meadow Lane Fresh Meadows NY 11365	Requested approval for the electric service equipment proposed to be installed	Chiller Upgrade Project 400 Park Avenue New York NY	Administrative Closure	\$650.00
4/25/14 Job submitted in error by contractor. Contractor submitted e-mail stating cancellation of job.						
52320	14A0242	Delta Star Electric Inc. 11-25 Broadway Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Chelsea Arts Tower 545 West 25th Street New York NY	Approved	\$650.00
9/23/14 Swapped drawing Revision 1.						
52321	14A0243	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	Vendors Market Apartments 27 Albany Avenue Brooklyn NY	Approved	\$650.00
52322	14A0244	East Bay Electrical Services Corp. 3300 Northern Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	33-00 Northern Blvd. Long Island City NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52323	14A0245	A.C. Morgan Electric 3601 Riverdale Avenue Bronx NY 10463	Requested approval for the electric service equipment proposed to be installed	208 Delancey Street New York NY	Approved	\$650.00
52393	14A0246	Maximum Electric Corp. 65-19 Metropolitan Avenue Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	470 West End Avenue New York NY	Approved	\$650.00
Provide coordination study by P.E. and stamped. 6/20/14 Job finalized.						
52324	14A0247	Horsepower Electric 188 21ST Street, 2nd Floor Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	15 Renwick Street New York NY	Approved	\$650.00
52325	14A0248	FSM Electrical Corp. 36-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Marmara Park Avenue Hotel 114 East 32nd Street New York NY	Approved	\$650.00
12/23/16 Swapped drawing 1-Revision 2.						
52326	14A0249	Cedar Electrical Contractors, Inc. 64 Fulton Street New York NY 10017	Requested approval for the electric service equipment proposed to be installed	60 West 57th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52327	14A0250	Allstate Electrical Group 120 West 31st Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	570 7th Avenue New York NY	Approved	\$650.00
7/23/14 Swapped Rev 1.						
52328	14A0251	K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	250 West 94th Street New York NY	Approved	\$650.00
52329	14A0252	Electrical Design Management, LLC 939 Eighth Avenue, Suite 301 New York NY 10019	Requested approval for the electric service equipment proposed to be installed	657 Morgan Avenue Brooklyn NY	Approved	\$650.00
52330	14A0253	Bass Electrical Corp. 10-17 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	300 North Henry Street Brooklyn NY	Approved	\$650.00
OR						
52331	14A0254	RX Electric Inc. 40-24 22nd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	151 West 46th Street New York NY	Approved	\$650.00
OR						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0255	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	552 West 24th Street New York NY	Pending	\$650.00
1) Not 1000KVA installation. 2) Service switches not identified in service room. 3) Equipment grounding conductors undersized. 4) Jockey pump overfused. 5) Remote service switches to be grounded. 6) Panel BD-PR not shown. 7) Verify that emergency feeders are not installed in the service room.						
	14A0256	A & M Electrical Service Inc. 617 Johnson Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1770 Madison Avenue New York NY	Rejected	\$650.00
1) Show short circuit current at meter bank. 2) Show OCPD type at meter banks. 8/28/14 Job finalized. 9/20/15 9/30/15 Rejected. New revisions are show as revision 0. They shall say revision 2. 11/4/15 Rejected. 1) Provide letter from utility showing correct fault current. 2) Bus sizes are missing on drawing. 3) Equipment grounding conductor for fire pump feeder undersized. 4) Switch sizes not shown in switchboard. 5) Provide cut sheets of meter bank circuit breakers. Review not complete, new submittal required.						
	14A0257	A & M Electrical Service Inc. 617 Johnson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	Triangle Plaza 459 East 149th Street Bronx NY	Rejected	\$650.00
Feeding to HDP panelborad overfused. 6/20/14 Job finalized. 10/6/15 Rejected Swap is using different manufacturer elevation has conflict with single line. New submittal is required.						
52332	14A0258	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	DC37 125 Barclay Street New York NY	Approved	\$650.00
52333	14A0260	Arch Electric Inc. 42-44 Crescent Street Long Island City NY 11101	Requesting permission due to lack of space outside of the elevator shaftway, to install a new elevator feeder fo fire rated MI cable inside of the elevator shaftway	333 West 52nd Street New York NY	Approved	\$350.00
Code: 620.11(c) and 620.37.						

# ADVISORY BOARD CALENDAR

**May 7, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0380	Hatzel & Buehler, Inc. 45 Broadway, Suite 1240 New York NY 10006	Requested approval for the electric service equipment proposed to be installed	60 Hudson Street New York NY	On Hold	\$650.00
1) Submit S.C. and coordination study. 2) Provide equipment submittals from manufacturers-Reactor-Neutral grounding resistors-15KV switches. 3) 480V system to be 3-wire. 6/30/14 1) Provide 2 full size drawings of SSL-9198 sheet 1 of 4. 2) Coordinate study not provided.						