

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45356CO2	03A0652CO2	Qncc Electrical Contracting Corp. 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Jacobi Medical Center  Bronx NY	Approved	\$0.00
Carryover from December 17, 2004 meeting.						
45388CO	03A0683CO	Gartech Electrical Contracting Corporation 4120 Baychester Avenue Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	DEP Spring Creek Project Flatlands Avenue Brooklyn NY	Denied	\$0.00
Carryover from December 17, 2003 meeting. 1) Key interlocking scheme was not provided. 2) The type of barriers was not provided. 3) Selectivity curves for the circuit breakers was not provided. 4) The drawings were not submitted in an Advisory Board format.						
45413CO	03A0700CO	DTE Energy Technologies 37849 Interchange Dr. Farmington Hills NY 48335	Requested approval for use in New York City of your Natural Gas-ENI 830; Diesel-ENR 750.		Approved	\$0.00
Carryover from December 17, 2003 meeting.						
45419CO2	04A0017CO2	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Random House 235 West 55th Street New York NY	Hold	\$0.00
Carryover from January 14, 2004 meeting.						
45442CO2	04A0024CO2	Electric Light & Power, Inc. 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Atlantic Terminal 139 Flatbush Avenue Brooklyn NY	Hold	\$0.00
Carryover from February 18, 2004 meeting. 1) Provide 2nd egress from generator enclosure. 2) ATS-6-1 undersized. 3) Show fire pump information. 4) FCO not permitted at 480V. 5) Switch and fuse required for fire alarm FBR, not circuit breaker. 6) Generator breakers should not have GFP. 7) Short circuit calculations.						

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45446CO	04A0028CO	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Greater NY Automobile Dealership 20th Avenue & 141st Street Whitestone NY	Approvd	\$0.00
Carryover from February 18, 2004 meeting.						
45585CO	04A0142CO	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Dept. of Environ. Protection 593 East 132nd Street Bronx NY	Hold	\$0.00
Carryover from April 14, 2004 meeting.						
45586CO	04A0143CO	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Dept. of Environ. Protection 432 East 110th Street New York NY	Hold	\$0.00
Carryover from April 14, 2004 meeting. Not reviewed.						
45610CO	04A0167CO	Schlesinger Electrical Contractors, Inc. 664 Bergen Street Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	930 Flushing Avenue Brooklyn NY	Approved	\$0.00
Carryover from April 14, 2004 meeting.						
45622CO	04A0174CO	Bretford USA 11000 Seymour Avenue Franklin Park IL 60131	Requested approval for use in New York City of your Power and Data delivery system for office, training and library environments "Liquid" M-SUB, MCH-P, MCH, M-SPT, MCJ, MSB-F, MSP-F, MSB-W, MSP-W, MSB-C, MSP-C, MPD, MDX and MSP.		Approved	\$0.00
Carryover from April 14, 2004 meeting						

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45626	04A0182	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Story Avenue H.S.  Bronx NY	Hold	\$650.00
1) Provide Con Ed short circuit current. 2) Size bus per New York City Electrical Code. 3) Show bus size on vert. bus in group mounted sections. 4) Clarify fuse cutouts for fire alarm feeds. Are they FCO's or sw/CB's? 5) Indicate generator grounding and 3p/4p ATS.						
45627	04A0181	The Sound Beyond Electrical Corp. 134 West 29th Street-11th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Bklyn Dis. Sanitation 161 Varick Street-Garages 1 and 4 Brooklyn NY	Hold	\$650.00
1) Multiple fire alarm disconnects not permitted. Provide FCO on secondary of F.A. XFMR. 2) Verify cable size for jockey pump feed. 3) Provide details of MDSA per title block. Drawing shows MDSI. 4) Provide room layout.						
45628	04A0180	Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	452 5th Avenue New York NY	Ok, but	\$650.00
1) Provide Con Ed short circuit current. 2) Provide drawing of new 800A panel.						
45629	04A0179	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requested approval for the electric service equipment proposed to be installed	325 North End Avenue New York Ny	Approved	\$650.00
1) Bus bar undersized in panel 'RDP'. 2) No coordination 1800A-1200A fuses. 3) Correct fuse size in 200A switch tapped from retail trough. 4) Provide Con Ed short circuit current.						
45630	04A0207	Hugh O Kane Electric Co., LLC 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Pfizer, Inc.-Utility Plant 630 Flushing Avenue Brooklyn NY	Ok, but	\$650.00
1) Provide system one-line diagram. Show connections 1st and 2nd fuse. 2) Provide and indicate correct bus bar sizes per New York City Electrical Code.						

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45631	04A0204	High-Tech Electrical Services Corp. 36-33 23rd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Affinity Health 2500 Halsey Street Bronx NY	Approved	\$650.00
45632	04A0202	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	One World Financial Ctr. 200 Liberty Street-Penthouse Level New York NY	Approved	\$650.00
45633	04A0199	Classic Electric, Inc. 29-05 21 Avenue Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Hazel Towers 1730 Mulford Avenue Bronx NY	Ok, but	\$650.00
1) Confirm induction generator only support 3 phase balanced loads. 2) Confirm fuse type; ratings in Siemens 100A switches. 3) Orient fusible switches with fuses on load side.						
45634	04A0221	Interphase Electric Corp. 16 Garfield Place Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Queen Hospital OCME Bldg. 160-52 82nd Drive Jamaica NY	Hold	\$650.00
1) Provide bus bar sizing per New York City Electrical Code. 2) Emergency fire pump breaker must tap line side of generator main.						
45635	04A0215	Tarasis Electric Corp. 36-08 Ninth Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	27 Murray Street New York NY	Hold	\$650.00
1) Jockey pump tap should be on line side of fire pump controller. 2) No coordination 1200 thru 800A fuses. 3) Provide justification for use of 65KA rated meterbanks. 4) 7 service switches-code violation. 5) Provide fuse types suitable for voltage.						

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45636	04A0205	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Int'l Airport Ctrs Bldg "A" 230-19 Rockaway Boulevard Springfield Garden NY	Approved	\$650.00
45637	04A0237	Fred Geller Electrical Inc. 37-32 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Four Times Square New York NY	Approved	\$650.00
45638	04A0236	Five Star Electric Corp 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Newtown Creek WPCP 329 Greenpoint Avenue Brooklyn NY	Ok, but	\$650.00
1) Barriers between switchboard sector. 2) Coordination study.						
45639	04A0233	Sure Electrical Contracting Corp. 3836 Richmond Avenue Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	52 Duane Street New York NY	Approved	\$650.00
Correct drawing 200A extg switch shown reversed. 8/23/04-Approval granted,						
45640	04A0178	Dal Electrical Corporation 5910 11th Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Friends Seminary 222 East 16th Street New York NY	Ok, but	\$650.00
1) 1200A feeder undersized. 2) Service conductors outside switchboard room should be concrete encased. 3) Provide Con Ed short circuit current.						

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45641	04A0177	Dooley Electric Co., Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	St. James Church 865 Madison Avenue New York NY	Ok, but	\$650.00
1) Provide bus bar sizing per New York City Electrical Code. 2) Fire pump FDR should be fire rated. 3) Provide clearances around distribution switchboard per New York City Electrical Code.						
45642	04A0209	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Home Depot Infrastructure 731 Lexington Avenue New York NY	Approved	\$650.00
45643	04A0224	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	State of NY Dept. of Trans. 28-11 Queens Plaza North Long Island City NY	Ok, but	\$650.00
Justify 65KA rating on new panel.						
45644	04A0225	Uptown Electric, Inc. 5-28 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Pergament Properties Richmond Ave. & Platinum Avenue Staten Island Ny	Ok, but	\$650.00
Size bus bars on line side of service switches per New York City Electrical Code.						
45645	04A0226	Solar Electric System Inc. 452 West 55th Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Duane Hall at Fordham Univ. 441 East Fordham Road Bronx Ny	Hold	\$650.00
1) Provide plan of XFMR vault and site plan of area where 5KV tie is provided. 2) Provide submission for new 5KV switchgear. 3) Secondary feeder on secondary of 500 KVA XFMR undersized.						

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45646	04A0227	S.A.L. Electric Corporation 69-63 75th Street Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	NYCHA Harlem Riverhouses 2580 Frederick Douglas Blvd. New York NY	Ok, but	\$650.00
1) Block off access to rear of service switchboard. 2) Correct notes to reflect current code.						
45647	04A0228	Sure Electrical Contracting Corp. 3836 Richmond Avenue Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	2800 Victory Blvd. Staten Island NY	Approved	\$650.00
1) Provide Con Ed short circuit current. 2) Provide min 36" clearance on side of 5kv switch.						
45648	04A0231	Cobra Electric Corp. 18-17 42nd Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Manhattan Town House Equity 309 West 118th Street New York NY		\$650.00
45649	04A0232	Cobra Electric Corp. 18-17 42nd Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Rosa Park Condominium 163 St. Nicholas Avenue New York NY	Approved	\$650.00
45650	04A0240	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Associated Press 450 West 33rd Street New York NY	Approved	\$650.00
1) Provide coordination curves; breakers settings. 2) Correct voltage on drawing. 3) Provide info on rear access. Job finalized 02/18/09.						

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45651	04A0191	Tri-Power Engineering, LLC 488 Schooley's Mountain Hackettstown NJ 07480	Requested approval for the electric service equipment proposed to be installed	555 Park Avenue New York NY	Approved	\$650.00
45652	04A0190	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	300 West 20th Street New York Ny	Approved	\$650.00
45653	04A0189	Pros Automated Electrical Construction Co 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	485 Fifth Avenue New York NY	Approved	\$650.00
45654	04A0188	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	304 West 117th Street New York NY	Approved	\$650.00
45655	04A0187	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	435 Hudson Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45656	04A0186	Cabin Electric Inc. 77 Commerce Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	140 West 57th Street New York NY	Approved	\$650.00
45657	04A0185	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	6910 Avenue U Brooklyn NY	Approved	\$650.00
45658	04A0184	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	666 3rd Avenue New York NY	Hold	\$650.00
45659	04A0222	P & M Electrical Contracting Corp. 1921 McDonald Avenue Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	233 Schermerhorn Street Brooklyn NY	Approved	\$650.00
45660	04A0192	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	119 East 23rd Street New York NY	Ok, but	\$650.00
Where is fire pump located?						

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45661	04A0238	Schlesinger Electrical Contractors, Inc. 664 Bergen Street Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	40 5th Avenue New York NY	Approved	\$650.00
45662	04A0203	Platinum Electrical Service 588 Broadway-Suite 205 New York NY 10012	Requested approval for the electric service equipment proposed to be installed	Archipelago 65 Broadway New York NY	Approved	\$650.00
45663	04A0201	Consolidated Electric Construction Co. 205 East 42nd Street New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Fisher Brothers 605 Third Avenue New York NY	Ok, but	\$650.00
Provide Barrier between switchboards emergency and normal.						
45664	04A0200	A.J. Ianni Electrical Contractor Ltd. 1402 B Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	190 Willow Avenue Bronx NY	Approved	\$650.00
45665	04A0198	Stasi/Dallas Electrical Contracting, Inc. 79-06 Jamaica Avenue Woodhaven NY 11421	Requested approval for the electric service equipment proposed to be installed	Polo Grounds Towers 2975 8th Avenue Building #1 New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45666	04A0197	Stasi/Dallas Electrical Contracting, Inc. 79-06 Jamaica Avenue Woodhaven NY 11421	Requested approval for the electric service equipment proposed to be installed	Polo Grounds Towers 2975 8th Avenue Building #3 New York NY	Approved	\$650.00
45667	04A0196	Stasi/Dallas Electrical Contracting, Inc. 79-06 Jamaica Avenue Woodhaven NY 11421	Requested approval for the electric service equipment proposed to be installed	Polo Grounds Towers 2975 8th Avenue Building #4 New York NY	Approved	\$650.00
45668	04A0195	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Bloomberg 731 Lexington Avenue New York NY	Hold	\$650.00
1) Need physicals of equipment. 2) Need coordination study. 3) Bus sizes of Russet switchgear.						
45669	04A0194	Nead Electric Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	1285 Avenue of Americas New York NY	Ok, but	\$650.00
Distance of switch from generator within 5'.						
45670	04A0193	Joseph Weinstein Electric Corp. 94-24 88th Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	383 Lafayette Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45671	04A0220	alvatore Campisi & Sons Electl Contr., Inc 453 Onderdonk Avenue Ridewood NY 11385	Requested approval for the electric service equipment proposed to be installed	450 7th Avenue New York NY	Approved	\$650.00
45672	04A0219	J.A. Lee Electric Corp. 10-18 47th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1841 Broadway New York NY	Approved	\$650.00
45673	04A0218	J.A. Lee Electric Co. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	488 Madison Avenue New York NY	Approved	\$650.00
45674	04A0217	J.A. Lee Electric Co. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	560 West 165th Street New York NY	Approved	\$650.00
45675	04A0216	Alom Electric LLC 148 22nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Long Island University Kumble Theater Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45676	04A0206	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	New York Life 51 Madison Avenue New York NY	Approved	\$650.00
45677	04A0214	Merit Electrical Contracting Corp. 648 4th Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	351 East 51st Street New York NY	Approved	\$650.00
45678	04A0213	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	The Olive Garden 201 West 47th Street New York NY	Approved	\$650.00
45679	04A0212	Judd Electric Inc. 1097 Second Avenue-Suite 300 New York NY 10022	Requested approval for the electric service equipment proposed to be installed	401 East 65th Street New York NY	Approved	\$650.00
45680	04A0183	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	75 9th Avenue aka 460 16th Street New York NY	Denied	\$650.00
1) The common neutral in the switchboard must be removed. 2) The 3 pole automatic transfer switch must be changed to a 4 pole type.						

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45681	04A0211	Judd Electric Inc. 1097 Second Avenue-Suite 300 New York NY 10022	Requested approval for the electric service equipment proposed to be installed	181 East 73rd Street New York NY	Ok, but	\$650.00
Provide short circuit curves 800 distribution.						
45682	04A0239	Campbell and Dawes Ltd. Electrical Concs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	90 Church Street New York NY	Approved	\$650.00
45683	04A0235	K & R Electric Co., Inc. 638 Sharrotts Road Staten Island Ny 10309	Requested approval for the electric service equipment proposed to be installed	18 Ninth Avenue New York NY	Approved	\$650.00
45684	04A0234	Premier Electric 38 Granite Avenue Staten Island NY 10303	Requested approval for the electric service equipment proposed to be installed	Kings County OCME 599 Winthrop Street Brooklyn NY	Approved	\$650.00
45685	04A0230	Illuminous Electric Inc. 1425 37th Street Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	739 East New York Avenue Brooklyn NY	Hold	\$650.00
Not reviewed. Wrong drawing submitted. New drawing to follow.						

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45686	04A0229	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	Buena Vida Continuing Care Ctr. 48 Cedar Street Brooklyn NY	Approved	\$650.00
45687	04A0210	Forum Engineering, P.C. 139 Fulton Street New York NY 10038	Requested approval for the electric service equipment proposed to be installed	195 Bowery Street New York NY	Denied	\$650.00
<p>1) The service entrance conductors are undersized, no notes of distance of the run are indicated for concrete encasement. 2) The bonding and grounding of the service equipment including the fuse cutout must be made in the service switches. A supplemental ground must be provided. 3) Two normal feeds are feeding the fire pump. 4) The full load amperage of the fire pumps was not provided on the drawing. 5) The fuse cutout is only fed with two #10 conductors. 6) Series ratings for the circuit breakers was not provided.</p>						
45688	04A0223	Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Columbia Univ.-Teach's College 525 West 120th Street New York NY	Approved	\$650.00
45689	04A0208	L & L Electric & Power Corp. 24-20 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	J.W. Mays Co. 25 Elm Pl. New York NY	Approved	\$650.00
45690	04A0246	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Price Waterhouse Coopers 300 Madison Avenue, 9th Floor New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45691	..	Pegasus Electrical Corp. 24-07 31st Street Astoria NY 11102	Request permission not to file Advisory Board drawings on a 1000KVA service where the second fuse was changed from 100 amps to 200 amps.	122 West 70th Street New York NY	Approved	\$0.00
45692	.	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requesting permission to leave as installed switchgear with rear access doors that has a clearance of less than 36 inches to the service room wall.	LIRR Atlantic Terminal Brooklyn NY		\$0.00
45693	..	Smith Electrical Contracting 120 Dobbin Street Brooklyn NY 11413	Requesting permission to leave as installed service equipment that is not grouped together in a 2 family building with common space in the existing building.	115-46 126 Street Queens NY		\$0.00
45694	.....	Joseph A. Skarulis Lic. Electl Contr 245 Wilson Avenue Brooklyn NY 11237	Requesting permission not to group together service equipment in a building that consists of 26 unit apartments and a public parking garage with no access between the buildings.	525-529 East 11th Street New York NY		\$0.00
45695	.....	Lehr Construction Corp. 902 Broadway New York NY 10010	Requesting permission to utilize 3 sets of 500 KCMIL to feed a 1200 amp automatic transfer switch in a building where the prior electrician filed a work permit prior to the new electrical code.	Atlantic Terminal Office Tower 139 Flatbush Avenue Brooklyn NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45696	---	Ambrosino DePinto & Schmieler 275 Seventh Avenue-2nd Floor New York NY 10001	Requesting permission to feed one building from another that are not under single management.	17 Eastern Parkway Brooklyn NY	Denied	\$0.00
Article 230.3 of the 2002 National Electrical Code states service conductors supplying a building or other structure shall not pass through the interior of another building or structure.						
45697	----	Zerem Electric Corp. 3011 Avenue L Brooklyn NY 11210	Requesting permission to leave as installed a 400 amp service for a one story synagogue on the outside of the building.	24-22 Bayswater Avenue Queens NY	Denied	\$0.00
Article 230.70 (a) of New York City's Amendments to the 2002 National Electrical Code and Article 3 Section 27-3045b of the old New York City Electrical Code prohibits the installation of outdoor service switches for non residential buildings.						
45698	..... .....	Blasko Electrical Contractors, Inc. 36-38 35th Street Long Island City NY 11106	Requesting permission to leave as installed a outdoor three gang meter pan using two threadless connectors on the bottom of the meter pan. The service is being feed underground by Con Ed.	94-15 40th Road Queens NY	Approved	\$0.00
45699	..... .....	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requesting permission to run an insulated air conditioning duct encased in two hour fire rated assembly through a service room that will provide air conditioning in the service room.	165 Charles Street New York NY	Approved	\$0.00
Concept approval only.						
45700	.....	Team Electric, Inc. 1261 Broadway, Suite 609 New York NY 10001	Requesting permission to leave as installed in an apartment dining room that has two glass walls and a under floor AC duct in front of the glass walls not to provide required outlets.	11 West 10th Street New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45701	.....	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requesting permission in an 274 unit apartment building not to install floor outlet receptacles in front of a corner glass wall, other receptacles will be installed on the other walls at a distance greater than 12 feet on center in 72 living rooms.	325 North End Avenue New York NY	Approved	\$0.00
45702	.....	Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission to install the receptacle outlet spacing as per the old New York City Electrical Code in a dormitory that was designed in 2002 and filed by the electrical contractor in August of 2003.	Brooklyn Law School Brooklyn NY	Approved	\$0.00
45703	.....	J.J. Rosenberg Electrical Contrs, Inc. 27 Herkimer Place Brooklyn NY 11216	Requesting concept approval to install secondary power to a fire pump located in 320 West 66th Street, New York. By tapping the line side of service in a adjoining building at 125 West End Ave, both buildings are under one ownership and upgrading the existing generator will create building reinforcement hardships.	20 W. 66th St. and 125 West End Av New York NY	Denied	\$0.00
<p>Article 695.3 (c) of New York City's Amendments to the 2002 National Electrical Code states: (c) Multiple Independent Sources. Two or more feeder sources to the building arranged to independently operated may permitted, as approved by the Commissioner of Buildings, where reliability of the sources can be demonstrated.</p>						
45704	.....	Diane Electric, Inc. 1371 Seabury Avenue Bronx NY 10461	Requesting permission to install a 3 phase 100 amp 250 volt service switch fused at 60 amps in lieu of a fuse cutout to power a fire alarm system. The 100 amp service switch will be painted red and labeled as fire service and be locked on the "on" position with a fireman's lock. The switch will be installed within 5 feet of the service equipment.	Verizon 230 West 36th Street New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45705	..... .....	Roland J. Wertz Inc. 436 Beach 129th Street Belle Harbor NY 11694	Requesting permission to install a six gang meter housing with service switches on the outside of a five family house with one meter for public light and power.	431 Beach 122nd Street Rockaway, Queen: NY	Approved	\$0.00
45706	04A0241	Conservation Technology, Ltd(Con-Tech Lt) 2783 Shermer Road Northbrook IL 60062	Requested approval for use in New York City of your Recessed Compact Fluorescent Lighting. Model/Series Numbers 1. RA 6" Series Vertical. 2. RS 6" Series Vertical. 3. RA 6" Series Horizontal. 4. RS 6" Series Horizontal. 5. RA 8" Series Vertical. 6. RS 8" Series Vertical. 7. RA 8" Series Horizontal. 8. RS 8" Series Horizontal.		Approved	\$200.00
45707	04A0242	Conservation Technology, Ltd(Con-Tech Lt) 2783 Shermer Road Northbrook IL 60062	Requested approval for use in New York City of your Recessed Incandescent Lighting. Model/Series. 1. RL30-IC. 2. RL30-ICSA. 3. RL30S-IC. 4. RL30-ICR. 5. RL30S-ICR. 6. RL38S. 7. RL38S-R. 8. RL38-ICER. 9. RL38-ICESA.		Approved	\$200.00
45708	04A0243	Fuel Cell Energy Inc. 3 Great Pasture Road Danbury CT 06813	Requested approval for use in New York City of your Stationary Fuel Cell Power System. Model/Series Numbers: DFC300A.		Approved	\$200.00

# ADVISORY BOARD CALENDAR

**May 19, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45709	04A0244	Dekko Engineering Inc. 11913 E. 450 South Laotto IN 46763	Requested approval for use in New York City of your Manufactured Wiring System Power Entry, Distribution, Jumper, Receptacle, "I" and "H" Connectors. Model/Series Numbers: 580000, 580006, 580265, 580346, 580373, 580236 and 580020		Denied	\$200.00

New York City does not accept 604 wiring methods except 604-1(a) (6)

45710	04A0245	Krueger International 1220 Bellevue Street Green Bay WI 54302	Requested approval for use in New York City of your Office Furnishing. Model/Series Numbers: AP, Series GC, GR, GS followed by additional suffixes.		Approved	\$200.00
-------	---------	---	---	--	----------	----------

45711	04A0247	Active Power Inc. 2128 West Braker Lane Austin TX 78758	Requested approval for use in New York City of your Uninterruptible Power Supply Equipment (UPS) Model/Series Numbers: UPS 1200, UPS900, UPS600, UPS300, UPS225, UPS300 N+1, UPS600 N + 1, UPS900 N +1, UPS150B, UPS150, UPS130, UPS100, UPS80, UPS65, UPS50, CS2-500, CS2-425, CS2-375, CS2-250, CS2-200, CS2-160, CS2-140, CS2-100 and APA-1.		Approved	\$200.00
-------	---------	---	---	--	----------	----------