

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47121CO	- -	Murray Diamond, Licensed Electrician 35-05 169th Street Flushing NY 11358	Requesting permission due to ground water conditions to run service entrance conductors in overhead troughs within a two hour fire rated room instead of concrete encased conduits (Cal. #42541).	Fresh Direct 23-30 Borden Avenue Queens NY	Hold	\$0.00
Carry over from April 12, 2006 meeting.						
47128CO	06A0215CO	ProtectConnect 8835 Research Drive Irvine CA 92618	Requested approval for use in New York City of your ProtectConnect Modular Integrated Wiring System.		Approved	\$0.00
Carryover from April 12, 2006 meeting.						
47131CO	06A0218CO	Danfoss Inc. 7880 Tranmere Drive Toronto ON L5S1L	Requested approval for use in New York City of your Danfoss GX Snow Melting System complete with GX 850. Model/Series Number: GX Series O88L.		Hold	\$0.00
Carryover from April 12, 2006 meeting. Need listing report						
47133	06A0252	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mandarin Oriental Hotel 80 Columbus Circle New York NY	Approved	\$650.00
47134	06A0277	Jata Electric Construction Corp. 16 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	137 Duane Street New York NY	Hold	\$650.00
Special permission required for 7th service switch.						

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47135	06A0248	KNC Electric Inc. 187-27 Linden Blvd. St. Albans NY 11412	Requested approval for the electric service equipment proposed to be installed	121 Beach 25th Street Queens NY	Approved	\$650.00
1) Coordinate service wiring with LIPA requirements. 2) Extend neutral and bond at FP. service switch. 3) Confirm FP voltage. Job finalized 7/6/06.						
47136	06A0231	Global Electrical Contg of Wechester, Inc. 4065 Boston Road Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	Jacobi Medical Center 1340 Pelham Parkway South Bronx NY	Approval	\$650.00
Confirm selective coordination between 600A TRS and service fuse 2000A A4BQ. Job finalized 6/9/06.						
47137	06A0254	Lite Tron Electrical Corp. 236 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Woolworth Building 233 Broadway New York NY	Hold	\$650.00
1) Transformer shall be 208A to 277/480 Y. 2) Provide neutral for 75 KVA and 30 KVA secondary to bond at disconnect or delete. 3) Delete neutral bond at disconnect on wiring trough.						
47138	06A0224	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	New York Blood Center 45-01 Vernon Blvd. Long Island City NY	Approved	\$650.00
47139	06A0260	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	635 Castle Hill Avenue Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47140	06A0258	Artic Electric Corp. 25 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	345 Seventh Avenue New York NY	Approved	\$650.00
47141	06A0256	Horsepower Electric 821 McDonald Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	6101 16th Avenue Brooklyn NY	Approved	\$650.00
Increase load bus size on SS#! to 800A/in squared for 1st 4' of bus. Job finalized 6/9/06.						
47142	06A0276	Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	200 West 24th Street New York NY	Approved	\$650.00
47143	06A0268	MSM Electric, Inc. 3089 Brighton 6th Street Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	8 West 40th Street New York NY	Approved	\$650.00
47144	06A0274	KGK Electric Corp. 21-03 21st Avenue Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Cornerstone Site II 313 West 119th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47145	06A0272	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	880 5th Avenue New York NY	Approved	\$650.00
47146	06A0270	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	440-442 West 14th Street New York NY	Approved	\$650.00
47147	06A0266	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Clarett Brooklyn Tower 130 Ashland Place Brooklyn NY	Approved	\$650.00
47148	06A0264	Campbell and Dawes Ltd. Electl Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	544 West 19th Street New York NY	Approved	\$650.00
Confirm ATS can accommodate conductors shown. Job finalized 6/9/06.						
47149	06A0262	Livingston Electrical Assoc. Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	210 Lafayette Street New York NY	Approved	\$650.00
Reverse door opening. 6/12/06 job finalized.						

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47150	06A0235	Pinto & Teger Electric Corp. 32-24 111th Street East Elmhurst NY 11369	Requested approval for the electric service equipment proposed to be installed	Verizon 137-34 Northern Blvd. Flushing NY	Ok, but	\$650.00
1) Correct designation for SS#2 on plan . 2) New FA connection shall be a fused cutout.						
47151	06A0236	Pinto & Teger Electric Corp. 32-24 111th Street East Elmhurst NY 11369	Requested approval for the electric service equipment proposed to be installed	Riverdale Country School 5250 Fieldston Road Bronx NY	Approved	\$650.00
47152	06A0225	I.S.M. Electric Contractor Inc. 512 73rd Street Brooklyn NY 11209		163 West 18th Street New York NY	Approved	\$650.00
47153	06A0253	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Ziff Brothers 350 Park Avenue New York NY	Approved	\$650.00
47154	06A0243	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	40 West 116th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47155	06A0241	Copper City Electric Corp. 330 East 38th Street-Suite 5G New York NY 10016	Requested approval for the electric service equipment proposed to be installed	475 Greenwich Street New York NY	Approved	\$650.00
47156	06A0239	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	Pool/Ice Rink 125-40 Roosevelt Avenue Flushing NY	Ok, but	\$650.00
Confirm location of emergency side disconnect for FP and FA conform to tap rules.						
47157	06A0237	A & Z Electl Maint. & Service Corp. 307 Seventh Avenue, Suite 403 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sherry Netherland 781 Fifth Avenue New York NY	Approved	\$650.00
47158	06A0220	Sterling Electric Inc. 863 Sterling Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	257 Clinton Street New York NY	Approved	\$650.00
Relocate tap to supply side of bus on DP-1A.. Job finalized 6/1/06.						
47159	06A0222	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Riverside South-Bldg. 'H' West 66th Street & West 64th Street New York NY	Ok, but	\$650.00
Confirm coordination between 1200 and 2000A A4BQ fuses.						

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47160	06A0232	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Korman Communities 42 West 58th Street New York NY	Approved	\$650.00
47161	06A0281	High-Tech Electrical Services Corp. 36-33 23rd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	GM 767 Building Avenue New York NY	Approved	\$650.00
47162	06A0245	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	141 West 73rd Street New York NY	Approved	\$650.00
47163	06A0251	J.H. Electric of New York Inc. 59-01 Grand Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	American Museum of Nat. Hist. New York NY	Approved	\$650.00
47164	06A0280	Flemington Electrical Maintenance Inc. 175 Varick Street, 7th Floor New York NY 10014	Requested approval for the electric service equipment proposed to be installed	292 Madison Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47165	06A0278	Jata Electric Construction Corp. 16 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	151 West 17th Street New York NY	Approved	\$650.00
47166	06A0247	BLZ Electric Co. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	20 Bayard Street Brooklyn NY	Hold	\$650.00
1) The service bus for the 1200 amp service switches is undersized. 2) Correct over fusing. 3) Disconnect switches are fed prior to metering.						
47167	06A0249	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	French Culinary Institute 462 Broadway New York NY	Approved	\$650.00
47168	06A0255	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Friends Seminary 222 East 16th Street New York NY	Approved	\$650.00
Increase bus size to 1200 amp in panelboard. Job finalized 6/9/06.						
47169	06A0246	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	823 Park Avenue New York NY	Ok, but	\$650.00
Identify fire pump service switch by painting red.						

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47170	06A0259	Artic Electric Corp. 25 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	130 West 42nd Street New York NY	Approved	\$650.00
47171	06A0257	Broadway Electric, LLC 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	6 West 48th Street New York NY	Hold	\$650.00
1) Provide two means of egress on each side of service room. 2) Provide manufacturer cut sheets of equipment.						
47172	06A0279	Another Nycer Electric Corp. 652 Sackett Street Brooklyn NY 11217	Requested approval for the electric service equipment proposed to be installed	415 East 37th Street New York NY	Hold	\$650.00
1) Provide coordination between generator circuit breaker switch. 2) Provide type of ATS 3 or 4 pole. 3) ATS for life safety shall be in a separate room.						
47173	06A0267	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	225 West 34th Street New York NY	Approved	\$650.00
47174	06A0275	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	11 East 36th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47175	06A0273	MSM Electric, Inc. 3089 Brighton 6th Street Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	250 Hudson Street New York NY	Approved	\$650.00
47176	06A0271	Bass Electrical Corp. 10-17 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	198 West Street Brooklyn NY	Approved	\$650.00
47177	06A0269	Rigid Electric Inc. 336 37th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	#1 Eastern Parkway Brooklyn NY	Approved	\$650.00
47178	06A0265	Hampton Electrical Corporation 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Astor Terrace 245 East 93rd Street New York NY	Approved	\$650.00
47179	06A0263	Livingston Electrical Assoc. Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	205 East 45th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47180	06A0244	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	200 Chambers Street New York NY	Approved	\$650.00
47181	06A0223	Judd Electric Inc. 41-41 38th Street New York NY 11101	Requested approval for the electric service equipment proposed to be installed	247 West 38th Street New York NY	Approved	\$650.00
47182	06A0261	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens West Building #7 4-76 47th Avenue Long Island City NY	Approved	\$650.00
47183	06A0230	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	1992 Broadway New York NY	Hold	\$650.00
1) Provide GFP on all service switches over 1000 amps and leave undersized bus. 2) Aluminum feeders are undersized. 3) Al bus.						
47184	06A0242	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Rockrose Development 645 Madison Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47185	06A0240	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	1-3 East 35th Street New York NY	Approved	\$650.00
47186	06A0238	D.J. Electrical Contractors Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	45 Sutton Place South New York NY	Approved	\$650.00
Block side service equipment. Job finalized 6/1/06.						
47187	06A0234	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	270 Greenwich Street New York NY	Hold	\$650.00
1) Service switches not provided with GFP. 2) MS-B board 3rd section of bus to be increased one size 3-3 x 1/4 to 3-4x 1/4. 3) Redesign emergency switchboard, no main.						
47188	06A0221	Schlesinger Electrical Contractors, Inc. 664 Bergen Street Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	1185 Park Avenue New York NY	Approved	\$650.00
47189	06A0233	Konsker Electric Corp. 32-15 36th Avenue Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	715 Lexington Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47190	06A0282	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	353 4th Avenue Brooklyn NY	Hold	\$650.00
1) Provide calculations to confirm adequacy of AIC at PNL RP. 2) Fire pump conductors too small. 3) Fire pump disconnect too small. 4) Jockey pump tap must be outside fire pump controller. 5) Fire pump conductors to be in rated assembly. 6) Fire pump and fire alarm to be made after CT. 7) Service conductors too small. 8) Eliminate dual neutral disconnect and indicate ground connection.						
47191	06A0283	B & G Electrical Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	112-20 Rockaway Blvd. Queens NY	Hold	\$650.00
1) New service conductors undersized. 2) Exist service conductors undersized. 3) Eliminate dual neutral disconnects and indicate ground connection. 4) Confirm coordination and AIC adequate for distribution breakers and service fuse. 5) Conductors in trough to be bunched per code.						
47192	06A0284	Levinson & Santoro Electric Corp. 20-16 130th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	PS 384 K 242 Cooper Street Brooklyn NY	Approved	\$650.00
47193	06A0285	Absolute Electric Contracting, Inc. One Cross Island Plaza Rosedale NY 11422	Requested approval for the electric service equipment proposed to be installed	540 Madison Avenue New York NY	Approved	\$650.00
Ground generator frame. Job finalized 4/19/07.						
47194	06A0286	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	The Hub Core & Shell 3000-3002 3rd Avenue Bronx NY	Hold	\$650.00
1) Tenant switchboard service entrance undersized. 2) Tenant switchboard bus undersized. 3) 800 amp feed to board LL PP undersized. 4) 400 amp fused do not coordinate with the 800 amp fuses. 5) Show bonding and grounding in both switchboards. 6) Fuse cutout in board SBA not on load side of CT. 7) Feeds for emergency loads on load side of 2nd fusing.						

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47195	--	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requesting permission for concept approval of a co-generator installation	110 East 59th Street New York NY	Approved	\$0.00
With the stipulation that either add an overcurrent device at the point of common coupling so that the existing load feeders would be protected or locate the point of common couplings so that the existing conductors are adequate based on the tap rules.						
47196	---	Lilker Associates Consulting Engs, PC 1001 Avenue of the Americas New York NY 10018	Requesting concept approval for the layout of a service room	Fashion Industries H.S, 225 West 24th Street New York NY	Approved	\$0.00
47197	---	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requesting permission to install a 7th service switch to provide power to a fire pump.	141 West 73rd Street New York NY	Approved	\$0.00
47198	----	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requesting permission to install a seventh service switch that will provide power to a special service fire booster pump	8 West 40th Street New York NY	Approved	\$0.00
47199	-----	Jaros Baum & Bolles Consulting Engs. 80 Pine Street New York NY 10005	Requesting permission to install dual plug type APC automatic transfer switch modulars will power desktop information technology equipment.	One Bryant Park New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47200	-----	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to add a new section of switchgear to an existing switchboard where the side clearance will be less than 36 inches.	Mandarin Oriental Hotel 80 Columbus Circle New York NY	Approved	\$0.00
47201	-----	Sage Electrical Contracting 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requesting permission to install Schedule 80 non metallic conduit as a wiring method for service entrance conductors that will run underground into a building	270 Greenwich Street New York NY	Approved	\$0.00
47202	-----	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requesting permission to install Schedule 80 non metallic conduit as a wiring method for service entrance conductors that will run underground into 2 buildings	40 West 116th Street New York NY	Approved	\$0.00
With the stipulation that signage is provided at the service equipment indicating where the feed is coming from.						
47203	-----	D & S Electrical Corporation 450 Beach 48th Street Far Rockaway NY 11691	Requesting permission to install Schedule 80 non metallic conduit standpipes on seven two family buildings located in a corrosive area, Far Rockaway, Queens.	4508 Bch Chl Dr., 151 Bch 27 St., Queens NY	Approved	\$0.00
47204	----- -	Gold Star Electrical, Inc. 121-04 101 Avenue Richmond Hill NY 11419	Requesting permission to install four 8 foot sections of non-metallic surface raceway in a ultra sterile clean room processing pharmacy where the room interior must be completely sterilized daily.	104-11 115th Street Queens NY	Denied	\$0.00
The Board has determined that either PVC coated metallic or stainless steel conduits, boxes and fittings be used as the wiring method. The face of the receptacles must also be properly protected to withstand the strong disinfectants that will be used.						

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47205	-----	D & S Electrical Corporation 450 Beach 48th Street Far Rockaway NY 11691	Requesting permission to install Schedule 80 non metallic conduit for three outdoor free standing services, distribution panels, site lighting and ballard lighting in a corrosive area, Far Rockaway, Queens.	c Dr., 7602 C Aquatic Dr. and 7718 Queens NY	Hold	\$0.00
Pending field inspection report for next meeting.						
47206	-----	Nivek Electrical Contracting, Inc. 301 East 119th Street New York NY 10035	Requesting permission to leave as installed a service switch for a cell site mounted on the outside of a commercial building that is not grouped together with the other service equipment.	2882 Gerritsen Avenue, 1st Floor Brooklyn NY	Approved	\$350.00
With the stipulation that signage is provided at each service indicating where the other service is located.						
47207	----- ----	Quantum Electric Corporation 36-24 34th Street Long Island City NY 11101	Requesting permission to temporarily run overhead service entrance conductors 80' into a building without concrete encasement where the entire service will be replaced in approximately a year.	DHL 500 Tenth Avenue New York NY	Approved	\$0.00
With the stipulation that the temporary wiring be removed by July, 2007.						
47208	-----	J.M.C. Electric Corp. 947 First Avenue Franklin Square NY 11010	Requesting permission due to lack of space inside of the service room to leave as installed service equipment for a cell site mounted on the outside of a commercial building not grouped together with other service equipment	300 West Service Road Staten Island NY	Approved	\$0.00
With the stipulation that signage is provided at each service indicating where the other service is located.						
47209	---	Richard Wehner Electrical Contg Corp. 120-06 31st Avenue Flushing NY 11354	Requesting permission to run service entrance conductors approximately 30' into a building without concrete encasement where 15 feet of the run are Con-Edison's conductors.	483 Broadway New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47210	-----	Artic Electric Corp. 25 West 45th Street New York NY 10036	Requesting permission in a building where the DC service will be eliminated, to temporarily feed a rectifier for approximately 13 months that will power a fire pump from a 800 amp second fuse due to lack of space inside of the service room	NY Times 229 West 43rd Street New York NY	Approved	\$0.00
With the stipulation that the electrical contractor is responsible to reinstall a new service switch for the fire pump if the temporary condition lasts longer than July, 2007.						
47211	-----	Ettinger Engineering Associates 505 Eighth Avenue New York NY 10018	Requesting permission on a project that has 14 multi family buildings that will not have common laundry areas, to install one 30 amp laundry branch circuit for a 30 amp receptacle in lieu of the 20 ampere circuit and receptacle as required in 210.11(C)(2) and 210.52(F) of the NEC	1 Flatbush Ave. 158 Madison Ave.e	Approved	\$0.00
47212	06A0226	Juno Lighting Inc. 1300 S. Wolf Road Des Plaines IL 60017	Requested approval for use in New York City of your Line of Edge Lit Signs. Model/Series: NNYXES, NNYXER and NNYXERB.		Approved	\$200.00
47213	06A0227	Conservation Technology, Ltd 2783 Shermer Road Northbrook IL 60062	Requested approval for use in New York City of your Recessed Compact Fluorescent Lighting consisting of a steel mounting plate. Socket whip assembly, electronic ballasts, and junction boxes along with various trim configurations.		Approved	\$200.00
47214	06A0228	Knoll, Inc. 1235 Water Street East Greenville PA 18041	Requested approval for use in New York City of your Daisy-Chained Fluorescent Task Lighting. Model/Series: "QC" Series.		Approved	\$200.00

ADVISORY BOARD CALENDAR

May 24, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47215	06A0229	Elliot Energy Systems, Inc. 2901 S.E. Monroe Street Stuart Fl 34997	Requested approval for use in new York City of your TA 100 Microturbines, Model/Series Number: TA100-CHP,-Monogen.		Hold	\$200.00
Listing report or field evaluation.						
47216	06A0250	Nordic Logistics 311 S. Arlington Heights Rd., Suite 102 Arlington Heights IL 60005	Requested approval for use in New York City of your Nordic Light AB Lighting Fixtures. (1.2) 1x35W T5 Fluorescent Luminaire (3) Portable Electric Lamp with Cord. Model/Series Numbers: (1) Grid Version 3, (2) PO63 Version 2 and (3) Ikea Mini 120 V.		Denied	\$200.00
1) Portable Lamp(Clamp-on) double insulated (not subject to listing lab report. 2) Flanges must be flat for connect and locknut bonding. 3) Grid fixture need a wiring trough.						