

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50360CO2	10A0381CO2	Star Delta Electric, LLC 17 Battery Place, Suite 203 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	40 Wall Street New York NY	Hold	\$0.00
Carry over from December 22, 2010 meeting. Load though overfilled, verify whether load is linear or non linear.						
50377CO	10A0395CO	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	JP Morgan Chase 270 Park Avenue New York NY	Ok, but	\$0.00
Carry over from December 22, 2010 meeting. Confirm all 20, 3-wire on new equipment.						
50382CO4	10A0400CO4	Jordan Daniels Electrical Contractors, Inc. 151 West 25th Street, 7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sprint 60 Hudson Street New York NY	Approved	\$0.00
Carry over from March 10, 2011 meeting. Provide GFP on distribution breakers on paralleling switchboard. 5/15/14 Job finalized.						
50567CO	11A0074CO	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Long Island Jewish-Zucker 75-59 263rd Street Glen Oaks NY	Hold	\$0.00
Carry over from February 18, 2011 meeting. Show 2nd level GF protection and coordination study still applies or verify that is no critical care on a in patient physically.						
50571CO	11A0078CO	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	St. Mary's Hospital for Children 29-01 216th Street New York NY	Approved	\$0.00
Carry over from March 10, 2011 meeting. 1) FP branch circuit undersized. 2) Jockey pump tap unacceptable. Tap on side ahead of ATS. 3) Ground wire undersized on norm F.P. feeder. Job finalized 10/4/11.						

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50604CO	11A0111CO	Kramer Electric, LLC 35 West 35th Street, Suite 503 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	The Puck Building 295 Lafayette Street New York NY	Approved	\$0.00
Carry over for April 13, 2011 meeting.						
50641CO	11A0107CO	Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Tallman Island WPCP 127-01 Powells Cove Boulevard College Point NY	Approved	\$0.00
Carry over from April 13, 2011 meeting. 1) Clarify connections of manhole HUMH-3. 2) Clarify warning sign language for transformer room and transformer door access. Job finalized 9/25/12.						
50643CO	11A0146CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Albert Einstein College of Med. 1225 Morris Park Avenue Bronx NY	Hold	\$0.00
Carry over from April 13, 2011 meeting. 1) Not in Advisory Board formatted. 2) Verify that all 30 4 wire ATS' are 3 or 4 pole types. 3) Is generator neutral bonded and grounded? 4) New equipment not identified on room layout drawings. 4) EGC undersized.						
50651CO		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission for like and kind replacement of equipment operating in excess of 600 volts.	Fordham Preparatory School 441 East Fordham Road Bronx NY	Approved	\$0.00
Carry over from April 13, 2011 meeting. For a like and kind emergency replacement already installed prior to special permission approval. It is recommended that the primary switch may not be suitable for the purpose intended.						
50655	11A0148	LFG Landmark Facilities Group, Inc. 252 East Avenue Norwalk CT 06855	Requested approval for the electric service equipment proposed to be installed	70 West 40th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50656	11A0149	Capitol Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Time Warner 409 East 60th Street New York NY	Hold	\$650.00
1) Provide make/model/details of 1500KVA transformers. 2) 480V secondary disconnect w/GFP required for 1500KVA transformers. 3) Gen G-I-A is emergency generator(not voluntary). 4) Show grounding for all transformers, generators. 5) Provide S.E.B. detail w/22 sets of cable. 6) Provide 2nd exist in all rooms can provide interconnecting doors. 7) All doors to swing out from electric rooms. 8) Generator main circuit breaker G-I-A GF indication, Circuit breaker G-I-B GF trip.						
50657	11A0150	Metro Electrical Contractors, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	902 Quentin Road Brooklyn NY	Approved	\$650.00
Provide 2nd means of egress in service room. Job finalized 6/20/11.						
50658	11A0151	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	VW/Audi 798 Eleventh Avenue New York NY	Approved	\$650.00
Neutral to be bonded in FA switch. Job finalized 6/28/11.						
50659	11A0152	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Concourse Plaza 900 Grand Concourse Bronx NY	Approved	\$650.00
50660	11A0153	D & D Electric Contracting Corp. 13 East 37th Street, Suite #701 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Vernado Realty Trust 1750 East Gun Hill Road Bronx NY	Ok, but	\$650.00
1) New equipment not indicated on room layout drawing. 2) Service entrance conductors undersized.						

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50661	11A0154	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Theater For a New Audience 262 Ashland Place Brooklyn NY	Approved	\$650.00
Emergency FP circuit not tapped from line side of generators disconnect switch. Job finalized 7/22/11.						
50662	11A0155	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	USTA Arthur Ashe Stadium 122-02 Roosevelt Avenue Flushing NY	Approved	\$650.00
1) Fused disconnect switch/cb must be provided for portable generator. 2) Verify loads: emergency or optional standby. Job finalized 9/19/11.						
50663	11A0156	Samco Electric Corp. 39-08 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	IS226Q 121-10 Rockaway Blvd. Queens NY	Approved	\$650.00
50664	11A0157	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Madison Sq. Gdn Core & Shell 4 Penn Plaza New York NY	Approved	\$650.00
Verify that emergency taps for F.A. and F.P. are on the line side of the generator disconnect. Job finalized 6/28/11.						
50665	11A0158	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mr. Sinai Icahn Bldg 1425 Madison Avenue New York NY	Approved	\$650.00
1) Verify that service room is ventilated. 2) Provide GFP on 1200A sw, 750 KVA transformer secondary. 3) Can 2nd egress be provided at other end of room? Job finalized 6/7/11.						

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50666	11A0159	Harley Electric Co, Inc. 1817 Unionport Road Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	NY Downtown Hospital 170 William Street, 8th Floor New York NY	Approved	\$650.00
50667	11A0160	Inner City Electrical Contractors, Inc. 160 21st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	800 Third Avenue New York NY	Approved	\$650.00
50668	11A0161	R.,N Electric Company, Inc. 400 St. Marks Place Staten Island NY 10301	Requested approval for the electric service equipment proposed to be installed	Self Help Association 136-39 45th Avenue Flushing NY	Approved	\$650.00
50669	11A0162	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	I.S./H.S. 404Q 1-51 51st Avenue & Second Street Long Island City NY	Approved	\$650.00
Provide ground lug for ss#2. Job finalized 6/28/11.						
50670	11A0163	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Weill Cornell Medical College 445 East 69th Street New York zz	Approved	\$650.00
1) Verify if service room is mechanically ventilated. 2) FA service entrance conductors undersized. 3) Explain manual transfer switch operation for chillers. Job finalized 6/22/11. 4/7/15 Swap rejected Drawing E is not in original set. Drawing T is still indicating wrong address, Drawing U is missing. Job must be refiled. 8/2/16 Swapped Drawing T-Revision 1; Drawing D-Revision 5 and Drawings A,B,C, E and H-Revision 6						

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50671	11A0164	Jeminis Electrical Contractors, Inc. 122-11 18th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Lefrak Organization 97-45 Queens Blvd. Queens NY	Approved	\$650.00
50672	11A0165	All-Star Electrical Services, Inc. 35 West 31st Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sephora 21 9th Avenue New York NY	Approved	\$650.00
50673	11A0166	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Rockefeller University 1216 York Avenue New York NY	Approved	\$650.00
1) Confirm emergency feeds for F.A. systems are from line side of gen. main c.b. 2) Provide cuts on 5KV switch and transformer. Job finalized 8/29/11.						
50674	11A0167	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	1501 Pitkin Avenue Brooklyn NY	Approved	\$650.00
1) Fire pump circuits to be fire rated. 2) Swbd room door to open out. Job finalized 8/29/11.						
50675	11A0168	Powerone Electrical Contracting Inc. 9202 Avenue M Brooklyn NY 11236	Requested approval for the electric service equipment proposed to be installed	555 6th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50676	11A0169	C.Q. Electrical Contracting Corp. 31-19 37th Avenue Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	260 East 161st Street Bronx NY	Approved	\$650.00
50677	11A0170	Amko Electrical Construction & Maint. 32-17 College Point Boulevard Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	23-11 21st Avenue Astoria NY	Approved	\$650.00
1) Indicate tap distances. 2) Verify 400A sw feeding 200A meter and 200A sw. Job finalized 8/29/11.						
50678	11A0171	Ostroff Electric Inc. 102-14 159th Road Howard Beach NY 11414	Requested approval for the electric service equipment proposed to be installed	91 Central Park West New York NY	Approved	\$650.00
50679	11A0172	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Credit Suisse 11 Madison Avenue New York NY	Approved	\$650.00
50680	11A0173	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Digital Realty Trust 111 8th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50681	11A0174	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Armory Renovation 56 West 66th Street New York NY	Approved	\$650.00
1) EGC undersized. 2) FA emergency switch not to be bonded. 3) Generator conductors feeding 600 A disconnects undersized. Job finalized 9/22/11.						
50682	11A0175	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Manhattan Plaza, Bldg B 583 9th Avenue New York NY	Approved	\$650.00
50683	11A0176	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Manhattan Plaza, Bldg. A 572 10th Avenue New York NY	Approved	\$650.00
Relocate 400A SAF.SW 89S-3A blocks egress. Job finalized 8/22/11.						
50684	11A0177	A.C. Morgan Electric 3601 Riverdale Avenue Bronx NY 10463	Requested approval for the electric service equipment proposed to be installed	315 West 36th Street New York NY	Approved	\$650.00
50685	11A0178	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	851 Grand Concourse Bronx NY	Denied	\$650.00
1) Emergency service room drawing not clear to read, clearance dimensions not shown, no title block with information shown. 2) 3" conduit overfilled. 3) Generator to have main disconnect switch. 4) Provide coordination study. 5) Show bus sizes in panel EDP-2.						

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50686	11A0179	Striano Electric Co., Inc. 246 Park Avenue Garden City Park NY 11040	Requested approval for the electric service equipment proposed to be installed	NYIT 26 West 61st Street New York NY	Hold	\$650.00
1) How long are tapped conductors. 2) New disconnect switch not identified in service room. 3) Neutral in disconnect switch bonded after the service switch.						
50687	11A0180	Campisano Electric, Inc. 355 Food Center Drive Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	276 Stagg Street Brooklyn NY	Approved	\$650.00
Feeders not properly identified, conductors in conduits. Job finalized 6/28/11.						
50688	11A0181	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Hines 140 Broadway New York NY	Hold	\$650.00
1) Fire pump service switches undersized and should not be GF protected. 2) Bus duct overfused. 3) Verify that emergency feeders are not being run through the service room, and is room mechanically ventilated. 4) Show all clearances in service room. 5) Existing tapped conductors are undersized. 6) Feeders misidentified. 7) Service bus in "SS-1" undersized. 8) FA ATS not shown.						
50689	11A0182	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	30 East 60th Street New York NY	Ok, but	\$650.00
1) Show size of section bus. 2) Physical of switchboard not provided. 3) Verify that F.P. conductors are fire rated.						
50690	11A0183	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Lakeside Center 171 East Drive Brooklyn NY	Hold	\$650.00
1) Physicals of equipment not provided. 2) Cut sheets not provided. 3) Secondary of transformer not bonded. 4) Transformer T-1, show clearances. 5) Verify in rush current of 2500 amp switch to transformer. 6) Electrical rooms to be mechanically ventilated. 7) Title block has 2 installation sites.						

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50691	11A0184	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Avenue-The World School 259 10th Avenue New York NY	Approved	\$650.00
4000 amp fuse on 3000 amp panel. Job finalized 8/31/11.						
50692	11A0185	Knight Electrical Services Corp. 111 Eighth Avenue New York NY 10011	Requested approval for the electric service equipment proposed to be installed	The Metropolitan Museum of Art 1000 Fifth Avenue New York NY	Approved	\$650.00
1) Neutral link not provided in sacker gear. 2) Verify all switches feeding step up transformers are sized for in rush currents. Job finalized 6/30/11.						
50693	11A0186	Shorr Electrical Contracting, Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Macy's Herald Square 151 West 34th Street New York NY	Hold	\$650.00
1) Verify that the bus ducts are service bus. 2) 2000 amp service switch not bonded. 3) ATS in service room "B" does it feed life safety. 4) Show tap detail of service bus where 2000 amp bus meets service bus. 5) Verify that service rooms are fire rated and not used for storage.						
50694	11A0187	Merit Electrical Contracting Corp. 642 4th Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	2129 White Plains Road Bronx NY	Approved	\$650.00
50695	11A0188	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mt. Sinai Guggenheim Pavilion 1468 Madison Avenue New York NY	Approved	\$650.00
Show grounding and bonding of paralleling gear. 5/19/14 Job finalized.						

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50696	11A0189	Naber Electric NY Corp. 3471 Steenwick Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	Phoenix House 42-44 Jay Street Brooklyn NY	Approved	\$650.00
50697	11A0190	Rico Electric Inc. 38-04 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	JRT Realty 470 Park Avenue South New York NY	Approved	\$650.00
50698	11A0191	Momern Electrical Contractors Inc. 927 Dumont Avenue Brooklyn NY 11207	Requested approval for the electric service equipment proposed to be installed	360 Furman Street Brooklyn NY	Approved	\$650.00
25' tapped conductor undersized. Job finalized June 28, 2011.						
50699	11A0192	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	NYHS Auditorium 170 Central Park West New York NY	Approved	\$650.00
50700	11A0193	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	370 Greenpoint Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50701	11A0194	Proscia Electrical Contracting Inc. 141-07 20th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	913 8th Avenue New York NY	Approved	\$650.00
50702	11A0195	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Presbyterian Hospital 620 West 168th Street New York NY	Hold	\$650.00
1) Tie switch to be 4 pole. 2) 3 sets of 600 MCR fused at 1600 amps.						
50703	11A0196	Samson Electric Corp. 3300 Northern Blvd-Basement Level Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	200 Madison Avenue New York NY	Approved	\$650.00
50704	11A0197	Hunter Electric Inc. 235-07 Braddock Avenue Queens Village NY 11428	Requested approval for the electric service equipment proposed to be installed	Tropicana 7-02 154th Street Whitestone NY	Approved	\$650.00
50705	11A0198	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	104 East 25th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50706	11A0199	Triple I Electrical Contracting, Inc. 64-05 34th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	44 Berry Street Brooklyn NY	Approved	\$650.00
50707	11A0200	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Building C 780 St. Anns Avenue Bronx NY	Ok, but	\$650.00
Show 2 feeders for 1200A switch to disconnect switches.						
50708	11A0201	CRM Electric Corporation 461 West 261st Street Bronx NY 10471	Requested approval for the electric service equipment proposed to be installed	3322 Decatur Avenue Bronx NY	Approved	\$650.00
50709	11A0202	A & R Electrical Maintenance, Inc. 64-14 69th Place Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	345 Adams Street Brooklyn NY	Approved	\$650.00
1) Show length of tap. 2) Equipment grounding conductor undersized. Job finalized 8/29/11.						
50710	11A0203	Hampton Electrical Corporation 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	366 Madison Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50711	11A0204	Cedar Electrical Contractors, Inc. 64 Fulton Street, Suite 602 New York NY 10003	Requested approval for the electric service equipment proposed to be installed	1328 Broadway New York NY	Approved	\$650.00
50712	11A0205	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	NYU Catholic Center 58 Washington Square South New York NY	Hold	\$650.00
1) Grounding electrode conductor to terminate on neutral bar and neutral to be bonded to enclosures in service switches. 2) Cut sheets, physicals of equipment not submitted. 3) Verify sets of conductors feeding fire pump. 4) Identify conductors on load side of ATS MTS-1. 5) 1600 MTS shall not be in the emergency room. 6) What is the AIC at the fire pump controller? 7) Send in 1 line coordination study.						
50713	11A0206	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Hamilton Marine Transfer Station 500 Hamilton Avenue Brooklyn NY	Hold	\$650.00
1) Provide fused service switch for FA system and identify conductors. 2) #12's fused at 30 amps. 3) FP service switch to be bonded and grounded with neutral. 4) Provide cut sheet of direct connect fire pump. 5) FA service switch to be bonded and grounded. 6) Is switchboard rear accessible?						
50714	11A0207	Brandl Electric Inc. 1926 Mott Avenue Far Rockaway NY 11191	Requested approval for the electric service equipment proposed to be installed	Jetro/Restaurant 100 Oak Point Road Bronx NY	Hold	\$650.00
Submission not in Advisory Board format.						
50715	11A0208	Shelter Electric 53-01 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	120 Schermerhorn Street Brooklyn NY	Hold	\$650.00
1) Provide coordination study. 2) Provide drip pans for all water pipes, drain pipes and deflection shields on steam pipes.						

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50716	11A0209	Team Electric, Inc. 20 West 36th, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Bryant Park Power Facility New York NY	Approved	\$650.00
1) Size of section bus not shown (take off bus). 2) Block off rear of switchboards. 3) Provide front views, section views manufacturer's equipment drawings. Job finalized 1/15/13.						
50717	11A0210	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Middle Village HS 45-35 Van Dam Street Long Island City NY	Hold	\$650.00
1) Emergency conductors feeding ATS #1 not identified. 2) New tapped conductors to terminate on single set of OCPD, is tap over 25'.						
50718	11A0211	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Kupferberg Ct for the Arts 65-30 Kissena Boulevard Flushing NY	Hold	\$650.00
No Drawings						
50720		Pulsar Electric, Inc. 51 Atlantic Avenue Floral Park NY 11001	Requesting permission due to lack of space inside of the existing service room, to install new service equipment the in the adjacent room where signage will be provided at each service location indicating where the other service is located.	GO Burger 1450 2nd Avenue New York NY	Approved	\$0.00
50721		A.J. Caruso Electrical, Inc. 4392 Victory Blvd. Staten Island NY 10314	Requesting permission to install 2 services on a one family building, where one service and panel will be installed outdoors to power a sewer ejection system for 15 buildings and the other service will be indoors powering the house signage will be provided indicating where the other service is located.	145 Roswell Avenue Staten Island NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50722		R. Donovan & Son Electric Co., Inc. 198-08 33rd Avenue Flushing NY 11358	Requesting permission due to lack of space inside of existing electrical closets, to replace existing 42 circuit panels with new 60 circuit breaker panels.	Hotel BelleClaire 250 West 77th Street New York NY	Approved	\$0.00
50723		Department of Environmental Protection 5-05 Horace Harding Expressway, 5th Floor Coron NY 11368	Requesting permission to install a new 480 volt motor control center that will face an existing 208 volt motor control center with a front clearance of 38 inches where warning signs will be installed.	Tallman Island College Point NY	Denied	\$0.00
50724		AKF Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting special permission to keep the existing reduced size neutral wire due to unique space and layout conditions which will make it impossible just to replace the neutral conductor without replacing the phase conductors.	70 Varick Street, 11th and 12th Floor New York NY	Approved	\$0.00
50725		DVL Consulting Engineers Inc. 137 Fifth Avenue New York NY 10010	Requesting concept approval for the installation of a ground loop system.	The Community Health Academy 504 West 158th Street New York NY	Approved	\$0.00
With the stipulation that the installation complies with Sections 250.53 and 250.56 of the 2005 NEC.						
50726		Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requesting permission due to extreme hardship to reinforce, to utilize the existing service bus rated at 1000 amps per square inch to install a new 4000 amp service switch to coordinate with downstream 2000 amp fuses where the combined service bus is 4300 amps.	Credit Suisse 11 Madison Avenue New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

May 25, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50727		Highland Associates 228 East 45th Street New York NY 10017	Requesting permission to waive fuse coordination requirements for a standalone data center.	Digital Realty Trust 111 Eighth Avenue New York NY	Approved	\$0.00
50728		Proven Electrical Contracting Inc. 247 Driggs Avenue Brooklyn NY 11222	Requesting permission to relocate underground 35KV feeders to new property line boxes on a property that will be split into separate lots.	New Stapleton Navy Yard 455 Front Street Staten Island NY	Approved	\$0.00
50729	11A0213	Workrite Ergonomics 1450 Technology Lane Petaluma CA 94954	Requested approval for use in New York City of your Verano Undercabinet LED Lights.		Approved	\$200.00
Portable use only.						
50730		AKF Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to allow an existing drip pan to be replaced with new when the existing UPS system is replaced	A/A/F TIAA-CREF 730 Third Avenue New York NY	Approved	\$0.00