

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53871	15A0633CO	Egg Electric Inc. 24 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	NYU 726 Broadway New York NY	Approved	\$0.00
Carry over from November 18, 2015 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54017	16A0012CO	A.S.R. Electrical Contracting, Inc. 969 Third Avenue, Suite 4F New York NY 10022	Requested approval for the electric service equipment proposed to be installed	225 East 126th Street New York NY	Approved	\$0.00
Carry over from February 10, 2016 meeting. 1) Verify compliance with Sections 700.10(B) and 225.32. 2) Correct contractors name on all drawings. 3) MSWBD section bus undersized last section with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53874	16A0020CO3	Jemco Electrical Contractors, Inc. 271 42nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	760 Broadway Brooklyn NY	Approved	\$0.00
Carry over from May 4, 2016 meeting. With the stipulation that barrier in CT to be coordinated with Con ED. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0027CO	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10003	Requested approval for the electric service equipment proposed to be installed	217 West 57th Street New York NY	On Hold	\$0.00
Carry over from April 13, 2016 meeting. 1) Fire pump service switchboard to have neutral conductor and to be bonded and grounded, sec's undersized R1FP. 2) Future fire pump service switch undersized. 3) DP-12 bus of 1000 KVA transformer undersized. 4) Bus sizes not shown on 3000 KW transformer gen set. 4) 3000 KW 4000 amp breaker to have GFI indication. 5) Change note on DWG L-No 2000 amp switch in switchboard-EM for DSBPMCP. 6) 1 Line don't physical for OSDP-MEP. 7) Explain the use of the neutral conductor on the double ended swbd R1/R2, is there transformer difference being used to protect transformer. 9) Provide short circuit study performed and signed, sealed by a P.E.. 10) Dwg M-3000 smp and 1200 amp fuses don't coordinate.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53961	16A0182	Heso Electrical Inc. 33-06 Ditmars Blvd. Astoria NY 11105	Requesting permission to install 1000 volt equipment for a solar photovoltaic system, Solar edge three 277/480V Grid SE20KUS, and Hyundal Solar module T1-Series on a non 1000 KVA service	1734 Bathgate Avenue Bronx	Approved	\$650.00
<p>1) Need detailed information of the service bus (4000) and switch is 2000A on the one line and tap details. 2) Clarify transformer size 500 of 750 KVA. 3) Show clearances around transformer and cable termination compartment. 4) Provide cuts of solar AC panelboards. 6) Not in Advisory format. 6/30/16 Job finalized . Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53879	16A0212	Goldstar Electric Inc. 59-24 57th Street Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	75 Henry Street Brooklyn NY	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	16A0244	Barth-Gross Electric Co., Inc. 46-02 37th Avenue Long Island City NY 11101	Requesting permission to leave as installed two-120/208 volt circuit breaker panels installed as per Table 110.26(A)(1) Condition 3 with a front clearance of 32 inches where one existing panel was replaced with new	450 Park Avenue New York NY	On Hold	\$0.00
<p>More infor required concerning other equipment in room and if panel can be installed in another location.</p>						
54056	16A0270	Fraccavento Electric Corporation 2375 McDonald Avenue Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	771 Metropolitan Avenue Brooklyn NY	Approved	\$650.00
<p>1. Provide coordination study - signed, sealed by a P.E. 8/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54027	16A0303	First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	500 Metropolitan Avenue Brooklyn NY	Approved	\$650.00
7/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53880	16A0323	Arch Electric Inc. 42-44 Crescent Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1790 Broadway New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53883	16A0328	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Lenox Hill Hospital 100 East 77th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53881	16A0333	Queensboro Electrical Contracting Corp. 12-23A 150th Street Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	336 Himrod Street Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0345	Allran Electric 120 Broadway,36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	Pier 57 Hudson River Greenway New York NY	Pending	\$650.00
1) Fire pump feeder not fire rated-normal and emergency. 2) Provide plan view of generator enclosure with clearance dims 3) Provide physical details of gen distribuion.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53882	16A0355	I.P. Electric Inc. 143 30th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	112 West 25th Street New York NY	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/26/16 Swap Dwg 1 Rev 1 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53873	16A0359	Patriot Electric Corp. 58-71 57th Road Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	Whole Foods Market 1095 Avenue of the Americas New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53850	16A0369	Walsh Electrical Contracting Inc. 15 Newark Avenue Staten Island NY 10302	Requested approval for the electric service equipment proposed to be installed	334 Furman Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53884	16A0373	Matore Campisi & Sons Lic. Electl Contrs, 18-31 Decatur Street Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	155 West 23rd Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0375	Top Shelf Electric Corporation 46-41 Vernon Boulevard Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Hudson Yards 550 West 34th Street New York NY	Denied	\$650.00
<p>1.52nd floor Transformer room and standby room, and emergency transformer rooms to be mechanically ventilated</p> <p>2.Switch board 55B-2 switch sizes don't match approval 53469</p> <p>3.Switch board 55B-3 fusing don't match approval 53469</p> <p>4.GEN-1 Through bus undersized</p> <p>5.Continuation numbers on drawing don't correspond with other drawings</p> <p>6.Cable sizes not shown on Sheet 2 or 12: Swbd 9-1, 9-1</p> <p>7.Fuse port numbers not shown on Swbd 9-2</p> <p>8.Format difficult to follow. Reduce jumping between sheets.</p> <p>9.Short Circuit study recommendations confirm fuser/conductors changed on updated drawings</p>						
53863	16A0390	Romero Electric LLC 147 West 35th Street, Suite 907 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	86-55 Broadway Queens NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53954	16A0396	Hatzel & Buehler, Inc. 230 Park Avenue New York NY 10169	Requested approval for the electric service equipment proposed to be installed	1114 6th Avenue New York NY	Approved	\$650.00
1) Bus feeding the 2-2000A s.s. undersized. 2) Need 3' on the side of the board to the wall. 3) Typo (3) 100A fuses instead of 4.. 6/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54018	16A0399	Roz-A-Lite Electric 159 20th Street, Suite 401 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	234-238 East 23rd Street New York NY	Approved	\$650.00
<p>1.7 Service switches installed not counting F.A & F.P 2.QED -2 service Bus undersized 3.Equipment grounding conductor load size of 800 switch undersized 4.Service Conductors feeding QED-2 (main service swbd) undersized 5.Confirm generator not separately derived 6.Available short circuit current at swbd "HDP" is in question. Switchboard rated 65KA with 119KA available at POE. Short circuit calculations include 50ft of Con Ed cable. This cable should not be included in calculations. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.2/13/17 Swap dwg # 1 of 2 Rev 2</p>						
53852	16A0401	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	501 7th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53872	16A0402	Jaros Baum & Bolles 80 Pine Street New York NY 10005	Requesting permission to install an manual operated fire alarm transfer switch from the load side of transformers serving a double ended switchboard that will connect to a automatic fire alarm ATS that will be connected to the buildings generator, which will allow the ability to transfer power between each side of the double ended switchboard in case of power failure or for maintenance one side of the switchboard	NYU Langone Medical Ctr New York NY	Approved	\$0.00
With the stipulation that Advisory Board filing is required. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53875	16A0407	Major Electric Inc. 41-30 37th Street Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	540 West 53rd Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54135	16A0409	SRS Electric 281 Skip Lane Bayshore NY 11706	Requested approval for the electric service equipment proposed to be installed	1050 6th Avenue New York NY	Approved	\$650.00
<p>1.Service switch clearance to comply with 230.64(B)(1)</p> <p>2.Provide type of Fire Rated conductors that will be installed for Fire Pump and manufacturer’s instructions showing that the fire rates convertors can be installed in conduit.</p> <p>3.Cut sheet of meter banks and overcurrent devices not provided, show coordination</p> <p>4.Genset cut sheet not provided</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector’s review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector’s review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/5/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53856	16A0410	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	1090 Amsterdam Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53870	16A0411	Evenlite, Inc. 2575 Metropolitan Drive Trevose PA 19053	Requesting approval for use in New York City of your Central Lighting Inverter System. Model/Series Numbers: LM/E3MAC-1000, 2200, 2800 and 3000.		Approved	\$200.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0412	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	47 West 66th Street New York NY	On Hold	\$650.00
<p>1) Bus undersized in Gen-DG-3 3000 amp switch. 2) DP-EMM-GEN-5 and 6/3 4/0 fused at 1200 and EGC is undersized, and 3 sets of 600 fused at 225A typo. 3)ATS-GEN-4/3-A--show fuse size from DP-EM panel on 22nd floor. 4) ATS-GEN-4/3-B- show fuse size from DP-EM panel on 22nd Floor. 5) Show normal fuse size for fire pumps. 6) Show normal fuse size for fire alarm. 7) EGC to fire pump emergency switches undersized. 8) Neutral in fire alarm emergency switch bonded and grounded on a non separately derived system. 9) Existing pull boxes to be barriered to separate normal and load cables. 10) DP-GEN-3-EMM rear working clearance not code compliant. Is switchboard front accessible only? 11) Clearance around DG-3 1500 KW generator inadequate. 12) Clarify rear access of ASCO parallelling switchboard. 13) Make changes to upgrade CB's per coordination study</p>						
53946	16A0413	Caruso & Sons Electl Contr Contg Inc. 412 City Island Avenue Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	Time Warner Cable - Ph 2 25-20 BQE Queens NY	Approved	\$650.00
<p>1. Verify that the ATS(s) in the service room are not for life safety 2. Confirm adequate from clearance for Con Ed 10-pt meter. 6/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53868	16A0414	Campbell and Dawes Ltd. Electrical Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	450 Lexington Avenue New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53901	16A0417	AKF 165 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	160 Water Street New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
53876	16A0418	C.M. Richey Electrical Contractors, Inc. 347 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	413 West 14th Street New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53957	16A0419	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Hudson Yards -Tower A 500 West 33rd Street New York NY	Approved	\$650.00
<p>1.Dwg C2 - verify size of fire alarm feeders and feeder to fire room 208V switch and control not shown 2.Dwg F2 - panel board TA-ED-DS-11B(TW) bus on line & load side of 3000 amp disconnect switch to be rated at 800 amps per square inch 3.Dwg G2 - panel board TA-ED-DS-11A(TW) bus line & load side of 3000 amp disconnect switch to be rated at 900 amps square inch 4. Dwg C2 - Fire pump switch undersized. 6/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54229	16A0420	Nash Electric 284 East 236th Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	207 West 79th Street New York NY	Approved	\$650.00
<p>1.Size of main bonding jumper not shown 2.3 pole ATS used on separately derived system 3.Meter Banks not included in short ckt study to show coordination With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/29/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54329	16A0421	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	707 Broadway New York NY	Approved	\$650.00
<p>1.Service room to comply with section 230.64(B)(5) 2.Where is existing cogen located? Provide approval # for it 3.New service switch, 1 line shows 3000A, Floor plan shows 4000A 4.Suggest removing double doors between rooms. Leave as open passageway 5.Confirm access to conduit pull box behind 1200A Transformer primary switch 6.Physical does not match room layout 1600A switch in MDPB. 1/31/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53869	16A0422	Solar Electric System Inc. 452 West 55th Street New York NY 10019	Requesting permission to leave as installed fire rated RHH conductors for fire pump wiring system installed prior 9/2012 when the conductors were delisted by UL and relisted in 2014.	89-11 Merrick Blvd. Queens NY	Approved	\$0.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53862	16A0423	Qnnc Electric 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Cogen Project 300 Central Park West New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53853	16A0424	AMC Electrical Services, Inc. 140 18th Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	38 Warren Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53949	16A0425	zardos Mechanical & Electrical Engineerii 240 West 35th Street, Suite 304 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	14 Washington Place New York NY	Approved	\$650.00
<p>1.Verify number of sets of tapped conductors from panel to panel 2.Correct Typo on 4000 amp note for incoming bus. 6/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53855	16A0427	J.A. Lee Electric Corp. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	140 Broadway New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53877	16A0428	L.E.A. Electric Corp. 2112 Broadway, Suite 204 New York NY 10023	Requested approval for the electric service equipment proposed to be installed	41 Flatbush Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0429	Facility Solutions Group 260 West 30th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	101 Pennsylvania Avenue Brooklyn NY	Denied	\$650.00
<p>1. Advisory Board drawings to be submitted by a NYC Licensed Electrician or PE with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53857	16A0431	Demand Electric, Inc. 230 49th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	80 58th Street, Third Floor Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53864	16A0433	Katco Electric, Inc. 44-15 Barnett Avenue Long Island City NY 11104	Requested approval for the electric service equipment proposed to be installed	Pace University 1 Pace Plaza New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54021	16A0434	EDM Electric, Inc. 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	30 West 46th Street New York NY	Approved	\$650.00
<p>1.3 Pole ATS' installed on a separately derived generator system 2.Neutral in service switch #2 to be bonded and grounded 3.Tapped conductors undersized 4.Verify 3 feet clearance in front of 400 & 200 Amp discount switches on side of switch board with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	16A0435	Levinson & Santoro Electric Corp. 18-20 130th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	P.S. 42 - Queens 488 Beach 66th Street Queens NY	Administrative Closure	\$0.00
<p>SANDY: 1.Emergency F.A. switch drawn backwards 2.Jockey pump tap to be ahead of ATS on normal side 3.Fire pump fuse to large. 8/5/16 Void as per submittal #16A0603.</p>						
53899	16A0436	Levinson & Santoro Electric Corp. 18-20 130th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	46-02 47th Avenue Queens NY	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53858	16A0437	Kleinknecht Electric Co., Inc. 252 West 37th Street, Suite 1402 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	200 Liberty Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53878	16A0438	Glo Electric LLC. 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	530 Exterior Street Bronx NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53846	16A0439	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	1335 6th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53847	16A0441	H & L Electric, Inc. 41-11 28th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	345 7th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53898	16A0442	Striano Electric Co., Inc. 42-24 Douglaston Parkway Douglaston NY 11363	Requested approval for the electric service equipment proposed to be installed	St. John's University Bent Hall Renovation Queens NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53849	16A0443	Gilston Electrical Contracting Corp. 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	NYULMC 303 Second Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/26/16 Swapped drawing A-Revision 1						
	16A0444	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	43-22 Queens Street Long Island City NY	Denied	\$650.00
1.Block off rear of switchboard MS-B 2.Second means of Egress required for service room 3.Verify that no emergency feeders will be installed in the service room 4.MS-A bus feeding circuit undersized 5.MS-A neutral not bonded and grounded 6.Fire pump service switch neutral to be bonded and grounded 7.300 KVA transformer T3 over fused 8.Transformer T1 secondary over fused 9.Verify 8 sets of 400 KCM in 5-4" conduits 10.Verify 14 sets of 800 KCM in 8-4" conduits 11.Ground bus in switchboards undersized						
53886	16A0445	Queue Electrical Contractors, Inc. 58-38 59th Street Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	2264 Morris Avenue Bronx NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54227	16A0446	Top Shelf Electric Corporation 4386 Victory lvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	28-02 Jackson Avenue Queens NY	Approved	\$650.00
<p>1) Verify 5' clearance in front of fire pump service switch. 2) Transformer cut sheets not provide, showing listing. 3) Bus in 4000 amp transformer disconnect switches undersized. 4) Drawing 2-MSS-1 correct typo in service switch #3 5) Drawing 2 of 6 correct note referring to drawing 3 of 5 for fire alarm and correct note on drawing 4 of 6 for F.A. ATS.. 6) Drawing 3-fire pump feeder undersized Bldg B1. 7) Confirm transformer primary switches rated for transformer inrush current. 8) Network protector ventilation load: if load is 3 phase 4W then 4-pole ATS is required. 9) Follow recommended changes to fuse types in coordination study. 8/22/16 1) Transformer cut sheets do not show listing. 2) Item #6 not addressed. 3) Where is the emergency feed for the network protector fan being taken from not on 1 Line? 11/29/16 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53900	16A0449	Top Shelf Electric Corporation 4386 Victory Blvd Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	19 Park Place New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53950	16A0450	Metro Electrical Contractors, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	97 Wythe Avenue Brooklyn NY	Approved	\$650.00
1. Egress doors to open out. 6/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53859	16A0453	Atlas-Acon Electric 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	645 5th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53897	16A0454	OM Electric, Inc. 262 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	9-19 9th Avenue New York NY	Approved	\$650.00
This submittal supercedes 15A0756 which is void. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53860	16A0455	OM Electric, Inc. 262 West 38th Street, Suite 1202 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	189 Berry Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53887	16A0456	Megan Electric 3651 Bell Blvd., Suite 208 Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	1205 Manhattan Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53861	16A0457	MT Electric 137-39 Kalmia Avenue Flushing NY 11355	Requested approval for the electric service equipment proposed to be installed	211 East 43rd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53867	16A0458	Response Electric Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	166 East 35th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53866	16A0459	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	1220 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53896	16A0460	M & R Electl Contg and Repair Servs. Inc. 149 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	1650 Broadway New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53888	16A0461	V-Mar Electric Ltd. 408 Grand Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	521 West 57th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/23/16 Swapped Drawing 1-Revision 2.						
54061	16A0463	AL-Lectric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	151 Maiden Lane New York NY	Approved	\$650.00
1. Generator Strip 2. Service switch 1 & 2 require GFP 3. Provide available short circuit current at panel 'RP-1' and panel rating. 8/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53895	16A0464	AL-Lectric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	97-45 63rd Drive Rego Park NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/30/16 Swapped drawing1-Revision 1.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53889	16A0465	AL-Lectric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	158-15 Union Turnpike Fresh Meadows NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53894	16A0466	ECNY Electric 42 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	112-07 14th Avenue College Point NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53885	16A0467	Accurate Electrical Corp. 11-07 43rd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2763 Morris Avenue Bronx NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0468	Horsepower Electric 4101 1st Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	250 South Street New York NY	On Hold	\$650.00

1) 71st Floor electrical room door and to open outwards. 2) Bus bars on secondary's of transformers 1000KVA or larger to comply with 408.60 (E)(1) and 240.21(c)(2). 3) Drawing 3 panel c verify 200 amp disconnect switch. 4) Drawing 5-277/480 volt disconnect switches to be GFI. 5) Drawing 5 -MV-27C neutral bonded and grounded after MV-4c. 6) Drawing 5-service entrance conductors to fire pump panelboard undersized and bus in panelboard undersized. 7) Verify that cogen system is listed. Provide manufacturer's cut sheet. 8) Verify 3/0 neutral for fire alarm system, Drawing 5. 9) 2 section bus' in MDBH-2 undersized Drawing 5. 10) Verify size of service entrance conductors to SS #3C, fire pump and F.A. Drawing 5. 11) Drawing 6-Bus undersized MDBH-3 panelboard. 12) Transformer secondary neutral to be grounded one time, either at the transformer terminal or the secondary main-not both. 13) Provide details of cogen system. 14) Provide rear clearances per 110.34(A) for 5KV equipment (2300V L-G). 15) All doors to swing out. Provide 2 means of egress where required. 16) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

With the stipulation:

Fire Rated Enclosure's must comply with the following:

1. A P.E. or R.A. must file a PWI as an AIT 3.
2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.
3. The fire proofing must be performed by a certified fire proofing installer.

53890	16A0469	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	1010 Park Avenue New York NY	Approved	\$650.00
-------	---------	--	--	---------------------------------	----------	----------

Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/14/16 Swapped Drawing 1,2 and 3-Revision 1. 8/24/16 Swapped drawing 1,2 and 3-Revision 3s. No more as built drawings. Resubmittal required.

54088	16A0470	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Brooklyn Navy Yard Building #72 Brooklyn NY	Approved	\$650.00
-------	---------	--	--	---	----------	----------

Provide plan view showing 2500KVA transformer and 5KV switch. 9/12/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53854	16A0471	Matros Automated Electl Constn Corp. 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	11 East 26th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/14/16 Swapped Drawing 1-Revision 1.						
53891	16A0472	FSM Electrical Corp. 38-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	529 Broadway New York NY	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53892	16A0475	HIG Electrical Associates NYC, Inc. 25-26 50th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	235 Park Avenue South New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53848	16A0476	Royal Electrical & Wiring Corp. 2558 Marion Avenue Bronx NY 10458	Requested approval for the electric service equipment proposed to be installed	140 West Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53893	16A0477	Queue Electrical Contractors, Inc. 58-38 59th Street Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	33-01 38th Avenue Queens NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0478	Eastern Electrical Construction Inc. 149-07 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	The Lewis Steel Building 76 North 4th Street Brooklyn NY	Pending	\$650.00
1. Provide available short circuit current at new panels PPAI, PPF, PPD and new meter bank. Provide equipment short circuit ratings.						
	16A0481	Multi-Phase Electrical Services, Inc. 1916-38 Park Avenue, STE 406 New York NY 10037	Requested approval for the electric service equipment proposed to be installed	1st Main Street Roosevelt Island NY	Denied	\$650.00
<p>1. Indicate on drawing which switch boards are supplying power to this building</p> <p>2. There are no 800 Amp Fire pump switches on 15A0 283</p> <p>3. Verify amount of conductors and conduits feeding 3000 Amp disconnect switch</p> <p>4. How does 250 mcm terminate into 60 amp Fire Alarm switch</p> <p>5. Verify that feeders supplied from 15A0 283 are underground</p> <p>6. Add note to drawing that installation will comply with 225.36 & 225.37</p> <p>7. Remove fusing from Fire Pump & Fire Alarm disconnect switches</p> <p>8. Generator feeder to comply with 445.13</p> <p>9. Are the generator and distribution equipment in the same room</p> <p>10. Fire pump feeders are not fire rated</p> <p>11. Grounding system to comply with 250.32(B) & 250.32(D)</p> <p>12. Neutral link(s) not provided 225.36</p> <p>13. ATS-EM & ATS-LR not to be 3rd fusing for Fire Alarm System</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						

ADVISORY BOARD CALENDAR

June 8, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53865	16A0482	Montgomery Electrical Contracting Corp. 4250 Van Cortland Park East Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	156 North 4th Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53960	16A0483	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	591 3rd Avenue New York NY	Approved	\$650.00
1) Service bus undersized. 2) Fire pump feeder not fire rated. 6/30/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/13/17 Swapped drawing 1-Revision 2.						
	16A0484	Goldman Copeland Associates 229 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	55 5th Avenue New York NY	Denied	\$650.00
1) Provide Advisory Board approval and electrical application the FA repair of service equipment 110.2(B)(2). 2) Neta report not submitted to replace water damaged equipment witnessed by a P.E. by signing , sealing report. 3) Full detailed report of what work ws performed was not submitted. 4) Design engineer to appear at Advisory Board meeting. Note: Provide statement confirming that the cause of the prior flooding has been mitagated, or relocate equipment to an area above the existing service room.						