

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51667	13A0051CO	Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	Throgs Neck Shopping Center 815 Hutchinson River Pkwy Bronx NY	Approved	\$0.00
Carry over from March 13, 2013 meeting. 9/20/13 Swapped for Rev. 2 single line drawing..						
	13A0190CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	4 New York Plaza New York NY	On Hold	\$0.00
Carry over from April 17, 2013. 1) Verify that existing service switches and service bus ties were not water damaged. 2) Verify that water main electrode is bonded to building steel. 3) Is fire pump splice 13ex from THHN to MI cable located in fire rated room? 4) Provide neutral links in 480 volt switchboards. 5) Verify that fire alarm system is being picked up from the generator. 6) Verify that all life safety is being picked up from the generator. 7) Verify size of normal fire pump switch. 8) Item #9 not addressed. 9) Item #10 not addressed. 10) Item #11 partially addressed. 11) Someone who designed this installation to appear when next meeting is scheduled. 12) Coordination study diagrams are to small to read. Coordination study not stamped by a PE.						
51783	13A0197	Spirelli Electric Inc. 1901 Amethyst Street Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	345 Adams Street Brooklyn NY	Approved	\$650.00
Bonding, grounding, and neutral links not shown on existing drawing. 7/30/13 job finalized.						
51760	13A0198	J. United Electric 651 Willowbrook Road Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	589 Fifth Avenue New York NY	Approved	\$650.00
1) Main and supplemental grounding electrode not shown on drawing. 2) Tap conductors over 10ft long main overcurrent disconnect means not provided at new distribution panel. 3) Provide barrier between bus bars and conductors on bottom of switchgear 408.3 Exception. 7/25/13 job finalized.						
51779	13A0199	Enterprise Electrical Systems, Inc. 40 Emerson Court Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	35 West 15th Street New York NY	Approved	\$650.00
1) Fire alarm emergency disconnecting means neutral bonded to enclosures (All 3 pole ATS installed). 2) Mechanical ventilation not provided at service room. 7/29/13 job finalized.						

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51743	13A0200	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	BSH 150 East 58th Street New York NY	Approved	\$650.00
Main grounding electrode not provided at 100A s.s. 7/24/13 job finalized. 9/20/13 Drawings swapped for Rev. 2						
51775	13A0201	Meir Electrical Corp. 423 East 78th Street New York NY 10021	Requested approval for the electric service equipment proposed to be installed	250 East 65th Street New York NY	Approved	\$650.00
Grounding not shown in existing switchboard. 7/29/13 job finalized.						
51899	13A0202	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	170 Broadway New York NY	Approved	\$650.00
1) 1200 and 800 amp service switches to have grounding electrode terminals. 2) Verify MI with aluminum conductors. 3) No one line shown in co-ordination study-explain co-ordination of HLM06 (BL-2) to BL-1 in time OJ2/current range and coordination of 400ALPN fuse to BL-2 breaker in rage from 1-2 sec. 9/24/13 Job finalized. 9/17/14 Swapped A & B, Rev 1, C-Rev 2.						
51744	13A0203	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	NY Life Service #9 Upgrade 51 Madison Avenue New York NY	Approved	\$650.00
Verify that service room has mechanical ventilation. 7/24/13. Job finalized. 11/24/15 Swapped Drawing A, Revision 3 and Drawing B, Revision 2.						
51694	13A0204	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	180 Broadway New York NY	Approved	\$650.00
Grounding electrode conductor to be terminated into 400 amp service switch. 7/15/13 job finalized.						

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51705	13A0205	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Fulton J. Sheen Ctr 18 Bleecker Street New York NY	Approved	\$650.00
1) Verify that switchboards have rear hinged doors. 2) 250 MCM emergency conductor overfused. 3) Coordination curves submitted for generator. Job finalized 7/16/13. 5/14/14 Swapped drawings A & B Rev 5.						
51668	13A0206	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 5th Avenue New York NY	Approved	\$650.00
51944	13A0207	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Governor Island 10 South Street New York NY	Approved	\$650.00
1) Equipment grounding conductor at secondary of 45 KVA transformer undersize. 2) Verify grounding electrodes provide at each. 3) Primary transformers overfused. 9/10/13-Grounding electrode conductor at secondary of 225 KVA transformer undersize. 10/10/13 job finalized.						
52742	13A0208	Redline Electric Inc. 1715 East 9th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	27-18 Hoyt Avenue Queens NY	Approved	\$650.00
1) Grounding electrode not provided at F.A. s.s. NYC Amendment Article 760. 2) Block/Barrier behind service equipment. 3) Submit coordination/short circuit must be submitted per 30-2018.L. 1/14/15 Job finalized. 3/30/15 Swapped Drawings 1 and 2, Revision 2s.						
51669	13A0209	A.S.K. Electrical Contracting Corp. 26-50 BQE West Unit 2 Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1182 Broadway New York NY	Approved	\$650.00
9/16/14 Swapped Drawing 1, Rev 1.						

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51670	13A0210	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	AT & T 630 West 55th Street New York NY	Approved	\$650.00
51758	13A0211	J.A. Lee Electric, Inc. 23-30 50th Avenue. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	AT & T 425 Madison Avenue New York NY	Approved	\$650.00
1) Building is steel structure #6 supplemental grounding electrode undersize. 2) Confirm fuse for new service switch (400?). 7/25/13 job finalized.						
51759	13A0212	Bestco General Electrical Inc. 922 East 233rd Street Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	229 Meserole Street Brooklyn NY	Approved	\$650.00
Supplemental grounding electrode not shown at s.s. #1. 7/25/13 job finalized.						
	13A0213	Roz-A-Lite Electric 163 20th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	170 Amsterdam Avenue New York NY	On Hold	\$650.00
1) GFP not provide at 1000Kva step-up transformed. 2) Grounding electrode and system bonding jumper not shown at transformer secondary. 3) Secondary overcurrent disconnect means not shown for transformer. 4) Second fusing not shown s.s. #4, s.s. #6. 5) Service room not mechanical ventilation. 6) Provide coordination/short circuit 27-3018.L.						
51671	13A0214	Laredo Electric, Inc. 2477 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	80 Fifth Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51672	13A0215	E.S.B. Electric Corp. 250 Walton Avenue, Suite 25 Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	110 West 40th Street New York NY	Approved	\$650.00
10/18/13 Swapped Rev 2. 12/17/15 Swap Drawing 1-Revision 3.						
51673	13A0216	FSM Electrical Corp. 36-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	123-125 West 28th Street New York NY	Approved	\$650.00
51674	13A0217	MSM Electric, Inc. 417 Brighton Beach Avenue Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	8 West 40th Street New York NY	Approved	\$650.00
51675	13A0218	MSM Electric, Inc. 417 Brighton Beach Avenue Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	80 Bruckner Boulevard Bronx NY	Approved	\$650.00
51676	13A0219	Demand Electric, Inc. 1219 Rocaway Avenue Brooklyn NY 11236	Requested approval for the electric service equipment proposed to be installed	4 East 28th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51754	13A0220	Samson Electric Corp. 825 8th Avenue, 2nd Fl. New York NY 10019	Requested approval for the electric service equipment proposed to be installed	515 7th Avenue New York NY	Approved	\$650.00
1) 1600 service switch not shown on room layout. 2) Physical of line side reinforcement location not shown. 7/25/13 job finalized.						
51677	13A0221	Techno-Volt Electric, Inc. 28-29 119th Street Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	Goddard Riverside Comm. Ctr 166 West 87th Street New York NY	Approved	\$650.00
51768	13A0222	HV Electric Corp. 36-17 Bud Place Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	1407 Broadway New York NY	Approved	\$650.00
1) Tap conductors undersized. 2) Provide signage on distribution switches warning that it is supplied by 2 sources. 3) How are the conductors routed to the distribution switches 408.3 Exception? 7/26/13 job finalized.						
51678	13A0223	M & R Electl Contrg and Repair Serv Inc. 149 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	21 West 46th Street New York NY	Approved	\$650.00
12/22/14 Swapped 1 and 2, Revision 1.						
51787	13A0224	Brandl Electric 1927 Mott Avenue Far Rockaway NY 11691	Requested approval for the electric service equipment proposed to be installed	Jetro/Restaurant Depot 100 Oak Point Avenue Bronx NY	Approved	\$650.00
1) Grounding electrode conductor and supplemental grounding conductor undersized. 2) Size of main bonding jumper not shown. 3) Verify size of service entrance and feeder conductors for fire alarm system. 4) Provide coordination/short circuit as per 27-3018.L. 8/13/13 Job finalized.						

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51947	13A0231	GTS Electrical 218-14 Northern Blvd. Bayside NY 1136	Requested approval for the electric service equipment proposed to be installed	39-06 30th Street Queens NY	Approved	\$650.00
1) Fire pumps service entrance emergency circuit and normal circuit conductors under size. 2) Normal and emergency feeders to distribution panel EDP over fused. 3) Fire pump emergency feeder under fuse not 150%. 4) Physical for distribution panel #2 different from one line diagram. 5) Verify EM fire pump circuit is fire rated. 6) Provide coordination/short circuit per 27-2018.L. 10/23/13 job finalized.						
	13A0232	A Tech Electric Enterprises, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	P.S. 316 @ New School 90-01 101ST Avenue Queens NY	Rejected	\$650.00
1) Fire pump service entrance equipment grounding conductor undersize. 2) Verify fire pump circuit conductors fire rated/concrete encased.(using RHH/RHW2). 3) Grounding electrode not provided at fire alarm s.s. 4) Verify 7ft in front of F.P.S.S. and S.S. #2. 5) Provide a second door. 6) Cut back concrete pad (tripping hazard). 7/29/13-#1 partially address(Article 250.122). #3 not addressed(NYC Amendments Section 760.22). 2/24/14 Rejected. Fire pump circuit conductor equipment grounding conductor undersized. 4/17/14 Job finalized. 9/15/15 Rejected. Approved drawings. 1 of 2, Revision 2. New Revised drawings show 1 of 3, Revision 0, 2 of 3, Revision 2, 3 of 3, Revision 0-Drawings don't show changes in title blocks-old drawing resubmitted showing fire pump equipment grounding conductors undersized, old drawings resubmitted. Resubmittal required..						
51891	13A0233	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU Langone Medical Center 550 1st Avenue New York NY	Approved	\$650.00
SANDY Company paid \$650.00 in error. 1) Verify that switchboard have rear hinged doors. 2) show side clearances of switchboards. 3) Show clearances behind switchboards. 4) Coordination study not provided. 5) 1200 amp service switch to have neutral link M52, M53. 6) Show size of service through bus in M52, 7) Verify if an equipment grounding conductor is being installed on load side of 2000 amp service switch in switchboard M54. 8) Provide clearance distance from equipment to concrete pads egress hazard. 9) Add additional door on right side of switchboard. 7/29/13 1) Provide barrier between the sides of the switchgear that does not have 3' clearance between the Boards or wall. 2) Item #9 not addressed. 3) Job changed additional services and distribution added new submittal required. 9/19/13 job finalized. 5/4/15 Too many changes, feeders, switchgear switches. New submittal required.						
	13A0234	Triple I Electrical Contracting, Inc. 64-05 34th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Steelworks Building 76 North 4th Street Brooklyn NY	Denied	\$650.00
1) 2 main bonding jumpers installed, 1-undersized and 1 with no size. 2) Service bus feeding 3-1200 amp service switches undersized. 3) Coordination study not provided, drawing not stamped by a PE 3018.L. 4) 1" RGS conduit to limited service fire pump undersized. 5) Limited service fire pump to be installed in RGS not EMT. 6) Where is limited service fire pump located. 7) Neutral in 800 trans-meter bonded on load side of service switch. 8) Tap rules apply for meter banks, what is the lengths of the taps?						

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51757	13A0235	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	IS 297 33-54 74th Street Queens NY	Approved	\$650.00
1) Main bonding jumper and switchboard equipment grounding bus undersized. 2) Feeders at loadside of 2000 amps s.s. not shown on drawing. 3) Feeders at loadside of 600 amps s.s. over fused. 4) Coordination study not provided and or drawing not stamped by a P.E. 3018.L. 5) Feeders conductor on loadside of 200A s.s. not shown on drawing. 6) block the side of service board. 7/25/13 job finalized.						
51679	13A0236	Moller & Moller Electric 148-19 Guy R. Brewer Blvd. Jamaica NY 11434	Requested approval for the electric service equipment proposed to be installed	27-35 Jackson Avenue, LLC 27-35 Jackson Avenue Long Island City NY	Approved	\$650.00
52073	13A0237	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	11 East 68th Street New York NY	Approved	\$650.00
1) Grounding electrode not provided at multi enclosures s.s. (F pump 1200A s.s. and 2,500A s.s.). 2) Coordination study and or drawing submitted not stamped by a NYS PE-NYC Amend-Section 27-3018.L. 3) Provide documentation that the meter banks assembly is rated for the available fault current. 1/13/14 job finalized. 12/23/14 Swapped 1. Revision 2.						
52994	13A0238	Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requested approval for the electric service equipment proposed to be installed	Riverdale Crossing North Bldg. 193 West 237th Street Bronx NY	Approved	\$650.00
1) Tap of conductor is undersized. 2) Coordination study and or drawing submitted not stamped by a N.Y.S. PE- NYC Amend. Section 27-3018L. 11/23/13 1) Item #1 is for future 800 Trans S and switch. 2) Drawing not identified as Rev 1. 4/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52072	13A0239	Power Masters Electrical 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	400 West 155th Street New York NY	Approved	\$650.00
1) Main grounding electrode not provided at all multiple enclosures s.s. 2) Supplemental grounding electrode not shown on drawing. 3) 800 amps Trans and s.s. neutral not bonded to enclosure. 4) Service entrance and feeder conductors at 800a trans s and s.s. overfused. 5) Feeders and tap conductors at loadside of 1600A s.s. undersize. 6) Equipment bonding conductor install with f.p. service entrance undersize. 7) Incorrect size fuses shown at 400A trans S and sw. 8) Provide coordination study & short circuit per 27-3018.L. 10/29/13 rejected items 6, 7 not addressed. 1/10/14 job finalized. 9/15/14 Rejected. 1) New drawing shows revision 3 in the Title Block with no indication of changes on the room layout drawing. 2) Will 2 meters be installed for the fire pump? 5/22/15 Swapped Revision 4. 1/19/16 Swapped drawing 1-Revision 5.						

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51822	13A0240	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Oceana Residence 50 Oceana Drive West Brooklyn NY	Approved	\$650.00
1) Main grounding electrode not provided at 200A s.s. 2) Provide coordination and short circuit per 27-3018,L. 8/16/13 job finalized. 5/22/15 Swapped Revision 2.						
51680	13A0241	Crana Electric Inc. 600A East 132nd Street Bronx NY 10454	Requesting permission to use 6"x6"x36" troughs for supporting conductors in a verical run.	Marriot Courtyard 21-23 West 37th Street New York NY	Approved	\$350.00
Special Permission Approval for concept only. Subject to field inspection.						
52246	13A0242	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University Manhattanville New York NY	Approved	\$650.00
1) Provide fire pump emergency information. 2) Fire pump switch information not provided. 3) Fire pump feeder to be fire rated. 4) Verify that switchboard rooms are mechanically ventilated. 5) Coordination study indicates uncoordinated devices(Pg 18. 19). 8/16/13 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
51830	13A0243	Schlesinger Electrical Contractors, Inc. 664 Bergen Street Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	60 Hudson Street New York NY	Approved	\$650.00
GFP not provided as per Article 215.10. 8/21/13 job finalized						
51681	13A0244	Cross Hudson Electrical Inc. 240-21 Braddock Avenue Bellerose NY 11426	Requested approval for the electric service equipment proposed to be installed	380 Layatette Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51831	13A0245	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	470 Vanderbilt Avenue Brooklyn NY	Approved	\$650.00
1) Neutral bonded on load side of service switch. BB-1. 2) Provide length of tapped conductor BB-1. 7/29/13- Rejected drawings D & E added-showing 2 new services new submittal required. 8/22/13 job finalized.						
	13A0246	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Hunter Point South 1-55 Borden Avenue Queens NY	On Hold	\$650.00
1) Verify that Capstone equipment is listed. 2) Verify that service room and ATS rooms are mechanically ventilated. 3) Verify that Con-Ed box is located in a fire rated room directly below the service board or provide elevation drawing. 4) Main bonding jumper undersized. 5) Energized vertical bus connected to neutral in 2-1200 amp service switch enclosure, vertical bus size not shown. 6) Provide tap lengths to emergency fire alarm disconnect switch and MEDP-2 disconnect switch. 7) Verify conductor size to 600 amp bus duct switches, top. 8) Jockey pump cannot be tapped in special fire pump ATS controller. 9) Tap conductor to 800 amp switch overfused. 10) Emergency systems to be connected to generator. 11) Provide sequence of operation for Capstone installation. 12) Fire pump to be connected to generator.						
51682	13A0247	Tarasis Electric Corp. 45-48 51st Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Marte Valle H.S. @ M025 145 Staton Street New York NY	Approved	\$650.00
51683	13A0248	Walsh Electrical Contracting Inc. 76 Midland Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	Van Cleef & Arpels 744 Fifth Avenue New York NY	Approved	\$650.00
51751	13A0249	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	21 East 1st Street New York NY	Approved	\$650.00
Grounding electrode conductor to be terminated in fire pump service switch. Job finalized 7/29/13, 8/29/13 Swapped A-Rev 4 and B-Rev 3.						

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51685	13A0272	A.L. Electrical Corp. 307 7th Avenue, Suite 404 New York NY 10001	Requesting permission to leave as installed a 3/0 copper-13' conductor tap off of a 1600 overcurrent protective device.	120 Riverside Blvd. New York NY	Approved	\$350.00
Special Permission						
51686	13A0275	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requesting permission due to lack of space inside of the existing service room to leave as installed new service equipment located in the adjacent room.	179 Henry Street New York NY	Approved	\$350.00
Special Permission. With the stipulation that signage is provided on each service room indicating where the other service is located.						
51745	13A0308	Brandl Electric 1927 Mott Avenue Far Rockaway NY 11691	Requested approval for the electric service equipment proposed to be installed	Jetro/Restaurant Depot 100 Oak Point Avenue Bronx NY	Approved	\$650.00
1) Line drawing only-provide room layout with service switch location. 2) Show ground/bonding. 7/25/13. 1/13/14 Swapped 1-Line Rev 3.						
51687	13A0315	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	2-26 Washington St.-aka 17 Batter Pl New York NY	Approved	\$0.00
SANDY						
	13A0316	Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	104 Broad Street New York NY	On Hold	\$0.00
SANDY 1) Verify what work is newly installed. 2) Feeders overfused.						

ADVISORY BOARD CALENDAR

June 12, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51706	13A0317	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	175 Water Street New York NY	Approved	\$0.00
SANDY 1) Verify that 4000A vault switch is under control of the utility. 2) Main bonding jumper undersized in 4000A service switches. 3) Show detail of how roll up generators will be connected to 4000 amp disconnect switches show outdoor connection boxes and location 2nd floor or ground floor. 4) Fire pump normal and emergency feeders to be fire rated. 5) Verify 1/0 conductors to 30 amp pull outs. Job finalized 7/16/13.						
51740	13A0318	Maximum Electric Corp. 65-19 Metropolitan Avenue Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	65 Oriental Boulevard Brooklyn NY	Approved	\$0.00
SANDY Grounding electrode conductor to be terminated in service switchboard containing service switches 4,5,& 6. Job finalized 7/19/13.						
	13A0321	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requesting permission to install new circuit breaker panels that will have 32 inches of front clearance where the current panels above the new panels are recessed in a wall that contains asbestos insulation.	10, 20, 30, 40 Richman Plaza Bronx NY	Denied	\$0.00