

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49275CO2	09A0072CO2	High Beam Electric Corp. 37 Kinsey Place Staten Island NY 10303	Requested approval for the electric service equipment proposed to be installed	1545 Atlantic Avenue Brooklyn NY	Approved	\$0.00
Carry over from April 15, 2009 meeting.						
49382CO	09A0141CO	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 1New York Plaza New York NY	Approved	\$0.00
Carry over from April 15, 2009 meeting.						
49385CO	09A0144CO	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	St. John's University 80-40 Utopia Parkway Queens NY	Ok, but	\$0.00
Carry over from April 15, 2009 meeting. 1) Neutral omitted in fire pump service switch, and bond. 2) Grounding electrode conductor to pick up fire pump service switch. 3) Provide neutral disconnect link for 1200 amp switch.						
49399CO	09A0158CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	N.Y.U. Co Gen Expansion 725 Broadway New York NY	Approved	\$0.00
Carry over from April 15, 2009 meeting. See item #4 and #10. 1) Verify what work is new, what work is existing, and what work will be future. 2) 1 line does not match room layout. 3) What work is electrician who filed drawing doing? 4) Verify 3' clearance in front of FACO box. 5) Provide cope compliant schematic for equipment grounding system for multiple buildings. 6) Locate new fuse cutout in 725 Broadway. 7) Correct Con-Ed service voltage for existing service(typo). 8) Confirm new 4160V generator system is compliant emergency source. 9) key interlocks must be installed. 10) Life safety ATS cannot be located in service room. Job finalized 7/29/09.						
49405CO2	09A0164CO2	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	NY Aquarium 502 Surf Avenue Brooklyn NY	Approved	\$0.00
Carry over from May 20, 2009 meeting. Verify 4000A BPS is applied within its rating for inrush is transformer low inrush? Job finalized 10/19/09.						

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49424CO2	09A0183CO2	CMS Electrical Services Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Equity Office Properties 717 Fifth Avenue New York NY	Hold	\$0.00
Carry over from May 20, 2009 meeting. Generator manufacturer to justify use of locomotive cable. Show ampacities and confirm use with molded case circuit breakers.						
49446CO	09A0190CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	N.Y.U. Co Gen Expansion 35 West 4th Street New York NY	Hold	\$0.00
Carry over from May 20, 2009 meeting. 1) 4000A switch in DP-EDU-SUB to be unfused. 2) Show load fed by 1600A switch in DP-EDU-sub. 3) Neutral of 750KVA transformer in ED building to be ungrounded. 4) Correc 1-Line on floor plan. 5) Clearance around 5KV equipment and substation to comply with 110.34 and 110.26.						
49470CO	09A0214CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	N.Y.U. Co Gen Expansion 6 Washington Place New York NY	Approved	\$0.00
Carry over from May 20, 2009 meeting. 1) Verify 'normal' and 'alt' source designation for all ATS's. 2) Lincoln to submit revised floor plan. Job finalized 7/29/09.						
49471CO	09A0215CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	N.Y.U Co Gen Expansion 715 Broadway New York NY	Approved	\$0.00
1) Close off access behind substation. 2) Verify ampere rating of Con-Ed service and service switchboard. 3) Correct 1-Line, change 1200 sw to 1600A. 4) Verify existing bus size. Job finalized 7/29/09.						
49478CO	09A0222CO	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	JPMC 270 Park Avenue, Floors 12-23 New York NY	Ok, but	\$0.00
Carry over from May 20, 2009 meeting. 1) Verify that there is a 12th floor distribution room besides the 2 service rooms. 2) Verify that generator is properly bonded and grounded. 3) Drawing L & 6 show largest size fuse on bus duct. 4) drawing G shows 2000 amp bus connected to 4000 amp fuse. Job finalized 7/16/09,						

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49493CO	09A0237CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	U Warner Weaver Cogeneration Pl 251 Mercer Street New York NY	Approved	\$0.00
Carry over from May 20, 2009 meeting. 1) Provide written sequence of operation. 2) Verify that rear covers of switchboard are hinged type. 3) Provide proper clearances in service room. 4) Is service room mechanically ventilated? 5) Person who knows job to appear at next meeting. 6) Verify that live bus is 12" off of the floor. 7) Physical drawing does not match 1-Line and is mismarked. 8) Confirm sync check relay(25) connected both side of tie breaker . 9) Show key interlinks on 480V mains and 5KV switches. Job finalized 7/17/09.						
49508CO	09A0240CO	Fab*Am Electric, Inc. 1243 Oakpoint Avenue Bronx NY 10474	Requested approval for use in New York City of your Meter Transformer Cabinet. Model/Series # FTS-400/3240, FTS-400/3480, FTS-800/3240, FTS-800/3480, FTS-R400/3240, FTS-R400/3480, FTS-R800/3240, FTS-R800/3480.		Approved	\$0.00
49509	09A0241	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	J.P. Morgan Chase 4 NY Plaza New York NY	Approved	\$650.00
1) Neutral grounded at Con Ed service and at generator transformers(standby system). Correct violation. 2) Provide coordination study showing new power breakers. Job finalized 12/28/09.						
49510	09A0242	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	R-LIC Realty, LLC 12-16 43rd Avenue Long Island City NY	Hold	\$650.00
More than 6 service switches installed.						
49511	09A0243	Integral Electrical Power & Control Corp. 307 7th Avenue, Suite 507 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	JR Music World 15 Park Row New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49512	09A0244	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	Board of Elections 5112 Seceond Avenue Brooklyn NY	Approved	\$650.00
1) Existing service switch #6 mismarked. 2) 3 sets of 350 MCM fused at 1200 amps. 3) New 800 amp equipment blocks access to existing master meter. 4) Show bus sizes in new panels. Job finalized 7/8/09.						
49513	09A0245	Artic Electric Corp. 25 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Metropolitan Jewish Geriatric Ctr 4915 10th Avenue Brooklyn NY	Ok, but	\$650.00
1) Verify that rear of switchboard does not have removable covers. 2) Verify FLA of fire pump. 3) Service switch and fuses undersized for fire pump. 4) Fire pump normal and emergency branch not fire rated.						
49514	09A0246	Power Surge Electric Inc. 122-20 Montauk Street Springfield Gardens NY 11413	Requested approval for the electric service equipment proposed to be installed	117 Hudson Street New York NY	Ok, but	\$650.00
1) Verify how may sets of conductors Con-Ed is bringing in. 2) Verify who will be installing new service entrance bus bars and perform testing. 3) Fire pump circuit conductors not fire rated. 4) Provide size of fire pump branch circuit.						
49515	09A0247	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	ABC 7 Lincoln Square New York NY	Approved	\$650.00
49516	09A0248	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Central Park North 111 Central Park North New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

June 17, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49517	09A0249	Famularo Electrical Contracting Corp. 60 East 42nd Street New York NY 10165	Requested approval for the electric service equipment proposed to be installed	Lutheran Familyh Ctrs Sunset Pk 5610 2nd Avenue Brooklyn NY	Approved	\$650.00
Show bus size on line side of 2500 amp service switch. Job finalized 7/20/09.						
49518	09A0250	Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	2nd Ave. Subway Temp. Serv. 92nd Street and 2nd Avenue New York NY	Approved	\$650.00
1) 5' clearance needed in front of service switch. 2) Connect grounding electrode conductor to water pipe electrode. 3) Verify adequacy of fault rating of fuse. Job finalized 7/20/09.						
49519	09A0251	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYC College of Technology 300 Jay Street Brooklyn NY	Approved	\$650.00
Verify that service room is ventilated. Job finalized 7/20/09.						
49520	09A0252	RNH Electric Company, Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1 Prospect Park West Brooklyn NY	Approved	\$650.00
49521	09A0253	Athens Electric, Inc. 1980 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	132 Nassau Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49522	09A0254	V-Mar Electric Ltd. 408 Grand Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	401 Park Avenue South New York NY	Approved	\$650.00
49523	09A0255	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	La Casa De La Estrella North 3rd Avenue & East 167th Street Bronx NY	Approved	\$650.00
49524	09A0256	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	La Casa De La Luna South 3rd Avenue & East 167th Street Bronx NY	Approved	\$650.00
49525	09A0257	Universal Electrical Installation Corp. 38-11 Bell Blvd. Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	Rockefeller Univ. Weiss Bldg. 1230 York Avenue New York NY	Approved	\$650.00
Equipment grounding conductor undersized. Job finalized 7/29/09.						
49526	09A0258	Jemco Electrical Contractors, Inc. 92-13 180th Street Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	John Dewey High School 50 Avenue X Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49527	09A0259	Arcadia Electrical Company, Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	284 Baltic Street Brooklyn NY	Approved	\$650.00
Verify if a second door can be installed near new equipment. Job finalized 8/11/09.						
49528	09A0260	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	H & M 435 7th Avenue New York NY	Hold	\$650.00
1) Equipment grounding conductor undersized. 2) Fire pump branch circuit not fire rated. 3) The Fire pump feeder cannot be tapped from the same cubicle that contains overcurrent protective devices, special permission required.						
49529	09A0261	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Sunset Park H.S. 156 34th Street Brooklyn NY	Ok, but	\$650.00
Fire pump switch to be minimum 1 Ft. from service switchboard.						
49530	09A0262	Holtaway Electrical Engineering Services 1691 Route 206 Bedminster NJ 07921	Requested for concept approval for:	Columbia University New York NY	Approved	\$650.00
With the stipulation that you do not locate new 5KV switchgear in vicinity of chilled water piping.						
49531	09A0263	Alef Electric Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed		Approved	\$0.00

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49532	09A0264	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	1844 Second Avenue New York NY	Hold	\$650.00
1) Verify who will be installing new bus bars and performing testing in existing switchgear. 2) All new work to be bubbled on drawing. 3) Verify if generator panel is new or existing and explain taps. 4) FACO normal side and ATS not shown. 5) Verify size and amount of sets to new ATS and transformer. 6) New generator to be bonded to building steel on water main. 7) New transformer to be bonded to building steel or water main. 8) ATS feeds back into normal switchgear without a break in the bus. 9) Transformer for fire pump undersized. 10) Emergency feed to fire pump not fire rated.						
49533	09A0265	Blue Ribbon Electrical Contractors Inc. 500 Smith Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Neff Residence 2 Horatio St., Penthouse C & D New York NY	Approved	\$650.00
1) Verify who will be installing new bus bar and performing testing. 2) 350 MCM fused at 400 amps. Job finalized 2/16/10.						
49534	09A0266	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1 Fordham Plaza Bronx NY	Approved	\$650.00
49535	09A0267	Rosselco, Inc. 988 Morris Park Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	1 Edgewater Plaza Staten Island NY	Approved	\$650.00
49536	09A0268	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The Jacob K. Javits Convention 460 12th Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

June 17, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49537	09A0269	James F. Volpe Electrical Contracting Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	I.S. 228X 400 East Fordham Road Bronx NY	Approved	\$650.00
49538	09A0270	Woodland Electrical Contracting Corp. 4601 White Plains Road Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	675 Zerega Avenue Bronx NY	Approved	\$650.00
49539	09A0271	Caruso & Sons Electrical Contracting, Inc. 1489 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Brooklyn Central Public Library 1 Grand Army Plaza Brooklyn NY	Ok, but	\$650.00
Verify that service room is mechanically ventilated.						
49540	09A0272	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	2 Cooper Square New York NY	Ok, but	\$650.00
#6 tap conductor undersized						
49541	09A0273	Royal Electrical & Wiring Corp. 27-07 BQE West Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Roscoe Brown Apartments 3952 3rd Avenue Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

June 17, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49542	09A0274	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	6 New Lane Staten Island NY	Approved	\$650.00
49543	09A0275	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Gold Street Apartments 40 Gold Street New York NY	Approved	\$650.00
49544	09A0276	Cedar Electrical Contractors, Inc. 130 Williams Street, Suite 603 New York NY 10038	Requested approval for the electric service equipment proposed to be installed	845 West End Avenue New York NY	Approved	\$650.00
49545	09A0277	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	201 Pearl Street New York NY	Approved	\$650.00
49546	09A0278	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	28 East 10th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49547	09A0279	Hugh O kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	N.Y.U. Co Gen Expansion 11 University Place New York NY	Approved	\$650.00
1) Existing 3000A switch unfused correct 1-Line. 2) Clarify 'Normal' and 'ALT' on ATS's 3) Indicate unique key interlink designations for each switch pair. Job finalized 7/29/09.						
49548	09A0280	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Columbia University 3024 Broadway New York NY	Approved	\$650.00
49549	09A0281	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	681 Fifth Avenue New York NY	Ok, but	\$650.00
1) Bus undersized in 4000 amp service switch. 2) Provide supplemental ground in new board. 3) Verify that ATS #1 does not serve emergency loads.						
49550	09A0282	Coast 2 Coast Electric Cabling, Inc. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Union Club 101 East 69th Street New York NY	Hold	\$650.00
1) Verify that rear covers can't be removed. 2) 36" clearance needed on side of switchboard. 3) Show coordination between 1st-2nd fusing.						
49551	09A0283	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	X440 Clinton High School 100 West Moshulu Parkway Bronx NY	Approved	\$650.00
1) Wall mounted generator connection cabinet 5-wire does not match one line feeders. 2) Generator cut sheets not provided. 3) 3 sets of 500 MCM fused at 1200 amps. 4) Verify if 600 MCM can be connected to generator connection box. Job finalized 8/28/09.						

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49552		DVL Consulting Engineers Inc. 137 Fifth Avenue New York NY 10010	Requesting permission to install underground concrete encased service lateral conductors in non metallic rigid conduit.	New IS 230 Annex First Avenue & 35th Street New York NY	Approved	\$0.00
49553		Fas Electrical Contractors, Inc. 90-61 Pitkin Avenue Ozone park NY 11417	Requesting permission in a corrosive area, Far Rockaway, Queens to install overhead service entrance conductors in rigid non metallic conduit.	1124 Foam Place Far Rockaway NY	Approved	\$0.00
49554		Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requesting permission to install jacketed mc cable, UF cable or non metallic conduit outdoor underground for temporary wiring of light poles.	Croton W.T.P. Offsite Faciltiy 3055 Goulden Avenue Bronx NY	Approved	\$0.00
49555		Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requesting permission to conceal the fixture power cord supply in the building structure.	Battery Park City Site 26 New York NY	Denied	\$0.00
49556		Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requesting permission to leave as installed in a mechanical room due to a hardship to reroute, piping located in the dedicated electrical space above distribution boards where protection will be installed to protect the electrical equipment.	Goldman Sachs Battery Park City Site 26 New York NY	Approved	\$0.00
With the stipulation that drip pans are installed over the electrode equipment.						

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49557		Cosentini Associates Two Pennsylvania Plaza New York NY 10121	Requesting permission on a 1000 KVA to utilize a 1200 amp service switch instead of 1600 amp service switch for a fire pump with a FLA of 211 amps.	400 5th Avenue New York NY	Approved	\$0.00
With the stipulation stipulation that 2 sets of revised drawings are submitted to the Advisory Board.						
49558		Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requesting permission to install a temporary service outdoors for the Second Avenue Subway.	2nd Avenue Subway New York NY	Approved	\$0.00
49559		Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requesting permission on a violation removal to the owner to leave in place non fire rated branch circuit for the fire pump.	435 7th Avenue New York NY	Denied	\$0.00
49560		J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requesting permission to leave an existing fire pump automatic transfer switch in the service room where a new 400 amp emergency side switch will be installed with fire rated conductors to feed the existing ATS in the service room.	ABC 7 Lincoln Square New York NY	Approved	\$0.00
49561		J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requesting permission to install an eighth service switch where one of the switches powers a fire pump.	R-LIC Realty, LLC 12-16 43rd Avenue Long Island City NY	Denied	\$0.00

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49562		Atkinson Koven Feinberg Engineers 330 West 42nd Street, 14th Floor New York NY 10036	Requesting permission due to cost limitations and visual consideration of installing catwalks to allow individual contactors for routine switching of feeders that provide power to circuit breaker panels, and stage equipment located approximately 65 feet off of the floor in lieu of the use of chains and hook sticks to operate overcurrent protective devices in a theater.	7th Regiment Armory 643 Park Avenue New York NY	Approved	\$0.00
49563		Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requesting permission to waive coordination between 4000 amp A4BQ fuses and 2500 amp WL circuit breakers.	NY College of Technology 300 Jay Street Brooklyn NY	Approved	\$0.00
49564		Robco Electric Corp. 2630 Chesbrough Avenue Bronx NY 10461	Requesting permission to leave as installed due to a hardship to correct to allow the grounding electrode conductor and main bonding jumper terminals in the CT compartment.	Harlem River Yard Intermodal 132nd Street and St. Anns Avenue Bronx NY	Approved	\$0.00
49565		M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requesting permission due to lack of space inside of the existing service room to leave as installed a new 600 amp service located outside of the service room where signage will be provided at each service indicating where the other service is located.	401 Lafayette Street New York NY	Approved	\$350.00
With the stipulation						
49566		JW Electric Corp. 1106 East 43rd Street Brooklyn NY 11210	Requesting permission to add a second service and not group it together with an existing indoor service for the dwelling unit, the new service will provide power for site lighting for a condo complex.	160 Dartmouth Loop Staten Island NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**June 17, 2009**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49567		Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requesting permission on approved Cal. #48814 to temporarily tap power for an existing fire pump service switch from switchboard SSB-C through bus due to service SSB-F being de-energized for approximately one year where the completed work will be as per drawing 48814.	East River Science Park 450 East 29th Street New York NY	Approved	\$0.00
49568	09A0284	Nualight Model Farm Road Cork, Ireland	Requested approval for use in New York City of your Cryoled/Uantium LED		Approved	\$200.00
49569	09A0285	Valentis Electric Inc. 32-21 58th Street Woodside NY 11377	Requested approval for use in New York City of your Spray Booth. Model/Series Numbers: IFPX-876/83009		Denied	\$200.00
Spray booth must be listed as a complete assembly						
49570	09A0286	Fab*Am Electric, Inc. 1243 Oakpoint Avenue Bronx NY 10474	Requested approval for use in New York City of your Meter Socket. Model/Series Numbers: FMS 10P-3 and FMS 7P-1.		Approved	\$200.00
49571		Amra Electrical Corporation 47 Buffalo Avenue Brooklyn NY 11233	Requesting permission to leave as intalled ina new multi dwelling unit building. Indoor receptacle outlets not installed as per 210.52(A)(1) and outdoor balcony receptacle outlets not installed due to the building having a glass and steel façade.	26-26 Jackson Avenue Long Island City NY	Denied	\$0.00