

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0017CO	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Southwest Bklyn Marine Transfer 400 Bay 41st Street Brooklyn NY	On Hold	\$0.00
<p>1.Service entrance conductors undersized 2.Fire pump service switches undersized, fusing undersized 3.250 KCM under fused at 1200 amps 4.Verify that the neutral conductor is being switched in FA ATS 5.Designer to appear at meeting to explain the installation with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p>						
54079	15A0455CO2	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	1 East Loop Road Roosevelt Island NY	Approved	\$0.00
<p>Carry over from August 12, 2015 meeting to July 13, 2016 Meeting. CUP building, 225.37, 230.2(E) 1.Provide Signage in the electrical room indicating which disconnect switches are supplied by the 2.Provide unfused disconnect switches for the Fire Alarm systems. Show compliance with 225.36 & 225.31 3.Provide signage at Fire pump controller switch indicating where the supply comes from in the Fire pump room and Electrical room 4.Verify size of Fire Alarm transformer 5.Where is the generator located 6.Provide 60 amp 1 and fuse for Fire alarm system with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
	16A0135	Team Electric, Inc. 20 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	222 East 44th Street New York NY	Rejected	\$650.00
<p>1) Does switchboard comply with 408.60(F)? 2) Verify incoming SED of Con-ED conductors. 3) SS #3 and 1200 amp KRPC don't coordinate. 4) SS #3 backwards, bond and ground on load side of neutral link. 5) Fire pump feeders not fire rated. 11/2/16 1) Verify 21 incoming sets of Con-ED conductors. 2) Fuses of ss#3 and 1200 amp KRPC don't coordinate.</p>						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54237	16A0272	Lippolis Electric Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	1501 Voorhies Avenue Brooklyn NY	Approved	\$650.00
<p>1) Neutral to be bonded to enclosures in Time Warner, fire alarm and fire pump service switches 250.64(D)(3). 2) Neutral conductors to remote service switches should be connected to the line side of the neutral link. 3) Equipment grounding conductors undersized on 4000 amp feeders with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/29/16 Item #3 not addressed. 12/5/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54006	16A0280CO	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	3080 Broadway New York NY	Approved	\$0.00
<p>Carry over from May 4, 2016 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54012	16A0309	Demand Electric, Inc. 230 49th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	411 East 178th Street Bronx NY	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0353	Roz-A-lite Electrical Contracting Inc. 159 20th Street, Room 401 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	118 Fulton Street New York NY	On Hold	\$650.00
<p>1. Verify types of ATS that will be installed by note at generator, Dwg 3 2.3 poke ATA for Fire Alarm on separately derived systems, Dwg 3 3. Dwg 2 – provide neutral links for 2500, 2000, 1200 amp service switches 4. Dwg 2 – T1 – 2 transformer secondary switch to be grounded fault type 5. Dwg2 – transformer secondary’s neutral to be bonded and grounded 6. Provide coordination study – signed, sealed by a P.E. 7. Barrier off rear of switch board MSB-C-13 8. Verify that 800 amp ATS and emergency feeder is not for life safety 9. Verify that service room is mechanically ventilated. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector’s review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector’s review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
54055	16A0363	A & R Electrical Maintenance, Inc. 85-44 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	2605 Grand Concourse Bronx NY	Approved	\$650.00
<p>1) Fire pump service entrance conductors to have a grounded conductor. 2) Fire pump service entrance conductors undersized. 3) Fire pump service switch undersized. 4) Service is not 1000 KVA. 8/23/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53985	16A0400	Hatzel & Buehler, Inc. 230 Park Avenue New York NY 10169	Requested approval for the electric service equipment proposed to be installed	102-01 66th Road Forest Hills NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54238	16A0405	Kleinknecht Electric Co., Inc. 252 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	40 West 25th Street New York NY	Approved	\$650.00
1) Service entrance conductors undersized. 2) Show bus size of 3000 amp ss. 11/30/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53984	16A0416	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	260 West 55th Street New York NY	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0426	Accurate Electrical Corp. 11-07 43rd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bushwich Ctr 50 Sheffield Avenue Brooklyn NY	Denied	\$650.00
1. Service room where the new 400 amp circuit breakers will be installed, door to open outwards with panic hardware 2. Show Fire pump emergency conductors to generator 3. Tapped conductors to new 400 amp disconnects undersized, equipment grounding conductors undersized. 4. Emergency feeder sizes to ATS not shown 5. Are ATS 3 or 4 pole type? 6. Length of Taps not shown 7. Are new panels feeding life safety loads						
54001	16A0430	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	90 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53994	16A0440	Nead Electric, Inc. 350 West 50th Street New York NY 10110	Requested approval for the electric service equipment proposed to be installed	1185 6th Avenue New York	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54022	16A0448	Top Shelf Electric Corporation 4386 Victory Blvd Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	211 McGuinness Blvd. Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54014	16A0451	Right Away Electric LLC 56-02 Arnold Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	455 Jefferson Street Brooklyn NY	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54005	16A0468CO	Horsepower Electric 4101 1st Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	250 South Street New York NY	Approved	\$0.00
Carry over from June 8, 2016 meeting. With the stipulation that the cogen system is listed and this drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.						

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

With the stipulation:

Fire Rated Enclosure's must comply with the following:

1. A P.E. or R.A. must file a PWI as an AIT 3.
2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.
3. The fire proofing must be performed by a certified fire proofing installer.

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53996	16A0474	JSP Electrical Contracting Corp. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	95 Horatio Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0479	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	AC Hotel Times Square 260 West 40th Street New York NY	Pending	\$650.00
1. Verify 3000 amps Emergency Panel off of 500KW generator 2. Correct typo on Fire pump emergency feeder, or check wire fill for 2" conduit 3. Provide short circuit, coordinator study performed, sealed and stamped by a P.E/ 4. Verify that switch board MSB-1 complies with 408360(F)						
53987	16A0486	HM Electrical Inc. 37-19 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	5 East 17th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0487	New York Empire Electrical Inc. 1236 Jerome Avenue Bronx NY 10452	Requested approval for the electric service equipment proposed to be installed	558 Grand Concourse Bronx NY 10451	Denied	\$650.00
<p>1.400 Amp service switch neutral not bonded & grounded 2.Emergency F.A. & F.P. switches neutrals are bonded & grounded 3.Verify MI Cable installed in conduit and MI terminating directly to devices 4.Verify 2 sets of MI cable on lead side of ATS to splice box 5.Show how splices will be made in Fire Pump splice box 6.Equipment grounding conductors undersized to fire pump 7.Each fire pump to have its own ATS 8.3000 Amp service switch, show bonding jumper size and ground lugs, supplemental ground lugs 9.4000 Amp service switch neutral not bonded and grounded Review stopped... with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53992	16A0488	Bigman Brothers, Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	One Broadway New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53989	16A0489	Nunez Electric, Inc. 32-14 Green Point Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	100-00 Beach Channel Drive Queens NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/5/16 Swapped drawing B-Revision 1. 2/8/17 Swapped drawing "D-1606-27268-B"-Rev 2.						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0491	A.S.R. Electrical Contracting, Inc. 969 Third Avenue New York NY 10022	Requested approval for the electric service equipment proposed to be installed	Hudson Yards Tower D 553 West 30th Street New York NY	On Hold	\$650.00
1.TD-ED-DS-37-1 (3) section bus 2nd cubicle and 1600 amp switch bus under sized 2.TD-ED-DS-11-2 (re/co) bus on line and load side of 3000 amp switch undersized 3.TD-DS FP-11-1 (13) remove spare service switch in fire pump board 4.Generator neutral to be bonded and grounded in one location 250.30(A)(1) 5.Show size and fuse size of fire alarm emergency switch 6.Bond and ground transformer secondary of fire alarm transformer						
54025	16A0493	Rainbow Electric Co. Inc. .76-18 Rockaway Boulevard Woodhaven NY 11421	Requested approval for the electric service equipment proposed to be installed	2550 Third Avenue Bronx NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book Requirements. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.						
53997	16A0494	John Stassi, Licensed Electrician 4347 Hylan Boulevard Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	255 West 43rd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/30/16 Swapped drawing A4-Revision 1.						
53995	16A0495	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	2483 West 16th Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53988	16A0496	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	71-61 159th Street Flushing NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53993	16A0497	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	350 65th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54085	16A0498	Lilker Assoc. Consulting Eng. 1001 Avenue of the Americas New York NY 10018	Requested approval for the electric service equipment proposed to be installed	610 West 112th Street New York NY	Approved	\$650.00
OR 1) Tapped conductor undersized length of tap not shown to panel "DPCA1. 2) Provide neutral link in SS #5. 3) Verify location of existing neutral disconnect link in switchboard. 9/1/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54288	16A0500	Anthony G. Ferry Inc. 1916 Park Avenue, Suite 520 New York NY 10037	Requested approval for the electric service equipment proposed to be installed	189 Bowery New York NY	Approved	\$650.00
<p>1) Emergency feeders for fire alarm and fire pump reversed. 2) Provide coordination study signed, sealed and stamped by a PE, 2000 amp KLU and 600A FRN don't coordinate with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 12/20/16 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0502	Lippolis Electric Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Queens Plaza Building 1 28-30 Jackson Ave Long Island City NY 11101	Denied	\$650.00
<p>Dwg 2</p> <p>1.Add note to 1 Line drawings indicating compliance with sections 225.34(A) & 225.37</p> <p>2.Where are the locations of the unfused Fire Pump disconnect switch</p> <p>3.Transformer secondaries' over fused</p> <p>4.TDS-A-1 and TDS-A-2 bus undersized</p> <p>5.Fire Alarm equipment grounding conductors undersized</p> <p>6.1600 Amp Equipment grounding conductors undersized</p> <p>7.EGC to emergency fire alarm switch undersized; how do 2/0 conductors connect to 60 amp switch terminals?</p> <p>8.Remove FA disc switch on load side of ATS</p> <p>9.EGC on load side of FA transformer undersized</p> <p>DWG 3</p> <p>10.Fire pump service switch undersized; FP B1-1</p> <p>Review stopped... with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
	16A0505	Shorr Electrical Contracting, Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	422 Fulton Street Brooklyn NY	Denied	\$650.00
<p>1) Show clearances in service room, show elevation drawing. 2) Service D all section bus undersized. 3) Provide coordination study signed, sealed performed by a P.E. 4) Transformer feeds more than 6 switches that are not grounded together, transformer shall be Y-Delta.</p>						
54011	16A0506	Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	210 East 64th Street New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0507	Pac Electric Corporation 124-20 Liberty Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	123 Varick Avenue Brooklyn NY	Administrative Closure	\$650.00
1) Verify amount of conductors in troughs, not derated. 2) Is entire job new, or bubble new work on all drawings. 8/25/16 This submittal number is void in lieu of new submission number of 16A0646.						
53978	16A0508	Eldor Electric LLC 18-15 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	199 Chambers Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53925	16A0509	Scheider Associates 866 Johnston Drive Watchung NJ 07069	Requested approval for the electric service equipment proposed to be installed	210 11th Avenue New York NY	Approved	\$0.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54031	16A0510	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	162 5th Avenue New York NY	Approved	\$650.00
<p>1.Fire pump - remove transformer secondary switch</p> <p>2.Will MI cables terminate directly to ATS</p> <p>3.Verify emergency Fire alarm system two switches installed prior to transformer</p> <p>4.Fire Alarm switch reversed</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/5/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53986	16A0511	Glo Electric LLC 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	149 Kent Avenue Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54000	16A0512	Egg Electric Inc. 35 West 45th Street, 4th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Bklyn Navy Yard-Bldg 293 63 Flushing Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53998	16A0513	Control Spec Electrical System, Inc. 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1930 Broadway New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53990	16A0514	Control Spec Electrical System, Inc. 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	350 East 79th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0515	FSG Electric Inc 494 8th Avenue New York NY 10001	Requested approval for the electric service equipment proposed to be installed	101 Pennsylvania Avenue Brooklyn Ny 11207	On Hold	\$650.00
Not reviewed - OK for 08/17/2016 meeting.						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53962	16A0519	High Beam Electric Corp. 1169 Bay Street Staten Island NY 10305	Requesting permission due to the existing space limitations and concrete encased steel beams located in the floors in front of the elevator shaft way to allow a new elevator feeder to be installed inside of the existing elevator shaftway as per section 620.37(C) & 620.37(C)(2)	150 West 30th Street New York NY	Approved	\$0.00

OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

53963	16A0521	R.J. Russo Electric Co. 45-57 Bell Blvd. Bayside NY 11361	Requesting permission to utilize Section 690.7(c) of the NEC and allow 1000 volt solar photovoltaic equipment to be installed, solar edge three phase inverters, solar bos source circuit combiners and solar edge power optimizer module.	25 Cornelia Street New York NY	Approved	\$0.00
-------	---------	---	--	-----------------------------------	----------	--------

OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

16A0522	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	226-6 56th Avenue Queens NY	Pending	\$650.00
---------	--	--	--------------------------------	---------	----------

1) Clearance to comply with Table 110.34(A) conductor #2. 2) Fusing for transformers undersized. 3) Address coordination study by others-Table 3.

16A0523	Matore Campisi & Sons Lic. Electl Contrs., 18-31 Decatur Street Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	88 Greenwich Street New York NY	Denied	\$650.00
---------	--	--	------------------------------------	--------	----------

- 1.Show Clearances in service rooms
- 2.Who will be replacing copper ¼" x6" bus bars
- 3.Portable generator connection box to comply with 700.6(G), where is switch located, provide back feed signage
- 4.Conductor in Trough to be derated; what type of cover will be used?
- 5.Bus sizes not shown on S.S 4B
- 6.Provide Key interlock for generator
- 7.Provide conductor calculations for wire way fill to supply service switches.

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54007	16A0524	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	204 2nd Avenue New York NY	Approved	\$650.00
<p>OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con Edison regarding Blue Book requirements. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
54058	16A0526	H Electric Corp. d/b/a Mage Electrical Co 156 Flushing Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	18 East 41st Street New York NY	Approved	\$650.00
<p>OR 1) Verify 5' front clearance in front of fire pump service switch. 2) Show clearances in front of store panels, store distribution board #2 and Con-ED store meter. 8/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54081	16A0527	V Electric NY, Inc. 11-11 44th Drive Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	203 East 92nd Street New York NY	Approved	\$650.00
<p>Bus in DP-C undersized and doesn't match physical. 8/30/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54302	16A0528	Denmar Electric Co. 11-11 44th Drive Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	670 Broadway New York NY	Approved	\$650.00
<p>1) Tapped conductor to 400 amp disconnect switch undersized. 2) New house panel not shown and size of breakers not shown. 3) Verify length of tap to 200 amp disconnect switch. 4) Verify existing house C.T. and house panel and elevator disconnect behind it show clearance. 1/5/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54010	16A0529	New York Empire Electrical Inc. 1236 Jerome Avenue Bronx NY 10452	Requested approval for the electric service equipment proposed to be installed	396 Broadway New York NY 10013	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53980	16A0530	sko Electrical Construction & Maintenance 21-24 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	535 Eighth Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53965	16A0531	Egg Electric Inc. 35 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	1 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54131	16A0532	Multi-Phase Electrical Services, Inc. 1916-38 Park Avenue, STE 406 New York NY 10037	Requested approval for the electric service equipment proposed to be installed	Cornell NYC Tech Bldg 1 Main Street Roosevelt Island NY	Approved	\$650.00
1.Where is the Fire pump disconnect switch located, will MI cable terminate in ATS 2.Where is Generator and emergency equipment located 3.Fire Pump emergency feeder underfused 4.Fire Alarm 200 amp disconnect switch bonded and grounded after service switch 5.Fire Pump disconnect switch to comply with 225.30 if switch is located in fire pump room, remove it and use controller 6.Fuse types in existing building not shown on drawing. 10/3/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53999	16A0533	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	670 Columbus Ave New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53964	16A0535	Egg Electric Inc. 35 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	770 Broadway New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0536	Re-Con Electric Inc. 79 Alexander Avenue, Suite 52 A Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	135 West 52nd Street New York NY	Pending	\$650.00
<p>1) Normal and emergency equipment in the service room. 2) Show how non 1000 KVA genset ties into service. 3) Emergency loads mixed with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
	16A0538	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Eagle Warehouse 43-22 Queens Street Long Island City NY 11101	Pending	\$650.00
<p>1. Transformer secondary neutral not bonded and grounded 2. Complete reduced neutral calculations not provided 3. Equipment grounding conductor for fire pump undersized 4.1 line drawings & fonts to be bigger in the future</p>						
53976	16A0539	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	90-15 Queens Blvd. Elmhurst NY	Approved	\$650.00
<p>OR With the stipulation that the fuel cells are listed equipment. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54004	16A0540	Fried Electric Company 67 West Street, Unit 321 Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	110 Beard Street Brooklyn NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53991	16A0542	Limongelli Electric Corp. 214-41 42nd Avenue, Fourth Floor Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	525 West 28th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/24/16 Swapped drawing A-Revision 1. 11/22/16 Received letter to change job location address from 528 to 525 West 28th Street. 11/29/16 Swapped drawing A-Revision 2 No more revisions.						
	16A0543	Allan Briteway Electrical Contractors, Inc. 360 Lexington Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	25-70 Whitestone Expressway College Point NY	On Hold	\$650.00
Not Reviewed - OK for 08/17/16 meeting						
	16A0544	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	11 Madison Avenue New York NY	On Hold	\$650.00
Not reviewed. OK for 08/17/2016 meeting						
53970	16A0545	Roz-A-Lite Electrical Contracting, Inc. 159 20th Street, Suite 401 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	453 West 37th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0546	Allran Electric of New York 120 Broadway, 38th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	110 East 42nd Street New York NY	Administrative Closure	\$650.00
1.Firm Pump supply to comply with 695.3(A)(1) & 408.3(A)(3) 2.Show fault current at Fire Pump and withstand ratings of ATS & Controller. 10/27/16 Void as per Sub. #16A0787, Approval #54179. 10/19/16.						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0547	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	222-05 56th Street Bayside NY	Denied	\$650.00
<p>1) Dwg 603 switchboard and notes backward on drawing. 2) Dwg 603 lengths of taps not shown and 400 amp tap conductor undersized. 3) All drawings-who will be installing incoming conductors distribution switchboards labeled as service switchboards, neutrals not to be bonded and grounded. 4) Drawings 603-switchboard to comply with 408.60(F) or 230.64(B)(4) and Table 110.34 clearances. 5) Drawing 602-length of taps not shown. 6) Drawing 605-tap conductors undersized and length not shown and overfused. 7) Drawing-605 doors to open outwards, 8) Drawing 605 section bus undersized middle section. 9) Drawing 604 4 pole ATS' used on non separately derived system. 10) Drawing 604 length of taps not shown. 11) Drawing 602 show elevations of ceiling boxes. Review Stopped. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
54084	16A0549	Royal Electrical & Wiring Corp. 27-07 BQE West Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	23-10 41st Street Long Island City NY	Approved	\$650.00
<p>1) Service room doors to comply with 230.64(B)(5). 2) Size of switchboard switches not show on 1 Line or physical for MSB. 3) Type of fuse not shown, coordination study performed signed and sealed by a P.E. not submitted. 4) Tapped conductors to 800 amp disconnect switch undersized. 9/1/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
54002	16A0550	M.C. Electrical NY, Inc. 835 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	1460 Broadway New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54003	16A0551	Egg Electric Inc. 35 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	75 9th Avenue New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/26/16 Rejected Fire alarm to be connected on line of source equipment. 12/2/16 Swapped drawing A2</p>						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54080	16A0552	Lina Electric Corp. 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	12 Rock Street Brooklyn NY	Approved	\$650.00
1) Service bus to 4000 amp service switch undersized, typo on line and load of switch. 2) Generator feeders overfused. 8/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53966	16A0553	Allstate Electrical Contracting, Inc. 120 West 31st Street, 7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	200 West 27th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/24/16 Swapped drawing 1-Revision 1.						
53967	16A0554	YS Electric 129-09 26th Street Avenue, Suite 203 Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	245 East 44th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54013	16A0555	Delco Electrical Corp. 241 West 37th Street, Suite 700 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	242 Broome Street New York NY	Approved	\$650.00
This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54281	16A0556	Delco Electrical Corp. 241 Wet 37th Street, Suite 700 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	412 West 15th Street New York NY	Approved	\$650.00
<p>1) Size of main bonding jumpers not shown, Swbd 1 and 2. 2) Service bus feeding 3000, 800, and 2-400 amp service switches undersized swbd 2. 3) Feeder to load bank overfused. 4) Fire pump emergency feeder underfused, and not fire rated with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/16/16 Rejected 1) Comments above not addressed and also below. 2) Service switchboard #2 to comply with 230.64(B)(4). 3) Provide coordination study performed, signed and sealed by a P.E. 4) Provide a note under emergency panel or generator whether 3 or 4 ATS' will be installed with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 12/16/16 Job finalized. The drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53968	16A0557	Brandl Electric 1926 Mott Avenue Far Rockaway NY 11691	Requested approval for the electric service equipment proposed to be installed	15-24 132nd Street College Point NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/13/17 Swapped drawing,- Revision 1 Job addressed changed.</p>						
53969	16A0558	Chaim Electric 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	445 West 35th Street New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54057	16A0559	MEO Electric Corp. 63 Flushing Avenue, Unit 340 Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	47-12 Grand Avenue Queens NY	Approved	\$650.00
8/23/16 Job finalized with the stipulation that SRP-6MA solar panels, 1000 volt sunny tripower inverters, Solar Bos string inverters be installed. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53971	16A0560	Kramer Electric, LLC 28 West 27th Street, Suite 701 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	5510-5520 Broadway Bronx NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53972	16A0561	Atlas-Acon Electric 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	100 6th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53973	16A0562	Atlas-Acon Electric 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	500 5th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/22/16 Swapped Drawing D-Revision 1						
53974	16A0563	Atlas-Acon Electric 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	250 Vesey Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53975	16A0564	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	57 West 57th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/22/16 Swapped drawing D-Revision 1						
54008	16A0565	Rightway Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	27-17 42nd Road Long Island City NY	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53977	16A0566	Tacos & K Electric, Inc. 38-58 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	95 Linden Blvd. Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53981	16A0567	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	211 West 56th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54060	16A0568	Belmont Electrical Inc. 5-12 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	303 Park Avenue South New York NY	Approved	\$650.00
OR Service room doors to open outwards. 8/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54009	16A0570	OM Electric, Inc. 262 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	2952 3rd Avenue Bronx NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53982	16A0571	QNNC Electric 84-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	320 Central Park West New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53983	16A0572	Rodel Electrical Contractors, Inc. 31-29 Vernon Blvd. Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	141 East 111th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/12/17 Swapped drawing #ACS-D-12312-Revision 1.						
	16A0573	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	160 Leroy Street New York NY	Administrative Closure	\$650.00
<p>1) Fire pump emergency feeder not fire rated. 2) Add note under D-P Gen panel whether 3 or 4 pole ATS' will be installed. 3) Coordination study signed, sealed and stamped by a PE not submitted with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PW1 as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 9/9/16 This submittal is void in lieu of new submittal #16A0662. 						

ADVISORY BOARD CALENDAR

July 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53979	16A0575	High Beam Electric Corp. 1169 Bay Street Staten Island NY 10305	Requesting permission to install an elevator feeder in the elevator shaftway as per 620.37(c) in a building where the elevator is being upgraded and due to many obstacles in the way of conduits and subject to vandalism to allow the feeder for the elevator to be installed in the shaftway	147 West 29th Street New York NY	Approved	\$0.00

OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

54028	16A0576	V Electric NY, Inc. 11-11 44th Drive Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	670 Broadway New York NY	Approved	\$650.00
-------	---------	--	--	-----------------------------	----------	----------

OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

54024	16A0577	ADS Engineers 45 Broadway, Suite 1200, 12th Floor New York NY 10006	Requesting permission to utilize Section 220.43(B) Exception of the 2011 NEC to install track lighting.	375 Broadway New York NY	Approved	\$0.00
-------	---------	---	---	-----------------------------	----------	--------

With the stipulation that the current limiting panel is listed as a complete assembly. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements