

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51073CO		Edison Electrical Corporation 36-11 22nd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	25 Elm Street Brooklyn NY	Approved	\$0.00
Carry over from February 15, 2012 meeting. 1) Verify that service switchboard complies with 230.64(4) or 408.60(F), elevation drawing of end box not shown. 2) Neutral not bonded in 1200 amp service switches. 3) Electrical contractor to provide letter for address correction. 4) Provide signage that indicates the location of the lower level service room. 5) Relocate doors to original layout to allow egress from dedicated service space without passing in front of other equipment. 9/15/14 Job finalized.						
52406	12A0000CO2	Roma Electric Corp. 30-75 14th Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	45 Main Street Brooklyn NY	Approved	\$0.00
Carry over from August 15, 2012 meeting						
52537	13A0350	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	DSNY Manhattan Garage 353 Spring Street New York NY	Approved	\$650.00
1) Remove gen main OCPD, so no OCPD ahead of fire pump switches. 2) indicate load shedding o ensure continuous power. 3) Provide LSIG on OCPD energizing service board. 4) Provide detail on the microsteam relay and utility interlock connection. 5) Provide listing documentation from a NRTL for the generator. 9/23/14 Job finalized. 1/14/15 Swapped Drawings 1 and 3 , Revision 3.						
	13A0712CO3	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Telx 32 Avenue of the Americas New York NY	On Hold	\$0.00
Carry over from June 11, 2014 meeting. 1) Gen has GFI alarm, must be trip unit. 2) Gen cuts missing, UPS, and sync board. 3) Clarify Sequence of Operation table w/ devices. 4) UPS interlock and camlock details.						
	14A0193CO	Fred Geller Electrical, Inc. 37-32 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	625 West 57th Street New York NY	Rejected	\$0.00
Carry over from April 9, 2014 meeting. 1) Show size of service bus feeding the service switches. 2) 1200 amp feeder to 750 KVA transformer undersized. 3) Bus sizes in MSWB and RBLE switchboards not shown. 9/16/14 Ok, With the stipulation that the gen-set is field evaluation and listed by an NRTL by the time DOB inspects the electrical installation. 9/29/16 New submittal is required, too may incorrect changes to drawings review and resubmit, changes were made and not identified on drawings						

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52408	14A0219CO	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	961 First Avenue New York NY	Approved	\$0.00
Carry over from May 7, 2014 meeting.						
52463	14A0222	Barth-Gross Electric Co., Inc. 46-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Verizon 680 Fifth Avenue New York NY	Approved	\$650.00
Verify that service conductors are not installed with non service conductors. 8/11/14 Job finalized.						
52688	14A0230	Innovative Electrical Services 3346 Provost Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	Dumbo Heights Building #1 117 Adams Street Brooklyn NY	Approved	\$650.00
<p>1) Provide documentation from a NRTL showing that generator and switchboard is listed as a complete assembly. 2) Grounding electrode conductor to be terminated in remote service switches.</p> <p>3) Fire pump conductors to fire pump undersized, EGC's undersized. 12/22/14 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52407	14A0278	Kew Electric Inc. 1428 Hylan Blvd. Staten Island NY 10305	Requesting permission on an installation where the equipment grounding conductors are undersized to allow to switch the 600MCM neutral conductors with the 1/0 equipment grounding conductors in each raceway. Tape the 600MCM neutrals green and tape the 1/0 equipment grounding conductors white at each end of the conductors and all other accessible locations. According to attached calculations and reduced neutral calculations the neutrals and equipment grounding conductors will be oversized on the 2000 amp feeders.	1552 Broadway New York NY	Approved	\$350.00

Code: 200.6(B) and 250.119(A).

52491	14A0280	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	546 West 44th Street New York NY	Approved	\$650.00
-------	---------	---	--	-------------------------------------	----------	----------

1) Grounding electrode conductor to terminate in all remote service switches. 2) Equipment grounding conductor to fire pump undersized. 8/28/14 Job finalized.

52492	14A0281	& D Electrical Construction Company Inc 18 West 27th Street, 12th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	35 West 15th Street New York NY	Approved	\$650.00
-------	---------	---	--	------------------------------------	----------	----------

1) Short circuit study to be performed by a PE and the PE stamp. 2) Verify bus sizes in DSB-MBSA, DSB-MC. 3) Provide neutral links in service switches 3,4, and 5. 4) Why are 3 devices shown on 1 line when they are not shown in the service room 110.2(B)(4)? Note: Fire rated Enclosures must comply with the following: 1) A.P.E. or R.A. must file a PW1 as an Alt 3. 2) A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3) The fire proofing must be performed by a certified fire proofing installer. 8/28/14 Job finalized. Note: Fire Rated Enclosures must comply with the following: 1) A.P.E. or R.A. must file a PW1 as an Alt 3. 2) A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3) The fire proofing must be performed by a certified fire proofing installer.

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0285CO	Rightway Electrical 1465A Flatbush Avenue Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	218 West 35th Street New York NY	Rejected	\$0.00
<p>Carry over from June 11, 2014 meeting. 1) SS #B-Verify bonding and grounding and neutral link, S6, W6 on ground bus on both service Switchboards. 2) Provide cut sheet of generator with switchboard showing that it is listed as a complete assembly, documentation from a NRTL. 3) F.A. taps must be fused safety switches. 9/23/14 Rejected. Fire alarm taps must be fused safety switches. 10/30/14 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/16/16 Rejected 1) Equipment grounding conductors to fire pumps undersized. 2) Both drawings marked revision 6 without showing six revisions that were made in the title block.</p>						
52657	14A0287	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S. 96X 2385 Olinville Avenue Bronx NY	Approved	\$650.00
<p>Provide listing documentation from a NRTL for the genset. 12/2/14 With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0293	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	1047 Amsterdam Avenue New York NY	On Hold	\$650.00
<p>1) MS-B verify 1/0 conductors to 30 amp switch. 2) Provide load calculations for services as per Section 230.42(A)(2) Exception for service entrance conductors or increase sec's to 600 MCM. 3) Fire alarm s.s. to be grounded. 4) Provide main in generator panel 408-36. 5) Show feeder size to elevator ATS emergency side. 6) MSA verify that the lugs in the 400 amp disconnect switches can terminate 900 MCM conductors. 7) Verify emergency side 400 amp switch with 2 sets of 750 KCM terminated on it. 7/25/14 Rejected 1. Item 7 not addressed. 2. Provide listing documentation for generator set showing that it is listed as a complete assembly. 1/6/15 Job finalized With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements .Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	14A0318	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	5 Beekman Street New York NY	On Hold	\$650.00
<p>1) Service room to be mechanically ventilated. 2) Neutrals not bonded to enclosures, grounding electrode conductors terminated to ground bus SDB1 and SDB2. 3) Supplemental ground not shown. 4) Length of taps not shown and equipment grounding conductors are undersized for retail tenants. 5) Tap conductor to 100 and 800 disconnect switches undersized. 6) Label transformers in the service room. 7) Where are the transformers for the fire pumps located? 1 line notes don't match service room drawing.</p>						
52409	14A0324	J.M.C. Electrical Corp. 172-02 39th Avenue Flushing NY 11354	Requesting permission due to lack of space inside the basement service area to leave as installed service equipment for cell site on the exterior of the building not grouped together with the other service equipment.	300 West Service Road Staten Island NY	Approved	\$0.00
<p>With the stipulation that signage is provided at each service location indicating where the other service is located.</p>						
52410	14A0325	R.J. Russo Electric Co. 45-57 Bell Blvd. Bayside NY 11361	Requesting permission to utilize Article 690 of the 2014 NEC to allow the installation of listed 1000 volt solar photovoltaic equipment systems to be installed on two buildings.	Lydig Ave.-Bx and 570 W. 204th St- NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52411	14A0327	Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	395 Flatbush Avenue Extension Brooklyn NY	Approved	\$650.00
	14A0328	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requesting permission to install GFCI receptacles in lieu of installing insulated copper equipment grounding conductors in patient care areas due to the hardship of replacing the cables.	175 Water Street New York NY	Denied	\$350.00
Code: 517.13(B)						
	14A0329	Bala\CSI Consulting Engineers PLLC 1 William Street, 2nd Floor New York NY 10019	Requesting permission to install multi outlet assemblies with rubber cords and plugs for rows of trading desks where the desks can be easily removed and new updated desks inserted back in place	250 Vesey Street New York NY	Denied	\$0.00
400.7(6) and 380.2(B)(7)						
52496	14A0334	Contact Plus Electrical Corp. 247 Van Brunt Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	361 Broadway New York NY	Approved	\$650.00
1) New cover letter with contractor's information required. 2) Show incoming AIC. 3) Will a generator be installed? Are there other service rooms in the building? 9/9/14 Job finalized.						
	14A0335	Litespeed Electric 135 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1515 Broadway New York NY	Pending	\$650.00
1) New 800 amp service switch requires neutral conductors and bonding and grounding. 2) 5' clearance required in front of service switch.						

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52444	14A0336	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	65-30 Kissena Blvd. Queens NY	Approved	\$650.00
OR						
52412	14A0337	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Brookfield Properties 1 Liberty Plaza New York NY	Approved	\$650.00
OR						
52413	14A0338	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	242-02 61st Avenue Douglaston NY	Approved	\$650.00
OR						
52414	14A0339	Ettinger Engineering Associates 505 Eighth Avenue New York NY 10018	Requesting permission to install branch circuits as per Section 210.60(A) and (B) in a building classified as a student apartment (multi-dwelling) and classified as a dormitory as per the NYC zoning resolution.	200 East 6th Street New York NY	Approved	\$0.00
OR						
52415	14A0341	Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requested approval for the electric service equipment proposed to be installed	902 Quentin Road Brooklyn NY	Approved	\$650.00
OR						

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52461	14A0342	YS Electric 39-39 63rd Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	340 East 64th Street New York NY	Approved	\$650.00
1) Provide warning signs on switches that terminals of switches may be energized in the open positions. 2) Disconnects for co-gens reversed. 8/8/14 Job finalized. 4/21/15 Swapped Drawings A-Revision 5 and B-Revision 2.						
	14A0345	Patriot Electric Corp. 96-06 220th Street Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	711 11th Avenue New York NY	Denied	\$650.00
1) Equipment grounding conductors on line and load side of fire pump undersized. 2) Provide manufacturer's cut sheets of switchgear and SEB. 3) Show size of main bonding jumper. 4) Show length of transformer secondary taps. 5) Transformer secondary switches to be grounded. 6) EMT cannot be installed in wet locations(underground). 4/21/15 Denied. 1) Item #1 partially addressed see Table 250.122. 2) Manufacturer of end box not note. 3) Transformer secondary grounds to be made at transformer or disconnect switch not both locations. 4) What is RGD in concrete slab? 5) Corrections not to be bubbled. 6) Fire pump service switch to be grounded. 7) Main bonding jumpers installed on load side of neutral links, Why is there one main neutral link feeding other neutral links?						
	14A0347	Twins Electric Corporation 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	511 West 114th Street New York NY	Pending	\$650.00
1) Explain 500 MCM cu to 1/4"x3" cu ground bar in switchboard in existing service switches. 2) Show incoming AIC.						
52416	14A0348	Capitol Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	325 Hudson Street New York NY	Approved	\$650.00
52417	14A0349	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requesting permission to leave as installed service equipment on the exterior of a commercial building that does not have any common areas	, 4366A, 4366B, 4370A and 4370B Staten Island NY	Approved	\$350.00
Code: 230.70(A)(1)						

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52418	14A0350	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	16-16 Whitestone Expressway Queens NY	Approved	\$650.00
With Note: It is not recommended to use Unity Power Factor. 3/11/16 F.A. sw must be in the service room. 9/6/16 Swapped A-Revision 5.						
52419	14A0351	HIG Electrical Associates NYC, Inc. 25-26 50th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	606 West 26th Street New York NY	Approved	\$650.00
1/28/16 Swapped Revision 1						
52661	14A0352	APS Electric Inc. 83-32 Parsons Blvd. Jamaica NY 11432	Requested approval for the electric service equipment proposed to be installed	456 Grand Street Brooklyn NY	Approved	\$650.00
1) Verify if the taps will be made with AL or CU and verify EGC sizes. 2) Provide cuts for series rating of BRH280 with Class T fuses. 9/11/14 1. Item #1 not addressed, type of conductors not identified on load side of 2 gang meter to 60A disconnect switches and EGC to be #6. Are copper or aluminum EGC's being installed on taps to 2. 400 and 1 .200 amp disconnect switches, if the 3/0 are aluminum the 3/0 are aluminum they are undersized. 12/5/14 Rejected. 1) EGC's on load side of 2 gang meters to disconnect switches undersized. 2) Verify wiring method (though)s from 400 amp trans S to 400 amp disconnect switches. 12/8/14 Job finalized Contractor appeared in office to correct drawing and removed above.						
52495	14A0353	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	203 East 92nd Street New York NY	Approved	\$650.00
1) Verify that generator is existing and not on separately derived system. Show generator on 1 line drawing. 2) Show sizes of bus feeding the service switches. 3) Bus undersized in service switchboards for Equinox gym and SS1 Winward school. 9/9/14 Job finalized.						
	14A0355	Edwards and Zuck Consulting Engineers 315 Park Avenue South, 17th Floor New York NY 10010	Requested approval for the electric service equipment proposed to be installed	330 West 30th Street New York NY	Pending	\$650.00
Reduce 1200 amp fusing on existing feeders to proper size.						

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0358	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Fed Ex 830 Fountain Avenue Brooklyn NY	On Hold	\$650.00
<p>1) Please use staples instead of paper clips for generator cut sheets and coordination studies! 2) Coordination study to be performed by a PE with sealed signature. 3) Provide listing documentation from an NRTL for the generator as a complete system with switchboard and battery changer. 4) Portable generator to comply with 700.6(G). 5) Is ATS and panel EDP feeding life safety loads? 6) Why is FDS-1 switch shown on 1-line 3rd device? 7) Job address not in title block. 8) Grounding electrode conductor to be terminated in all remote service switches. 9) 2 fire alarm switches installed prior to FACP's. 10) Equipment grounding conductors undersized for fire pump. 8/20/14 Items 3,9, & 10 not addressed.</p>						
	14A0362	L & B Electrical International, Inc. 2063 Atlantic Avenue Brooklyn NY 11233	Requested approval for the electric service equipment proposed to be installed	120 West 41st Street New York NY	On Hold	\$650.00
<p>1) Provide mechanical ventilation in the service room. 2) Provide coordination study on emergency side from P.E. 3) Show details of MI connections to 75 degree devices.</p>						
52788	14A0364	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	237 East 34th Street New York NY	Approved	\$650.00
<p>Provide listing documentation from on NRTL for the gen set. 9/29/14 Rejected. Generator information received does not indicate that the generator, feeders and disconnect switch is listed as a complete assembly. 3/4/15 With the stipulation this drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52420	14A0366	AMC Electrical Services, Inc. 140 18th Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	366 Broadway New York NY	Approved	\$650.00
<p>3/25/15 Swapped drawing A, Revision 1. 1/21/16 Swapped drawing A-Revision 2. 9/6/16 Swapped drawing A-Revision 3 and Drawing B-Revision 1. No more swaps accepted, a new submission is required.</p>						

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52421	14A0367	Mid-County Electric Inc. 121-06 89th Avenue Richmond Hill NY 11418	Requesting permission to replace 10 sets of 600 MCM cu conductors and 10-4" conduits from the utility vault to an existing 4000 amp service switch due to water leaking from the vault into the conduits.	143-51 Roosevelt Avenue Queens NY	Approved	\$0.00
	14A0369	Bestco General Electrical Inc. 922 East 233rd Street Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	289 Meserole Street Brooklyn NY	Denied	\$650.00
1) Bus undersized in 2000 amp service switches. 2) Confirm that clearance in front of S.E.B. is acceptable to Con Ed. 3) Clarify DP-2 is existing-see elevation. 3/23/15 1) Line and load mixed together in Con-Ed box and cubicle next to Con-Ed box. 2) 3'clearance required in front Con ED box.						
52452	14A0370	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Weill Cornell Medical Center 156 William Street New York NY	Approved	\$650.00
Verify that existing switchboards are grounded. 7/31/14 Job finalized.						
52458	14A0371	& H Electrical Corp. d/b/a Mage Electrica 156 Flushing Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	118 West 22nd Street New York NY	Approved	\$650.00
1) Provide warning signage on rear of switchboard indicating not to remove rear covers. 2) Show existing 400 amp disconnect switches and panel in service room. 3) Block space behind new ss#2. 8/8/14 Job finalized.						
52422	14A0372	Dola Electric Co., Inc. 3044 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Sunny Days Café 401 West 79th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52423	14A0375	Mac Electrical Contracting, Inc. 2807 Flatbush Avenue Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	175 Kent Avenue Brooklyn NY	Approved	\$650.00
10/6/15 Swapped drawing 1, Revision 1.						
52424	14A0376	Forest Brook Electrical Contractor Inc. 2217 Avenue X Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	2161 Broadway New York NY	Approved	\$650.00
52459	14A0377	Associated Electrical Contrs of N.Y. Corp. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	2-40 51st Avenue Queens NY	Approved	\$0.00
SANDY 1) Feeders to 1200 amp panelboard overfused. 2) Provide short circuit CDLC at meter bank. 8/8/14 Job finalized.						
	14A0379	Walsh Electrical Contracting Inc. 76 Midland Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	Staten Island Mall Staten Island NY	Rejected	\$650.00
1) Drawing not in Advisory Board format. 2) Is there an existing service switchboard containing all service switches with 1 point of entry or are switches separate with separate points of entry? 3) Coordination study to be performed by a P.E. and stamped. 4) Provide scope of work by note on drawing. 9/19/14 Same comments as above.						
52484	14A0380CO	Hatzel & Buehler, Inc. 45 Broadway, Suite 1240 New York NY 10006	Requested approval for the electric service equipment proposed to be installed	60 Hudson Street New York NY	Approved	\$0.00
Carry over from May 7, 2014 meeting. Correct E transformer designation on plan. 8/22/14 Job finalized.						

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52425	14A0381	G. Poulakis Electrical Contracting, Inc. 23-82 Brooklyn Queens Expressway West Long Island City NY 11103	Requested approval for the electric service equipment proposed to be installed	24 John Street New York NY	Approved	\$650.00
<p>9/6/16 Swapped drawing 1-Revision 1. With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PW1 as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 						
52426	14A0382	East Bay Electrical Services Corp. 3300 Northern Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	33-00 47th Avenue Long Island City NY	Approved	\$650.00
address has an a.k.a 47-00 33rd Street.						
	14A0383	Response Electric Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	1185 Park Avenue New York NY	Administrative Closure	\$650.00
1) Relocate meter pan to provide 5' clearance in front of service switch. It is recommended to relocate new apartment distribution board to left wall to provide better egress. 8/26/14 Job finalized. 4/2/15 Void as per Approval number 52509.						
52427	14A0384	Response Electric Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	825 5th Avenue New York NY	Approved	\$650.00
OR						
52428	14A0385	OM Electric, Inc. 262 West 38th Street, Suite 1202 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	31 Lincoln Road Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52429	14A0386	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	150 East 42nd Street New York NY	Approved	\$650.00
9/23/14 Swapped Revision 1.						
52430	14A0387	Nivek Electrical Contracting, Inc. 301 East 119th Street New York NY 10035	Requested approval for the electric service equipment proposed to be installed	3779 Nostrand Avenue Brooklyn NY	Approved	\$650.00
OR						
52431	14A0388	KMB Design Group 1800 Route 34, Suite 209 Wall NJ 07719	Requested approval for the electric service equipment proposed to be installed	250 Park Avenue New York NY	Approved	\$650.00
52432	14A0389	AL-Lectric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	71-15 51st Street Queens NY	Approved	\$650.00
52433	14A0390	P.M. Electrical Maintenance 15 East 40th Street, Suite 303 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	72-06 Northern Blvd. Jackson Heights NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52434	14A0391	Lux Electric 142 West 19th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	150 West 22nd Street New York NY	Approved	\$650.00
2/17/16 Swapped drawing 1, Revision 1.						
52489	14A0392	Brandl Electric 1926 Mott Avenue Far Rockaway NY 11691	Requested approval for the electric service equipment proposed to be installed	138 Pierrepont Street Brooklyn NY	Approved	\$650.00
1) Fire pump feeder to be fire rated. 2) Verify size of service bus 2- 1/4"x4" or provide load calculations 230.42. 8/28/14 Job finalized						
52485	14A0393	Dudley & Associates 6 East Clarke Place Bronx NY 10452	Requested approval for the electric service equipment proposed to be installed	31-30 Hunters Point Avenue Long Island City NY	Approved	\$650.00
Provide manufacturer's cut sheet of inverter and provide listing documentation from a NRTL for the inverter. 8/26/14 Job finalized.						
52683	14A0395	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	175 West 60th Street New York NY	Approved	\$650.00
<p>1) Neutral conductor feeding fire pump service switch undersized 250.24(c) (1). 2) Transformer secondary grounds to be connected to building steel or grounding electrode. 3) Provide listing information from a NRTL showing that the gen set is listed as a complete assembly. 8/28/14 Provide manufacturer's installation instructions for the particular model gen-set being installed. 12/19/14 Job finalized. With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/24/16 Swapped drawings 1 and 2-Revision 2.</p>						

ADVISORY BOARD CALENDAR

July 16, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52435	14A0399	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	25 Broadway New York NY	Approved	\$650.00
3/14/16 Swapped Drawing 1, Revision 1.						
52436	14A0400	High Volt Electric Corp. 16-29 Stephen Street Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	985 Rockaway Avenue Brooklyn NY	Approved	\$650.00