

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51708	13A0110CO	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	432 Park Avenue New York NY	Approved	\$0.00
Carry over from April 17, 2013 meeting.						
52137	13A0128CO	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	Brittany Hall 55 East 10th Street New York NY	Approved	\$0.00
Carry over from April 17, 2013 meeting. 1) Neutral conductor to be brought to direct connect fire pump controller. 2) Fire pump controller to be bonded and grounded. 3) Equipment grounding conductor emergency side for fire pump feeder undersized. 4) Fire pump shall be service rated. 10/17/13 Equipment grounding conductor #3 on supply side of fire pump s.s./controlled under sized(equipment grounding conductor #3 between fire pump motor and controller under sized. Article 250.122). 1/24/14 job finalized.						
51854	13A0136CO	Campisano Electric, Inc. 355 Food Center Drive Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	Dairy Land USA 240 Food Center Drive Bronx NY	Approved	\$0.00
Carry over from May 8, 2013 meeting. 1) F.P. emergency circuit have two fuses in series. 2) Grounding electrode not provided from transformer secondary to fire alarm systems. 3) ATS-E, confirm rating KAIC, 42K or 65K, 42K is not good, available short circuit is 48K. 8/29/13 job finalized.						
51880	13A0138CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	90 Broad Street New York NY	Approved	\$0.00
SANDY Carry over from March 13, 2013 meeting. 1) Section bus distribution switchboard undersized. 2) Automatic fire pump feeder transistors undersized. 3) Special permission F.P.s-Ok with stipulation-6 month, R6s, 4) Where is service equipment located in relation to service equipment located in relation to service end box? 5) Show all clearances in service room. 6) Clarify switchboard signages. 9/18/13 job finalized.						
52062	13A0146CO	KD Electric, Inc. 39 West 14th Street, Suite 502 New York NY 10011	Requested approval for the electric service equipment proposed to be installed	100 Wall Street New York NY	Approved	\$0.00
Sandy Carryover from March 13, 2013 meeting. 1) Rev#2 GFP not provided at generator. 2) Verify type ATS installed EMDP and sub panels. 12/18/13 job finalized.						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	13A0148CO	Top Shelf Electric Corporation 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	80 Broad Street New York NY	Pending	\$0.00
Sandy Carry over from March 13, 2013 meeting. Provide rating of distribution from SS1.						
	13A0149CO	Zwicker Electric Co., Inc. 360 Park Avenue South, 4th Floor New York NY 10010	Requested approval for the electric service equipment proposed to be installed	60 Broad Street New York NY	Denied	\$0.00
SANDY Carry over from March 13, 2013 meeting. 1) Verify that service room is mechanically ventilated. 2) Verify what the dotted lines above the equipment are for. 3) Life safety ATS' are installed in the service room. 4) 1 line doesn't match room layout fire pump. 5) Identify which loads are future. 6) Fire pump conductors undersized. 7) Fire pump emergency feeders are not fused at the generator(130'). 8) Type of ATS' supplied from DS-EM panel not noted on drawing. 9) Existing equipment grounding conductor to DS-EM panel undersized. 10) Indicate where the emergency fire alarm is installed footage. 11) Indicate if the emergency generator is a separately derived system. 12) Doors in service room to open outwards. 13) Coordination to be verified by a PE by stamped documentation or drawing 27-3018L. 9/6/13-rejected. 9/20/13 Same revision 3's received with revised short study w/PE stamp not identified as Revision 2. This installation to be resubmitted. See documentation from electrical contractor.						
51853	13A0184CO	Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	32 Old Slip New York NY	Approved	\$0.00
SANDY Carry over from April 17, 2013 meeting. 1) Tap conductors to 800 amp switch undersized tap over 10'. 2) Remove neutral bond in utility owned fire house switch 1. 3) Existing fuse sizes and conductor sizes to ATS #2 not shown. 4) 4 sets of 500 MCM fused @ 1600A. 5) #14 not addressed, type of emergency and normal fire pump conductors not shown.						
51707	13A0190CO2	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	4 New York Plaza New York NY	Approved	\$0.00
SANDY Carry over from June 12, 2013 meeting.						
	13A0196CO	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 Fifth Avenue New York NY	On Hold	\$0.00
Carry over from May 8, 2013 meeting. 1) Elevator switchboard mismarked 4 wire, should be 3 wire. 2) What are the other loads on open knife switches? 3) Provide detail of how new 2500 replacement switch picture will be installed. Pictures don't appear to match. 4) Explain why new 2500 amp disconnect switch couldn't be tapped from existing switchboard to a new separate disconnect switch next to the existing board.						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51786	13A0213CO	Roz-A-Lite Electric 163 20th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	170 Amsterdam Avenue New York NY	Approved	\$0.00
Carryover from June 12, 2013 meeting. Provide coordination short circuit 27-3018.L. 8/2/13 job finalized. 1/10/14 Swapped D-1 Rev 2. 1/8/15 Swapped D-1, Rev 3 and D-2, Rev 3. 10/30/15 Rejected Swap 4 has many changes. Provide coordination for emergency side devices.						
51709	13A0246CO	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Hunters Point South-Parcel B 1-55 Borden Avenue Queens NY	Approved	\$0.00
Carry over from June 12, 2013 meeting. 1/14/14 Swapped C Rev 2, D Rev 3. E Rev 4 and F and 3., 8/26/15 Swapped drawings C-Revision 3, E-Revision 5 and F-Revision 4. 12/15/15 Swapped drawings C-Revision 4, D-Revision 4 and E-Revision 6. No more as built after this						
51752	13A0250	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	250 Bowery New York NY	Approved	\$650.00
S.S. #5 feeders size not shown on drawing. Job finalized 7/30/13.						
51710	13A0251	Nunez Electric, Inc. 32-14 Greenpoint Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Adult Learning Center-3rd Fl. 27-35 Jackson Avenue Queens NY	Approved	\$650.00
52281	13A0252	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	NYULMC 141 East 3rd Street New York NY	Approved	\$650.00
1) fused and unfused (service) in same enclosure. 2) Missing floor plan. 3) Provide supplemental gnd. 4/16/14 Job finalized.						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51711	13A0253	Balance Electrical Contracting Corp. 37-20 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	242 West 76th Street New York NY	Approved	\$650.00
51712	13A0254	Heso Electric Inc. 30-36 41st Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	22 East 1st Street New York NY	Approved	\$650.00
51827	13A0256	JMC Electrical Corp. 172-02 39th Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	475 Driggs Avenue Brooklyn NY	Approved	\$650.00
Explain 200 amp switch with 400 amp fuses and fuse type. 8/16/13 job finalized.						
51856	13A0269	Fresh Meadow Electl Contrs, LLC 65-01 Fresh Meadow Lane Fresh Meadow NY 11365	Requested approval for the electric service equipment proposed to be installed	Beth Israel Medical Center 281 First Avenue New York NY	Approved	\$650.00
1) Existing switchboard one line diagram not shown in Advisory Board format as originally approved. 2) Feeder conductors at secondary of 750 KVA transformer undersize. 3) Verify mechanical ventilation provided for transformers. 9/12/13 job finalized.						
	13A0271	APS Electric Inc. 2614 West 13th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	2244 Church Avenue Brooklyn NY	Rejected	\$650.00
1) Fire alarm fuse shown incorrectly on drawing. 2) Grounding electrode not provide at fire pump s.s. 3) Fire alarm s.s. neutral not bonded to enclosure. 4) All EGC for the taps are undersized. 5) Verify DP-EM panel is life safety loads. 12/16/13 item #5 not addressed. 2/25/14 Rejected twice 1) Item #5 not addressed. 2) Emergency fire alarm switch wired reverse. 3) Emergency side fire pump fusing undersized. 4/15/14 Job finalized. 12/5/14 Rejected As built drawings, shows to many revision that the drawing must be completely re-reviewed. A new submittal required.						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52068	13A0274	Lens Electric, Inc. 2802 Avenue Y Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	511 West 182nd Street New York NY	Approved	\$650.00
Tap conductors undersize. 10/17/13 #1 not addressed (see length of tap shown). 1/10/14 job finalized.						
	13A0276	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Gateway Center II 340 Gateway Drive Brooklyn NY	Rejected	\$650.00
1) Utility in coming not show on the drawing. 2) Drawing not submittal in Advisory Board format. 3) Is work by others "Existing on new". 4) All new work to be bubbled on all the drawings. 5) Neutral link not to be installed on main bonding jumpers. 6) AIC calculations not provided. 7) Review not complete. 9/18/13-1) None of the drawings are marked Revision 1 and corrections are not shown in the title block with triangle symbols 1 identifying where on the drawings the correction were made. 2) Not in Advisory Board format.						
	13A0278	I.S.M Electric, Inc. 249 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	PS437K 713 Caton Avenue Brooklyn NY	Denied	\$650.00
1) Vertical bus sizes not shown in service room. 2) Fire rated cable is no longer listed. 3) Grounding electrode conductor to be terminated in remote service switches. 4) Neutral to be bonded in fire alarm switch. 5) Emergency conductors and wiring methods not shown. 6) Will 3 or 4 pole ATS be installed, will generator be a separately derived system. 7) Verify bus size in 3000 amp MSB-B board. 8) Verify bus sizes in 4000 amp distribution board. 9) Size of main bonding jumper not shown.						
51876	13A0279	Wamco Electric, Inc. 828 9th Avenue, 3rd Floor New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Crossroads 535 Union Avenue Bronx NY	Approved	\$650.00
1) Verify who the equipment manufacturer is. 2) Grounding electrode conductor to be terminated in fire pump service switch. 3) Conductor and wiring method to jockey pump not shown. 4) Equipment grounding conductors undersized to 1200 service swtichboard. 5) Service bus undersized to service switch #2. 6) Section bus undersized in MDP board. 9/18/13 job finalized.						
51823	13A0280	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU Langone Medical Center 550 1st Avenue New York NY	Approved	\$650.00
Provide signage on rear of the switchboard stating "do not remove rear covers". 8/16/13 job finalized.						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51713	13A0281	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1221 Avenue of the Americas New York NY	Approved	\$650.00
51818	13A0282	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	150 Broadway New York NY	Approved	\$650.00
1) Verify that Con-ED is bringing in the service entrance. 2) Provide size on main bonding jumpers. 3) Existing ss service undersized (conductors). 4) New distribution board fist sections take off bus is undersized. 8/16/13 Job finalized. 1/27/14 Swapped AB10-10 and SB10 1 of 2. 3/23/15 Swapped AB10-01, Revision 3 and SB10, 2of 2 Revision 4.						
51903	13A0283	Crana Electric Inc. 600A East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	BJ's Riverdale Crossing 184 West 237th Street Bronx NY	Approved	\$650.00
1) Verify 60 amp fuse size in MDB-VT board. 2) Verify F.P. circuits are 2-hr rated. 3) F.P. EGC is undersized. 9/25/13 job finalized. 7/29/15 Rejected. 1) Revisions not to be bubbled use triangles only with comments of changes in the title block. 2) Two transformers indicated as T2s. 3) Show doors to service room. 4) 1 Line drawing to match new service room layout of incoming sec. 9/14/15 Swapped drawing FP50 1 of 2, Revision.						
51819	13A0284	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	120 West 42nd Street New York NY	Approved	\$650.00
Neutral in distribution bonded after the service switch. 8/16/13 job finalized.						
51892	13A0285	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Vornado 280 Park Avenue New York NY	Approved	\$650.00
1) Load conductors ran through vertical switchboard Section 408.3(3). 2) Neutral in 800 amp disconnect bonded to enclosure after service switch. 3) Grounding electrode terminate not shown in 1200 amp service switch. 9/20/13 job finalized.						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51821	13A0286	Mar-Kam Electrical Contracting Inc. 153 32nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Tao-The Maritime Hotel 80-102 9th Avenue New York NY	Approved	\$650.00
Provide signage on both service room door indicating where the other service is located. 8/16/13 job finalized. 8/11/14 Swapped drawings 1 and 2 Revision 2.						
51826	13A0287	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2 Cooper Square New York NY	Approved	\$650.00
Verify clearance from service switch in existing board to side of new 1200 amp s.s. 8/16/13 job finalized.						
	13A0288	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Macedonia Plaza 37-08 Union Street Queens NY	Pending	\$650.00
1) Verify length of undersize tap conductors at 500KVA transformer. 2) Tap conductors between LVP panels undersize. 3) LVP panels bus rated 400 amps over fused 800 amps. 4) Provide cuts per co-gen to indicate it is listed.						
51832	13A0289	T & T Electrical Corp. 24-30 47th Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	592 Wales Avenue Bronx NY	Approved	\$650.00
1) Verify that 1200 amp service switch has a neutral link. 2) Remove neutral bond in fire alarm emergency switch. 8/16/13 job finalized.						
51714	13A0290	Patriot Electric Corp. 96-06 220th Street Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	Joe's Crab Shack 301 West 125th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	13A0291	zardos Mechanical & Electrical Engineerin 240 West 35th Street, Suite 304 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	New York University 100 Washington Square East New York NY	Denied	\$650.00
1) Explain how the installation of the trough will comply with Section 376.12 when installed in a wet location in concrete slab in contact with the earth. 2) Show clearances of all new equipment on room layout. 3) Bus sizes on feeders on load side of 4160/208 transformer not shown on 1 line or cut sheet. 4) Fuse types on load side fo step down transformer not shwon on 1 line. 5) Feeder sizes on load side of 4000 amp service switch not shown. 6) Explain new 4000 amp fuses in existing 2500 amp disconnect switch, feeders over fused to . 7) Room layout drawing not in Advisory Board format very confusing.S-12-DB						
	13A0292	Innovative Electrical Services 3346 Provost Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	SL Green 919 3rd Avenue New York NY	Pending	\$650.00
Cut sheet of new chiller not provided or 2nd fusing of chiller switch.						
51715	13A0293	A & M Electrical Service Inc. 617 Johnson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	310 East 2nd Street New York NY	Approved	\$650.00
8/22/14 Swapped A & B, Revision 1s. 1/8/15 Swapped drawings A & B, Revision 2.						
51716	13A0294	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S. 313Q 45-45 42nd Street Queens NY	Approved	\$650.00
51717	13A0295	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	I.S. H.S. 868M 10 East 15th Street New York NY	Approved	\$650.00
4/18/16 Swapped drawing A-Revision 2						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51835	13A0296	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Memorial Sloan Kettering Outpatient 1133 York Avenue New York NY	Approved	\$650.00
4/0 fused at 600 amps paralleling gear to ATS 7. 7/30/13- #1 not addressed. 8/22/13 job finalized. 6/27/16 Swapped drawings A-Revision 3; Drawing B-Revision 2 and Drawings C and D-Revision 3.						
52187	13A0297	Broadway Electric LLC 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	55 Church Street New York NY	Approved	\$650.00
1) Provide cut sheet for co-gen units showing that they are listed. 2) Provide sequence of operation of cogen units. 3) If main circuit does not contain bonding and grounding ,new 30 amp service switches are to have grounding electrode conductor terminals,. 2/26/14 job finalized.						
51718	13A0298	Tower Electric 21-19 40th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	3050 Corlear Avenue Bronx NY	Approved	\$650.00
51719	13A0299	Bestco General Electrical Inc. 922 East 233rd Street Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	NY Presbyterian Hospital 409 East 60th Street New York NY	Approved	\$650.00
12/24/15 Swapped Drawing 1 and 2-Revision 1						
51720	13A0300	BLH Electrical Contractors, Inc. 146 E. 151 Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	2334 Boston Road Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51721	13A0301	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	120 East 23rd Street New York NY	Approved	\$650.00
9/13/13 Drawings swapped -Rev 1.						
51722	13A0302	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	253 East 142nd Street Bronx NY	Approved	\$650.00
9/13/13 Drawings swapped -Rev 1.						
51723	13A0303	GRX Euro Electric Corp. 164-13 Cross Island Parkway Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	23-25 31st Street Queens NY	Approved	\$650.00
1/10/14 Swapped Rev 1						
51724	13A0304	Athens Electric, Inc. 1980 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	145 East 16th Street New York NY	Approved	\$650.00
1/10/14 Swapped Rev 1						
	13A0305	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	108-11 Queens Blvd. Queens NY	Pending	\$650.00
1) Reduced neutral calculation not provided. 2) Fuse coordination study not provided(27-3018-L) by P.E. 3) Tap of a tap not permitted, tap length not provided. 4) Provide main in BDP, and tap length.						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51889	13A0306	Horsepower Electric 821 McDonald Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	313 Gold Street Brooklyn NY	Approved	\$650.00
Fire pump feeders to be fire rated. 9/19/13 job finalized.						
51885	13A0307	Accurate Electric Inc. 486 Avenue P Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	28 Debevoise Street Brooklyn NY	Approved	\$650.00
Verify size of service entrance to service switch #2. 9/19/13 job finalized.						
51725	13A0309	Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	240 Riverside Blvd. New York NY	Approved	\$650.00
51726	13A0310	Jorob Contracting and Electrical Co. Inc. 104-29 Jamaica Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	301 West 125th Street New York NY	Approved	\$650.00
51727	13A0311	Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456	Requested approval for the electric service equipment proposed to be installed	900 West End Avenue New York NY	Approved	\$650.00
12/19/14 Swapped Revision 1. 3/23/15 Rev 1 was already swapped on 12/19/14. 7/28/15 Swapped Drawing 1, Revision 2.						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51728	13A0312	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	80 Maiden Lane New York NY	Approved	\$650.00
10/22/13 Swapped Rev 2.						
51729	13A0313	K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	167 East 67th Street New York NY	Approved	\$650.00
51730	13A0314	L.E.A. Electric Corp. 2112 Broadway, Suite 204 New York NY 10023	Requested approval for the electric service equipment proposed to be installed	1775 Grand Concourse Bronx NY	Approved	\$650.00
	13A0316CO	Allran Briteway Electrical Contrs, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	104 Broad Street New York NY	Pending	\$0.00
SANDY Carry over from June 12, 2013 meeting. 1) Provide GFP on both utility and emergency feeder. 2) Confirm trx is step-up trx and is used in accordance with manufacturer's requirement.						
	13A0320	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Cobble Hill Health Center 380 Henry Street Brooklyn NY	Denied	\$650.00
1) #6 Grounding electrode conductor to building steel undersized. 2) Verify F.P. emergency circuit fire protected (RHN 2hr fire rated cable no longer listed). 3) Physical not provided for new service switches distribution switchboard. 4) Verify 4 pole ATS are used to justify bonding neutral at generator frame. 5) Fire alarm service switch to have a terminal for grounding conductor and neutral bond to enclosure. 6) Fire pump service switch to have a ground terminal. 7) ATS #1 not protected on line side for fire alarm. 8) Clearances not shown in service room.						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	13A0325	Dynamic Electric System, Inc. 121 Greenpoint Avenue Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	St. John's University 8000 Utopia Parkway Queens NY	On Hold	\$650.00
1) Cut sheet of transformer not provided. 2) Clearance for transformer to comply with table 110.34A. 3) Fire pump tapped from cubicle that contain overcurrent protective devices. 4) New bus 5KV to match existing , bus to be 1/2x6" and fused at 1200A no 2000A. 5) Parallel operation of trans, to comply w/450.7. 6) Remove one of the neutral bondings. 7) Indicate the interlock on 5kv pad MTD substation(sw). 8) Provide 60" clearance behind new switch, comply w/T110.34(A). 9) Page 2 of coordination study, issue must be addressed.						
	13A0333	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Water's Edge Educational Campus 49 Flatbush Avenue Extension Brooklyn NY	On Hold	\$650.00
1) Fire pump s.s. less than 1ft from 4000A S.S. 2) Verify generator is a separately derived systems(4 pole ATS used). 3) Drawing not in Advisory Board format. 4) Which service are new taps being made from?						
51907	13A0337	Hylan Datacom & Electrical 455 Morgan Avenue Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Hamilton Avenue Asphalt Plant 422 Hamilton Avenue Brooklyn NY	Approved	\$650.00
1) EGC's undersized. 2) Verify through bus sizes in MCC#2 and MCC#1. 3) Show bus sizes in existing Gallagher switchgear, bonding and grounding. 4) Coordination study service #2 is overlapping not good. 10/1/13 job finalized.						
52135	13A0346	NYMEC 269 37th Street, Suite 200 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	95 Wall Street New York NY	Approved	\$650.00
SANDY 1) Show location of service end box and routing of conduit run to 2nd floor, show cable support boxes if required. 2) Verify that Con-Ed will not require a utility disconnect switch at the point of entry. 3) Verify that ATS' will be in a fire rated enclosure, and no emergency feeders will be run through the service room. 4) Verify 5' clearance in front of service switch #3. 5) EGC for fire pump undersized, verify size of f.p. transformer. 6) Show fire pump connection to generator. 7) Verify if generator neutrals are bonded if yes, 4 pole ATS' to be used. 8) Roll up generator to comply with 700.6(G). 1/24/14 job finalized. 5/15/14 Swapped 2 drawing Rev 2. 6/24/14 Swapped 4,5 and 6 Rev 1.						
52244	13A0349	Sheridan Electric, Ltd. 197 Grand Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Hilton Garden Inn 99 Washington Street New York NY	Approved	\$650.00
1) Show bus size on lower vertical bus that feeds the fire pumps and fire alarm. 2) Fire pump feeder to be fire rated. 3) Ground connector to fire alarm service switch undersized. 4) Show size of through bus between the last 2 sections of switchboard MDS-1 Service A. 3/26/14 job finalized.						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51881	13A0354	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	90 West Street New York NY	Approved	\$650.00
SANDY 1) Show routing of service entrance conductors from basement to garage, show cable support boxes if requested. 2) Verify if special service fire pump switch is a service switch. 3) Special service fire pump switch is reversed on drawing. 4) Manual service switch for fire pump not shown on room layout drawing. 9/18/13 job finalized.						
51820	13A0365	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	17 Battery Place New York NY	Approved	\$650.00
SANDY Provide copy of detailed NETA testing report showing complete testing of all existing equipment. 7/17/13 job finalized.						
51948	13A0366	Qncc Electric 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	90 Washington Street New York NY	Approved	\$650.00
SANDY 1) F.P. S.S. Neutral not bonded to the enclosure. 2) Grounding electrode not provided at F.P.S.S. 3) Feeder conductors at loadside of 1200 amps service switches overfused. 4) The physical for distribution panel DPA, DP-C and DP-D doesn't match one line drawing. 5) Provide door giving. 10/23/13 job finalized.						
	13A0367	Litespeed Electric 135 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Pier 92-Temporary Service 711 12th Avenue New York NY	Rejected	\$650.00
SANDY 1) Neutral already bonded to generator enclosures. Also, 3000 amp and 2-1600 amps disconnect switches. 2) Physical for temp switchboard 2B does not match one line. 3) DLO cables to be installed in cable tray. 4) How will be the length of the temp be? 9/18/13 1) Item #3 and #4 not addressed. 2) How many sets of conductors will be installed?						
51851	13A0368	AMA Consulting Engineers, P.C. 250 West 39th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Pier 92 Permanent Service 711 12th Avenue New York NY	Approved	\$0.00
SANDY 1) Tap fir fire pump supply to be on line side of main switch n transformer cabinet or isolated cabinet. 2) Provide sequence of operation for GFP. 3) Include sub-station breakers in coordination study. 4) Indicate grounding electrode system. 5) Indicate grounding and bonding. 6) Verify if grounding switch on the primary side of different equipment. 8/26/13 job finalized. 12/18/15 Swap Drawing A-Revision 6, Drawing B-Revision 5, Drawing C-Revision 4 and Drawing D-Revision 4						

ADVISORY BOARD CALENDAR

July 17, 2013

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	13A0376	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	360 Furman Street Brooklyn NY	On Hold	\$650.00
1) Length of tap conductors not provided. 2) Grounding electrode not provided at F.P. S.S. 3) GFP not provided secondary of step-up 1500 KVA transformer. 4) Neutral not bonded to enclosure Switchboard "A" 2500A S.S. 5) Tap conductors length, size and type fuses at retail trough not provided. 6) New cellar distribution panel bus size not provided. 7) Verify mechanical ventilation provided service room. 8) Verify switchboard provided rear doors.						
51731	13A0382	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requesting permission to install enclosed outdoor feeders on two buildings in Schedule 80 nonmetallic conduit in a corrosive area, Far Rockaway, Queens.	146 Bch 59th St. & 141 Bch 56th Pl Far Rockaway NY	Approved	\$0.00
51732	13A0385	Richard Neu, Licensed Electrician 4347 Hylan Blvd. Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	Bronx Lebanon Hospital 1285 Fulton Avenue Bronx NY	Approved	\$650.00
51733	13A0389	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission on submittal 13A0138 to allow the use of fire rated RHH for temporary connection of the fire pumps until permanent locations are determined.	90 Broad Street New York NY	Approved	\$0.00
With the stipulation that the temporary manual fire pump installation lasts no longer than 6 months and the conductors are installed in rigid galvanized. Steel conduit.						
51998	13A0416	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requesting permission utilize Exception No.2 to Section 725.130(A) with Section 725.30 in an existing underground conduit that supplies power to led luminaires and their drivers.	1000 Fifth Avenue New York NY	Approved	\$0.00
Approved 10/27/13.						