

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46242CO	05A0100CO	Al-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	180 Livingston Street Brooklyn NY	Approved	\$0.00
Carry over from March 16, 2005 meeting.						
46358CO	05A0176CO	Robco Electric Corp. 2630 Chesbrough Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	60 East 55th Street New York NY	Denied	\$0.00
Carry over from May 25, 2005 meeting. 1) Drawing submittal is not in Advisory Board format. 2) Bus sizes for existing equipment was not provided. 3) Bonding, grounding and fuse types were not provided.						
46420CO	05A0257CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	325 5th Avenue New York NY	Approved	\$0.00
Carry over from June 15, 2005 meeting.						
46428CO	05A0285CO	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	Mutual Redevelopment Hses 321 Eight Avenue New York NY	Hold	\$0.00
Carry over from June 15, 2005 meeting. Need short circuit calculations.						
46474	05A0307	Falco Electrical Services, Inc. 2220 Voorhies Avenue Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	260 Madison Avenue New York NY	Hold	\$650.00
1) Provide room layout. 2) Confirm Compliance with tap rules.						

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46475	05A0319	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	David Burke@Bloomingdales 1000 3rd Avenue @ E. 59th Street New York NY	Approved	\$650.00
46476	05A0321	Rigid Electric, Inc. 336 37th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Hospital for Special Surgery 535 East 70th Street New York NY	Approved	\$650.00
46477	05A0320	Christopher Jon Electrical Contractors, Inc 108 Frost Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	21-21 Maiden Lane New York NY	Approved	\$650.00
46478	05A0318	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	William Taft High School 240 East 172nd Street Bronx NY	Approved	\$650.00
Provide signage indicating multiple service rooms.						
46479	05A0317	Crossland Electrical Systems, Inc. 846 East 52nd Street Brooklyn NY 11203	Requested approval for the electric service equipment proposed to be installed	1125 Park Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46480	05A0316	JFI Electric Co. 24-25 46th Street Long Island City NY 11103	Requested approval for the electric service equipment proposed to be installed	Mairon & Sons 220 Coster Street Bronx NY	Approved	\$650.00
46481	05A0315	Edwards & Zuck, PC 315 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Tishman 30 Rockefeller Plaza New York NY	Hold	\$650.00
1) Clarify job location. 1-Line says 630 5th Ave. Title block and letter says 30 Rockefeller Plaza. 2) Existing 3-500 KCM tap too small for new load off. 3) Identify building and floor of generator and generator distribution switchboard.						
46482	05A0314	JB Electric Corp. 3702 Rombouts Avenue Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	Verizon 1095 Sixth Avenue New York NY	Hold	\$650.00
1) Show Con Ed point of entry for new services. 2) Confirm new Cutler-Hammer busway is 3 phase 3W or show neutral transfer scheme. 3) Confirm there no 4-wire loads downstream of service.						
46483	05A0313	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	AT & T Site N116A 3200 Baychester Avenue Bronx NY	Approved	\$650.00
46484	05A0312	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	AT & T Site N115 1010 Underhill Avenue Bronx NY	Approved	\$650.00
Confirm generator controls and equipment are not obstructed by new equipment.						

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46485	05A0311	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Atlas Park 80th Street & Cooper Avenue Glendale NY	Hold	\$650.00
1) Clarify transformer connection of step-down XMFR. Should be 4160 Delta-480/277Y coordinate with Olsum cuts. 2) Provide floor plan of step-down XFMR location. 3) Provide secondary overcurrent protection on step-down XFMR.						
46486	05A0310	BLZ Electric, Inc. 620 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	Bronx Lebanon Hospital 1276 Fulton Avenue Bronx NY	Approved	\$650.00
46487	05A0309	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Bank of America 261 Broadway New York NY	Approved	\$650.00
46488	05A0308	Argon Electric Corp. 34-18 Northern Boulevard Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	50 Central Park West New York NY	Approved	\$650.00
46489	05A0343	Strand Electric Co., Inc. 160 Eleventh Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Hall Street Cold Storage 12-38 Hall Street Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46490	05A0344	Nead Electric Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Northern Power Cogen. Plant 717 Fifth Avenue New York NY	Approved	\$650.00
1) Provide signage on fusible switches feeding bus duct : "Fuses may be energized by back feed". 2) Provide floor plan for installations of cogen equipment.						
46491	05A0345	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 193 Manhattan Avenue New York NY	Approved	\$650.00
46492	05A0346	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Fortress Investments 145 Avenue of the Americas "Bldg. C" New York NY	Hold	\$650.00
Comply with code required side clearances or request special permission.						
46493	05A0347	Highland Associates 228 East 45th Street New York NY 10017	Requested approval for the electric service equipment proposed to be installed	5 Madison Avenue New York NY	Approved	\$650.00
46494	05A0348	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Bank of America 1633 Broadway New York NY	Hold	\$650.00
Provide floor plan.						

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46495	05A0349	Kleinknecht Electric Company, Inc. 940 Eighth Avenue New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Ann Taylor Cafeteria 7 Times Square New York NY	Approved	\$650.00
46496	05A0350	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Gramercy Pk Hotel Residences 50 Gramercy Park North New York NY	Approved	\$650.00
46497	05A0351	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Best Buy 529 Fifth Avenue New York NY	Approved	\$650.00
Tap feeder is undersized.						
46498	05A0339	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	400 West 55th Street New York NY	Approved	\$650.00
46499	05A0340	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	19-35 West Houston Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46500	05A0330	Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Jacobi Medical Center 1400 Pelham Parkway South Bronx NY	Denied	\$650.00
1) Section 230.70(A) of the New York City's amendments requires the service disconnecting means to be installed at a readily accessible location inside a building or structure nearest the point of entrance of the service conductors.						
46501	05A0331	Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	3000 Avenue X Brooklyn NY	Approved	\$650.00
46502	05A0332	Hatzel & Buehler, Inc. 45 Broadway, Suite 1240 New York NY 10006	Requested approval for the electric service equipment proposed to be installed	Thomson Financial 3 Broadway, 15th, 16th, 21st & 22nd F. New York NY	Approved	\$650.00
1) Show length of taps. 2) Show 2 800 amp disconnect switches on service room layout.						
46503	05A0334	OM Electric, Inc. 262 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	21 West 86th Street New York NY	Approved	\$650.00
46504	05A0335	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	Montefiore Medical Center 111 East 210th Street New York NY	Ok, but	\$650.00
1) Verify if a steel PVC is being used. 2) ATS 3 or 4 pole. 3) Size of bonds.						

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46505	05A0336	Queens Electrical Contractors, Inc. 32-17 Broadway Astoria NY	Requested approval for the electric service equipment proposed to be installed	555 Prospect Place Brooklyn NY	Approved	\$650.00
46506	05A0337	Thorn Electric Inc. 322 East 117th Street New York NY 10035	Requested approval for the electric service equipment proposed to be installed	P.S. 279K 1070 East 104th Street Brooklyn NY	Approved	\$650.00
46507	05A0338	Norway Electrical Corp. 1205 Jerome Avenue Bronx NY 10452	Requested approval for the electric service equipment proposed to be installed	t. Washington Ave. aka 651 W. 168t New York NY	Approved	\$650.00
46508	05A0306	DiFazio Electric NY, Inc. P.O. Box 140219 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 125 W. 73rd Street New York NY	Ok, but	\$650.00
1) Provide tap detail. 2) Provide size of line side conductor.						
46509	05A0305	OHR Chodosh Electl Contg, Inc. 979 East 35th Street Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	Yeshiva Noviminsk 1690 60th Street Brooklyn NY	Hold	\$650.00
Provide cut sheets of equipment.						

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46510	05A0304	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1655 Flatbush Avenue Brooklyn NY	Approved	\$650.00
46511	05A0303	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	90-10 Grand Central Parkway East Elmhurst NY	Approved	\$650.00
46512	05A0302	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	4101 Broadway New York NY	Approved	\$650.00
46513	05A0301	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	25 Tudor City Place New York NY	Approved	\$650.00
46514	05A0300	Quest Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	Claremont Apartments 1450 Clay Avenue Bronx NY	Hold	\$650.00
1) Service bus undersized. 2) Feeder of 1200A service switch undersized. 3) No coordination between 1200 amp and 800 amp fuses. 4) Show where pull box is located in service room. 5) Provide coordination curves for fuses to circuit breakers.						

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46515	05A0322	Shorr Electrical Contracting Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Supersign Upgrade 1600 Broadway New York NY	Approved	\$650.00
46516	05A0341	Stonehill Electric Corp. 33-00 Northern Blvd.-Lobby Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Morimoto Restaurant 88 Tenth Avenue New York NY	Approved	\$650.00
with the stipulation that signage is provided in the service room indicating that there is a service on the other side of the archway.						
46517	05A0323	K.N.C. Electric 187-27 Linden Blvd. St. Albans NY 11412	Requested approval for the electric service equipment proposed to be installed	333 West 17th Street New York NY	Approved	\$650.00
46518	05A0324	Blasko Electrical Contractors, Inc. 36-38 35th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	233 Spring Street New York NY	Approved	\$650.00
46519	05A0325	Barbaro Electric Co., Inc. 331 38th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	48 West 37th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46520	05A0333	Barbaro Electric Co., Inc. 331 38th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	1071 6th Avenue New York NY	Approved	\$650.00
46521	05A0326	Barbaro Electric Co., Inc. 331 38th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	5 West 32nd Street New York NY	Approved	\$650.00
46522	05A0327	Barbaro Electric Co., Inc. 331 38th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	463 7th Avenue New York NY	Approved	\$650.00
46523	05A0329	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	134-54 Maple Avenue Flushing NY	Approved	\$650.00
46524	05A0328	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	144-06 94th Avenue Jamaica NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46525	05A0352	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Restaurant Depot 43-40 57th Avenue Queens NY	Denied	\$650.00
1) The 2000 to 1200 amp fuses do not coordinate. 2) The fire pump shall only be fed by one service switch only. 3) The center tap on the transformer is not bonded. 4) A fuse cut out on load side of the transformer was not provided. 5) The mounting of the transformer in service room was not shown. 6) The fire pump is unmetered.						
46526	05A0342	Double D Electric Corp. 33 2nd Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Mak Imaging 163 East 84th Street New York NY	Approved	\$650.00
1) Tap to fire alarm cut out not on line side of service switch. 2) Provide supplemental ground.						
46527	05A0353	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	25 West 51st Street New York NY	Approved	\$650.00
1) Provide supplemental ground. 2) Provide bond in 200 service switch. 3) Provide location of fire pump. 4) Remove fuse cut out before fire alarm.						
46528	05A0354	Zev Electric Corp. 54 Pearl Street Brooklyn NY 11201	Requested approval for the electric service equipment proposed to be installed	Josh Guttman 68 Jay Street Brooklyn NY	Hold	\$650.00
1) Provide Manufacturers physical drawings of equipment. 2) Provide 7 foot clearance when switchboards are facing each other.						
46529	05A0355	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1075 Park Avenue New York NY	Approved	\$650.00
Provide manufacturer's cut sheet of panel HDP.						

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46530	05A0356	High-Tech Electrical Services Corp. 36-33 23rd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Nokia 1515 Broadway New York NY	Approved	\$650.00
46531	--	altPower, Inc. 160 Fifth Avenue, Suite 807 New York NY 10010	Requesting permission one time location to install unapproved photovoltaic panels.	Battery Park City Site 18B 211 North End Avenue New York NY	Approved	\$0.00
with the stipulation that all components must be listed and approved and shall be field evaluated as a complete system by a nationally recognized testing laboratory.						
46532	--	June Electric Corp. 3110 Wilkinson Avenue, Suite 2C Bronx NY 10461	Requesting permission on a new service to utilize amendment 220.35, optional calculations where the service was violated for being undersized.	1240 Washington Avenue Bronx NY	Hold	\$0.00
Provide load calculations.						
46533	--	James, Lasala & Associates, LLP 11 Oval Drive, Suite 129 Islandia NY 11749	Requesting permission not to file Advisory Board drawings for additional new service work do to the 1600 amp fusing in the 4000 amp switch.	395 Brook Avenue Bronx NY	Denied	\$0.00
Advisory Board submittals are required for any change in the service equipment with the rating of 1000 KVA or larger, up to and including 2nd level of overcurrent protection.						
46534	--	Lehr Construction Corp. 902 Broadway New York NY 10010	Requesting permission to omit two electrical panel system service entry boxes by directly connecting the panel system using the manufacturers listed MC cable feed.	55 Water Street New York NY	Approved	\$0.00
with the stipulation that special permission is required for each installation.						

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46535	-----	Platinum Electrical Contracting Inc. 360 Industrial Loop Road Staten Island NY 10309	Requesting permission to leave as installed a service entrance trough without a front clearance of 36 inches.	Strip Mall 4906 Arthur Kill Road Staten Island NY	Denied	\$350.00
Section 110.26 requires sufficient access and working space for examination, adjustment, servicing or maintenance while energized shall comply with the dimensions of 110.26(A)(1), (2) and (3) or as required elsewhere in the 2002 NEC and New York City's amendments.						
46536	-----	Megarix Electrical Contracting Corp. 37-12 13th Street Long Island City NY 11101	Requesting permission to install Schedule 80 PVC conduit service standpipes on 5 homes located in a corrosive Far Rockaways areas.	34, 336, 338 and 340 Beach 102nd St Far Rockaway NY	Approved	\$0.00
46537	-----	Marriott Electric Corp. 182-25 150 Avenue Springfield Gardens NY 11413	Requesting permission to install Schedule 80 PVC conduit service standpipes on 27 homes located in a corrosive Far Rockaways area.	150 Avenue Road, Brunswick Avenue & Seagraves Far Rockaways NY	Approved	\$0.00
46538	-----	Chaim Electric 2920 Avenue J Brooklyn NY 11210	Requesting permission to leave as installed Schedule 40 PVC conduit for a service standpipe on a single family home.	549 Jarvis Avenue Far Rockaway NY	Approved	\$0.00
46539	-----	D & S Electrical Corporation 450 Beach 48th Street Far Rockaway NY 11691	Requesting permission to install Schedule 80 PVC conduit service standpipes on 26 homes located in a corrosive Far Rockaways area.	1 Aquatic Dr, 2 Beach 77th St. & 3 Beach Far Rockaways NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 20, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46540	-----	Lawless & Mangione, Arch. & Eng. LLP 480 North Broadway Yonkers NY 10701	Requesting permission in a building that is being electrically upgraded to temporarily install a fire pump that will be fed by a second fuse.	San Remo 145-146 Central Park West New York NY	Denied	\$0.00
Section 695.3(A)(1) of the New York City's amendment to the National Electrical Code states that power for a fire pump shall be supplied by a separate service, or by a tap located ahead of and not within the same cabinet, enclosure, or vertical switchboard section as the service disconnecting means.						
46541	-----	Edwards & Zuck, PC 315 Park Avenue South New York NY 10010	Requesting permission to tap power for the 32nd floor fire alarm system from the line side of a local emergency generator panel in lieu of tapping the line side of the generator's main switch located on the roof of an 40 story building.	Rockefeller Plaza a.k.a 630 5th Ave New York NY	Approved	\$0.00
with the stipulation that this approval only applies to the existing system.						
46542	-	Wank Adams Slavin Associates LLP 740 Broadway New York NY 10003	Requesting permission to apply Section 210.60(B) in lieu of 210.52 for receptacle outlet spacing requirements in a college dormitory where the furniture will be fixed in place.	Fashion Institute of Technology 406 West 31st Street New York NY	Approved	\$0.00
with a stipulation.						
46543	05A0357	Design Plan 79 Trenton Avenue Frenchtown NJ 08825	Requested approval for use in New York City of your Exit Signs. Series XLW, XLC and XLS.		Denied	\$200.00
46544	*	Atkinson Koven Feinberg Engineers, LLP 1501 Broadway, Suite 700 New York NY 10036	Requesting concept approval for providing generator backed optional standby power at 30 Rockefeller Plz that will feed 10 Rockefeller Plz by routing through common garages and underground tunnels by one owner and will comply with Articles 225.30(A)(4) and 225.32 of NYC Electrical Code.	10 Rockefeller Plaza. New York NY	Approved	\$0.00