

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 8-05-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, Unincorporated Division of Honeywell International Inc.,
3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name – System Sensor.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Tests - UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report – UL File S3705, Project 04NK16146, Vol. 23 Section 1, issued 11/29/04.

Description – Fire alarm equipment as listed below:

Model No.	Fike Model No.	Description
EM-1SR	55-042	Supervising control modules
EM-1SRI	55-047	Supervising control modules
EM-1M	55-041	Monitor modules
EM-1MI	55-046	Monitor modules
EM-1MM	55-045	Monitor modules
EM-1MMI	55-050	Monitor modules
EM-1R	55-043	Relay modules
EM-1RI	55-048	Relay modules

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated January 10, 2005, F.P. Index No. 0412071.

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements and functions, applications and installations shall comply with all applicable provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard RS 17-3. The above referenced products shall be used only with listed and approved control panels and accessories. The compatibility must be specified or determined by a UL test report or the Engineer of Record. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

February 28, 2005

Examined by