

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49426CO2	09A0185CO2	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Randall's Island Field Devel. Randall's Island Park Randall's Island NY	Hold	\$0.00
Carry over from July 14, 2010 meeting. Engineer did not appear at meeting.						
50110CO	10A0172CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	HBO 1100 Avenue of the Americas New York NY	Approved	\$0.00
Carry over from May 19, 2010 meeting.						
50164CO	10A0212CO	C.M.S. Electrical Services Co., Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Sony Building Gen. Replacement 550 Madison Avenue New York NY	Approved	\$0.00
Carry over from June 16, 2010 meeting. 1) Isolate emergency neutral conductor in service switchboards. 2) Relocate F.A. transformer switch tap for emergency side into service switchboard 'B'. Fuse at 40 amp normal and emergency. Job finalized 10/21/10.						
50224CO	10A0266CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Fordham University 655 East Fordham Road Bronx NY	Approved	\$0.00
Carry over from July 14, 2010 meeting.						
50232	10A0270	Lilker Associates Consulting Engs, PC 1001 Avenue of the Americas New York NY 10018	Requested approval for the electric service equipment proposed to be installed	30 East 9th Street New York NY	Approved	\$650.00
Door in service room to open outwards. Job finalized 9/20/10.						

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50233	10A0271	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	61 Broadway New York NY	Approved	\$650.00
60 HP F.P. not classified special service. Must size service switch for 600% 800A switch ok. Job finalized 3/31/11.						
50234	10A0272	Hal Electrical Contractors Inc. 32 East 31st Street, Suite 812 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	1854 Cedar Avenue Bronx NY	Approved	\$650.00
50235	10A0273	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Triennale Museum 40 West 53rd Street New York NY	Hold	\$650.00
1) Provide short circuit calculations and coordination curves for DP-H. 2) Where is DP-H located.						
50236	10A0274	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Randall's Island Field Develo Randall's Island NY	Hold	\$650.00
1) 4 sets of 500 MCM fused at 1600 amps. Type W cable in raceway nto permitted. 2) Secondary fo transformers to be bonded and grounded. 3) Provide detail of connections from 1500KVA secondary teams to CB's. 4) Provide bus sizes for East switchboard "MDPB"						
50237	10A0275	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Medgar Evers College 1150 Carroll Street Brooklyn NY	Approved	\$650.00
Indicate length of tap. Job finalized 11/16/10.						

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50238	10A0276	Twins Electric Corporation 695 East 132nd Street, Suite 205 Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	568 Union Avenue Brooklyn NY	Approved	\$650.00
<p>1) Cut sheet for fuel cell not provided. Is it listed equipment? 2) Add clearances on floor plan. 3) Clarify fuel cell system shuts down when 800A maintenance disconnect switch is open. 4) Correlate maintenance disconnect switch truth table device designations with 1-Line. Job finalized 10/21/10.</p>						
50239	10A0277	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Beacon Capital Partners 1211 6th Avenue New York NY	Approved	\$650.00
<p>1) Verify if MTS' are 3 or 4 pole types. Verify generator grounding. 2) Provide generator back-up source to fire alarm system. 3) Provide GFP on generator switchboard breakers 1000 and above. 4) Provide overall 1-Line showing all transfer switches. 5) Provide sequence of operation,</p>						
50240	10A0278	A.S.R. Electrical Contracting, Inc. 845 Lexington Avenue, Suite 3R New York NY 10021	Requested approval for the electric service equipment proposed to be installed	Roosevelt Island-Tram Mod. Roosevelt Island NY	Hold	\$650.00
<p>1) Verify if MTS' are 3 or 4 pole types. Verify generator grounding. 2) Provide generator back-up source to fire alarm system. 3) Provide GFP on generator switchboard breakers 1000 and above. 4) Provide overall 1-Line showing all transfer switches. 5) Provide sequence of operation,</p>						
50241	10A0279	alvatore Campisi & Sons Electl Contr., Inc 453 Onderdonk Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	218 West 40th Street New York NY	Approved	\$650.00
<p>1) Verify what work is new. 2) 4000 amp feeder not GFP. 3) Service room doors to open out. 4) Provide selective coordination on new 4000A tap system. Consider relocating tap on line side of existing service switch.</p>						
50242	10A0280	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Lehman College 2990 Goulden Avenue Bronx NY	Hold	\$650.00

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50243	10A0281	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Proskauer-Rose 11 Times Square New York NY	Approved	\$650.00
1) No coordination 800A to 600A. 2) Neutral tap for new service switch to be on line side of switchboard disconnect link. Job finalized 9/17/10.						
50244	10A0282	Gallant Fox Electrical Corp. 162-20 77th Road, Suite 2C Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	Dow Jones/NYPost 900 East 132nd Street Bronx NY	Approved	\$650.00
50245	10A0283	Testa Electric 1435 65th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	110-60 Dunkirk Street Queens NY	Approved	\$650.00
50246	10A0284	V-Mar Electric Ltd. 408 Grand Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	521 West 57th Street New York NY	Ok, but	\$650.00
Personnel can be trapped in front new CT comp. Reconfigure.						
50247	10A0285	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	BRC 127 West 25th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50248	10A0286	RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2411 Frederick Douglass Blvd. New York NY	Approved	\$650.00
50249	10A0287	Amko Electrical Construction & Maint. Inc 32-17 College Point Blvd. Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	420 Park Avenue South New York NY	Approved	\$650.00
12/18/13 Swapped Revision 1 5/6/14 Address Correction and Swapped Rev 2. 12/19/14 Swapped Revision 1. 3/24/15 Swap for Rev 3 already done.						
50250	10A0288	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Fordham University 405 East Fordham Road Bronx NY	Approved	\$650.00
50251	10A0289	Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	820 St. Anns Avenue Bronx NY	Approved	\$650.00
50252	10A0290	Power Tech Electric Corp. 245 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	820 Concourse Village West Bronx NY	Approved	\$650.00
1) Barrier off back of switchboard. 2) Need Con ED metering for fire pump. Job finalized 9/20/10.						

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50253	10A0291	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	95-25 Queens Boulevard Queens NY	Approved	\$650.00
50254	10A0292	Athens Electric, Inc. 1980 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	15 Maiden Lane New York NY	Approved	\$650.00
50255	10A0293	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Clinton Park/Mercedes Benz 770 11th Avenue New York NY	Approved	\$650.00
50256	10A0294	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	One World Trade Ctr-Tower New York NY	Approved	\$650.00
50257	10A0295	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Standard Charter Bank 1095 6th Avenue New York NY	Hold	\$650.00
1) Distribution boards not identified on room layout drawing. 2) Verify GFP on generator breaker. 3) Bus sizes not provided in MDS A & B panels. 4) Special permission needed for non selectivity.						

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50258	10A0296	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	19 West 34th Street New York NY	Approved	\$650.00
50260	10A0298	Slattery Engineering, P.C. 216 Sprett Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	Kings Plaza Co-gen Plant Brooklyn NY	Ok, but	\$650.00
Subject to grounding grid scheme is capable of holding 400 pumps.						
50261	10A0299	A.T.J. Electrical Co., Inc. 122-11 15th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	PS-69R 144 Keating Place Staten Island NY	Approved	\$650.00
1) Detail of taps not shown that feed service switches PPA and PPB. 2) Grounding and bonding of service switches PPA and PPB not shown. 3) Short circuit calculations not provided. 4) Is new device a circuit breaker or switch? Job finalized 10/6/10.						
50262	10A0300	erified Electrical & Technical Services, In 27 William Street, Suite 409 New York NY 10005	Requested approval for the electric service equipment proposed to be installed	310 Lexington Avenue New York NY	Ok, but	\$650.00
Equipment grounding conductor undersized for 4/0 service entrance conductors.						
50263	10A0301	Laredo Electric, Inc. 2477 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Veterans Road Retail, Bldg A 2955 Veterans Road West Staten Island NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50264	10A0302	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	Union League Club 38 East 37th Street New York NY	Approved	\$650.00
50265	10A0303	Konsker Electric Corp. 35-37 36th Street, Suite 402 Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	414 West 14th Street New York NY	Approved	\$650.00
50266	10A0304	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Mt. Sani 4 East 102nd Street New York NY	Hold	\$650.00
1) Drawings from other contractor needed to complete review of this submittal, not complete. 2) The source of the 4000 amp switch is not indicated.						
50267	10A0305	Merit Electrical Contracting Corp. 648 4th Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	2129 White Plains Road Bronx NY	Ok, but	\$650.00
Equipment grounding conductors for feeders undersized.						
50268	10A0306	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Williamsburg Charter H.S. 198 Varet Street Brooklyn NY	Approved	\$650.00
Stairwell pressurization equipment to fed off of 1st fusing. Job finalized 1/5/11.						

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50269	10A0307	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Queens West Parcel 4 46-15 Center Blvd. Hunters Point Long Island City NY	Ok, but	\$650.00
1) Service entrance conductors undersized. 2) Equipment grounding conductors on load side of F.P. service switch undersized. 3) Time Warner disconnect switch bonded after service switch. 4) Bus feeding 1600 amp switch in MS-B undersized. 5) Indicate where rear cabinet doors will be installed.						
50270	10A0308	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The Farber Center 100 Church Street New York NY	Approved	\$650.00
50271	10A0309	Samson Electric Corp. 3300 Northern Blvd, Basement Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	33-00 Northern Boulevard Long Island City NY	Approved	\$650.00
50272	10A0310	Martin Dorkin, Licensed Electrician 547 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	400 Casanova Street Bronx NY	Approved	\$650.00
50273	10A0311	I.K.E. Electrical Corp. 601 West 26th Street, Suite 2M New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Hegeman Residence Hegeman Avenue & Amboy Street Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50274	10A0312	K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	14 East 75th Street New York NY	Approved	\$650.00
50275	10A0313	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	60 East 42nd Street New York NY	Approved	\$650.00
50276	10A0314	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Triennale 31 West 52nd Street New York NY	Approved	\$650.00
50277	10A0315	Vlashava Electrical Contracting Corp. 171 Bayard Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	151 East 80th Street New York NY	Approved	\$650.00
50278	10A0316	A & R Electrical Maintenance, Inc. 64-14 69th Place Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	Hobbs Court 315 East 102nd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50279	10A0317	Belmont Electrical Inc. 5-12 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	30 West 47th Street New York NY	Approved	\$650.00
50280	10A0318	Blasko Electrical Contractors, Inc. 36-38 35th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	233 Spring Street New York NY	Approved	\$650.00
50281	10A0319	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	140 Broadway New York NY	Ok, but	\$650.00
1) Service entrance conductors to be installed in raceways, 230.44. 2) Fire pump service entrance conductors undersized, not bonded or grounded. 3) Switchboard #2 bus sizing not indicated. 4) Are switchboards rear accessible?						
50282	10A0320	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	J.P. Morgan Chase 270 Park Avenue New York NY	Hold	\$650.00
1) Fire pump conductors line and branch undersized. 2) Equipment grounding conductor for 200 amp service switch undersized. 3) Neutrals in fire alarm disconnect switches bonded. 4) SB drawing set not complete drawing 5 missing.						
50283		Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requesting permission to leave as installed AC cable that does not contain an insulated equipment grounding conductor as wiring method inside of a place of assembly, as per the 2008 NEC, Article 518.4.	112 Rochelle Street Bronx NY	Approved	\$350.00

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50284		Cogen Electrical Services inc. 528 Craven Street Bronx NY 10474	Requesting permission to install high voltage wiring from Con Ed utility pole to Con Ed transformer on customer property. All high voltage terminations by Con Edison.	112 Rochelle Street Bronx NY	Denied	\$0.00
No jurisdiction from NYC. This is Con-Ed requirements						
50285		New York City Housing Authority 90 Church Street New York NY 10007	Requesting permission for 24 buildings under going elevator upgrades to install unspliced elevator feeders inside existing shaftways.	HYCHA Developments , Sedgwick, Chelsea, Drew Hamiltor Bronx NY	Approved	\$0.00
50286		Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requesting permission to leave as installed AC cable that does not contain an insulated equipment grounding conductor as a wiring method for a place of assembly.	3213 Third Avenue Bronx NY	Approved	\$350.00
50287		K & R Electric Co., Inc. 4347 Hylan Blvd. Staten Island Ny 10312	Requesting permission due to lack of space inside of the building to install the service equipment on the exterior of the commercial building.	386 Forest Avenue Staten Island NY	Approved	\$0.00
50288		RX Electric Inc. 121-13 14th Road College Point NY 11356	Requesting permission to install underground service conductors in non metallic conduit in a corrosive area with a high water table in Far Rockaway, Queens.	Breezy Point Far Rockaway NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

August 11, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50289		Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requesting permission to install outdoor overhead triplex service entrance conductors as a wiring method between the meter pan and service switch masts for an outdoor service located in a remote area on the south shore of Staten Island, NY.	Tottenville Racquet Club 36 Sprague Avenue Staten Island NY	Approved	\$0.00
50290		AECOM 20 Exchange Place New York NY 10005	Requesting permission to accept the submission made for Lincoln Medical Center (Calendar No. 50014CO2, Submission No. 10A0098CO2 by Sajiun Electric Inc.) with regard to non-coordination and close selectivity due to partial overlapping of breaker and fuse curves as shown on the coordination study provided with this submission.	Lincoln Medical Center 234 East 149th Street Bronx NY	Denied	\$0.00
50291	10A0321	Via Glass LLC 185 Varick Street, Suite 302 New York NY 10014	Requested approval for use in New York City of your Low Voltage Window Motor. Model/Series Numbers: Electric Chain Actuator G5-XT.		Denied	\$200.00
The approved testing report from a nationally recognized testing laboratory was not submitted, the report shall approve the entire product as a complete assembly.						