

# ADVISORY BOARD CALENDAR

August 18, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45395CO	03A0690CO	Cross-Hudson Electrical Inc. 155-06 Sanford Avenue Flushing NY 11356	Requested approval for the electric service equipment proposed to be installed	740 Broadway New York NY	Approved	\$0.00
Carry over from December 17, 2003 meeting.						
45575CO	04A0132CO	Unisys Electric Inc. 19 Irving Place Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	Brooklyn Navy Yard 63 Flushing Avenue-Bldg. 500 Brooklyn NY	Hold	\$0.00
Carry over from April 14, 2004 meeting. 1) Old Code: switchboard requires 3ft one side and 2ft other side. No side clearance. Possibly add door/egress in rear						
45645CO	04A0226CO	Solar Electric System Inc. 452 West 55th Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Duane Hall at Fordham Univ. 441 East Fordham Road Bronx NY	Approved	\$0.00
Carry over from May 19, 2004 meeting.						
45761CO	04A0284CO	UL Electrical Corp. 115-05 Liberty Avenue, 2nd Floor Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	225 Broadway New York NY	Hold	\$0.00
Carry over from July 21, 2004 meeting. 1) Confirm both sets of 300 KCM cable are being tapped for each disconnect switch. 2) Clarify short circuit rating of new circuit breaker panels. Indicate available short circuit current at new panels. 3) Provide detail of bus tap to existing switchboard.						
45762CO	04A0285CO	Forum Engineering, P.C. 139 Fulton Street New York NY 10038	Requested approval for the electric service equipment proposed to be installed	195 Bowery Street New York NY	Hold	\$0.00
Carry over from July 21, 2004 meeting. 1) Service conductors undersized. 2) Fire pump fed from 2 normal sources. 3) Clarify the single-line and floor plan for ss#2, #3, #4.						

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45763CO	04A0286CO	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Con Ed 4 Irving Place New York NY	Hold	\$0.00
Carry over from July 21, 2004 meeting. 1) Provide single line. 2) Provide plan layout.						
45764CO	04A0287CO	Roz-A-Lite Electrical Contracting, Inc. 163 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	220 West 26th Street New York NY	Approved	\$0.00
Carry over from July 21, 2004 meeting.						
45765CO	04A0288CO	Arc Electrical & Mechanical Contrs, Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Hunter College 71 East 94th Street New York NY	Hold	\$0.00
Carry over from July 21, 2004 meeting. New switch and circuit cabinet obstructs access around service switchboard A.						
45768CO	04A0291CO	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	ABG Hotel 125 West 45th Street New York NY	Ok, but	\$0.00
Carry over from July 21, 2004 meeting. 1) Reduce F.P. fuse to 600% FLA.						
45769CO	04A0292CO	ICOR Associates, LLC 21 Commerce Drive Cranford NJ 07016	Requested approval for the electric service equipment proposed to be installed	Parkmed Eastern Women's 800 2nd Avenue New York NY	Approved	\$0.00
Carry over from July 21, 2004 meeting.						

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45770CO	04A0294CO	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	UBS Building 1285 6th Avenue New York NY	Approved	\$0.00
Carry over from July 21, 2004 meeting. Linkss replacing fuses in 800A main switch to be on load size of switch.						
45771CO	04A0295CO	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Price Waterhouse Coopers 300 Madison Avenue, 9th Floor New York NY	Ok, but	\$0.00
Carry over from July 21, 2004 meeting. Clarify feeders sizes, number of cables, number of conduits on all feeders.						
45791CO	04A0283CO	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Atlantic/Court 211 Atlantic Avenue Brooklyn NY	Approved	\$0.00
Carry over from July 21, 2004 meeting.						
45795CO	04A0311CO	Dal Electrical Corp. 5910 11th Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Verizon Generator 355 Forest Avenue-1st Floor Staten Island NY	Approved	\$0.00
Carry over from July 21, 2004 meeting. 1) Show 2nd fuse equipment for all service switches. 2) Verify location of neutral disconnect link ground lug, ground strap. 3) Clarify routing of service conductors thru A/C duct and verify concrete encasement of entire run.						
45796CO	04A0310CO	Dooley Electric Company, Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Max Capital 230 Park Avenue, Suite 2527 New York NY	Approved	\$0.00
Carry over from July 21, 2004 meeting.						

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45817CO	04A0340CO	A.K. Electrical Contracting Inc. 261 46th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Holmes Towers 1780 First Avenue New York NY	Approved	\$0.00
Carry over from July 21, 2004 meeting.						
45818CO	04A0341CO	A.K. Electrical Contracting Inc. 261 46th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Holmes Towers 40 5 East 92nd Street New York NY	Approved	\$0.00
Carry over from July 21, 2004 meeting.						
45823CO	---	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting special permission to install new lighting conduits that will support new 277 volt fixtures that will be supported from existing emergency circuit conduits in hazardous and non hazardous locations.	Newtown Creek W.P.C.P. 301 and 403 Greenpoint Avenue Brooklyn NY	Approved	\$0.00
Carry over from July 21, 2004 meeting. Code 410. Page 105.						
45834CO	04A0293CO	Steelcase Inc. 7220 Edgewater Drive Oakland CA 94621	Requested approval for use in New York City of your Manufactured Wiring System. Model/Series Numbers: Metro Furniture "Topo".		Approved	\$0.00
Carry over from July 21, 2004 meeting. With stipulation that when pole is used as a sleeve and not as a raceway. Also, the revised installation instructions supplied to us on 7/12/04, are acceptable because they show the pole used a sleeve. However, the "wire fill capacity for power" table must be removed because the pole can only be used as a sleeve and not as a raceway.						
45836	04A0343	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Museum of Jewish Heritage Battery Park City New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45837	04A0344	Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Studio 54 254 West 54th Street New York NY	Approved	\$650.00
45838	04A0345	T & R Alarm and Electrical Systems, Inc. 1870 Webster Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	Medgar Evers College 1607-1625 Bedford Avenue Brooklyn NY	Ok, but	\$650.00
Change F.P. fuse to 400A.						
45839	04A0346	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Starret Lehigh Building 601 West 26th Street New York NY	Approved	\$650.00
45840	04A0347	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	100-17 23rd Avenue Queens NY	Hold	\$650.00
1) Type of connection in 600A disconnect switch that feeds the other 600A disconnect switch. 2) Sequence of operation(key interlocks). 3) Explain why the 2 sets of 4/0 are feeding 600 MCM. 4) Are generators running in parallel?						
45841	04A0348	Vilanova Electric Co. LLC 141 5th Avenue New York NY 10010	Requested approval for the electric service equipment proposed to be installed	109 Eastg 16th Street-Basement New York NY	Approved	#Error

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45842	04A0349	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	32 East 31st Street-8th Floor New York NY	Approved	\$650.00
45843	04A0350	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	455 Main Street, Bldg. #3 Roosevelt Island NY	Approved	\$650.00
With the stipulation if concrete encasement is required.						
45844	04A0351	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	CIBC 300 Madison Avenue New York NY	Approved	\$650.00
1) Remove neutral bond at generators. 2) Feeder to MTS #9 undersized. 3) Verify two entrances to paralleling gear room. 4) Life safety equipment and transfer switches outside of service room.						
45845	04A0352	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Weill Med. Coll. of Cornell U. 1300 York Avenue New York NY	Approved	\$650.00
1) Provide disconnect switch on load side of transformer A-SB-1 - 240.21. 2) Install bonding and grounding of new disconnect switch.						
45846	04A0353	ICOR Associates, LLC 21 Commerce Drive Cranford NJ 07016	Requested approval for the electric service equipment proposed to be installed	Manhattan Eye Ear & Throat 210 East 64th Street New York NY	Approved	\$650.00
Move disconnect switch to provide proper clearance on side of switchboard if possible.						

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45847	04A0354	Quantum Electric Corporation 30-30 Northern Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	John Jay College 500 West 56th Street New York NY	Approved	\$650.00
45848	04A0355	Control Spec Electrical System, Inc. 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	300 East 75th Street New York NY	Approved	\$650.00
Neutral must be bonded to enclosure at generator panel.						
45849	04A0356	Cerrito Electric of New York, Inc. 85-45 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	333 East 102nd Street New York NY	Hold	\$650.00
Service bus and feeder conductors are undersized.						
45850	04A0357	Schlesinger Electrical Contractors, Inc. 664 Bergen Street Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	1136 5th Avenue New York NY	Approved	\$650.00
45851	04A0358	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	ABG Hotel 125 West 45th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45852	04A0359	Dorion Norton Electrical Contracting Corp 218 Clifton Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	130 West 30th Street New York NY	Approved	\$650.00
45853	04A0360	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Bronx Public Library 296/310 East Kingsbridge Road Bronx NY	Ok, but	\$650.00
Verify the use of 3 pole and 4 pole transfer switches, no mixing.						
45854	04A0361	B & G Electrical Contractors of NY Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Stop & Shop Supermarket 2754 Hylan Blvd. Staten Island NY	Denied	\$650.00
1) Service entrance conductor are undersized. 2) Bond neutral at 400 amp HDP panel and PSP. 3) Remove neutral bond at generator and just ground chasis of generator. 4) Provide tap box on line side of 100A service switch PSP. 5) 15 30 amp FACP service rated and neutral is required. 6) Equipment in service room not properly identified.						
45855	04A0362	Citywide Electrical Corp. 142 22nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Yeshiva Darchei Torah H.S. 2-11 Beach 17th Street Far Rockaway NY	Ok, but	\$650.00
Feed to 1600 amp service switch is undersized.						
45856	04A0363	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Times Square Hotel 1021-1029 Avenue of the Americas New York NY	Void see new submittal Cal #46090	\$650.00
Verify the size of tap wire off of the 1600 amp service switch.						

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45857	04A0364	Emergency Electrical Contracting Inc. 9202 Avenue M Brooklyn NY 11236	Requested approval for the electric service equipment proposed to be installed	Access IT 882 3rd Avenue-9th Floor Brooklyn NY	Approved	\$650.00
45858	04A0365	Dudley and Assoc. Lic. Electl Contrs. 6 East Clarke Place Bronx NY	Requested approval for the electric service equipment proposed to be installed	2116 Adam Clayton Powell Blvd. New York NY	Approved	\$650.00
45859	04A0366	Team Electric, Inc. 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	912 Fifth Avenue. New York NY	Approved	\$650.00
45860	04A0367	Kings Electric Company, Inc. 2113 West 6th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	St. George Hotel 51 Clark Street Brooklyn NY	Approved	\$650.00
45861	04A0368	Kelleher Electricians 2142 Richmond Terrace Staten Island NY 10302	Requested approval for the electric service equipment proposed to be installed	Toyota of Manhattan 645/659 11th Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45862	04A0369	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	200 5th Avenue New York NY	Approved	\$650.00
45863	04A0370	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	85 10th Avenue New York NY	Approved	\$650.00
45864	04A0371	Rigid Electric Inc. 336 37th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	New York University 251 Mercer Street New York NY	Approved	\$650.00
45865	04A0372	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	47-47 Austell Place Long Island City NY	Approved	\$650.00
45866	04A0373	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	435 Hudson Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45867	04A0374	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	39 West 19th Street New York NY	Approved	\$650.00
45868	04A0375	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	140 East 45th Street New York NY	Approved	\$650.00
45869	04A0376	NJD Wiring & Electric, Inc. 55 Huron Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	225 West 86th Street New York NY	Approved	\$650.00
45870	04A0377	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	110-60 Dunkirk Street Jamaica NY	Approved	\$650.00
45871	04A0378	MF Electrical Service Co., Inc. 3323 Merritt Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	Hutchinson Corp. Center 1200 Waters Place Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45872	04A0379	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Pathmark-Bradhurst Court 300 West 145th Street New York NY	Approved	\$650.00
1) Provide Con Ed short circuit current and impedance. 2) Provide calendar number for original service installation.						
45873	04A0380	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Memorial Sloan Kettering ork & 1st Avenue, 68th & 69th Stree New York NY	Ok, but	\$650.00
Confirm scope of work is adding 300 KVA XFMR and 1200A switch.						
45874	04A0381	Dean Electric Co., Inc. 7909 Third Avenue Brooklyn NY 11209	Requested approval for the electric service equipment proposed to be installed	Maimonides Medical Center 1025 48th Street Brooklyn NY	Approved	\$650.00
45875	04A0382	Emergency Electrical Contracting Inc. 9202 Avenue M Brooklyn NY 11236	Requested approval for the electric service equipment proposed to be installed	Franklyn Plaza Apts 2081 2nd Avenue New York NY	Hold	\$650.00
Verify service entrance its undersized.						
45876	04A0383	Genmar Electric Co. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	Bay Plz.-Linen & Things 2100 Bartow Avenue Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45877	04A0384	Watchtower Bible and Tract Society of NY 25 Columbia Heights Brooklyn NY 11201	Requested approval for the electric service equipment proposed to be installed	55 Prospect Street Brooklyn NY	Ok, but	\$650.00
Verify conductor size and on load side of T2 disconnect switch.						
45878	04A0385	Qncc Electrical Contracting Corp. 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	300 East 54th Street New York NY	Approved	\$650.00
45879	04A0386	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	166 East 61st Street New York NY	Approved	#Error
45880	-----	Ostroff Electric Inc. 102-14 159th Road Howard Beach NY 11414	Requested permission not to file Advisory Board drawings for the installation of a 200 amp second fusing circuit breaker fed from a 1200 amp service switch with 650 amp fuses on an 1000 KVA service the switch will be installed on the 10th floor.	135 West 70th Street New York NY	Denied	\$0.00
Full Advisory Board drawings must be submitted. Sketch shows a 1200 amp switch fused at 650 amp and your letter says the switch is 800 amps fused at 650 amps. A 200 amp second fuse circuit breaker was installed on the 10th floor. Manufacturer cuts sheets of the circuit breaker were not submitted.						
45881	-----	MetroYork Electrical, Inc. 23-86 BQE Long Island City NY 11103	Requesting permission not to file Advisory Board drawings where the second fusing will be changed from 200 amps to 400 amps a 1000 KVA service.	2720 Broadway New York NY	Denied	\$0.00
1) Full Advisory Board drawings must be submitted. 2) Service switch is rated over 600 amps. 3) Neutrals must be shown. 4) Tap off 800 amp service switch should be detailed.						

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45882	-----	Hanington Engineering Consultants 1 Gold Mine Road Flanders NJ 07836	Requesting permission not to file Advisory Board drawings for the installation of a 400 amp second fusing disconnect switch on an 1000 KVA service.	820 Fifth Avenue, Apt. #7 New York NY	Approved	\$0.00
Pending further review.						
45883	-----	Atria 2000 Associates, LLC 158-13 72nd Avenue Flushing NY 11365	Requesting permission on previously denied special permissions to pull direct burial cable (U.S.E.) inside existing aluminum conduits that are installed underground without supplementary corrosion protection and penetrate through a concrete slab into the bottom of service equipment.	159-10 71st Avenue Flushing NY	Approved	\$0.00
With the stipulation that the installation conforms with Article 338 of the National Electric Code and the New York City amendments.						
45884	-----	Emergency Electrical Contracting Inc. 9202 Avenue M Brooklyn NY 11236	Requesting permission to leave as installed service entrance conductors that run approximately 20' into a building encased behind two 5/8" layers of sheetrock instead of concrete encasement.	239 Bay 23rd Street, 1 & 2 Floors Brooklyn NY	Denied	\$0.00
Article 230.6 of the National Electrical Code requires the service entrance conduit to be encased by not less than 2 inches of concrete or brick.						
45885	-----	Atkinson Koven Feinberg Engineers, LLP 1501 Broadway, Suite 700 New York NY 10036	Requesting concept approval due to lack of space inside of a existing service room to install new service equipment in an adjoining room and run approximately 15 to 35 feet of service entrance conductors in rigid conduit without concrete encasement in these fire rated rooms. Signage will be provided at the entrance of these service rooms indicating where the other service is located.	685 Third Avenue New York NY	Approved	\$0.00
For concept approval only.						

# ADVISORY BOARD CALENDAR

**August 18, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45886	----- ---	M-E/Vogel Taylor Engineers, P.C. 417 Fifth Avenue, Suite 501 New York NY 10016	Requesting permission to leave as installed surface non metallic raceway mounted on the ceiling in non residential building.	40 Washington Square South New York NY	Denied	\$350.00
Section 352-22(b)9 of the 1999 New York City amendments to the 1999 National Electrical Code prohibits the installation of surface non metallic raceways in commercial buildings.						
45887	-----	Kiss + Zwigard Architects 120 Duane Street, Suite 402 New York NY 10007	Requesting permission to install Wiremold 4000 series raceway under the finished floor with the receptacles in a face up position with a MOP proof cover.	Samsung Time Warner Center - 3rd Floor New York NY	Denied	\$0.00
The wiremold 4000 series raceway is not suitable for the purpose intended.						
45888	04A0387	Boston Metal Products 400 Riverside Avenue Medford MA 02155	Requested approval for use in New York City of your FastLane Modular Wiring System.		Denied	\$200.00
Article 604 of the New York City Electrical Code only permits manufactured wiring systems to be used for general lighting circuits above the hung ceiling line.						
45889	-----	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested for concept approval.	Newton Creek-35E  Bronx NY	Approved	\$0.00