

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner  
MEA 9-05-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name – Fike.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Tests - UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report – UL File S911, Projects 02NK30168 & 04CA26647, Vol. 114 Section 1, issued 10/30/04.

Description – Fire alarm equipment as listed below:

Model No.	Fike Model No.	Description
EB	63-1055	Smoke Detector Base
EBF	63-1054	Smoke Detector Base
EBFI	63-1060	Smoke Detector Base
EBI	63-1061	Smoke Detector Base

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated January 14, 2005, F.P. Index #0412072.

**Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements and functions, applications and installations shall comply with all applicable provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard RS 17-3. The above referenced products shall be used only with compatible, listed and approved smoke detector heads. The installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard (File S911 Vol. 114).**

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance February 28, 2005.  
Examined by 