

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53841	13A0589CO	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	104 Haven Avenue New York NY	Approved	\$0.00
<p>Carry over from December 11, 2013 meeting. Identify fire pump service switch as installed in fire pump room and provide signage indicating where the other services are located 220.2(E) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/24/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/24/16 Job finalized.with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/24/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53234	15A0263CO	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	IS R 002 333 Midland Avenue Staten Island NY	Approved	\$0.00
<p>Carry over from May 20, 2015 meeting. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53270	15A0344CO2	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	101 Barclay Street New York NY	Approved	\$0.00
<p>Carry over from August 12, 2015 meeting. 1) Verify that 480 volt equipment complies with 408.60(F). 2) Update coordination study to include 480 volt system. 3) Include trip settings on 1 Line drawing for 480 volt system. 10/6/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
53235	15A0435	Rainbow Electric 76-18 Rockaway Boulevard Woodhaven NY 11421	Requested approval for the electric service equipment proposed to be installed	Flushing Town Center 40-24 College Point Boulevard Flushing NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/17/16 Swapped drawing A,B,C,D and Revision 1. 9/1/16 Swapped drawings L & E-Revision 2</p>						
53217	15A0452	A & M Electrical Service Inc. 617 Johnson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	City Point Phase 2 445 Gold Street Brooklyn NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0476	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	3 Chase Metrotech Center Brooklyn NY	Denied	\$650.00
<p>1) Identify switchboards on both drawings, if it is a one for one replacement state so, what is new and what is existing. 2) Show switch sizes on room layout drawing. 3) Main bus undersized take off bus sizes not shown, reduce main feeders to 2500 amps. 4) What are the rectangles with X's in their in front of the equipment. 5) Doors in electrical rooms to open outwards to legal exists from all rooms. 6) Bubble new work in service room.</p>						
53440	15A0498	Delta Phase Electric Corporation 137 29th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Sheppard Residence 62 Cooper Square New York NY	Approved	\$650.00
<p>OR Verify service entrance conductors to service switch #4. 1/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53241	15A0499	Striano Electric Co., Inc. 246 Park Avenue Garden City Park NY 11040	Requested approval for the electric service equipment proposed to be installed	NYU 60 5th Avenue New York NY	Approved	\$650.00
<p>This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53236	15A0502	GRX Electric Corp. 8 West 38th Street, Suite 804 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	151 West 30th Street New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53269	15A0505	Right Away Electric, LLC 56-15 Andrews Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	95 Evergreen Avenue Brooklyn NY	Approved	\$650.00
<p>1) Incoming fault current not shown on drawing. 2) Show fault current at fire pump controller with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/6/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
53310	15A0517CO	Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Penn South Houses 315 West 25th Street New York NY	Approved	\$0.00
<p>Carry over from August 12, 2015 meeting. Provide GFCI on Asco ATS. 10/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	15A0519	Allan Briteway Electrical Contractors, Inc. 360 Lexington Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Weill Cornell Medical College 413 East 69th Street New York NY	Denied	\$650.00
<p>1) Show bus sizes of "SWG-MB-18-1" and provide cut sheet. 2) SWG-MB-B1-1 does not match 1 Line. 3) Coordination study not provided. 4) Remove bond from 200 amp fire alarm switch emergency side. 5) Verify that switchgear complies with 408.60(F). 6) Bubble all new work on room layout and 1 Line drawing. 7) Are ATS' 3 or 4 pole, feeder sizes of load side of ATS not shown. 8) Review stopped with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53266	15A0542	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	NBA 545 5th Avenue New York NY	Approved	\$650.00
Provide room layout drawing. 10/6/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53218	15A0550	ECNY Electric 42 West 38th Street, Suite #501 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	R445 Port Richmond H.S. 45 Innis Street Staten Island NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 ER Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 OK, with the stipulation that: JAP6 72/295-315/3BB modules, Advanced Energy AE 3TL 1000 series 3 phase transformerless string inverters, conext CL-NA 3 phase grid tie inverters, 1000 volt equipment can be installed.						
53219	15A0551	ECNY Electric 42 West 38th Street, Suite #501 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	X425-NYC Public Schools 800 Gun Hill Road Bronx NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/3/15 Swapped drawing 1, Revision 2. 3/25/16 ER Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 OK, with the stipulation that: JAP6 72/295-315/3BB modules, Advanced Energy AE 3TL 1000 series 3 phase transformerless string inverters, conext CL-NA 3 phase grid tie inverters, 1000 volt equipment can be installed.						
53220	15A0552	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYPH-Lower Manhattan Hospital 170 William Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
	15A0555	Phillips Lighting NA. 3 Burlington Woods Drive Burlington MA 01803	Requesting approval for use in New York City of your Office Furnishings. PowerUp, Series 46-1487.		Denied	\$200.00
Your request for NYC acceptance of the "system" should not include any equipment not part of the "listed assembly". We found mention of a "Hoisting System". Previous conversations indicated this was not part of the listed lighting assembly. Advisory Board approval for this particular product is limited to Section 411.3(A) of the 2011 NYC Electrical Code.						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53552	15A0557	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	320 Park Avenue New York NY	Approved	\$650.00
1) Physical of bus duct tap boxes not provided, is it by Lincoln or bus duct manufacturer. 2) Provide coordination study. 3) ATS to be rated at 2000 amps. 2/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53469	15A0558	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	55 Hudson Yards New York NY	Approved	\$650.00
aka 550 West 34th Street. 1) Verify if fire pump feeders are included in the submittal, if yes darken dotted line on 1 Line. 2) Transformer secondary conductors undersized to 450 amp fuses. 1/19/16 1) If fire pumps are not included on this installation remove them from drawing. 2) Size of transformer secondary conductors not shown. 1/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53242	15A0560	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Temp 217 West 57th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53444	15A0561	M.C. Electrical NY Inc. 843 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Queen of Peace 110-30 221 Street Queens NY	Approved	\$650.00
<p>1) Provide separation between newly sectioned board. 2) F.A. transfer switch to be indicated. 3) Change designation on gen p.s. stand-by with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/21/16 Job finalized. This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/21/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53233	15A0566	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Capital One 299 Park Avenue, 27-32 Floors New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53308	15A0567	L.E.A. Electric Corp. 1001 Sixth Avenue, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Barnard College 600 West 116th Street New York NY	Approved	\$650.00
Provide series rating on both new panels and cat cut c.b. indicating rating. 10/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53309	15A0568	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	4275 Park Avenue Bronx NY	Approved	\$650.00
Indicate manufacturer for laundry panel. 10/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53243	15A0569	Bayside Electrical Contractors Corp. 40-18 31st Avenue Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	70 West 139th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53232	15A0570	MSM Electric, Inc. 417 Brighton Beach Avenue Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	315 Hudson Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53597	15A0571	Nead Electric, Inc. 530 West 50th Street New York NY 10110	Requested approval for the electric service equipment proposed to be installed	HSBC 330 Madison Avenue New York NY	Approved	\$650.00
Show fuse types in existing bus ducts switches and show main fuse type for ducts. 12/1/15 Revision not showing revised number and need to show rev number next to changed part. 3/15/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/22/16 Swapped drawing #A081501-Revision 2.						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0574	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	550 Vanderbilt Avenue Brooklyn NY	Denied	\$650.00
<p>1) Reduced neutral calculations not provided. 2) Verify that all 3 level ATS are 3-pole types. 3) Service entrance conductors on 1 Line show PVC conduits, room layout shows overhead pull box, confirm how SEC will be run. 4) Verify that fire pump load conductors are not passing through the overhead pull box to the service switch with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/31/15 Swap #1 item one was not attached with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/17/16 Item #1 not addressed, full reduced neutral calculations required.</p>						
53244	15A0575	Southwire Company, LLC One Southwire Drive Carrollton, GA GA 30119	Requested approval for use in New York City of your Copper Power & Control Conductors. Model/Series Numbers: Armolite Type MC-PCS		Approved	\$200.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0576	Arcadia Electrical Company, Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requesting permission to leave as installed a circuit breaker panel installed recessed between a bus duct and building column where the width of the working space is 22"	Hilton Grand Inn 136 West 42nd Street New York NY	Denied	\$350.00

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0577	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	435 West 31st Street New York NY	Denied	\$650.00
<p>1) Fire pump feeder not fire rated. 2) Show feeders inside of the substation switchboards. 3) Verify 400 amp fuse in 800 amp ss#1, #10 tap may be undersized. 4) 4000 amp ss#2 overfused MSB board. 5) 300 amp ss #3 overfused MSA board. 6) Tap conductor undersized in WT#2. 7) Verify that rear doors for switchboards are supplied. 8) Coordination study says 375 9 Avenue verify address. 9) Provide GFCI on 480V s.s. 1/26/ Items 3,5,6 and 8 not addressed. 6/30/16. 1) item #5 not addressed. 2) Item #6 not addressed. 3) Coordinate study not prepared by a P.E. with stamp and signature. 4) Fire pump transition conductors not shown. 5) Drawing D. All changes are not shown and type of equipment. 6) Bus' from 1500 KVA transformers to 4000 and 3000 amp switches undersized, feeder from 1500 KVA transformer to 3000 and 800 amp disconnect switch undersized. 7) SS # 3 and 4 overfused. 8) Is generator new or existing? 9) 2 fire alarm switches installed on line side of ATS'</p>						
53227	15A0578	Team Electric, Inc. 20 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Vice Media 9 South 2nd Street/289 Kent Avenue Brooklyn NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
53223	15A0579	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	1035 Third Avenue New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/17/16 Swapped drawing A-Revision 1.</p>						
	15A0580	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Coney Island Hospital 2601 Ocean Parkway Brooklyn NY	On Hold	\$650.00
<p>1) All equipment on the drawing says existing what is new. 2) What floor is the emergency room located on? 3) If existing equipment was water damaged, it must be replaced not relocated. 4) Explain existing gen switchboard "Being moved to Roof". 5) Roll up generator to comply with 700.6(G).</p>						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0581	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	10 South Street New York NY	Denied	\$650.00
<p>1) Provide documentation from transformer manufacturers stating that transformers can be installed in a stacked position , and show elevation drawing and transformers. 2) Equipment grounding conductors to be installed for feeders in PVC conduits. 3) Show sizes of equipment grounding conductors in MC cables. 4) Bus on line side of SS#3 undersized. 5) Indicator #5 and 1 don't match 1 Lines of both drawings. 6) 500 KVA transformer feeding 2-400 amp disconnect switches, tap of a tap not permitted, each switch to be separately tapped. 7) Secondary of 225 KVA transformer over fused. 8) generator frame to be grounded to building steel. 9) #6 aluminum conductor fused at 60 amps. 10) #1 aluminum conductor fuse at 150 amps. 11) ILine drawing does not match room layout. 12) If equipment on ILine is not in service room , note it on 1 Line drawing with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/3/15 1. Items 1 and 2 not addressed. Review stopped new submittal required, entire drawing to be re-reviewed.</p>						
53793	15A0582	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	415 Red Hook Lane Brooklyn NY	Approved	\$650.00
<p>Indicate location of emergency F.A. switch. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/2/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53794	15A0583	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	210 East 39th Street New York NY	Approved	\$650.00
<p>1) Verify 3' clearance in front of distribution section #3. 2) 200 amp feeder off of generator overfused. 3) Emergency panel #3 conductor overfused. 5/2/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53451	15A0584	AMRA Electrical Corp. 47 Buffalo Avenue Brooklyn NY 11233	Requested approval for the electric service equipment proposed to be installed	16-26 Madison Street Queens NY	Approved	\$650.00
Provide type of c.b. for APC-TEC panel and series rating documentation. 1/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53231	15A0590	Wise Electrical Service 307 West 38th Street, Suite 1501 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	The New School 2 West 13th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/11/16 Swapped drawing 1, Revision 1. 4/21/16 Swapped Drawing 1-Revision 2. 1/3/17 Swapped drawing 1-Revision 3. No more swaps.						
53311	15A0592	Nead Electric Inc. 530 West 50th Street New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Sushi Ginza 461 5th Avenue New York NY	Approved	\$650.00
Show fault current at circuit breaker panel. 10/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53221	15A0593	Quantum Electric Corporation 36-24 34th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Roundabout Theater-Studio 54 254 West 54th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53226	15A0594	Reliable Electric 133 Storer Avenue Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Tesla 160 Van Brunt Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53225	15A0595	Stanco Systems Electrical Contracting 4061 Victory Boulevard Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Biobat 140A 58th Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53312	15A0596	Sidney Electrical Contracting Inc. 1950 Coney Island Avenue Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	East Haven Nursing Home 2323 Eastchester Road Bronx NY	Approved	\$650.00
1) Why is switchboard being replaced. 2) Was generator in service room under approval 48916.? 3) Copy of 48916 wasn't in this submittal. 4) Doors to service room to open outwards. 11/2/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53224	15A0598	Stanco Systems Electrical Contracting 4061 Victory Boulevard Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Pre-K Center M453 2 Lafayette Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53546	15A0600	A & R Electrical Maintenance, Inc. 85-45 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Melrose Commons Site C 499 Elton Street Bronx NY	Approved	\$650.00
P.V. Connection must be filed if it is interactive and located within 2nd fusing. 2/19/16 Job finalized.. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53306	15A0601	A & M Electrical Service Inc. 617 Johnson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	388 Bridge Street Brooklyn NY	Approved	\$650.00
OR 1) Tapped conductors undersized. 2) Verify grounding of fire pump, fire alarm and cable supply service switches. 10/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53222	15A0602	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Hearst Communication 300 West 57th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53450	15A0603	Patriot Electric Corp. 96-06 220th Street Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	711 11th Avenue New York NY	Approved	\$650.00
1) Fire pump feeders undersized for 60 HP fire pump. 2) Verify low in rush current for transformers being fed from 2000 amp switches. 3) Neutrals bonded after main disconnect link. 4) Verify location of neutral disconnect link. 11/4/15 Rejected. Fire pump neutral conductor to be tapped after neutral link. 1/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/17/16 Swapped drawing 1 and 2-Revision 4. 8/23/16 Fire pump system wiring removed from drawing. 10/6/16 Swapped drawings 1and 2-Revision 6.						
53259	15A0604	HIG Electrical Associates NYC, Inc. 25-26 50th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	99 Wall Street New York NY	Approved	\$650.00
1) 1/0 fused at 200 amps emergency panel pp-pan 100 A MLO. 2) Verify wire bending radius from 4000A MLO section to service switch #1. 9/30/15 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53228	15A0606	Laredo Electric, Inc. 2477 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	116 West 32nd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53229	15A0607	Response Electric Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	60 Beach Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53230	15A0608	Belmont Electrical Inc. 5-12 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	#1 Gracie Terrace New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0609	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	NYU MSB Infrastructure Project 435 East 30th Street New York NY	Administrative Closure	\$0.00
SANDY Job doesn't comply with 110.34(A) and Building Code CH27 (Emergency and normal services in same room) review stopped. 3/9/16 This submittal void as per submittal number 15A0651.						
	15A0610	Bala Consulting Engineers 1 William Street New York NY 10004	Requested approval for the electric service equipment proposed to be installed	9 Metrotech Center Brooklyn NY	Denied	\$650.00
1) Drawings to have Bala engineering in the Title blocks. 2) If the job was approved in February 52992, why is it being resubmitted due to grounding and bonding changes instead of submitting "As built" drawings? 3) Indicate what work is new and what is existing , Bala phone number is not on letterhead. 4) Feeder to panel DP-TE overfused and EGC undersized. 5) Can't mix separately and non separately derived systems on load side of Gensets for 4 wire systems						

ADVISORY BOARD CALENDAR

September 9, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0611	Fred Geller Electrical, Inc. 37-32 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	390 Madison Avenue New York NY	Rejected	\$650.00
<p>1) Show clearances from corners of cement column to corners of switchgear. 2) Verify that service bus complies with 368.119 A through I. 3) Remove SEC taps on switchboard C. 4) Verify EGC with MI cable. 5) Provide Gen set cut sheet. 6) Provide bus sizes, elevation and sections for gen board with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/9/15 Rejected No good for 10/21/15 carryover. 1) Equipment show be installed so that there is 3' clearance provided when walking around the switchboard sides. 2) Provide cut sheets showing amperage ratings of Pentair Pyrotenax system-not clear on drawings. 3) Item 6 not addressed.</p>						
53238	15A0618	Jones Group 126 Park Avenue Bronxville NY 10708	Requested approval for the electric service equipment proposed to be installed	1400 Broadway New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						