

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52541	13A0699CO	Top Shelf Electric Corporation 4386 Victoria Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	500 Sterling Place Brooklyn NY	Approved	\$0.00
Carryover from December 11, 2013 meeting. 1) Feeders on load side of service switch #1 are overfused. 2) Sizes of equipment grounding conductors not shown. 9/26/14 Job finalized.						
52497	14A0275	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	350 Madison Avenue New York NY	Approved	\$650.00
52656	14A0284	Facility Solutions Group 96 Station Plaza Lynbrook NY 11563	Requested approval for the electric service equipment proposed to be installed	434 Broadway New York NY	Approved	\$650.00
1) Can fire pump service switch be relocated to opposite wall for better egress. 2) Show feeder size from load side of service switch #3 to trough. 3) Show type of fire pump normal conductors being used. 4) Fire pump emergency feeder to be fire rated, F.P. EGC undersized on normal side. 5) S.S #2 not identified on room layout drawing, verify conduit from section 1 to section 2 in Switchboard-2. 6) Emergency side tapped conductors show conductors sizes to 400 amp disconnect switch, EGC's to 200 amp disconnect switches undersized. 7) SS#3, 1200A feeder to distribution board does not match (cables and lugs). 8) SS #2 and 3 are mislabeled on 1 Line. 12/2/14 Job finalized.						
52498	14A0403CO	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	450 West 33rd Street New York NY	Approved	\$0.00
Carry over from August 13, 2014 meeting. 5/29/15 Swapped Drawing A, Revision 5 and C, Revision 6. 7/20/15 Swapped drawings A and C, Revision 6s.						
	14A0407	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Coney Island Hospital 2601 Ocean Parkway Brooklyn NY	On Hold	\$650.00
1) Provide sequence of operation for interlocking scheme. 2) Is 5000 amp switch 3 or 4 pole? 3) Is roll up generator a separately derived system?						

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52658	14A0412	C.M. Richey Electrical Contractors, Inc. 347 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	105 5th Avenue New York NY	Approved	\$650.00
1) Verify that service room is 2 hour fire rated, and verify wall in front of end box. 2) New 1600 amp "MDP" switch bonded and grounded on load side of 2000 amp service switch. 3) Incoming fault current not shown. 12/4/14 Job finalized. 8/20/15 Swapped drawing revision 2.						
	14A0413	EDM Electric, Inc. 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Cambria Suites 30 West 46th Street New York NY	Pending	\$650.00
1) Show fuse size on normal side of FACP. 2) Provide manufacturer's installations for the particular model generator being installed. 3) Equipment grounding conductors undersized for tap conductors fed from trough.						
	14A0418	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Hyatt House Hotel 101 West 28th Street New York NY	On Hold	\$650.00
1) Incoming fault current not shown. 2) Provide manufacturer's installation instructions for the particular gen-set being installed. 3) Rigid conduit to be installed for fire pump not EMT unless fire rated conductors are being installed. 4) Provide short circuit calculation for ss #1 and H.D.B. switchboard. 5) Jockey pump can't be tapped from F.P> controller. 6) Equipment cuts bus sizes don't match single line, F.P.						
52630	14A0419	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	626 Flatbush Avenue Brooklyn NY	Approved	\$650.00
1) Provide manufacturer's installation instructions for the particular gen set being installed. 2) Who will be installing Co-Gen unit? 3) Verify compliance with 110.26(A)(3) and 110.26(E) for the fire pump service switch, verify size of fire pump service switch. 3) Show incoming fault current. 11/26/14 With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.						

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52499	14A0437	FSM Electrical Corp. 38-06 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	501 East 74th Street New York NY	Approved	\$650.00
52500	14A0444	R.J. Russo Electric Co. 45-57 Bell Blvd. Bayside NY 11361	Requesting permission to utilize Article 690 of the 2014 National Electrical Code to allow the installation of listed 1000 volt solar photovoltaic system to be installed at twelve locations.	Job addresses in comment section	Approved	\$0.00
8802 Ridge Blvd., 9229 Shore Rd., and 321 61st Street-Brooklyn; 500 Trinity Ave., 440-442 and 455 Jackson Ave. and 535 Wales Ave.-Bx;; 23-08 Newtown Ave., 47-46 40th St., 90-31 Whitney Ave, 21-06 33rd St. and 31-15 21st Street-Queens						
	14A0451	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Magnum Apartment Conversion 140 West Street New York NY	On Hold	\$650.00
1) Remove fused disconnect switch on good side of ATS for fire alarm switch. 2) Service switchboard 2A-3 not shown for fire pump normal feeder. 3) Reduce fuse size in Switchboard 2A-1 to 2500 amps on install main OCPD for 5-11M. 4) Gen-set to be listed as a complete assembly, not be available to be listed. 5) Remove 480V disconnect after F.A. ATS, coordinate fuse sizes at secondary switch and downstream devices. 6) Remove F.A. distribution out main electric service room.						
52686	14A0458CO	Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	93 Gansevoort Street New York NY	Approved	\$0.00
Cary over from August 13, 2014 meeting. Provide short circuit study from a P.E. bearing the stamp. 12/22/14 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52692	14A0460	EDM Electric, Inc. 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1414 6th Avenue New York NY	Approved	\$650.00
<p>Provide the gen-set manufacturer's installation instructions for the particular model gen-set being installed. 12/23/14 Job finalized With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52903	14A0467	Delta Star Electric Inc. 11-25 Broadway Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	951 Brook Avenue Bronx NY	Approved	\$650.00
<p>1) Provide manufacturer's installation instructions for the particular model gen-set being installed. 2) Is emergency switchboard new or existing, are ATS' 3 or 4 pole types? 12/4/14 Rejected. 1) Generator neutral to be bonded and grounded as per 250.20(D). 2) New emergency switchboard to be shown on Drawing 27-3018-L and 700.27. 3/20/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	14A0471	Kleinknecht Electric Company, Inc. 252 West 37th Street, Suite #1402 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Moore Capital 11 Times Square New York NY	On Hold	\$650.00
<p>1) Provide gen set manufacturer's installation instructions for the particular model that will be installed, is axis a UL listed shop. 2) Verify whether generator will be separately derived or not. 3) Show feeder size to load bank.</p>						
52501	14A0472	CHT Electric Corp. 535 5th Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	148 West 125th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52627	14A0473	Corporate Electric Group, Inc. 17 State Street, Suite 4000 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	Green Asphalt Service 37-98 Rail Road Avenue Long Island City NY	Approved	\$650.00
1) EGC for feeders undersized. 2) Neutral in generators to be picked up in the grounding system. 3) Provide coordination study by a P.E. bearing the stamp. 11/24/14 Job finalized. 6/22/15 Swapped drawing 1, Revision 2.						
52887	14A0475	Noble Electric Contracting Co. Inc. 1794 Clinton Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	Tallman Islands 27-01 Powells Cove Boulevard College Point NY	Approved	\$650.00
1) Coordination study to be performed by a PE and bearing the stamp. 2) ATS MTS "S3" and transformer not protected. 3) Indicate bonding locations. 4) Indicate location of MCC in the building. 5) Comply w/section 240.21(c) (4) (4). 6) Provide proper disconnect means to MTS,. 3/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53182	14A0477	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Columbia University 701 West 168th Street New York NY	Approved	\$650.00
1) New service switches to have ground fault protection. 2) Show room layout. 6/2/15 1) Job changed. 2) Verify job address, 168 Fort Washington St. Does not exist as written in the title block, contractors letter says 701 West 168 Street. As per property profile building goes under 190-200 Fort Washington Avenue (aka) 632-650 West 168 Street, please clarify. 3) Existing distribution board #1 neutral bonded on load side of service switch. 4) Vertical bus in existing switchboard #1 undersized. 5) Interest says address showed be 650 West 168 Street for Columbia University Medical Center. 8/17/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52502	14A0478	Control Spec Electrical Ssystems, Inc. 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Paramount Towers 240 East 39th Street New York NY	Approved	\$650.00
OR						
52503	14A0479	Control Spec Electrical Systems, Inc. 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Liberty Plaza 10 Liberty Street New York NY	Approved	\$650.00
OR 3/15/16 Swapped drawing A, Revision 1.						

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0480	Qncc Electric 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	315 East 68th Street New York NY	Rejected	\$650.00
1) Service bus and service entrance conductors undersized. 2) New 1200 amp BPS not shown on room layout drawing, How long is the tap? Switch is bonded and grounded after service switch. (Verify conductors, board size, and protection). 3) Verify amount of feeders to existing 600 amp disconnect switch and new west commercial distribution panel. 12/2/14 Rejected 1) Item #1 partially addressed. 2) Length of tap to 600 amp disconnect switch not shown and disconnect switch is bonded and grounded after service switch.						
52864	14A0481	Litespeed Electric 135 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	120 Johnston Street Brooklyn NY	Approved	\$650.00
1) Length of tap not shown, tap conductors may be undersized. 2) Equipment grounding conductors undersized. 3) Neutral in new 800 amp disconnect switch is bonded. 4) Provide physical of new switch. 12/2/14 Rejected 1) Tap conductors undersized. 3/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52739	14A0482	Qncc Electric 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	4-74 48th Avenue Long Island City NY	Approved	\$650.00
1) Verify physical of 1200 amp disconnect switch room layout notes don't match cut sheet Cat #. 2) Equipment grounding conductor undersized. 3) Show length of tap. 4) Provide coordination curves to verify coordination. 11/18/14 1) Physical of 1200 amp Boltswitch Cat. #VL368N does not match Cat #VL468N on room layout drawing. 2) Coordination curves to verify coordinator not addressed. 3) Items 1 & 4 not addressed. 1/12/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52655	14A0483	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	College of Mt. St. Vincent 6301 Riverdale Avenue Riverdale NY	Approved	\$650.00
1) Provide signage on rear of switchboard stating "Do not remove rear covers". 2) Short cut curves not provided. 12/2/14 Job finalized.						
52901	14A0484	Primiano Electric Co. 600 Third Avenue, 2nd Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	New York Aquarium 514 Surf Avenue Brooklyn NY	Approved	\$650.00
1) Coordination study to be performed by a P.E> and bearing the stamp/not complete. 2) Show fuse types on 1 Line drawing. 3) Sprinkler pump overfused, verify type of pump being installed. 4) Coordination study recommends 450E fuses. 3/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52504	14A0488	New Phase Electrical Contractors, Inc. 725 East 136th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	211 Central Park West New York NY	Approved	\$650.00
OR						
52505	14A0489	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	145 Fourth Avenue New York NY	Approved	\$650.00
OR 6/25/15 Swapped Drawing1, Revision 1.						
53211	14A0490	Robert S. Covello 51-20 35th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	254 Park Avenue South New York NY	Approved	\$650.00
1) Tap of a tap is not permitted on load side of 1600 amp service switch. 2) Provide information for spare meter and disconnect switch or remove it from drawing, tap of a tap. 8/27/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52628	14A0491	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Fulton Market Building 11 Fulton Street New York NY	Approved	\$650.00
<p>1) Provide manufacturer's installation instructions for the particular gen-set model being installed. 2) Service bus to 2000 amp and fire pump service switches undersized. 3) Switchboard not bonded and grounded. 4) Fire pump controller not bonded and grounded. Feeders to be fire rated(230-6). 5) Manufacturer's equipment information to be on the 1 Line drawings. 6) Provide disconnect link for 1600A s.s. 7) Provide short circuit curves (coordination study). 11/26/14 With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0492	RGF Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	1 John Street New York NY	On Hold	\$650.00
1) Verify 36" front clearance in front of panel "LP-M". 2) Where is the Con-ED end box located? Is it remote from the service room? 3) EGC for fire pump undersized, FP not metered. 4) Show size of service bus feeding service switches 2,3, 4 and 5.. 5) Section bus feeding service switches 2, 3, and 4 undersized. 6) Coordination study returned.						
52506	14A0493	alvatore Campisi & Sons Electl Contr., Inc 453 Onderdonk Avenue Ridewood NY 11385	Requested approval for the electric service equipment proposed to be installed	19 West 24th Street New York NY	Approved	\$650.00
9/28/16 Swapped drawing 1 and 2-Revision 3						
	14A0494	Wise Electrical Service 307 West 38th Street, Suite 1501 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Tribeca Towers 105 Duane Street New York NY	On Hold	\$650.00
1) Provide the gen-set manufacturer's installation instructions for the particular gen-set model being installed. 2) Emergency wiring and equipment not to be installed in the service room. 3) New 400 amp new tap does not comply with tap rules. 4) Provide coordination study. 5) Review not complete.						
52689	14A0495	Mac Electrical Contracting Inc. 2807 Flatbush Avenue Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	12 East 13th Street New York NY	Approved	\$650.00
<p>1) Verify 3 pole ATS' being used in a separately derived system. 2) Slow fault current at meter bank, provide coordination study. 3) Incoming fault current not shown. 4) Service bus undersized. 12/23/14 Job finalized This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/6/15 Rejected. 1) Fire alarm ATS cannot be located in service room. 2) If equipment in service room is 3rd fusing or more indicate it on drawing. 1/20/16 Swapped Drawing 1-Revision 2 and Drawing 2-Revision 1.</p>						

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0496	Interphase Electrical Corp. 5304 Seventh Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	St. Barnabas Hospital 4422 Third Avenue Bronx NY	Rejected	\$650.00
1) Signage to be provided at each service location indicating where the other service is located. 2) Show existing Con-ED end box, show existing service room clearances. 3) Show doors on new service room. 4) Verify that ATS' are 3 poles types, new and existing on 1 Line. 5) Where is switchboard BP located? 6) Coordination study does not match 1 Line, 2000 amp switch feed 1600 amp switch, not completely reviewed. 7) ATS notes don't match 1 Line. 11/6/14 Carry over no good for 11/19/14 meeting for the following reasons: 1) Updated coordination study not submitted. 2) Item #3 not addressed. 3) Item #4 not addressed. 4) Item #7 not addressed.						
52507	14A0497	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	225 Varick Street New York NY	Approved	\$650.00
52516	14A0498	ELPO Electrical Contracting Inc. 172 North 11th Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	Trump International Hotel & TWR 61st Street & Central Park West New York NY	Approved	\$650.00
OR						
52517	14A0499	Belmont Electrical Inc. 5-12 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	941 Park Avenue New York NY	Approved	\$650.00
OR						
52508	14A0500	OM Electric, Inc. 262 West 38th Stree, Suite 1202 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	238 Bedford Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52509	14A0501	Response Electric Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	1185 Park Avenue New York NY	Approved	\$650.00
3/24/15 Swapped drawings 1 and 2, Revision 3s.						
52510	14A0502	MSM Electric, Inc. 417 Brighton Beach Avenue Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	675 Morris Avenue Bronx NY	Approved	\$650.00
52625	14A0503	Maximum Electric Corp. 65-19 Metropolitan Avenue Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	One Main Street Brooklyn NY	Approved	\$650.00
Verify fire alarm system installation. 11/24/14 Job finalized.						
52511	14A0504	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	22 Caton Place Housing Brooklyn NY	Approved	\$650.00
52660	14A0505	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	Steinway Estates 19-73 38th Street Astoria NY	Approved	\$650.00
Booster pump overfused. 12/5/14 Job finalized.						

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52626	14A0506	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 Fifth Avenue New York NY	Approved	\$650.00
Verify room is fire rated. 11/24/14 Job finalized.						
52512	14A0507	KNC Electric Inc. 187-27 Linden Blvd. St. Albans NY 11412	Requested approval for the electric service equipment proposed to be installed	92 3rd Street Brooklyn NY	Approved	\$650.00
9/10/15 Swapped Drawings, 1 and 2-Revision 2s.						
52513	14A0508	Nu-Wire Electric, Inc. 212-89 26th Avenue Bayside NY 11360	Requested approval for the electric service equipment proposed to be installed	245 East 80th Street New York NY	Approved	\$650.00
52659	14A0509	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	440 West 42nd Street New York NY	Approved	\$650.00
Verify compliance with 110.26(A)(3). 12/5/14 Job finalized.						
52684	14A0510	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	2182 Broadway New York NY	Approved	\$650.00
Provide disconnect on 2500A board. 12/19/14 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/21/15 Swapped drawings. 1 and 2, Revision 3s. 9/18/15 Swapped drawings 1 and 2, Revision 4. 12/28/15 Swapped drawings 1 and 2-Revision 5s. 1/21/16 Swapped drawing 2-Revision 5.						

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52685	14A0512	Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Time Warner 100 Cable Way Staten Island NY	Approved	\$650.00
<p>1) Permanent generator disconnect switch to be ground-fault protected. 2) Provide manufacturer's installation instructions for the particular gen-set being installed. 12/19/14 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/7/15 Job finalized. 1 of 2 Rev. 2, 2 of 2 Rev 0. 6/30/15 Added room layout drawing 3 of 3, Revision 0.</p>						
52654	14A0513	Hatzel & Buehler, Inc. 230 Park Avenue, Suite 925 New York NY 10169	Requested approval for the electric service equipment proposed to be installed	Sprint LIC 32-50 Hunters Point Avenue Queens NY	Approved	\$650.00
Neutral in new service end box to be bonded to enclosure 250.102(c) and 250.4(A)(4). 11/28/14 Job finalized.						
52679	14A0515	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	350 5th Ave., 28th and 29th Flrs New York NY	Approved	\$650.00
1) Verify that service room is mechanically ventilated. 2) Equipment grounding conductors on load side of transformer undersized, provide lengths of transformer secondary taps. 12/18/14 Job finalized.						
52514	14A0517	Walter T. Gorman, P.E., P.C. 414 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	561 7th Avenue New York NY	Approved	\$650.00
OR						

ADVISORY BOARD CALENDAR

September 10, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52515	14A0678	Montgomery Electrical Contracting Corp. 4250 Van Cortland Park East Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	156 North 4th Street Brooklyn NY	Approved	\$650.00
OR 5/28/15 Job finalized. Swapped Drawings A and B Revision 1s.						