

# ADVISORY BOARD CALENDAR

**September 12, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47909CO2	07A0221CO2	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	YWCA 30 Third Avenue Brooklyn NY	Approved	\$0.00
Carry over from July 18, 2007 meeting.						
48005CO2	07A0313CO2	Proven Electrical Contracting Inc. 247 Driggs Avenue Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Con Edison Inc. of New York 4 Irving Place New York NY	Approved	\$0.00
Carry over from August 15, 2007 meeting. 1) Provide bus sizes for switchgear. 2) Revise 1-Line diagram to represent switchboard as shown on GE drawings. Job finalized 1/23/08.						
48023CO	07A0338CO	Uptown Electric, Inc. 128-20 14th Avenue College NY 11356	Requested approval for the electric service equipment proposed to be installed	Manhattan College 4455 Manhattan College Parkway Bronx NY	Approved	\$0.00
Carry over from July 18, 2007 meeting. 1) Generator neutral shall be bonded to enclosure. 2) Generator neutral to be connected to water ground electrode. Job finalized 5/19/08						
48024CO	07A0352CO	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	The Rockefeller University 1230 York Avenue New York NY	Approved	\$0.00
Carry over from July 18, 2007 meeting.						
48037CO	07A0319CO	Platinum Electrical Contracting Inc. 360 Industrial Loop Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	XO Communications 111 Eighth Avenue, 12th Floor New York NY	Approved	\$0.00
Carry over from July 18, 2007 meeting.						

# ADVISORY BOARD CALENDAR

**September 12, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48084CO	07A0372CO	Approved Electrical Contractors, Inc. 6318 New Utrecht Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Silvercrest Nursing Home 144-45 87th Avenue Briarwood NY	Approved	\$0.00
Carry over from August 15, 2007 meeting. 1) Provide description of operation of co-gen system 2 scenarios: on Con Ed power on emergency power. Job finalized 10/29/07.						
48098CO	07A0385CO	Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Rikers Island 18-01 Hazen Street Rikers Island NY	Approved	\$0.00
Carry over from August 15, 2007 meeting.						
48105CO	07A0380CO	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Extell Development 305/311 East 46th Street New York NY	Approved	\$0.00
Carry over from August 15, 2007 meeting.						
48127CO	07A0391CO	Petrocelli Electric Co. Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The (New) Yankee Stadium 1 Yankee Stadium Way Bronx NY	Approved	\$0.00
Carry over from August 15, 2007 meeting.						
48128CO	07A0417CO	Mass Electric Construction Company 150-50 14th Road Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	Coney Island Water Treatment Brooklyn NY	Approved	\$0.00
Carry over from August 15, 2007 meeting. 1) Verify that 1200A aux. Bus does not carry more than 1200A. 2) comply with table 110.34(A) for working clearance. 3) Relocate CCTV and fire alarm out of switchgear room. 4) Provide documentation of switchgear bus sizes. 5) Confirm proper key interlocking.						

# ADVISORY BOARD CALENDAR

**September 12, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48142	07A0421	High-Tech Electrical Services Corp. 36-33 23rd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	545 Madison Avenue New York NY	Hold	\$650.00
1) More than 6 service switches installed off of one point of entry. 2) Provide cut sheets of emergency panel board, and other equipment.						
48143	07A0422	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1775 Grand Concourse Bronx NY	Approved	\$650.00
1) Provide generator cuts. 2) Provide coordination study for ideal switchgear. Job finalized 9/12/08.						
48144	07A0423	Knight Electrical Services Corp. 111 Eighth Avenue New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Next Jump 261 Fifth Avenue, 7th Floor New York NY	Approved	\$650.00
48145	07A0424	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	PS/IS K229 1400 Benson Avenue Brooklyn NY	Approved	\$650.00
1) Bond neutrals to enclosure in 30 amp FCO and fire pump service switches. 2) Provide supplemental ground in fire pump service switch. 3) Are 3 or 4 pole ATS being used. 4) Provide bus sizes on line side of 5000 amp service switch. 5) Generator frame not grounded. Job finalized 10/29/07.						
48146	07A0425	Crana Electric Inc. 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	The Singer Building 561 Broadway New York NY	Approved	\$650.00
New feeders to existing 800 amp C.T. to comply with tap rules. Job finalized March 24, 2009.						

# ADVISORY BOARD CALENDAR

**September 12, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48147	07A0426	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	City Clerk Office Relocation 155 Worth Street New York NY	Hold	\$650.00
1) MI cable can not be used in lieu of 230.6. 2) MI service entrance conductors are undersized and can't operate at 90 degree. 3) No notes provided on drawing. 4) Is live bus 12" off of the floor? 5) Provide coordination. 6) Bus size not provided in end box.						
48148	07A0427	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 1221 6th Avenue New York NY	Approved	\$650.00
48149	07A0428	Kleinknecht Electric Company, Inc. 252 West 37th Street New York NY 11018	Requested approval for the electric service equipment proposed to be installed	American Bible Society 1865 Broadway New York NY	Approved	\$650.00
48150	07A0429	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Art Leather H.S. 45-10 94th Street Elmhurst NY	Approved	\$650.00
1) Fire pump emergency feed and control wiring to ATS to comply with 695.14(F) and 700.9(D)(I). 2) Verify that fire pump ATS is supplied by 3 conductors, no neutral. Job finalized 10/29/07.						
48151	07A0430	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Northrup Grumman 2432 Grand Concourse Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

September 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48152	07A0431	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S. 244 Queens 137-20 Franklin Avenue Flushing NY	Approved	\$650.00
48153	07A0432	Double D Electric Corp. 33 2nd Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Queens Medical Associates 176-60 Union Turnpike Jamaica NY	Approved	\$650.00
48154	07A0433	ID Electric Corp. 143 30th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	30-50 Whitestone Expressway Queens NY	Approved	\$650.00
48155	07A0434	RNH Electric Company, Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1700 Grand Concourse Bronx NY	Approved	\$650.00
48156	07A0435	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	1 Lincoln Plaza, a.k.a. 20 W. 64th St New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

September 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48157	07A0436	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Candid Litho 25-11 Hunters Point Avenue Long Island City NY	Approved	\$650.00
48158	07A0437	I. & R. Electl Contg and Repair Service In 149 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	21 West 46th Street New York NY	Approved	\$650.00
48159	07A0438	RNH Electric Company, Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	P.S. 60 55 Merrill Avenue Staten Island NY	Approved	\$650.00
48160	07A0439	Lakhani and Jordan Engineers, PC 50 East 42nd Street, Suite 1001 New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Starbucks @ Empire State Bldg 350 Fifth Avenue & 34th St. New York NY	Approved	\$650.00
48161	07A0440	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Albert Einstein College of Med. 1300 Morris Park Avenue Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**September 12, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48162	07A0441	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	PS/IS 113 Queens 87-21 79th Avenue Glendale NY	Approved	\$650.00
48163	07A0442	Amko Electrical Construction & Maint. Inc 32-17 College Point Blvd. Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	11-11 131 Street College Point NY	Approved	\$650.00
48164	07A0443	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	The Venetian 447 Avenue P Brooklyn NY	Hold	\$650.00
1) Verify that not CT is required prior to the 1200 amp service switch. 2) Show fuse types. 3) General notes not on drawing.						
48165	07A0444	Crana Electric Inc. 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	The Advertising 815 Second Avenue New York NY	Approved	\$650.00
48166	07A0445	Knight Electrical Services Corp. 111 Eighth Avenue, Suite 526 New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Bloomberg 340 West Street New York NY	Hold	\$650.00
1) Circuit breaker ratings not provided. 2) Provide curves. 3) Explain operation of the static switches and provide Siemens' circuit information.						

# ADVISORY BOARD CALENDAR

September 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48167	07A0446	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Tenant Upgrades 455 Main Street Roosevelt Island NY	Approved	\$650.00
48168	07A0447	Folks Electrical, Inc. 670 Broadway New York NY 10012	Requested approval for the electric service equipment proposed to be installed	170 East 77th Street New York NY	Approved	\$650.00
48169	07A0448	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Prime House 381 Park Avenue South New York NY	Approved	\$650.00
48170	07A0449	Integral Electrical Power & Control Corp. 307 7th Avenue, Suite 507 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	55-57 Flatbush Avenue Brooklyn NY	Approved	\$650.00
48171	07A0450	Athens Electric, Inc. 1980 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	72 Spring Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

September 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48172	07A0451	Athens Electric, Inc. 1980 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	1 East 1st St., a.k.a. 11 East 1st St. New York NY	Approved	\$650.00
48173	07A0452	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	125 East 72nd Street New York NY	Approved	\$650.00
48174	07A0453	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	1965 Broadway New York NY	Approved	\$650.00
48175	07A0454	Citi-Wide Electrical Inc. 2434 Prospect Avenue Bronx NY 10458	Requested approval for the electric service equipment proposed to be installed	57 West 75th Street New York NY	Approved	\$650.00
48176	07A0455	Hampton Electrical Corporation 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	366 Madison Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

September 12, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48177	07A0456	Frank Pugliese Electrical Contracting Corp 141-18 Holly Avenue Flushing NY 11355	Requested approval for the electric service equipment proposed to be installed	30-02 48th Avenue Long Island City NY	Approved	\$650.00
48178	07A0457	Apollo Electric Inc. 390 Manhattan Avenue New York NY 10026	Requested approval for the electric service equipment proposed to be installed	137 Varick Street New York NY	Approved	\$650.00
48179	07A0458	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Atria Nursing Home 3718-3726 Henry Hudson Pkwy Riverdale NY	Hold	\$650.00
1) MC cable installation must comply with 330.108 and 310.15(B)(2) and 250.122. 2) Special permission is needed from the Advisory Board to leave bonding as is #2, instead of 400 MCM for paralleling.						
48180	07A0459	Izzo Electric Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	500 East 165th Street Bronx NY	Approved	\$650.00
48181	07A0460	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested concept approval for:	New York Times Headquarters 620 Eighth Avenue New York NY	Approved	\$0.00
With the stipulation that drawings in Advisory Board format are submitted for approval. Life safety generators and their equipment must be installed in separate 2 hour fire rated rooms. The one line diagram shall show how all systems tie into each other. Drawings to show what equipment is new and what is existing. Provide information showing that the generators are in separate fire rated rooms.						

# ADVISORY BOARD CALENDAR

**September 12, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48182		altPower, Inc. 125 Maiden Lane, Suite 307 New York NY 10038	Requesting concept approval for the installation of a solar photovoltaic system	Dalton School 108 East 89th Street New York NY	Approved	\$0.00
<p>Note: Concept approval from the Advisory Board for solar photovoltaic system installations is not required if the installation is filed and installed by a New York City licensed electrician, the PV system is tested and listed by nationally recognized testing laboratory as a complete system and a pw1 form is submitted to the department attesting to the structural integrity of the mounting of the PV arrays.</p>						
48183		Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval for the installation of a solar photovoltaic system	Kinloch Co. Inc. 27-10 Hunters Pt Avenue Brooklyn NY	Approved	\$0.00
<p>Note: Concept approval from the Advisory Board for solar photovoltaic system installations is not required if the installation is filed and installed by a New York City licensed electrician, the PV system is tested and listed by nationally recognized testing laboratory as a complete system and a pw1 form is submitted to the department attesting to the structural integrity of the mounting of the PV arrays.</p>						
48184		altPower, Inc. 125 Maiden Lane, Suite 307 New York NY 10038	Requesting concept approval fo9r the installation of a solar photovoltaic system	630 5th Avenue New York NY	Approved	\$0.00
<p>Note: Concept approval from the Advisory Board for solar photovoltaic system installations is not required if the installation is filed and installed by a New York City licensed electrician, the PV system is tested and listed by nationally recognized testing laboratory as a complete system and a pw1 form is submitted to the department attesting to the structural integrity of the mounting of the PV arrays.</p>						
48185		altPower, Inc. 125 Maiden Lane, Suite 307 New York NY 10038	Requesting concept approval for the installation of a solar photovoltaic system	900 West 190th Street New York NY	Approved	\$0.00
<p>Note: Concept approval from the Advisory Board for solar photovoltaic system installations is not required if the installation is filed and installed by a New York City licensed electrician, the PV system is tested and listed by nationally recognized testing laboratory as a complete system and a pw1 form is submitted to the department attesting to the structural integrity of the mounting of the PV arrays.</p>						
48186		Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requesting permission to leave as installed jacketed MC cable installed on the roof of a building due to a hardship to remove and replace	Atria Assisted Living 3718-3726 Henry Hudson Parkway Riverdale NY	Denied	\$0.00
<p>The installation of eight sets of 500 MCM MC cable fused at 3000 amps does not comply with 330.108.</p>						

# ADVISORY BOARD CALENDAR

**September 12, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48187		James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requesting permission to waive selective coordination between the 3000 amp A4BQ fuses and 2,000 and 1,600 amp Siemens circuit breakers, where the 2000 amp breaker feeds a bus duct and the 1600 amp breaker is a spare	Verizon 1421 Ocean Avenue Brooklyn NY	Approved	\$0.00
48188		BT Electrical, Inc. 85-02 67th Drive Rego Park NY 11374	Requesting permission due to hardship to replace, to leave as installed in a place of religious worship AC cable that does not contain an insulated grounding conductor	Synagogue 8-10 Clinton Street New York NY	Approved	\$350.00
With the stipulation that ground fault circuit breakers are installed on all of the branch circuits.						
48189		Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requesting permission to leave as installed MC cable that does not comply with Section 330.108.	3536 Cambridge Avenue Bronx NY	Denied	\$350.00
48190		A. Rocco & Son Electrical Inc. 248 Port Richmond Avenue Staten Island NY 10302	Requesting permission not to group together service equipment in a two family building where one service is installed on the outside of the building to provide power for condo parking area.	7300 Amboy Road Staten Island NY	Approved	\$0.00
48191		Tanachion Electrical Contracting Inc. 15 Olympia Blvd. Staten Island NY 10305	Requesting permission due to the tenant where the service switches are located not providing access to others, to relocate the service switch from Store A to Store B and to not group together service equipment.	977 Victory Blvd. Staten Island NY	Approved	\$0.00
With the stipulation that the service switch for store B is installed outdoors where the electric meters are located and signage is provided at each service (indoor and outdoor) meters are located.						

# ADVISORY BOARD CALENDAR

**September 12, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48192		Robert M. Tieger, Architect 3 Patchin Place New York NY 10011	Requesting permission to leave as installed a listed relocated and reinstalled spray-tech spray booth.	Earl Scheib Facility 787 Bruckner Blvd. Bronx NY	Approved	\$0.00
With the stipulation that installation is subject to a final field inspection by the Electrical Division.						
48193		Concessi Engineering, P.C. 575 Eighth Avenue New York NY 10018	Requesting concept approval to connect a temporary mobile generator to an existing service in the event of utility failure.	Forbes 60 Fifth Avenue New York NY	Denied	\$0.00
48194		Flack and Kurtz 475 Fifth Avenue New York NY 10017	Requesting permission due to lack of space in the electrical room and coordination issues to tap temporary power from the load side of a 4000 amp fuse with 4 sets of 600 MCM that will feed two separate 800 amp fused disconnect switches instead of terminating in a single overcurrent device on a job that will last 3 to 4 months to test new presses.	The New York Times 1 New York Times Plaza Flushing NY	Approved	\$0.00
With the stipulation that the temporary wiring is filed for and installed by a New York City licensed electrician. The temporary wiring shall not be energized and left in service longer than requested.						
48195		Bestco General Electrical Inc. 922 East 233rd Street Bronx NY 10466	Requesting permission to run unprotected service entrance conductors in a trough approximately 22 feet to the service switch where about 16 feet of the run is inside a fire rated service room.	346 Powers Avenue New York NY	Approved	\$0.00
With the stipulation that the service entrance conductors are installed in conduit to maintain the service room's fire rating, the fire command station, telephone junction box must be removed from the service room. The installation must comply with the requirements of 110.26.						
48196		Arup 155 Avenue of the Americas New York NY 10013	Requesting permission to install a new air intake duct system for a new generator that will run through an existing service room that will encroach the dedicated electrical space above the electrical equipment	Lincoln Center 140 West 65th Street New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**September 12, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48197		H & L Electric Inc. 41-11 28th Street Long Island City NY 11101	Requesting permission to remove emergency power off systems for New York's Fire Department information technology equipment room due to meeting the exception requirement of 645.10	11 Metro Tech Brooklyn NY	Denied	\$0.00
This is not an industrial building, no documentation was provided from the New York City Fire and Police Department stating why this system should be installed. It wasn't explained, if the building has a qualified engineering and maintenance staff why must the emergency power off system be omitted.						
48198		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to leave as installed 1/0 copper bonding jumpers for a 1200 amp feeder that does not have mechanical continuity on the load side of a 1200 amp switch	310 West 52nd Street New York NY	Denied	\$0.00
48199	07A0461	Toshiba International Corporation 13131 W. Little York Rd. Houston TX 77041	Requested approval for use in New York City of your Toshiba G8000MM Uninterruptible Power Supply (UPS) system with battery cabinet, maintenance bypass, and remote monitor. Model/Serial Numbers: T8MSK3K15KK6XSN, M8B-1512-D40, M8W-MBS-225-43 and RMTI-EXT-R4.		Approved	\$200.00
48200		Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission due to lack of space to mount the fire alarm cut-out in the service room, to tap power for the FACO on the main lugs of a distribution panel located in the tenant space. The fire alarm control panel will be provided with back up batteries with a 24 hour supervisory mode capacity and 60 minutes in alarm mode.		Approved	\$0.00
With the stipulation that the installation is subject to inspection to other jurisdictions.						