

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51514		Dean Electric 45 Page Avenue Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	1400 Fifth Avenue New York NY	Approved	\$650.00
New 1600 amp switch cannot be installed in same switchboard section that contains a fire pump service switch. Job finalized 12/28/12.						
51483	12A0040CO2	Kleinknecht Electric Co., Inc. 252 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	452 5th Avenue New York NY	Approved	\$0.00
Carry over from July 18, 2012 meeting. Confirm that intake and exhaust for generator maintains the ambient temperature. Job finalized 12/18/12.						
	12A0084CO	APS Electric Inc. 2614 West 13th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	456 Grand Street Brooklyn NY	Rejected	\$0.00
Carry over from July 18, 2012 meeting. 4/16/14 Rejected 1. 2-100 amp disconnect switches not shown on drawings, show short circuit current at 100 amp disconnects, show conductors to 100 amp disconnect switches. 6/20/14 Rejected New submittal required too many changes to original submittal.						
	12A0139CO	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	93 Worth Street New York NY	Pending	\$0.00
Carry over from July 18, 2012 meeting. EGC feeding trough undersized should be 4/0.						
51449	12A0170CO	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Sims, South Bklyn Marine Terminal 472-490 2nd Avenue Brooklyn NY	Approved	\$0.00
Carry over from August 15, 2012 meeting. 1) Normal emergency circuits cannot be supplied from the same vertical switchboard section. 2) Provide cut sheet of ATS. 3) Feed for fire alarm system to be fed from line side of service equipment and line side of emergency equipment. Job finalized 10/12/12.						

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51379	12A0183CO	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Societe Generale 245 Park Avenue New York NY	Approved	\$0.00
Carry over from August 15, 2012 meeting. 8/1/16 Swapped Drawings AB-3,4 and 5-Revision 1; FP-1-Revision 2 and SB 2-Revision 3. 12/20/16 Swapped drawings AB40-0-01,02,03,04,05, 06-Revision 2. AB40-07-Revision 0, FP40-01,02-Revision 3.						
51169CO2	12A0192	A to Z Electl Maint. & Service Corp. 307 Seventh Avenue, Suite 403 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	650 Park Avenue New York NY	Approved	\$0.00
Carry over from June 13, 2012 meeting. 4/7/15 Swapped Drawing 1 of 2, Revision 3 and 2 of 2 Revision 4.						
51380	12A0193	Innovate Electrical Services 3346 Provost Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	Jump Trading 15 East 26th Street Bronx NY	Approved	\$650.00
	12A0194	Verified Electl & Technical Services, Inc. 27 William Street, Suite 409 New York NY 10005	Requested approval for the electric service equipment proposed to be installed	1441 Broadway New York NY	On Hold	\$650.00
1) Type fuses not shown on drawing. 2) Neut. Disconnect linkds not shown on drawing for existing service switch. 3) Main bonding jumper not shown on drawing at service switch neutral. 4) Use step-up trans delta Y. 5) Primary switch rating to be adequate for TRX In-rush current. 6) Provide cat cuts for transformers. 7) Provide mech vent for old tel RM. 8) Verify that there are no active tel eq.						
51464	12A0195	Patriot Electric Corp. 96-06 220th Street Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	619 West 54th Street New York NY	Approved	\$650.00
1) Neutral not bonded to generator frame/chassis on drawing. 2) Verify available short circuit at MDB-1( Has to be less than 100 KAIC). Job finalized 11/29/12. 3/24/15 Swapped drawing 1 of 1, Revision 3.						

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0196	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	80 Centre Street New York NY	On Hold	\$650.00
1) Verify that switchboard have hinged lockable rear doors. 2) Rear of switchboard to have 3' clearance. 3) Feeder to ATS-4 overfused. 4) Take off bus supplying 1600 amp disconnect switch under sized in switchboard SSB-C. 5) Emergency system to have ground fault indication. 6) Fire rated conductors shall not be installed in RGS conduits. 7) What are the fire rated conductors feeding?						
	12A0197	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Middle College H.S. 4535 Van Dam Street Long Island City NY	On Hold	\$650.00
1) Folders from existing 2500A service switch to MDSB# 2A under size. 2) Tap conductors between MDSB #1A under size. 3) Main bus inside MDSB #2 Section 1 and Section 2 under size. 4) Grounding electrode not shown drawing for fire alarm service switch #3 N.Y.C. Amendement 760.33A. (5) Type 1 withstand ratings of fuses for fire alarm and fire pump not shown on drawing Article.110.9 and 110.10. (6) Em board shall comply with 700.9(B)(a) if em loads and optional load are fed from the board. (7) Provide CAT cuts for em board. 8) Fire rated cables shall not be installed in RMC.						
51381	12A0198	Denmar Electric Corp. 5 Penn Plaza, 195h Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	330 East 75th Street New York NY	Approved	\$650.00
51382	12A0199	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	38 West 31st Street New York NY	Approved	\$650.00
	12A0200	Campbell and Dawes Electl Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	Deloitte & Touche 30 Rockefeller Plaza New York ny	On Hold	\$650.00
1) Main bonding jumped and grounding electrode not shown on drawing for step-down transformers Article 250.30. 2) Correct transformer designations on trans. 3) Verify mech vent is provided. 4) Verify that space behind requirement complies with condition 1, (ungrounded surface). 5) Doors shall swing out. 6) Provide cross sections of substations. 7) Provide cuts for transformers. 8) Verify what eq. Or system is installed in the corner of 300 KVA RM. Note: Replace drawing (B) at the meeting. 9) Coordination study not provided sub-station and up stream cb. 10) Correct sub-station fuse type to 5KV type.						

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0201	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1633 Broadway New York NY	On Hold	\$650.00
Provide calculation for new connected load to indicate demand does not exceed 4000A.						
51383	12A0202	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	655 Madison Avenue New York NY	Approved	\$650.00
51384	12A0203	Citi-Wide Electric 3411 Fort Hamilton Parkway Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	45-25 Kissena Boulevard Queens NY	Approved	\$650.00
51385	12A0204	Athens Electric, Inc. 1980 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	145 East 16th Street New York NY	Approved	\$650.00
51386	12A0205	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	1771 Monroe Avenue Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51460	12A0206	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	555 5th Avenue New York NY	Approved	\$650.00
Two switch (2 sets fuses) in series fire pump circuit. Job finalized 11/8/12.						
51387	12A0207	A.C.G, Electric Co. Inc. 153 Main Street Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	147 West 15th Street New York NY	Approved	\$650.00
51511	12A0208	Maximum Electric Corp. 65-19 Metropolitan Avenue Middle Village NY 11137	Requested approval for the electric service equipment proposed to be installed	Monsignor McClancy H.S. 71-06 31st Avenue East Elmhurst NY	Approved	\$650.00
Transformer secondary cond shall comply with 240.4(B) provide 600KCMIL. Job finalized 11/8/12.						
51388	12A0209	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	NYU Langone Medical Center 550 First Avenue New York NY	Approved	\$650.00
51389	12A0210	I.P. Electric Inc. 143 30th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	131-10 Maple Avenue Flushing NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51390	12A0211	Walsh Electrical Contracting Inc. 76 Midland Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	745 Fifth Avenue New York NY	Approved	\$650.00
7/15/14 Swapped 1-Revision 3.						
51465	12A0212	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	500 West 30th Street New York NY	Approved	\$650.00
Verify switchboard 1B and 2B equipped with rear doors NYC Amendment 408.60(F). Job finalized 11/20/12. 12/1/15 Swapped drawing 1,2,3-Rev 4.						
51391	12A0213	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Park Central Hotel 870 7th Avenue New York NY	Approved	\$650.00
51416	12A0214	Modern Trend Electrical Contracting Corp. 45-06 108th Street Corona NY 11368	Requested approval for the electric service equipment proposed to be installed	19-48 Troutman Street Ridgewood NY	Approved	\$650.00
1) EGC on load side (secondary) of transformer must be sized per 250.66(#1/0). 2) Verify inverter sizes 100 KW or 75 KW. Job finalized 10/5/12.						
51466	12A0215	AL-Lectric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	Marriott Hotel 95 Henry Street New York NY	Approved	\$650.00
1) Neutral not bonded to enclosure at fire alarm service switch. 2) Grounding electrode conductor not provided at fire alarm service switch. 3) Verify that fire rated conductors are installed in EMT or intermediate raceways. Job finalized 11/20/12.						

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51392	12A0216	Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	3170 Webster Avenue Bronx NY	Approved	\$650.00
51393	12A0217	Parcel Licensed Electrical Contracting Corp 1406 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Fairway Market 550 2nd Avenue New York NY	Approved	\$650.00
51394	12A0218	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	675 6th Avenue New York NY	Approved	\$650.00
	12A0219	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Skyview Towers 5700 Arlington Avenue Bronx NY	On Hold	\$650.00
<p>1) Conductors from new generator not protected. 2) Does existing MDP switchboard feed life safety. If yes, the ATS cannot be located in the service room. 3) Verify that 75 KW generator is large enough to carry the emergency loads. 4) Verify that all required emergency loads are being picked up by the generator, fire alarm system. 5) Neutrals from generator to be used from the gas engine generator. 6) Relocate disconnect switch for co-gen to another area.</p>						
	12A0220	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Skyview Towers 5900 Arlington Avenue Bronx NY	On Hold	\$650.00
<p>1) Conductors from new generator not protected. 2) Does existing MDP switchboard feed life safety? If yes, the ATS cannot be located in the service room. 3) Verify that 80KW generator is large enough to carry the emergency loads. 4) Verify that all required emergency loads are being picked up by the generator, emergency lighting and fire alarm system. 5) Neutrals from generator to be used from the gas engine generator. 6) Relocate ATS switch for co-gen to another area away from the doorway.</p>						

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0221	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Skyview Towers 5800 Arlington Avenue Bronx NY	On Hold	\$650.00
1) Conductors from generator not protected. 2) Does switchboard MPD feed life safety? If yes, the ATS cannot be located in the service room. 3) Verify that 75KW generator is large enough to carry the emergency loads. 4) Verify that all required emergency loads are being picked up by the generator, emergency lighting, and fire alarm system. 5) Neutrals from generator to be used from the gas engine generator.						
	12A0222	Accurate Electric Corp. 4319 18th Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	153 West 21st Street New York NY	On Hold	\$650.00
Indicate what is new and what is existing(Bubble). Drawing not reviewed.						
51467	12A0223	Knight Electrical Services Corp. 599 Eleventh Avenue New York NY 10036	Requested approval for the electric service equipment proposed to be installed	AT & T DAS Installation 399 Park Avenue New York NY	Approved	\$650.00
Equipment grounding conductor undersized. Job finalized 11/30/12.						
	12A0224	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	330 Madison Avenue New York NY	On Hold	\$650.00
1) Verify whether 3 or 4 pole ATS' will be installed on emergency system. 2) Identify which feeders will be run inside of the steam room. 3) Equipment grounding conductor undersized. 4) Are emergency loads life safety?						
	12A0225	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mt. Sinai Ctr for Science and Med. 1470 Madison Avenue New York NY	On Hold	\$650.00
1) I-Line submitted for reference indicates Cal. #50565 which was for a special permission. Cal. #50415 revision 2 was approved now we receive Rev 3 for reference. Where the feeders to ATS switches were changed 3 wire feeders to 4 wire feeders with no mention of what type ATS' are being installed. Drawings not reviewed.						

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51415	12A0226	Striano Electric Co., Inc. 246 Park Avenue Garden City Park NY 11040	Requested approval for the electric service equipment proposed to be installed	Milford Plaza Hotel 700 8th Avenue New York NY	Approved	\$650.00
1) Clearly show entrance and exit into service room where the new work is installed on the room layout drawing. 2) Show detail of how troughs will be connected together. 3) Will copper detail be installed in the trough? If yes, show the details. 7/1/15 Swapped Drawing A, Revision 3.						
51568	12A0227	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Brookfield Properties 245 Park Avenue, 6th Floor New York NY	Approved	\$650.00
1) Install signage on switchboard indicating that 3 pole ATS are to be installed on emergency system in the future. 2) Provide cut sheet of generator with switch. 3) Verify that generator room is mechanically ventilated. 4) Verify that generator disconnect switch is ground fault protected. Job finalized 2/12/13.						
51404	12A0228	J. United Electric 651 Willowbrook Road Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	589 Fifth Avenue New York NY	Approved	\$650.00
Provide signage for service switches in adjacent service room. Job finalized 9/26/12.						
51419	12A0229	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Isreal Discount Bank 511 Fifth Avenue New York NY	Approved	\$650.00
New feeder and panel undersized for loads. Job finalized 10/10/12.						
	12A0230	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Columbia University 3020 Broadway New York NY	On Hold	\$650.00
1) Show all clearances in the service room. 2) Show splicing method that feeds the 2 - 800 amp disconnect switches on emergency system. 3) Neutral disconnect links to be installed in series with load side neutral bus. 4) Tap length from generator to new 1200 amp switch not shown. 5) Provide lline for UPS system. 6) Verify that the anticipated future load is accounted for.						

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51421	12A0231	Apollo Electric, Inc. 212 Wet 29th Street, 2nd Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	150 Nassau Street New York NY	Approved	\$650.00
Second fusing to be LPN type. Job finalized 10/22/12. 4/10/14 Swapped A and B Rev 1.						
51510	12A0232	Metro Electrical Contractors, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Chelsea Hotel 222 East 23rd Street New York NY	Approved	\$650.00
1) Fire rated conductor shall be installed in EMT or intermediate raceways for the fire pump. 2) No.6 tap conductors on load side of 1200 amp service switch undersized. Job finalized 12/26/12.						
51395	12A0233	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Target Store 2889 Richmond Avenue Staten Island NY	Approved	\$650.00
51396	12A0234	Glo Electric LLC 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	45-56 Pearson Street Long Island City NY	Approved	\$650.00
51397	12A0235	Amber Lite Electric Corp. 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Harlem River Point 200 East 131st Street New York NY	Approved	\$650.00
4/10/14 Rejected 2nd switch added to fire alarm system-remove switch on load side of ATS. 4/16/14 Swapped Rev 1.						

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51398	12A0236	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Catholic Charities Nursing Home 2440 Fulton Street, 2nd Floor Brooklyn NY	Approved	\$650.00
<p>1) Equipment grounding conductor to fire pump undersized. 2) Fire rated conductor shall not be installed in rigid metallic conduit. 3) Verify that switchboard rear has tamper resistant bolts with signage stating "Do not remove rear covers". 9/13/12 job finalized.</p>						
51868	12A0237	James F. Volpe Electl Contracting Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Verizon-Life Safety Design 435 West 50th Street New York NY	Approved	\$650.00
<p>1) Existing service "F" service switch #1 not shown on room layout. 2) Verify that be the rear switchboard covers have tamper resistant bolts with signage indicating "Do not remove rear covers". 3) Indicate the front of the switchboard. Job finalized 9/27/12.</p>						
51402	12A0239	Robert B. Samuels Inc. 235 Wet 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	120 Broadway New York NY	Approved	\$650.00
<p>1) Verify that switchboard have rear doors. 2) Vertical bus feeding 2-400 amp switches undersized. 3) Verify location of the ground fault sensor CT. Job finalized 9/27/12.</p>						
51414	12A0240	Arcadia Electrical Company, Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	The Interchurch Center 475 Riverside Drive New York NY	Approved	\$650.00
<p>1) Existing DP-3 panelboard overfused. Does not comply with 25' tap rule. 2) Provide signage on rear of switchboard indicating "Do not remove rear covers". 12/26/12-Buss in DP (1)-3"x1/4" under size feeder taps conductors 3 sets 500 MCM Article 240 21(B)(1)(b). Job finalized 1/3/13. 8/2/16 Swapped Drawing A-Revision 1 and Drawing B- Revision 3.</p>						
51524	12A0241	Z & Z Electric Inc. 2380-82 Hughes Avenue Bronx NY 10458	Requested approval for the electric service equipment proposed to be installed	32-00 Skillman Avenue Queens NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**September 12, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51403	12A0242	Joseph Skarulis Electrical 245 Wilson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	245 5th Avenue New York NY	Approved	\$650.00
1) Service room to be ventilated. 2) Is new 400 amp disconnect switch 3rd fusing? Job finalized 9/26/12.						
	12A0243	Allstate Electrical Contracting 34 West 38th Street New York NY 10018	Requesting permission to omit a wall countertop receptacle outlet where the counter space is 12" wide or more due to a pocket door installed in the counter top wall	983 Park Avenue New York NY	Denied	\$350.00
51399	12A0244	AKF 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to utilize the 200t NYC Electrical Code for delayed phase 2 portion of electrical work originally designed under application # 120635465 on 11/17/2011.	555 Sixth Avenue New York NY	Approved	\$0.00