

ADVISORY BOARD CALENDAR

September 14, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49957CO3	10A0058CO3	Global Electrical Contg of Wechester, Inc. 400 Boston Post Road Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	Harlem Hospital 506 Lenox Avenue New York NY	Approved	\$0.00
Carry over from December 22, 2010 meeting. FP emergency circuit not tapped from load side of transformer. Job finalized 10/24/11. 6/4/14 Swapped Revision 4						
50366CO	10A0387CO	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	NYU Medical Science Building 550 First Avenue New York NY	Denied	\$0.00
Carry over from October 13, 2010 meeting. 1) Tapped conductors to terminate in fused disconnect switch, length of tap not provided. 2) 120/280 volt panel used on 277/480 volt system. 3) Conductors overfused. 4) Verify what an emergency service room is. is it emergency or normal.						
50717CO	11A0210CO	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Middle College HS 45-35 Van Dam Street Long Island City NY	Denied	\$0.00
Carry over from May 25, 2011 meeting. Tap rules not followed. Item #2 not addressed.						
50785CO	11A0259CO	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	NYC Dept. of Environ Protection 259 Java Street Brooklyn NY	Approved	\$0.00
Carry over from July 13, 2011 meeting. 1) Provide 1-Line (composite) in Advisory Board format. 2) Show main-tie-main interlocking on 480V switchgear. 3) Provide GFP on substation main secondary breakers. 4) Show tie breaker size in 480V switchgear. Job finalized 11/2/11.						
50806CO	11A0276CO	Kramer Electric, LLC 336 West 37th Street, Suite 510 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	The Puck Building 295 Lafayette Street New York NY	Approved	\$0.00
Carry over from August 17, 2011 meeting.						

ADVISORY BOARD CALENDAR

September 14, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50830CO	11A0300CO	CSA Group 17 Battery Place, Suite 100 New York NY 10004	Requested Concept Approval for:	CBS Broadcast Center 513 West 56th Street New York NY	Hold	\$0.00
Carry over from August 17, 2011 meeting. 1) Detailed drawing of service room must be provided. 2) Show details of the rear of switchboards of clearances. 3) Provide elevator drawings. 4) Coordinate 1st and 2nd fusing 3000 to 2000. 5) Provide new service room layout drawings.						
50831CO	11A0301CO	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Buckingham Hotel 101 West 57th Street New York NY	Approved	\$0.00
Carry over from August 17, 2011 meeting. 5/5/15 Rejected. Drawing were resubmitted with no indications of revisions shown on the drawings. 6/25/15 Rejected. 1) Drawing 2 and 3 wiring methods not shown. 2) Drawing 2 show feeders and wiring method from 5th floor to 15th Floor between meter banks. 3) Drawing 3 normal side FA not shown and fire alarm switch to be remote from emergency switchboard. 9/15/15 Swapped drawings 1,2 and 3, Revision 3s.						
50845CO	11A0315CO	Jeminis Electrical Contractors, Inc. 22-42 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Hebrew Home for the Aged 5903 Palisades Avenue Bronx NY	Approved	\$0.00
Carry over from August 17, 2011 meeting.						
50858		WSP Flack and Kurtz 512 Seventh Avenue New York NY 10018	Requested Concept Approval for :	250 East 57th Street New York NY	Approved	\$0.00
With the stipulation tap Bldg. 1 service for fire pump and fire alarm and run as service conductor to Bldg. 2. No disconnect in Bldg. 1.						
50859		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	NYU Langone Med. Ctr 323 East 29th Street New York NY	Void	\$650.00
1) New 4000 amp 277/480v switch not ground fault protected. 2) Verify if new distribution feed life safety loads. Provide GF trip or indication as appropriate in parallel switchgear breaker. 3) Rear access of new section appears obstructed by existing door frame. Verify. Void 50859 as per resubmitted w/ correct address 550 1st Avenue 51144.						

ADVISORY BOARD CALENDAR

September 14, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50860		C.M.Richey, Inc. Electrical Contractors 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	CVS 300 Park Avenue South New York NY	Hold	\$650.00
1) Submittal not in Advisory Board format. 2) Length of tapped conductor not provided.						
50861		Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	650 Madison Avenue New York NY	Approved	\$650.00
Length of tapped conductor not provided. Job finalized 11/29/11.						
50862		Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	XO Communications 32 Avenue of the Americas New York NY	Approved	\$650.00
On key interlocked emergency source breakers neutral paths are paralleled. GFP will not operate correctly in generator switchboard. Job finalized 2/27/12.						
50863		Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	The New School 65 Fifth Avenue New York NY	Approved	\$650.00
1) Does service equipment have rear doors? 2) Service switches 1000 amps and greatest to be ground fault protected except for the fire pump. 3) Verify 3 sets of 4/0 feeding the fire pump. 4) Provide ground fault indication on emergency board. 5) Confirm access in generator room near radiator discharge. Job finalized 11/1/11. 11/26/14 Swap rejected Revision 3 indications not shown. 3' clearance required on each side of switchgear. No changes shown on drawing 6 of 6. 3/23/15 Swapped Drawing 3 of 6, Revision 3.						
50864		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Bank of America 114 West 47th Street New York NY	Approved	\$650.00
1) Show load bank breaker (LBB) on 1-Line. 2) Ground mid point of Y on transformers. Job finalized 9/22/11.						

ADVISORY BOARD CALENDAR

September 14, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50865		Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	307 West 38th Street New York	Approved	\$650.00
50866		Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	10 East 39th Street New York NY	Approved	\$650.00
50867		A & R Electrical Maintenance, Inc. 64-14 69th Place Middle Village NY 11373	Requested approval for the electric service equipment proposed to be installed	345 Adams Street Brooklyn NY	Approved	\$650.00
Verify routing of service entrance conductors to new 2000 amp service switch. Job finalized 5/30/12.						
50868		Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	330 Madison Avenue New York NY	Approved	\$650.00
1) Equipment grounding conductors undersized. 2) Generator main breaker to have GFP (trip) unless feeding life safety. Job finalized 9/22/11.						
50869		All American Electric Corp. 508 Lefferts Avenue Brooklyn NY 11225	Requested approval for the electric service equipment proposed to be installed	George Washington H.S. 549 Audobon Avenue New York NY	Hold	\$650.00
1) Drawing can not be read. 2) Job address not on drawing title block.						

ADVISORY BOARD CALENDAR

September 14, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50870		Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	The Claremont 1421 College Avenue Bronx NY	Approved	\$650.00
1) Numbered chart not to be used to identify equipment. 2) Is Con-Ed supplying the service. Job finalized 10/21/11.						
50871		HIG Electric Associates NYC, Inc. 25-26 50th Street Woodside NY	Requested approval for the electric service equipment proposed to be installed	Chelsea Imaging 230 West 17th Street New York NY	Approved	\$650.00
1) Verify who is feeding the end box. 2) 1000 amp panelboard overfused. 3) Bus sizes not shown on drawings. Job finalized 10/4/11.						
50872		Metro Electrical Contractors, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	229-231 Duffield Street Brooklyn NY	Approved	\$650.00
50873		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Pace University 182 Broadway New York NY	Approved	\$650.00
1) Service entrance undersized. 2) Verify if 3 or 4 pole ATS' are used in the emergency system. 3) Neutrals bonded after the service switch. 4) Service bus feeding 1200 and 1600 am service switches undersized. Job finalized 10/21/11. 6/12/12 as per letter, address changed to 182 Broadway.						
50874		Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	26th Ward Water Pollution Con Brooklyn NY	Hold	\$650.00
1) Switchboard to have rear hinged doors. 2) Rear of switchboard to comply with Table 110.34(A). 3) Advisory Board notes not on drawing. 4) 1 Line drawing not in Advisory Board format. 5) Coordination study not submitted.						

ADVISORY BOARD CALENDAR

September 14, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50875		Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Uniqlo 31-39 West 34th Street New York NY	Approved	\$650.00
Load side conductors size 500 or 600 MCM. Job finalized 9/22/11.						
50876		I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	601 West 26th Street New York NY	Approved	\$0.00
50877		Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	121 Varick Street New York NY	Approved	\$650.00
50878		Jeminis Electrical Contractors, Inc. 22-42 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Lefrak 97-77 Queens Blvd. Queens NY	Approved	\$650.00
50879		Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Hearst Corporation 300 West 57th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 14, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50880		Arc Electrical & Mechanical Contrs Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Newtown Creek Water Pollution 329 Greenpoint Avenue Brooklyn NY	Hold	\$650.00
Submittal not in Advisory Board format.						
50881		Contact Plus Electrical Corp. 247 Van Brunt Street Brooklyn NY 11231	Requesting permission to leave as installed EMT run inside of a fire rated shaft to protect the conductors that were not installed in rigid galvanized steel or intermediate conduits that power a limited service fire pump	2 Park Avenue New York NY	Approved	\$0.00
Code: 695.6(B)(2). With the stipulation that this installation is subject to field inspection.						
50882		Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requesting permission to leave as installed on a 1000KVA 120/208 volt service where the existing service equipment was retro fitted with new leaving a front clearance of 37 and 40 inches	Buckingham Hotel 101 West 57th Street New York NY	Approved	\$0.00
Code: 230.64(B)(1).						
50883		Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requesting permission to leave as installed AC cable without an insulated equipment grounding conductor as a wiring method in a place of assembly	820 St. Anns Avenue Bronx NY	Approved	\$350.00
Code: 518.4.						
50884		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to replace an existing 480 volt panel with new where the front clearance is 40" as condition 3 of Table 110.26	NY Post 1185 Avenue of the Americas New York NY	Approved	\$0.00
Code: Table 110.26 Condition 3.						

ADVISORY BOARD CALENDAR

September 14, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50885		Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requesting permission to leave as installed on a 1000KVA service live bus installed 5" above the finished floor	Williamsburg Charter H.S. 198 Varet Street Brooklyn NY	Denied	\$350.00
Code: 230.64(B)(2).						
50886		Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requesting permission to leave as installed 120/208 volt 1000KVA service equipment with a front clearance of 3'10".	Adams Houses 720 Westchester Avenue, Bldg. #3 Bronx NY	Approved	\$0.00
Code: Table 110.26(A).						
50887		California Pulse, Inc. 23433 Keator Road Apple Valley CA 92307	Requested approval for equipment for use in New York City of your Electric heater line for spray booths.		Hold	\$200.00
Need verification this cc covers models in submittal. Are both classes certified to US standards?						