

ADVISORY BOARD CALENDAR

September 15, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49426CO3	09A0185CO3	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Randall's Island Field Devel. Randall's Island Park Randall's Island NY	Approved	\$0.00
Carry over from 8/11/10 meeting. Provide grounding drawings E6.04. Job finalized 10/23/12.. 1/22/14 Swapped.						
49829CO2	09A0487CO2	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Jacobi Medical Center 1400 Pelham Parkway South Bronx NY	Hold	\$0.00
Carry over from June 16, 2010 meeting. . 1) Switchgear layout to comply with 230.64 clearances. 2) Portable generator to have permanent disconnecting means in or outside of building with fusing. 3) Provide door between generator board. 4) Show emergency loads for life safety.						
50184CO2	10A0232CO3	Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Lincoln Center Theatre 3 150 West 65th Street New York NY	Pending	\$0.00
Carry over from July 14, 2010 meeting.						
50194CO	10A0238CO	Broadway Electric 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Times Square Church 226 West 52nd Street New York NY	Approved	\$0.00
Carry over from July 14, 2010 meeting. 1) Neutral bond after neutral links. 2) Length of taps not provided. 3) Provide switchboard section views. Job finalized 5/3/11.						
50207CO	10A0249CO	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Lowes of Staten Island 661 Veterans Road Staten Island NY	Hold	\$0.00
Carry over from July 14, 2010 meeting. 1) Physical drawings of equipment not provided. 2) Equipment grounding conductors undersized. 3) Switch not bonded or grounded. 4) Conductors not shown on load side of service switch. 5) Provide coordination curves to 0.01 Sec.						

ADVISORY BOARD CALENDAR

September 15, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50210CO	10A0252CO	J.A. Lee Electric, Inc. 23-55 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Basketball City USA Pier 36 @ South Street New York NY	Hold	\$0.00
Carry over from July 14, 2010 meeting. Designer to appear to explain installation.						
50231CO	10A0269CO	Teknion, LLC 350 Fellowship Rd. Suite 100 Mount Laurel NY 08054	Requested approval for use in New York City of your Teknion Leverage Furniture System.		Approved	\$0.00
Carry over from July 14, 2010 meeting						
50236CO	10A0274CO	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Randall's Island Field Devel. Randall's Island New York NY	Approved	\$0.00
Carry over from 8/11/10 meeting. 1) 4 sets of 500 MCM fused at 1600 amps. Type W cable in raceway not permitted. 2) Provide detail of connections from 1500KVA secondary teams to CB's. 4) Provide bus sizes for East switchboard "MDPB" Job finalized 11/29/10. 1/22/14 Swapped.						
50240CO	10A0278CO	A.S.R. Electrical Contracting, Inc. 845 Lexington Avenue, Suite 3R New York NY 10021	Requested approval for the electric service equipment proposed to be installed	Roosevelt Island-Tram Modern. Roosevelt Island NY	Ok, but	\$0.00
Carry over from August 11, 2010 meeting. Subject to FDNY approval. No generator back-up for F.A. system.						
50282CO	10A0320CO	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	J.P. Morgan Chase 270 Park Avenue New York NY	Ok, but	\$0.00
Carry over from August 11, 2010 meeting. Transition length from MI to RHHI not shown can RHH dissipate heat from MI cable to 75 degree equipment terminals. Documentation shall be provided and shown on the drawing..						

ADVISORY BOARD CALENDAR

September 15, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50292	10A0322	Allran Electric of New York 120 Broadway, 38th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	Silverstein Properties 120 Broadway New York	Approved	\$650.00
Equipment end conductor not required for F.P. feeder. 3/0 shown undersized. Job finalized 10/25/10.						
50293	10A0323	Interphase Electric Corp. 5304 Seventh Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	McCarren Pool 776 Lorimier Street Brooklyn NY	Hold	\$650.00
No drawings.						
50294	10A0324	NYMEC 269 37th Street, Suite 200 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Industry City Building 10 882 Third Avenue Brooklyn NY	Hold	\$650.00
1) Provide submittal on substation "USS" 10" from manufacturer. 2) Provide hinged rear doors on rear accessible equipment.						
50295	10A0325	Broadway Electric 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	410 West 13th Street New York NY	Approved	\$650.00
1) Show equipment downstream of new 1600A switch. 2) Indicate location of new switch. Job finalized 2/3/11.						
50296	10A0326	Jemco Electrical Contractors, Inc. 92-13 180th Street Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	K324 800 Gates Avenue Brooklyn NY	Ok, but	\$650.00
1) Tap conductor undersized must be 10% of upstream fu. 2) 1-Line shows adding 1-200/3. Floor plan show 2. Clarify.						

ADVISORY BOARD CALENDAR

September 15, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50297	10A0327	Jemco Electrical Contractors, Inc. 92-13 180th Street Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	K296 125 Covert Street Brooklyn NY	Approved	\$650.00
50298	10A0328	Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requested approval for the electric service equipment proposed to be installed	408 Broadway New York NY	Approved	\$650.00
50299	10A0329	Belmont Electrical Inc. 5-12 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	19 East 88th Street New York NY	Approved	\$650.00
50300	10A0330	Roman Electrical Contracting, Inc. 1715 West Farms Road Bronx NY 10460	Requested approval for the electric service equipment proposed to be installed	Western Beef 2050 Webster Avenue Bronx NY	Approved	\$650.00
Verify 750KVA transformer primary switch rated for inrush current. Job finalized 10/20/10.						
50301	10A0331	Wesler-Cohen Associates Consulting Engs 740 Broadway Amityville NY 11701	Requested approval for the electric service equipment proposed to be installed	Staten Island Stapleton Marin 9 FDNY Firehouse Staten Island NY	Hold	\$650.00
Not in Advisory Board format, submit manufacturer's drawing.						

ADVISORY BOARD CALENDAR

September 15, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50302	10A0332	Jordan Daniels Electrical Contractors, Inc. 151 West 25th Street, 7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	HSBC 1 West 39th St./425 5th Ave. New York NY	Approved	\$650.00
50303	10A0333	A. Ferry Electrical 217A Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	American Stock Transfer & Trust 6201 15th Avenue Brooklyn NY	Approved	\$650.00
50304	10A0334	Campbell and Dawes Ltd. Electrical Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	St. Francis College 180 Remsen Street Brooklyn NY	Ok, but	\$650.00
1) Line and load mixed. 2) Service switches reversed. 3) Delta and Y reversed.						
50305	10A0335	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Sky View 40-28 College Point Boulevard Flushing NY	Hold	\$650.00
New equipment not shown on room layout.						
50306	10A0336	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	80 Bruckner Blvd. Bronx NY	Approved	\$650.00
1) FACO to be a switch. 2) Rating of service switches not shown on drawing. 3) FACO to be bonded and grounded. 4) Fuses do not coordinate(show fuse type). Job finalized 2/3/11.						

ADVISORY BOARD CALENDAR

September 15, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50307	10A0337	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	105 Willis Avenue Bronx NY	Approved	\$650.00
1) FACO to be a switch. 2) FACO to be bonded and grounded. 3) Ratings of service switch not shown on drawing. 4) Service bus feeding 1600 & 400 amp switches undersized. 5) Provide fuse types instead of class. Job finalized 2/3/11.						
50308	10A0338	Eric & Ng Electrical Inc. 155 Suffolk Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	Ares Printing 31-22 College Point Blvd. Flushing NY	Approved	\$650.00
50309	10A0339	CRM Electric Corporation 461 West 261st Street Bronx NY 10471	Requested approval for the electric service equipment proposed to be installed	1334 Louis Nine Blvd. Bronx NY	Approved	\$650.00
50310	10A0340	CRM Electric Corporation 461 West 261st Street Bronx NY 10471	Requested approval for the electric service equipment proposed to be installed	870 Jennings Street Bronx NY	Approved	\$650.00
50311	10A0341	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Time Life 1271 6th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 15, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50312	10A0342	Star Electric 494 Greenwich Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	40 West 57th Street New York NY	Approved	\$650.00
50313	10A0343	Twins Electric Corporation 695 East 132nd Street, Suite 205 Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	1880 Boston Road Bronx NY	Approved	\$650.00
50314	10A0344	James F. Volpe Electl Contrg Corp. 81Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	PS 264 371 89th Street Brooklyn NY	Approved	\$650.00
50315	10A0345	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Via Verde-The Green Way 700 Brook Avenue Bronx NY	Approved	\$650.00
50316	10A0346	Petrocelli Electric Co. Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Grace Building 1114 Avenue of the Americas New York NY	Approved	\$650.00
1) Disconnect switch backwards. 2) Length of tap not provided. Job finalized 9/23/10.						

ADVISORY BOARD CALENDAR

September 15, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50317		Roz-A-Lite Electric 164 20th Street, Suite 2D Brooklyn NY 11232	Requesting permission on a job which has 1-1200, 1-400 and 1-125 amp existing service switches, to add a new 1200 amp service switch without filing Advisory Board drawings.	Brooklyn Brewery 79 North 11th Street Brooklyn NY	Denied	\$0.00
50318		Hirschel Electrical, Inc. 411 Beach 30th Street Far Rockaway NY 11691	Requesting permission to install underground service entrance conductors in non metallic conduit in a corrosive area Far Rockaway, Queens.	257 Beach 17th Street Far Rockaway NY	Approved	\$0.00
50319		Polaris Electrical Construction Inc. 738 New Lots Avenue Brooklyn NY 11207	Requesting permission to install outdoor photovoltaic feeders in non metallic conduit in a corrosive area Far Rockaway, Queens.	14 Bch 19th St. and 145 Bch 137th S Far Rockaway NY	Approved	\$0.00
50320		Goldman Copeland Associates, P.C. 520 Eighth Avenue New York NY 10018	Requesting permission due to lack of space inside of the existing service room, to install a new service switch in an adjacent room where signage will be provided as per 230.2(E).	317 East 64th Street New York NY	Approved	\$0.00
50321		Douglas Electrical Contracting Corp. 87-25 78th Street Woodhaven NY 11421	Requesting permission to utilize one field evaluation report from a NRTL for another installation that is identical.	854-864 Shepherd Avenue Brooklyn NY	Approved	\$0.00
With the stipulation that one inspector performs both inspections.						

ADVISORY BOARD CALENDAR

September 15, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50322		K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requesting permission on a 1000 KVA service to replace a defective 200 amp service switch and meter pan with new and replace a defective 60 amp fuse cut with a new service switch without filing full Advisory Board submittal.	250 West 94th Street New York NY	Approved	\$0.00
50323		Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requesting permission to replace two defective 277/480 volt service switches 1-2000 and 1-600 with new and replace one 2000 amp 277/480 volt distribution panel with new without filing full Advisory Board drawings.	245 Park Avenue New York NY	Denied	\$0.00
50324		Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requesting permission due to financial difficulty of replacing undersized equipment grounding conductors, to install 1-400 MCM copper equipment grounding conductor in conduit from each service switch enclosure to the bus duct termination enclosures. All feeder raceways are nonmetallic conduit.	80 DeKalb Avenue Brooklyn NY	Denied	\$0.00
50325		Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requesting permission to utilize Section 250.122(F)(2) where undersized equipment grounding conductors were installed in conduits.	Queens Hospital Ambulatory 82-50 164th Street Jamaica NY	Denied	\$0.00