

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49349CO2	09A0136CO2	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Verizon 240 East 38th Street New York NY	Ok, but	\$0.00
Carry over from April 15, 2009 meeting.						
49351CO2	09A0138CO2	Litespeed Electric, Inc. 135 West 29th Street, Suite 301 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Bloomberg Data Center 340 West Street New York NY	Approved	\$0.00
Carry over from August 19, 2009 meeting.						
49583CO	09A0298CO	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	PS 101 141 East 111th Street New York NY	Hold	\$0.00
Carry over from July 15, 2009 meeting. Relocate switchboard to provide access around equipment.						
49594CO	09A0303CO	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Emblem Health 32 Old Slip New York NY	Approved	\$0.00
Carry over from July 15, 2009 meeting.						
49611CO		K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requesting permission due to water damage to: 1) Replace a defective feeder and 400 amp disconnect switch. 2) Replace 2 sets of 500 MCM feeders fed from a 3000 amp service switch fused at 800 amps. 3) Replace 8 sets of 500 MCM fed off of another 3000 amp service switch fused at 3000 amps on a 1000 KVA service without filing full Advisory Board drawings.	244 Madison Avenue New York NY	Hold	\$0.00
Carry over from July 15, 2009 meeting. The drawing is not clear as far as: 1) The end box, explain fuses. 2) The 4 sets of 500 MCM RH cables existing, where are they on the diagram. 3) Where is the 3000 amp service switch fed from.						

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49661CO	09A0364CO	Centrum Electric Corporation 12 Lombardy Street New York NY 11222	Requested approval for the electric service equipment proposed to be installed	402 Avenue U Brooklyn NY	Ok, but	\$0.00
Carry over from August 16, 2009 meeting. Verify that QCP breakers are selective w/1200 amp class L fuses.						
49677	09A0369	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	es Square, 640 8th Avenue and 41st New York NY	Approved	\$650.00
49678	09A0370	Stat Electric, Inc. 118-21 Queens Blvd.-suite 311 Queens NY 11375	Requested approval for the electric service equipment proposed to be installed	300 Riverdale Avenue Brooklyn NY	Approved	\$650.00
49679	09A0371	Anthony G. Ferry, Inc. 217A Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	33 East 70th Street New York NY	Approved	\$650.00
1) Verify existing feeder off of 800 service switch 4 sets 350 MCM. 2) Feeder off of new generator not shown. 3) Generator neutral not to be bonded to enclosure only generator frame to be grounded. 4) Verify that emergency feeders fed off of new panel(if any) are feeding 3 pole ATS, or are only 3 phase loads. 5) Service room door to open out with panic hardware. 6/4/10.						
49680	09A0372	James F. Volpe Electl Contracting Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	IS HS 43R Marsha Avenue and Essex Drive Staten Island NY	Approved	\$650.00
1) Indicate FACP step down transformer. 2) FACP feeder indicates neutral but note 5 indicates no neutral-clarify. Job finalized 9/28/09.						

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49681	09A0373	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	J.P. Morgan Chase 4 NY Plaza New York NY	Approved	\$650.00
Provide GFP on new switch or confirm GFP on an upstream switch. Job finalized 11/9/09.						
49682	09A0374	Accu-Glo Electric of New York, Inc. 38-26 30th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	American Eagle Outfitters 1551 Broadway New York NY	Approved	\$650.00
49683	09A0375	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	R-LIC Realty, LLC 12-16 43rd Avenue Long Island City NY	Approved	\$650.00
Stair pressurization is a required emergency load. Provide generator connection per code. Job finalized 10/19/09.						
49684	09A0376	Red Wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	Metro PCS 54-44 Little Neck Parkway Little Neck NY	Approved	\$0.00
Egress door to open out with panic hardware. Job finalized 10/19/09.						
49685	09A0377	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Emblem Health 21 East 22nd Street New York NY	Approved	\$650.00
Grounding and bonding to be on line side of neutral link.(New and existing) Job finalized 10/29/09.						

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49686	09A0378	Quenzer Electric Systems, Inc. 11 West 25th Street, 9th Floor New York NY 10010	Requested approval for the electric service equipment proposed to be installed	6100 Francis Lewis Blvd. Queens NY	Hold	\$650.00
Drawings not submitted in Advisory Board format.						
49687	09A0379	Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Grand Hyatt Grand Central Station 42nd Street New York NY	Approved	\$650.00
49688	09A0380	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	235 West 56th Street New York NY	Approved	\$650.00
49689	09A0381	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	870 Jennings Street Bronx NY	Approved	\$650.00
49690	09A0382	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Coney Island Hospital Brooklyn NY	Hold	\$650.00
<p>1) Fire pump and fire alarm feeds to be tapped ahead of generator main breaker. 2) No coordination w/ 4000A breaker in G2 distribution panel. 3) provide coordination study. 4) feeder to G2 distribution panel undersized. 5) ESWB-2 not shown on 1-line but referred to on key interlock configuration. 6) Key interlock configurations not shown correctly.</p>						

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49691	09A0383	Jeminis Electrical Contractors, Inc. 122-11 18th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	128 West End Avenue New York NY	Ok, but	\$650.00
1) Verify that bus duct above hung ceiling are enclosed type. 2) Generators are optional standby not emergency.						
49692	09A0384	Quantum Electric Corporation 38-24 34th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Zurich 105 East 17th Street New York NY	Approved	\$650.00
Is service room mechanically ventilated? Job finalized 9/23/09.						
49693	09A0385	Inner City Electrical Contractors, Inc. 160 21st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	HBO 120A East 23rd Street New York NY	Approved	\$650.00
1) Service entrance conductors are undersized and end box copper detail might have to be reinforced. 2) Verify that there are 2 doors. 3) Provide neutral calculations for service entrance. Job finalized 1/19/10.						
49694	09A0386	Inner City Electrical Contractors, Inc. 160 21st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	800 Third Avenue New York NY	Approved	\$650.00
49695	09A0387	Double K Electric Corp. 247-03 Jamaica Avenue Bellerose NY 11426	Requested approval for the electric service equipment proposed to be installed	1949 Turnbull Avenue Bronx NY	Approved	\$650.00
Conductors other than service entrance are contained in the same raceway. Job finalized 10/6/10.						

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49696	09A0388	Kleinknecht Electric Co., Inc. 252 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Thomas Reuters 195 Broadway New York NY	Approved	\$650.00
1) Show details of 1200 amp service switch and 600 disconnect switch. 2) Clarify sets of conductors and number of conduits. Job finalized 3/23/10.						
49697	09A0389	Intelogic Electric, Inc. 1000 Grand Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	The Apthorp 390 West End Avenue New York NY	Approved	\$650.00
49698	09A0390	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1334 Louis Nine Blvd. Bronx NY	Approved	\$650.00
49699	09A0391	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	75 Varick Street New York NY	Approved	\$650.00
Equipment grounding conductors are undersized. Job finalized 9/22/09.						
49700	09A0392	Dynamic Electric Service Inc. 14-17 110th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	110 East 40th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49701	09A0393	Christopher Jon Electrical, Inc. 108 Frost Street Brooklyn NY 10014	Requested approval for the electric service equipment proposed to be installed	105 Chambers Street New York NY	Approved	\$650.00
49702	09A0394	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	40 Broad Street New York NY	Approved	\$650.00
SP service fire pump feed to be in RGS. Job finalized 9/23/09.						
49703	09A0395	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	60 Hudson Street New York NY	Approved	\$650.00
49704	09A9396	BLZ Electric Co. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	313 Gates Avenue Brooklyn NY	Approved	\$650.00
49705	09A0397	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	David H. Koch Theatre 20 Lincoln Center New York NY	Hold	\$650.00
Drawing not submitted in Advisory Board format.						

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49706	09A0398	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	1382 Shakespeare Avenue Bronx NY	Approved	\$650.00
49707	09A0399	Accu-Glo Electric of New York, Inc. 38-26 30th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	443 Park Avenue South New York NY	Approved	\$650.00
49708	09A0400	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	10 Hudson Square New York, NY	Approved	\$650.00
Verify size of bus to 3000 amp service switch. Job finalized 9/23/09.						
49709	09A0401	K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	56 7th Avenue New York NY	Approved	\$650.00
49710		Roosevelt Island Operating Corporation 591 Main Street Roosevelt Island NY 10044	Requesting permission to install exposed non metallic conduit as a wiring method in an open air parking garage located in a highly corrosive area, Roosevelt Island.	Roosevelt Island Bridge New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49711		Northeast Electrical Contractors Inc. 105-08 150th Street, Suite 2 Jamaica NY 11435	Requesting permission to leave as installed as a wiring method in a place of assembly AC cable that does not contain an equipment grounding conductor.	23-58 Bell Blvd. Bayside NY	Approved	\$350.00
49712		Al-Wes Electric Services, Inc. 415 West 47th Street, Lower Level New York NY	Requesting permission to utilize Article 518.4 of the 2008 NEC by installing AC cable that does not contain an equipment grounding conductor.	765 Ninth Avenue New York NY	Approved	\$0.00
49713		L.N. Consulting Inc. P.O. Box 65178 Burlington VT 05406	Requesting permission to utilize Article 692 of the 2008 NEC for the installation of a fuel cell due to significant updates made to the article.	888 Main Street Roosevelt Island NY	Approved	\$0.00
The concept drawings previously submitted were not reviewed at this meeting.						
49714		Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting permission to utilize Article 690 of the 2008 NEC for the installation of a photovoltaic system due to significant updates made to the Article.	Fordham University Walsh Family Library Bronx NY	Approved	\$0.00
With the stipulation that if the electrical contractor files prior to adoption of the New York City 2008 Electrical Code Section 690.1 of the New York City 2005 Code applies.						
49715		Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting permission to utilize Article 690 of the 2008 NEC for the installation of a photovoltaic system due to significant updates made to the article.	Boundary Wholesale Fence Dist. 132-02 89th Avenue Richmond Hill NY	Approved	\$0.00
With the stipulation that if the licensed electrical contractor files prior to the adoption of the New York City 2008 Electrical Code Section 690.1 of the New York City 2005 Code applies.						

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49716		Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requesting permission to utilize Section 220.16(c) of the New York City 2002 Electrical Code to calculate air conditioning receptacle outlets.	Boricua Village-Building "D" 507 East 161st Street Bronx NY	Denied	\$0.00
49717		Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requesting permission to utilize Section 220.16(c) of the New York City 2002 Electrical Code to calculate air conditioning receptacle outlets	Shakespeare Place 1382 Shakespeare Avenue Bronx NY	Denied	\$0.00
49718		Stat Electric Inc. 118-24 Queens Blvd., Suite311 Forest Hills NY 11375	Requesting permission to leave as installed service equipment mounted on the outside of a commercial building that powers a cell site.	250-12 Hillside Avenue Queens NY	Approved	\$350.00
49719		C.M.Richey Electrical Contractors, Inc. 712 Fifth Avenue Brooklyn NY 11215	Requesting permission to leave as installed due to lack of space inside of the building service equipment on the outside of a commercial building.	TGIF 1770-1778 East Gun Hill Road Bronx NY	Approved	\$350.00
49720		Stat Electric, Inc. 118-21 Queens Blvd.-Suite 311 Queens NY 11375	Requesting permission to install a seventh service on a 1000 KVA service where one of the switches powers a fire pump.	300 Riverdal Avenue Brooklyn NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49721		Christopher Jon Electrical, Inc. 108 Frost Street Brooklyn NY 10014	Requesting permission to install a seventh service switch on a 1000 KVA service that will power a fire pump.	105 Chambers Street New York NY	Approved	\$0.00
49722		A/C Electric of New York, Inc. 32 Union Square East New York NY 10003	Requesting permission due to lack of space inside of the electrical closet to install a circuit breaker panel where the width of the working space is 25 inches	188 West 230th Street Bronx NY	Approved	\$0.00
49723		Axcel Electric Co. Inc. 535 West 46th Street New York NY 10036	Requesting permission to replace an existing 400 amp 7th service switch with a 600 amp service switch where one of the service switches powers a fire pump	330 Wilson Avenue Brooklyn NY	Approved	\$0.00
49724		Joseph Weinstein Electric Corp. 94-24 88th Street Ozone Park NY 11416	Requesting permission to leave as installed without complying with Section 225.33 service equipment and apartment disconnect switches installed in a underground unattached structure located 6 feet directly in front of a residential complex	792 Sterling Place Brooklyn NY	Approved	\$350.00
With the stipulation that permanent signage is provided at the entrance of the building indicating where the service equipment is located.						
49725		Atkinson Koven Feinberg Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting permission due to a hardship to selectively coordinate 1600 amp A4BQ fuses and 800 amp at GE circuit breaker to wave coordination where the load will consist of information technology and mechanical equipment.	RCN Metro Optical Networks 111 8th Avenue, 8th Floor New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

September 16, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49726		Flack & Kurtz Inc. 512 Seventh Avenue New York Ny 10018	Requesting special permission for lack of selectivity between each of the 4000A/6000A main service fusible circuit breaker and the associated UPS input switchgear feeder breakers for each of the 2N-UPS system A and B. Each of the input switchgears consists of two(2)-4000A/6000A fusible feeder circuit breakers and three (3) 1600/3000A fusible feeder circuit breakers serving as maintenance bypassed to the PDU distribution panels.	Bloomberg Data Center 340 West Street New York NY	Approved	\$0.00
49727		Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requesting permission due to hardship to relocate the new switchboard, to allow a drip pan to be installed in the dedicated electrical space above the switchboard.	PS101 141 East 111th Street New York NY	Hold	\$0.00
Relocate switchboard to provide access around equipment.						
49728		Atkinson Koven Feinberg, LLP 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to utilize an existing conduit located in a elevator shaft to refeed the elevator in a building undergoing DC conversion.	250 West 57th Street New York NY	Approved	\$0.00
49729	09A0402	Capsys Corp. 63 Flushing Avenue, Unite 240 Brooklyn NY 11205	Requested approval for use in New York City of your Modular Building Components. Model/Series Numbers: MOD 02-E1, MOD 03-E1, MOD 04-E1, MOD 05-E1, MOD 06-E1, MOD 07-E1, MOD 08-E1, MOD 09-E1, MOD 10-E1, MOD 11-E1, MOD 12-E1, MOD 13-E1, MOD 14-E1 and MOD 15-E1		Approved	\$200.00

With the stipulation that only the dwelling units are approved.