

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48318CO	07A0563CO	A.L. Electrical Corp. 307 7th Avenue, Suite 404 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	4433 Victory Boulevard, 1st Floor Staten Island NY	Denied	\$0.00
Carry over from November 14, 2007 meeting.						
48361CO	07A0633CO	Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456	Requested approval for the electric service equipment proposed to be installed	200 West 90th Street New York NY	Approved	\$0.00
Carry over from December 12, 2007 meeting. 1) Show clearer drawing of troughs, end box in routing. 2) How do you access the trough with barrier? 3) Why can't conduit be installed? Job finalized 10/27/08.						
48595CO		Crana Electric Inc. 600A East 132nd Street Bronx NY 10454	Requesting permission to install circuit breaker panels above meter banks where the height of the top of the breakers handles will be 81 inches off of the finished floor.	333 Rector Place New York NY	Denied	\$0.00
Carry over March 12, 2008 meeting. The short circuit calculations showing that the circuit breakers can be rated at 10,000 AIC where not provided as requested by the Advisory Board.						
48793CO	08A0348CO	Rothstein & Hoffman Electric Service, Inc 257 Centre Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Four Point Sheraton Hotel 66 Charlton Street New York NY	Approved	\$0.00
Carry over from June 18, 2008 meeting.						
48861CO2	08A0365CO2	Guth DeConzo Consulting Engineers, P.C. 242 West 30th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sprint Generator Reconnect 111 8th Avenue New York NY	Approved	\$0.00
Carry over from August 13, 2008 meeting.						

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48878CO	08A0382CO	Belway Electric NYC 38 East 29th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Jack Resnick & Sons 250 Hudson Street New York NY	Approved	\$0.00
Carry over from July 16, 2008 meeting.						
48913CO	08A0405CO	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	26 Broadway New York NY	Approved	\$0.00
Carry over from August 13, 2008 meeting.						
48915CO	08A0407CO	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	AT & T 811 10th Avenue New York NY	Approved	\$0.00
Carry over from August 13, 2008 meeting. Furnish coordination study. Job finalized 10/21/09.						
48921CO	08A0413CO	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	DEP English Kill Phase 1 Aeration 1106 Grand Street Brooklyn NY	Ok, but	\$0.00
Carry over from August 13, 2008 meeting. 1) Bus on load of service breaker undersized. Reduce main breaker trip 2) Service conductors undersized. Reduce main breaker size. 3) Show coordination between main and branches. 4) Provide 2nd means of egress. If main breaker reduced to 1200A frame Advisory Board rules not apply. 1 exist ok.						
48951	08A0435	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	NYU Stern School 40 West 4th Street New York NY	Hold	\$650.00
Existing feeders undersized.						

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48952	08A0436	Caruso & Sons Electrical Contracting, Inc. 1489 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Time Warner Cable 5120 Broadway New York NY	Approved	\$650.00
1) Generator breaker must be readily accessible. 2) Provide coordination study for emergency system(2-leves). Job finalized 2/20/09.						
48953	08A0437	Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Nexacor 2 Avenue of the Americas, 23rd Flo New York NY	Approved	\$650.00
48954	08A0438	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requested concept approval for	150 East 69th Street New York NY	Ok, but	\$0.00
1) Insufficient front clearance for service switchboards. 2) Service conductors from CT compartments undersized. 3) Breaker must have AIC rating for available s.c. current.						
48955	08A0439	Christopher Jon Electrical Contractors, Inc 108 Frost Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	Walgreens #10678 150 Clermont Avenue Brooklyn NY	Approved	\$650.00
Provide coordination curves and breaker settings. Job finalized 9/25/08.						
48956	08A0440	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	247 West 30th Street New York NY	Approved	\$650.00
Allow access between new service switches and meter banks to allow proper egress from room. Job finalized 9/25/08.						

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48957	08A0441	Hugh O kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Lincoln Center 140 West 65th Street New York NY	Approved	\$650.00
1) Equipment grounding conductor undersized. 2) Main switch shown backward. Job finalized 10/29/08.						
48958	08A0442	C.M.S. Electrical Services Co., Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	717 5th Avenue New York NY	Approved	\$650.00
Tap conductors feeding 200 amp disconnect switch undersized. Job finalized 11/17/08.						
48959	08A0443	A.P.E. Electrical, Inc of NY & NJ 581 Amboy Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	14 East 60th Street New York NY	Approved	\$650.00
Grounding electrode conductor and supplemental grounding conductor not on drawing. Job finalized 12/12/08.						
48960	08A0444	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	177 Ninth Avenue New York NY	Approved	\$650.00
1) Size of take off bus not provided in service switch board. 2) Bus undersized in panel MLO. Job finalized 9/24/08						
48961	08A0445	Major Electric, Inc. 19-31 Ditmars Blvd. Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	255 Fourth Avenue Brooklyn NY	Approved	\$650.00
1) Grounding and supplemental grounding conductors not on drawing. 2) Provide disconnect switch for "cable system". Job finalized 9/24/08.						

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48962	08A0446	Department of Environmental Protection 59-17 Junction Boulevard Flushing NY 11373	Requested approval for the electric service equipment proposed to be installed	Wards Island WPCP New York NY	Approved	\$650.00
48963	08A0447	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	208 West 23rd Street New York NY	Approved	\$650.00
48964	08A0448	Samson Electric Corp. 37-10 33rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	119 West 40th Street New York NY	Approved	\$650.00
48965	08A0449	Zerem Electric Corp. 3011 Avenue L Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	174 Vanderbilt Avenue Brooklyn NY	Approved	\$650.00
48966	08A0450	RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1 Tiffany Street Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48967	08A0451	Selectric Electrical Contracting Co., Inc. 78-14 46th Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	PS 57R 140 Palma Drive Staten Island NY	Approved	\$650.00
48968	08A0452	Maximum Electrical Contracting Corp. 708 Mace Avenue Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	Beth Abraham Nursing Home 612 Allerton Place Bronx NY	Approved	\$650.00
48969	08A0453	Maximum Electrical Contracting Corp. 708 Mace Avenue Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	37 West 24th Street New York NY	Approved	\$650.00
48970	08A0454	Maximum Electrical Contracting Corp. 708 Mace Avenue Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	330 West 40th Street New York NY	Approved	\$650.00
FCO shown on floor plan, not on 1-line. Is this life safety? Is generator feed required? Job finalized 9/30/08.						
48971	08A0455	Promax Electrical Contracting Corp. 112-08 101 Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	Park Lane at Seaview 460 Brielle Avenue Staten Island NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48972	08A0456	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	503-511 Broadway New York NY	Approved	\$650.00
48973	08A0457	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	150 William Street New York NY	Approval	\$650.00
1) Wire bending radius in splice box not followed in picture. 2) Are bonding locknuts being used with the chase nipples? 3) Verify that overhead pullbox contains only service entrance conductors. 4) Verify 2 C.T.'s feeding rectifier. 5) Subject to Con-Ed approval. 6) Provide service terminations listed for application. Job finalized 3/30/09.						
48974	08A0458	Al-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	1980 Jerome Avenue Bronx NY	Approved	\$650.00
48975	08A0459	Kew Electric Inc. 1428 Hylan Blvd. Staten Island NY 10305	Requested approval for the electric service equipment proposed to be installed	Brooklyn College-Boylan Hall Bedford Avenue and Campus Road Brooklyn NY	Approved	\$650.00
1) Verify fusing and bus sizes in existing service branch. Job finalized 9/24/08.						
48976	08A0460	Red Wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	49 East 73rd Street New York NY	Ok, but	\$650.00
1) Verify that power telco cabinet is listed equipment. 2) A fused disconnect switch shall be installed between generator feeders and telco cabinet receptacle.						

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48977	08A0461	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	350 West Broadway New York NY	Hold	\$650.00
Job changed. Drawings to follow.						
48978	08A0462	B & G Electl Contractors of New York 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	East River Plaza 536 East 116th Street & F.D.R. Dr. East Harlem NY	Approved	\$650.00
48979	08A0463	Sure Electrical Contracting Corp. 3836 Richmond Avenue Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	Commerce Bank 254 Canal Street New York NY	Approved	\$650.00
48980	08A0464	Bard, Rao & Athanas Consulting Engs. PC 105 Madison Avenue New York NY 10016	Requested concept approval	The NY Presbyterian Hospital New York NY	Approved	\$0.00
1) Fire pump and fire alarm feeds must be taken ahead of the 2000 amp disconnect switch or provide a positive lock on generator. 2) Full Advisory Board to follow. Job finalized 10/2/08. With the stipulation that full Advisory Board drawings are submitted for approval and the use of DLO cables may not be installed or listed for the purpose intended.						
48981	08A0465	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	156 5th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48982	08A0466	Angel Power & Light, LLC 32 East Street, suite 805 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	400 East 62nd Street New York NY	Approved	\$650.00
1) Show tap detail in trough. 2) Show size of tap conductors. 3) Verify length of tap. 4) Verify notes next to new 400 disconnect switch. Job finalized 10/3/08.						
48983	08A0467	Lan Utilities Electric Inc. 30 Conselyea Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	Ann Taylor 7 Times Square New York NY	Approved	\$650.00
48984	08A0468	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	18 East 41st Street New York NY	Approved	\$650.00
Can a second door be added to service room? Job finalized 9/24/08						
48985	08A0469	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens Gateway H.S. 160-20 Goethals Avenue Jamaica NY	Approved	\$650.00
1) Correct address in title block. 2) Panel MDP provide through bus size in last panel. 3) panel DPH provide vertical bus size. 4) Verify bus accessibility. Job finalized 9/24/08						
48986	08A0470	Dooley Electric Company, Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Staten Island University Hosp. 475 Seaview Avenue Staten Island NY	Approved	\$650.00
1) Verify that no emergency y feeders are ran through the service room to the ATS room. 2) Service room to be mechanically ventilated. 3) Transformer secondary for FACO to be bonded to building steel. 4) Provide short circuit curves from generator breaker to distribution. Job finalized 9/24/08.						

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48987	08A0471	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Silverstein Properties 120 Broadway New York NY	Approved	\$650.00
48988	08A0472	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	216 Duffield Street Brooklyn NY	Approved	\$650.00
48989	08A0473	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	880 3rd Avenue New York NY	Approved	\$650.00
48990	08A0474	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	63 West 35th Street New York NY	Approved	\$650.00
48991	08A0475	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	405 East Fordham Road Bronx NY	Approved	\$650.00
Fire pump branch circuit to be fire rated. Job finalized 9/30/08.						

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48992	08A0476	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	403 East Fordham Road Bronx NY	Approved	\$650.00
48993	08A0477	Dross Electrical Contracting Inc. 9202 Avenue M Brooklyn NY 11236	Requested approval for the electric service equipment proposed to be installed	189-02 64th Avenue Queens NY	Approved	\$650.00
48994	08A0478	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	2182 3rd Avenue New York NY	Approved	\$650.00
48995	08A0479	adley & Assoc Licensed Electl Contrs, Cor 6 East Clarke Place Bronx NY 10452	Requested approval for the electric service equipment proposed to be installed	170 East 233rd Street Bronx NY	Approved	\$650.00
48996	08A0480	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	P.S. IS 263M 202 Sherman Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48997	08A0481	Royal Electrical & Wiring Corp. 27-07 BQE West Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Atlantic Terrace S. Oxford St. and S. Portland Ave. Brooklyn NY	Approved	\$650.00
1) Short circuit calculations not provided @ 100 amp panels 2-100 amp panel fused at 200 amps. 3) RHH conductor fused at 90', undersized. 4) Provide bus size for 1600 amp service switch. 5) Cut sheets of circuit breaker panels not provided. 6) Show location of fire pump service switch. Job finalized 10/25/10.						
48998	08A0482	Allran Electric of New York 120 Broadway, 38th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	Bank of New York/Mellon 101 Barclay Street New York NY	Approved	\$650.00
48999	08A0483	Belmont Electrical Inc. 244 Fifth Avenue, Suite 2352 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	520 8th Avenue New York NY	Approved	\$650.00
1) Verify that there is 5' clearance in front of 4000 amp switch. 2) Bonding and grounding not shown on drawing. Job finalized 2/20/09.						
49000	08A0484	Kew Electric Inc. 1428 Hylan Blvd. Staten Island NY 10305	Requested approval for the electric service equipment proposed to be installed	265 Livonia Avenue Brooklyn NY	Approved	\$650.00
Provide signage on service switch "fuses not to exceed 601 amps". Job finalized 9/24/08.						
49001	08A0485	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	125 Worth Street New York NY	Hold	\$650.00
1) Verify that no emergency life safety feeders are run though the service room. 2) West service fire cut, out service entrance conductors must be tapped in c.t. 3) Remove neutral bond in FACO off of emergency side. 4) FACO on emergency side to be tapped on line side of generator switch. 5) I-line busway not approved for service conductors. Provide service busway or cable/conduit. 6) Provide FCO not disconnect switch for fire alarm feeds. 7) Confirm code-compliant terminations of MI cable. 8) Coordinate ASCO drawings with Square D drawings. 1-lines inconsistent. 9) No bus sizes or section views for ASCO switchboard.						

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49002		Triangle Electric Inc. 102-04 89th Street Ozone Park NY 11416	Requesting permission to install overhead service entrance conductors in Schedule 80 rigid non-metallic conduit due to the building being located in a corrosive are, Far Rockaway, Queens.	174 Beach 131st Street Queens NY	Approved	\$0.00
49003		B & G Electrical Contractors of New York 38-22 55th Street Woodside NY 11377	Requesting permission to install a seventh service switch where one of the service switches will provide power to a fire pump	East River Plaza 536 East 116th Street & F.D.R. Drive East Harlem NY	Approved	\$0.00
49004		United Electrical Contracting Corp. 69 Ludlow Street New York NY 10002	Requesting permission to install a seventh service switch in a building that will provide power to a fire pump where it was decided after the completion of the electrical installation that a fire pump is required due to low water pressure	59-40 55th Road Queens NY	Approved	\$0.00
49005		Ridge Electrical, Inc. 684 Richmond Road State Island NY 10304	Requesting permission to install 3 service switches on the outside of a mixed use building that will provide power for 1 doctor's office, 1 apartment and 1 PLP equipment	192 Guyon Avenue Staten Island NY	Approved	\$0.00
49006		Valmar Electric Corp. 2826 Westchester Avenue, Suite 202 Bronx NY 10461	Requesting permission to leave as installed approximately 100 fluorescent luminaires that are wired without disconnects on the line side of the ballasts	1250 Waters Pl. Bronx NY	Approved	\$350.00

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49007		Control Spec Electrical System, Inc. 30-60 Review Avenue Long Island City NY 11101	Requesting permission to leave as installed non metallic-sheathed cable as a wiring method for 3-multi family buildings that are four floors above grade	E. 120th Street New York NY	Approved	\$0.00
With the stipulation that the top duplex apartment branch circuits are arc fault protected.						
49008		Cosentini Associates Two Pennsylvania Plaza New York NY 10121	Requesting permission due to Con-Ed constructing new electrical vaults in the street in front of a construction site and lack of space to install a temp feed to the construction site, to bring in a new temp feed to 951 1st Ave. that will feed next door 959 1st Ave. where the service entrance conductors will pass through the interior of one structure and feed the construction site.	959 1st Avenue New York NY	Approved	\$0.00
49009		S.N.D. Electrical Contracting Inc. 2615 Nostrand Avenue Brooklyn NY 11210	Requesting permission to leave as installed service equipment for cell sites installed on the outside of a building not grouped together with the indoor service equipment.	138-13 Springfield Blvd. Queens NY	Approved	\$350.00
With the stipulation that signage is provided at each service indicating where the other service is located.						
49010		Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requesting permission due to lack of space in the service room to allow 1 set of 500 MCM to be tapped from the load side of a 2500 amp feeder approximately 18' to a 400 amp fused switch.	Nexacor 2 Avenue of the Americas, 23rd Floor New York NY	Approved	\$0.00
49011		Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requesting permission to allow a non-selective system feed for non-life safety loads.	AT & T 811 10th Avenue, 3rd Floor New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49012		W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requesting permission to replace one for one the interiors of one 800 and one 30 amp automatic transfer switches on an existing 1000 KVA service	Isabella Geriatric Center 515 Audubon Avenue New York NY	Approved	\$0.00
49013		ATN Electric Corp. 240-19 Jamaica Avenue Bellerose NY 11426	Requesting permission to install overhead service entrance conductors in rigid non metallic conduits	62-12 65th Street Maspeth NY	Denied	\$0.00
49014		Stat Electric, Inc. 118-21 Queens Blvd.-suite 311 Queens NY 11375	Requesting permission to leave as installed service equipment on the outside of a commercial building that will provide power to a cell site.	46-25 54th Avenue Queens NY	Approved	\$350.00
With the stipulation that signage is provided at each service indicating where the other service is located.						
49015		Red Wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requesting permission due to lack of space inside of the existing service room to install a replacement service in an adjacent room where signage is provided indicating where the other service is located	Foot Locker 226 East Fordham Road Bronx NY	Approved	\$350.00
With the stipulation that this installation complies with all the requirements to Section 110.26 and is subject field inspection.						
49016		Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456	Requesting permission to leave as installed due to a hardship to relocate service equipment that has a front clearance of 23 inches.	944 East 228 Street Bronx NY	Denied	\$350.00

ADVISORY BOARD CALENDAR

September 17, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49017	08A0486	Kimball International Inc. 1881 W. Seltice Way Post Falls ID 83854	Requested approval for use in New York City of your Hum, Minds at Work series furniture system. Mode/Series Numbers: 21Hxxxxxxx		Approved	\$200.00
When installed per NYC amendments. For commercial only.						