

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

**BOARD MEMBERS PRESENT: BOGAD, BUNK, CANGEMI, CATALANO, COLUCCIO, GOTTFRIED, LORENZ, MARCOVICI, MILLER, MONIZ, PANARIELLO, PESCATORE, PETROU, TRONGONE, XANTHOS, CHAIRMAN ZEC AND DIRECTOR MINTZ.**

- |  |                 |   |
|--|-----------------|---|
| 44291 H.P. Electrical Designs Inc.<br>321 West 44 <sup>th</sup> Street, Suite 405<br>New York, NY 10036-5404 | <b>Denied</b>   | Sub. #02A0561   |
| Requested approval for the electric service equipment proposed to be installed in the building at:           |                 | Jacob Reingold Pavilion<br>5901 Palisade Avenue<br>Bronx, NY                    |
| 44292 T & R Alarm and Electric Systems, Inc.<br>1870 Webster Avenue<br>Bronx, NY 10457                       | <b>Approved</b> | Sub. #02A0522   |
| Requested approval for the electric service equipment proposed to be installed in the building at:           |                 | Queens House of Detention<br>126-02 82 <sup>nd</sup> Avenue<br>Queens, NY       |
| 44293 James, Lasala & Associates, LLP<br>538 Broadhollow Road-Suite 2 West<br>Melville, NY 11747             | <b>Hold</b>     | Sub. #02A0563   |
| Requested approval for the electric service equipment proposed to be installed in the building at:           |                 | Industry City Associates<br>@ Bush Terminal<br>832 Third Avenue<br>Brooklyn, NY |
| 44294 Switch Electric Company Inc.<br>178 Industrial Loop<br>Staten Island, NY 10309                         | <b>Approved</b> | Sub. #02A0564   |
| Requested approval for the electric service equipment proposed to be installed in the building at:           |                 | Landmark Education<br>17 Penn Plaza<br>New York, NY                             |
| 44295 Kanta Electric Corporation<br>76-11 37 <sup>th</sup> Avenue<br>Jackson Heights, NY 11372-6602          | <b>Approved</b> | Sub. #02A0565   |
| Requested approval for the electric service equipment proposed to be installed in the building at:           |                 | George Washington H.S.<br>549 Audobon Avenue<br>New York, NY                    |
| 44296 Pinto & Teger Electric Corp.<br>32-24111 <sup>th</sup> Street<br>East Elmhurst, NY 11369               | <b>Approved</b> | Sub. #02A0566   |

Requested approval for the electric service equipment proposed to be installed in the building at:

Verizon  
11-31 46<sup>th</sup> Road  
Queens, NY

-1-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

44297 Zwicker Electric Co., Inc.  
200 Park Avenue South  
New York, NY 10003

**Approved**

Sub. #02A0567

Requested approval for the electric service equipment proposed to be installed in the building at:

776 Avenue of the Americas  
New York, NY

44298 R & L Systems, Inc.  
37-20 56<sup>th</sup> Street  
Woodside, NY 11377

**Approved**

Sub. #02A0568

Requested approval for the electric service equipment proposed to be installed in the building located at:

Hudson Square Lofts  
145 Hudson Street  
New York, NY

44299 Fox Electric, Inc.  
262 Mott Street  
New York, NY 10012

**Approved**

Sub. #02A0569

Requested approval for the electric service equipment proposed to be installed in the building located at:

Information Technology H.S.  
43-44 21<sup>st</sup> Street  
Long Island City, NY

44300 GMA Electrical Corp.  
267B McClean Avenue  
Staten Island, NY 10305

**Approved**

Sub. #02A0570

Requested approval for the electric service equipment proposed to be installed in the building located at:

Verizon  
547 Clinton Avenue  
Brooklyn, NY

44301 Inner City Electrical Contractors, Inc.  
160 21<sup>st</sup> Street  
Brooklyn, NY 11232

**Approved**

Sub. #02A0571

Requested approval for the electric service equipment proposed to be installed in the building located at:

Young & Rubicam  
285 Madison Avenue  
New York, NY

44302 Unity Electric Co., Inc.  
65-45 Fresh Meadow Lane  
Flushing, NY 11365

**Approved**

Sub. #02A0572

Requested approval for the electric  
service equipment proposed to be  
installed in the building located at:

72 Wall Street  
New York, NY

-2-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

44303 Jata Electrical Construction Corp.  
2 West 46<sup>th</sup> Street-Suite 706  
New York, NY 10036

**Approved**

Sub. #02A0573

Requested approval for the electric  
service equipment proposed to be  
installed in the building located at:

151 West 46<sup>th</sup> Street  
New York, NY

44304 Allran Electric of New York Inc.  
88-25 138<sup>th</sup> Street  
Jamaica, NY 11435

**Approved**

Sub. #02A0574

Requested approval for the electric  
service equipment proposed to be  
installed in the building located at:

Pret-A-Vivre/Alex Hotel  
205-209 East 45<sup>th</sup> Street  
New York, NY

44305 Roz-A-Lite Electrical Contracting, Inc.  
163 20<sup>th</sup> Street  
Brooklyn, NY 11232

**Hold**

Sub. #02A0575

Requested approval for the electric  
service equipment proposed to be  
installed in the building located at:

15 Cliff Street  
New York, NY

44306 Heller Electric Co.  
1688 47<sup>th</sup> Street  
Brooklyn, NY 11204

**Approved**

Sub. #02A0576

Requested approval for the electric  
service equipment proposed to be  
installed in the building located at:

55 Washington Street  
Brooklyn, NY

44307 Fervent Electric Co.  
111 3<sup>rd</sup> Street  
Brooklyn, NY 11231

**Approved**

Sub. #02A0588

Requested approval for the electric service equipment proposed to be installed in the building located at:

Hughes Apartments Building #2  
315 Sutter Avenue  
Brooklyn, NY

44308 Robert-Allen Associates  
37-36 61<sup>st</sup> Street  
Woodside, NY 11377

**Denied**

Sub. #02A0589

Requested approval for the electric service equipment proposed to be installed in the building located at:

136-26 37<sup>th</sup> Street  
Flushing, NY

-3-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

44309 Olympic Electrical Wiring Corp.  
133 50<sup>th</sup> Street  
Brooklyn, NY 11232

**Ok**

Sub. #02A0609

**Revision Pending**

Requested approval for the electric service equipment proposed to be installed in the building at:

NYCHA-Metro North Plaza  
305 East 101<sup>st</sup> Street  
New York, NY

44310 Lowy & Donnath, Inc.  
10-37 49<sup>th</sup> Avenue  
Long Island City, NY 11101

**Approved**

Sub. #02A0577

Requested approval for the electric service equipment proposed to be installed in the building located at:

Memorial Sloan Kettering Cancer Ctr.  
1275 York Avenue  
New York, NY

44311 R. Donovan & Son Electric Co. Inc.  
198-08 33<sup>rd</sup> Avenue  
Flushing, NY 11358

**Approved**

Sub. #02A0578

Requested approval for the electric service equipment proposed to be installed in the building located at:

Concord Village  
175 Adams Street  
Brooklyn, NY

44312 R. Donovan & Son Electric Co. Inc.  
198-08 33<sup>rd</sup> Avenue  
Flushing, NY 11358

**Approved**

Sub. #02A0579

Requested approval for the electric service equipment proposed to be installed in the building located at:

Concord Village  
230 Jay Street  
Brooklyn, NY

- 44313 R. Donovan & Son Electric Co. Inc.  
198-08 33<sup>rd</sup> Avenue  
Flushing, NY 11358 **Approved** Sub. #02A0580
- Requested approval for the electric service equipment proposed to be installed in the building located at: Concord Village  
215 Adams Street  
Brooklyn, NY
- 44314 Mazza Electric Corp.  
494 Eighth Avenue-6<sup>th</sup> Avenue  
New York, NY 10001 **Approved** Sub. #02A0581
- Requested approval for the electric service equipment proposed to be installed in the building located at: 132 West 21<sup>st</sup> Street-Bsmt.  
New York, NY

-4-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

- 44315 Qncc Electrical Contracting Corp.  
86-40 122<sup>nd</sup> Street  
Richmond Hill, NY 11418 **Hold** Sub. #02A0582
- Requested approval for the electric service equipment proposed to be installed in the building located at: Jacobi Medical Center  
1400 Pelham Parkway South  
Bronx, NY
- 44316 Forest Electric Corp.  
Two Penn Plaza  
New York, NY 10121 **Approved** Sub. #02A0583
- Requested approval for the electric service equipment proposed to be installed in the building located at: Brause Infil Building  
27-01 Bridge Plaza North  
Long Island City, NY
- 44317 Forest Electric Corp.  
Two Penn Plaza  
New York, NY 10121 **Hold** Sub. #02A0584
- Requested approval for the electric service equipment proposed to be installed in the building located at: Brown Brothers Harriman  
140 Broadway  
New York, NY
- 44318 Forest Electric Corp.  
Two Penn Plaza  
New York, NY 10121 **Approved** Sub. #02A0585

Requested approval for the electric service equipment proposed to be installed in the building located at:

Prudential Financial Signage  
3 Times Square  
New York, NY

44319 Forest Electric Corp.  
Two Penn Plaza  
New York, NY 10121

**Approved**

Sub. #02A0586

Requested approval for the electric service equipment proposed to be installed in the building located at:

West Services Distribution  
111 8<sup>th</sup> Avenue  
New York, NY

44320 Robco Electric Corp.  
2630 Chesbrough Avenue  
Bronx, NY 10461

**Approved**

Sub. #02A0587

Requested approval for the electric service equipment proposed to be installed in the building located at:

Footlocker  
150 East 42<sup>nd</sup> Street  
New York, NY

-5-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

44321 J.A. Lee Electric  
10-87 47<sup>th</sup> Road  
Long Island City, NY 11101

**Approved**

Sub. #02A0590

Requested approval for the electric service equipment proposed to be installed in the building located at:

560 Broadway  
New York, NY

44322 J.A. Lee Electric  
10-87 47<sup>th</sup> Road  
Long Island City, NY 11101

**Approved**

Sub. #02A0591

Requested approval for the electric service equipment proposed to be installed in the building located at:

500 10<sup>th</sup> Avenue  
New York, NY

44323 G.S.H. Electric Inc.  
491 East 166<sup>th</sup> Street  
Bronx, NY 10456

**Approved**

Sub. #02A0592

Requested approval for the electric service equipment proposed to be installed in the building located at:

I.S. 278(K)  
1925 Stuart Street  
Brooklyn, NY

44324 Commercial Electrical Contractors, Inc.  
10-28 47<sup>th</sup> Avenue  
Long Island City, NY 11101      **Approved**

Requested approval for the electric  
service equipment proposed to be  
installed in the building located at:

Sub. #02A0593

599 Lexington Avenue  
New York, NY

44325 Five Star Electric Corp.  
101-32 101<sup>st</sup> Street  
Ozone Park, NY 11416-2616      **Approved**

Requested approval for the electric  
service equipment proposed to be  
installed in the building located at:

Sub. #02A0594

NYU School of Law  
89 West 3<sup>rd</sup> Street  
New York, NY

44326 Knight Electrical Services Corp.  
111 Eighth Avenue  
New York, NY 10011-5298      **Approved**

Requested approval for the electric  
service equipment proposed to be  
installed in the building located at:

Sub. #02A0595

North Fork Bank  
424 Madison Avenue  
New York, NY

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

- |  |                 |   |
|--|-----------------|---|
| 44327 Sage Electrical Contracting<br>651 Willowbrook Road, Suite 201<br>Staten Island, NY 10314            | <b>Approved</b> | Sub. #02A0596   |
| Requested approval for the electric service equipment proposed to be installed in the building located at: |                 | 340 Madison Avenue<br>New York, NY  |
| 44328 June Electric Corp.<br>11-19 49 <sup>th</sup> Avenue<br>Long Island City, NY 11101                   | <b>Approved</b> | Sub. #02A0597   |
| Requested approval for the electric service equipment proposed to be installed in the building located at: |                 | St. Barnabas Hospital<br>Ambulatory Care<br>182 <sup>nd</sup> St. & 3 <sup>rd</sup> Avenue<br>Bronx, NY |
| 44329 Donald McGeachy Inc.<br>957 Park Avenue<br>New York, NY 10028  | <b>Approved</b> | Sub. #02A0598   |
| Requested approval for the electric service equipment proposed to be installed in the building located at: |                 | 24 5 <sup>th</sup> Avenue<br>New York, NY   |
| 44330 Fred Geller Electrical, Inc.<br>36-26 31 <sup>st</sup> Street<br>Long Island City, NY 11106          | <b>Approved</b> | Sub. #02A0599   |
| Requested approval for the electric service equipment proposed to be installed in the building located at: |                 | 32 Avenue of the Americas<br>New York, NY   |
| 44331 Michael Schondorf, Inc.<br>450 West 31 <sup>st</sup> Street<br>New York, NY 10001                    | <b>Approved</b> | Sub. #02A0600   |
| Requested approval for the electric service equipment proposed to be installed in the building located at: |                 | Chelsea Market<br>75 9 <sup>th</sup> Avenue<br>New York, NY   |
| 44332 Venus Electrical Contractors, Inc.<br>34-14 Crescent Street<br>Astoria, NY 11106                     | <b>Approved</b> | Sub. #02A0601   |
| Requested approval for the electric service equipment proposed to be installed in the building located at: |                 | P.S. 124<br>129-15 150 <sup>th</sup> Avenue<br>Ozone Park, NY   |

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

- 44333 Alom Electrical Co., Inc. Sub. #02A0602  
148 22<sup>nd</sup> Street  
Brooklyn, NY 11232 **Approved**
- Requested approval for the electric service equipment proposed to be installed in the building located at: 131 Spring Street  
New York, NY
- 44334 M.O.S. Electrical Contracting Corp. Sub. #02A0603  
4340B Katonah Avenue  
Bronx, NY 10470 **Approved**
- Requested approval for the electric service equipment proposed to be installed in the building located at: 240 East 39<sup>th</sup> Street  
New York, NY
- 44335 Action Light & Power, Inc. Sub. #02A0604  
106 North 6<sup>th</sup> Street  
Brooklyn, NY 11211 **Approved**
- Requested approval for the electric service equipment proposed to be installed in the building located at: 700 Pacific Street  
Brooklyn, NY
- 44336 S.J. Electric, Inc. Sub. #02A0605  
601 Union Street  
Brooklyn, NY 11215 **Approved**
- Requested approval for the electric service equipment proposed to be installed in the building located at: 39 West 33<sup>rd</sup> Street  
New York, NY
- 44337 Ramdeen's Electrical Contracting Corporation Sub. #02A0606  
132-10A Liberty Avenue  
Richmond Hill, NY 11419 **Approved**
- Requested approval for the electric service equipment proposed to be installed in the building located at: 88 9<sup>th</sup> Avenue  
New York, NY

44338 Citi-Wide Electrical Corp.  
1702 8<sup>th</sup> Avenue  
Brooklyn, NY 11215

**Approved**

Sub. #02A0607

Requested approval for the electric service equipment proposed to be installed in the building located at:

Harlem Heath Center  
133 Morningside Avenue  
New York, NY

-8-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

44339 K & R Electric Co., Inc.  
638 Sharrotts Road  
Staten Island, NY 10309

**Approved**

Sub. #02A0608

Requested approval for the electric service equipment proposed to be installed in the building located at:

40 Oceana Terrace Building "O"  
Brooklyn, NY

44340 A.J. Caruso Electrical, Inc.  
684 Richmond Road  
Staten Island, NY 10304

**Approved**

Requesting permission to leave as installed the switch in a raintight enclosure for the sewer ejector pump, in a building located at:

30 Leewood Loop  
Staten Island, NY

44341 Vulpis Eastin Electric Company, Inc.  
76 Court Street  
Brooklyn, NY 11201

**Approved**

Requesting permission to install Schedule 80 PVC conduit underground with galvanized elbows and stub ups, in a building located at:

214 East 135<sup>th</sup> Street  
Bronx, NY

44342 Dello Russo Electric, Inc.  
3211 Richmond Road  
Staten Island, NY 10306

**Approved-with signage**

Requesting permission to leave as installed two one hundred amp main disconnect switches, in the first floor owners apt and in the basement tenants apt, for a one family home that was converted into a legal two family home, with no common area, in a building located at:

177 Mayberry Promenade  
Staten Island, NY

44343 Glen Oaks Electrical, Inc.

219-51 Jamaica Avenue  
Queens Village, NY 11428

**Approved**

Requesting permission to use Schedule 80 PVC conduit for a branch circuit imbedded in concrete, where stub-ups will be galvanized conduit, with a proper sized grounding wire in all conduits, at a parking lot located at:

56-256 68<sup>th</sup> Street  
Maspeth, NY

-9-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

44344 North Point Electrical Corporation of NY & NJ  
651 Bay Street  
Staten Island, NY 10304

**Approved**

Requesting permission to use Schedule 40 PVC conduit in soil 20" deep for a 120/208V service as per attached sketch in a building located at:

NYC Parks & Recreation Nature Ctr.  
700 Rockland Avenue  
Staten Island, NY

44345 Five Star Electric Corp.  
101-32 101<sup>st</sup> Street  
Ozone Park, NY 11416-2616

**Approved**

Requesting a one time, one location permission to install "MC Cable" in the auditorium, stage and dressing room, in a building located at:

NYU Kimmel  
566 LaGuardia Place  
New York, NY

44346 Positive Electro Mech. Corp. d/b/a P.E. Electrical Cont'g Co.  
1131 39<sup>th</sup> Street  
Brooklyn, NY 11218

**Approved-with signage**

Requesting permission to leave as installed two service switches, approximately ten feet apart that are not grouped together in the same room due to space restrictions, as per submitted sketch and photos, in a building located at:

230 West 48<sup>th</sup> Street  
New York, NY

44347 MDM Consulting Engineers  
65 Bleecker Street  
New York, NY 10012

**Approved**

Requesting permission for an Advisory Board approved job (Cal. #44278) over 1000 KVA, where a double five foot 2 hours fire rated door cannot be provided, to create

a two hour fire rated room around the combination service end box/current transformer, with a three foot clearance, as per submitted sketch, in a building located at:

275 Atlantic Avenue  
Brooklyn, NY

44348 Aarco Electric Inc  
5902 Avenue N  
Brooklyn, NY 11234

**Approved**

Requesting special permission to relocate one existing service switch for an existing fire pump, into the fire room which is adjacent to the service switch room, in a building located at:

Surfside Manor  
9502 Rockaway Beach Blvd.  
Rockaway Beach, NY

-10-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

44349 Ohr Chodosh Electrical Contracting, Inc.  
979 East 35<sup>th</sup> Street  
Brooklyn, NY 11210

**Approved**

Requesting permission to leave installed two circuit breaker panels installed approximately 38" off of the finished floor in a garage, as per submitted photos, in a building located at:

5116 17<sup>th</sup> Avenue  
Brooklyn, NY

44350 Fertitta Electrical Contracting, Inc.  
112 St. Marys Avenue  
Staten Island, NY 10305

**Approved**

Requesting permission to leave installed five combination panels with service switches that are not grouped together, where there is no common area, as per submitted sketch, in a building located at:

1890 Richmond Terrace  
Staten Island, NY

44351 Dorion Norton Electrical Contracting Corp.  
218 Clifton Place  
New York, NY 11216

**Approved**

Requesting permission to leave as installed 20 ampere circuit breakers on all lighting circuits through-out a five family building located at:

44 West 106<sup>th</sup> Street  
New York, NY

44352 Matros Automated Electrical Construction Corp.

214 West 29<sup>th</sup> Street  
New York, NY 10001

**Approved**

Requesting permission for concept approval of a common riser where two sets of 350 MCM fused at 500 amps will feed three circuit breaker panels on the 9<sup>th</sup>, 10<sup>th</sup>, and 11<sup>th</sup> floors, as per schematic, in a building located at:

San Carlos Hotel  
150 East 50<sup>th</sup> Street  
New York, NY

44353 A.T.J. Electrical Co., Inc.  
33-61 55<sup>th</sup> Street  
Woodside, NY 11377

**Approved**

Requesting permission not to file Advisory Board drawings for the installation of a 100 amp exit and emergency light switch, that is tapped from line side of a 2000 amp TV studio service switch at the WNYE-TV facility located at:

112 Tillary Street  
Brooklyn, NY

-11-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

44354 Solar Electric Systems Inc.  
452 West 55<sup>th</sup> Street  
New York, NY 10019

**Denied**

Requesting permission not to encase a portion of a fire pump feeder ( approximately 25 feet) in a concrete, that will be run through a corridor constructed of masonry wall and concrete floor and ceiling, as per submitted drawings, in a building located at:

300 East 77<sup>th</sup> Street  
New York, NY

44355 EE Linden Associates, Inc.  
110 Richards Avenue, North Wing  
Norwalk, CT 08654

**Hold**

Requesting permission to use an existing cellular metal under floor raceway having no splices and to be covered with a marble floor, in a building located at:

767 5<sup>th</sup> Avenue  
New York, NY

44356 Litelab Corp.  
251 Elm Street  
Buffalo, NY 14203-1675

**Hold**

Requesting a one time special permission to modify Advisory Board approved (Cal. #40681, 41704) fixtures

with the addition of a battery system form an Advisory Board approved emergency fixture (Cal. #41411) to provide emergency lighting, as per submitted specifications and photos, in a building located at:

663-665 Fifth Avenue  
New York, NY

44357 Jen Electrical Contractors, Inc.  
7812 New Utrecht Avenue  
Brooklyn, NY 11214

**Hold**

Requesting permission to replace a 37.5 KVA, 208/600V step-up transformer with a 75 KVA, 208V/600V transformer with a tap to a 37.5 KVA transformer at the mausoleum to feed the 100 amp breaker panel, as per submitted specifications and one-line diagram, in a garage building located at:

Evergreen Cemetery  
Brooklyn, NY

44358 New York City School Construction Authority  
30-30 Thomson Avenue  
Long Island City, NY 11101-3045

**Denied**

Requested permission to inject waterproofing cement into galvanized rigid conduit after draining out all the water, due to a high water level in the area conductors will be megga-tested and replaced as needed, as per submitted Fuko hose waterproofing literature, in a building located at:

Intermediate School 5  
50-40 Jacobs Street  
Queens, NY

-12-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

44359 Lawless & Mangione Architects & Engineers, LLP  
480 North Broadway  
Yonkers, NY 10701-1945

**Denied**

Requesting permission to run new low voltage, copper cables for a building intercom system, from each intercom device (e.g. vestibule, lobby, etc.) into the electrical room and splice these cables to the existing fiber optic cables within the electric room, in a housing complex located at:

Mutual Redevelopment Houses  
321 Eighth Avenue  
New York, NY

44360 Flack + Kurtz Inc.  
475 Fifth Avenue  
New York, NY 10017

**Hold**

Requesting a one time, one location permission to replace all existing underground direct buried PVC lighting conduits and direct PVC electrical feeder, serving a remote building site, with type VF cable, direct buried in a serpentine manner, in a trench protected with pressure treated wood planks and electrical tape, as per submitted specifications and sketch,

One NY Times Plaza

in a building located at:

Queens, NY

44361 ColeHaan  
One Cole Haan Drive  
Yarmouth, MN 04096

**Approved**

Requesting permission to run communications cabling between floors 19-20 through existing telephone riser/electrical closets as per submitted specifications closet detail drawing, and floor diagram, in a building located at:

680 Fifth Avenue  
New York, NY

44362 Herman Miller, Inc.  
855 E. Main Avenue-P.O. Box 302  
Zeeland, MI 49464-0302

**Approved**

Sub. #02A0535

Requested approval for use in New York City of your Electrical Distribution Accessories for Office Furnishings. Model No. R1341 and R1351 Series.

44363 Byrne Electrical Specialists, Inc.  
320 Byrne Industrial Drive  
Rockford, MI 49341

**Approved**

Sub. #02A0536

Requested approval for use in New York City of your Multi-Outlet Assembly. Model BE48113-X-X-XX.

-13-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

44364 Byrne Electrical Specialists, Inc.  
320 Byrne Industrial Drive  
Rockford, MI 49341

**Approved**

Sub. #02A0537

Requested approval for use in New York City of your Multi-Outlet Assembly. Model BEO1578-X-XX.

44365 R.W. Swarens Assoc., Inc.  
10768 Lower Azusa Road  
El Monte, CA 91731

**Approved**

Sub. #02A0538

Requested approval for use in New York City of your VT Series Light Fixtures. Model Nos. 240 BXVT.

44366 Lightolier, a Genlyte Thomas Group, LLC

Sub. #02A0539

631 Airport Road  
Fall River, MA 02720

**Approved**

Requested approval for use in New York City of your  
Recessed Fluorescent Luminaries (Fixtures), Series "Matrix".

44367 Brightline  
33-4 McGovern Boulevard  
Crescent, PA 15046

Sub. #02A0540

**Approved**

Requested approval for use in New York City of your  
Brightline Light Fixtures. Series One Surface Mounted  
Studio Lights and T-Series Ceiling-Recessed Conferencing  
Lights.

44368 Steelcase Inc.  
901 44<sup>th</sup> Street SE.  
Grand Rapids, MI 49508

Sub. #02A0546

**Approved**

Requested approval for use in New York City of your  
Technology Hub Series: BPHPH and BTHPH.

44369 U.L. Lighting Fixtures Corp.  
34-43 10<sup>th</sup> Street  
Long Island City, NY 11106

Sub. #02A0547

**Approved**

Requested approval for use in New York City of your  
Linear Fluorescent Fixture. Model: KDS-1-48.

-14-

**ADVISORY BOARD CALENDAR  
SEPTEMBER 18, 2002**

44370 U.L. Lighting Fixtures Corp.  
34-43 10<sup>th</sup> Street  
Long Island City, NY 11106

Sub. #02A0548

**Approved**

Requested approval for use in New York City of your  
Recessed Fluorescent Fixtures. Model No. STLP22.

44371 U.L. Lighting Fixtures Corp.  
34-43 10<sup>th</sup> Street  
Long Island City, NY 11106

Sub. #02A0549

**Approved**

Requested approval for use in New York City of your

Linear Fluorescent Fixtures. Model No. WI-3-32-48-EO-1-SR.

44372 U.L. Lighting Fixtures Corp. Sub. #02A0550  
34-43 10<sup>th</sup> Street  
Long Island City, NY 11106 **Approved**

Requested approval for use in New York City of your  
Linear Fluorescent Fixtures. Model No. WP-4-48.

44373 Alkco Lighting Sub. #02A0551  
11500 Melrose Avenue  
Franklen Park, IL 60131 **Hold**

Requested approval for use in New York City of your  
Incandescent Undercabinet Systems. Series No.  
"Halogen 120" Series.

44374 Alkco Lighting Sub. #02A0552  
11500 Melrose Avenue  
Franklen Park, IL 60131 **Hold**

Requested approval for use in New York City of your  
Incandescent Undercabinet Light. Xenix Series.

44375 E-Lite Technologies, Inc. Sub. #02A0553  
2285 Reservoir Avenue  
Trumbull, CT 06611 **Hold**

Requested approval for use in New York City of your  
Lamp and Power Supply.

44376 Mono-Systems, Inc. Sub. #002A0554  
4 International Drive  
Rye Brook, NY 10573 **Hold**

Requested approval for use in New York City of your  
Surface Raceway.

-15-

**ADVISORY BOARD CALENDAR  
SEPTMEBER 18, 2002**

44377 Rocbestos Surprenant Cable Corporation Sub. #02A0556  
172 Sterling Street  
Clinton, MA 01510 **Hold**

Requested approval for use in New York City of your  
RSCC2700 Series Heating Cable/ThermaLin-X

44378 Dual-Lite Inc. Sub. #02A0557  
60 Fieldstone Court  
Cheshire, CT 06410 **Approved**

Requested approval for use in New York City of your Dual-Lite SEMPRA™ Series Cast Aluminum LED Exit Signs,

44379 Cutler Hammer Sub. #02A0560  
2256 29<sup>th</sup> St. NE  
Calgary, AB T1Y7G4 Canada **Approved**

Requested approval for use in New York City of your Transient Voltage Surge Suppression Devices CH Visor CPS Series.

44380 Comverge Technologies Inc. Sub. #02A0610  
23 Vreeland Road  
Florham Park, NJ 07923 **Hold**

Requested approval for use in New York City of your Residential Network Meter with Integral Electronic Data Collection.

44381 Comverge Technologies Inc. Sub. #02A0611  
23 Vreeland Road  
Florham Park, NJ 07923 **Hold**

Requested approval for use in New York City of your Residential Network Meter with Integral Electronic Data Collection.

44382 K & R Electric Co., Inc. **Approved**  
638 Sharrotts Road  
Staten Island, NY 10309

Requesting permission to install Schedule 40 PVC conduit in the slab for branch circuit wiring for the floor outlets, in a building located at:

Chuck E. Cheese  
1816 E. Gunhill Road  
Bronx, NY

-16-

**ADVISORY BOARD CALENDAR  
SEPTMEBER 18, 2002**

**Carry-overs:**

**Cal. #            Original Meeting Date            Disposition**

44106	(6/12/02-Equipment)	Approved
44152	(7/3/02-Service)	Approved
44192	(7/17/02-Service)	Approved
44227	(8/7/02-Equipment)	Approved
44234	(8/14/02-Service)	Approved
44243	(8/14/02-Service)	Approved
44281	(8/14/02-Special Permission)	Approved
44282	(8/14/02-Special Permission)	Approved
44283	(8/14/02-Special Permission)	Approved

Note-Advisory Board approvals are specific to the condition and specification detailed in the request and should not be construed as precedent for other installations.