



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 100-99-M Vol. 6

Manufacturer: Hilti, Inc., 5400 S. 122 E. Avenue, Tulsa, OK 74146

Trade Name(s): Hilti

Product: Fill, void or cavity material for fire protection

Pertinent Code Section(s): 27-345

Prescribed Test(s): UL 2079, FS 5-19 (ASTM E814)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File R12340

Description: Fill, void or cavity material for fire-rated construction joints. The Hilti CP 606 Flexible Firestop Sealant shall be applied in accordance with Underwriters Laboratories, Inc. system number listed below in achieving the required fire resistance ratings.

System No.	Fire Protection Ratings (HR)	
	F	T
CAJ1149	2	0
CAJ1150	3	0
CAJ1151	2	0
CAJ1152	2	0
CAJ1158	2	0
CAJ1177	2	0
CAJ 1372	3	0
CAJ1435	2	1/4
CAJ1453	2	1/4
CAJ1517	2	0

System No.	Fire Protection Ratings (HR)	
	F	T
CAJ2094	2	0
CAJ2110	3	0
CAJ3070	3	0
CAJ3181	3	0
CAJ5048	2	2
CAJ5265	2	0, 1/2
CAJ7051	3	1
CAJ7084	2	0
FA2025	2	2
FC0002	1, 2	1, 2
FC1009	1, 2	1, 2
FC1096	1	1
FC1106	1	1/4
FC1134	1	0
FC2242	1	3/4
FC2262	1	1
FC2263	1	3/4
FC3071	1	1
FC3074	1	1
FC5065	1	3/4
FC5066	1	1
FC7025	1	0
FC8032	1	1/4
WJ1124	2	0
WJ1128	2	0
WJ1191	1	0
WJ3060	2	0
WJ5134	2	1
WJ7001	1	0
WJ7021	1, 2	0
WJ7022	1, 2	0
WJ7085	2	1/2
WL1170	1, 2	0
WL1290	1, 2	0
WL1297	2	0
WL1304	1, 2	0
WL1389	1	0
WL3065	1, 2	0
WL5257	1, 2	0, 1
WL7003	1	0
WL7040	1, 2	0
WL7042	1, 2	0
WL7130	1, 2	0
WL7143	1, 2	0, 1/2
BWS0001	1, 2	1, 2
BWS0002	1, 2	1, 2
FFD0052	2	2
FFD0055	3	3

System No.	Fire Protection Ratings (HR)	
	F	T
FFD1012	2	2
FWD0041	2	2
FWD0042	3	3
FWD1012	2	2
FWD1043	2	2
HWD0045	1, 2	1, 2
HWD0077	1, 2	1, 2
HWD0081	2	2
HWD0083	1, 2	1, 2
HWD0085	1, 2	1, 2
HWD0154	1, 2	1, 2
HWD0155	2	2
HWD0184	1, 2	1, 2
HWD0209	1, 2	1, 2
HWD0225	2	2
HWD0268	2	2
HWD0324	1, 2	1, 2
HWD0342	2	2
HWD0396	1, 2	1, 2
HWD0403	3	3
HWD1009	2	2
HWS0054	1, 2	1, 2
HWS0055	1, 2	1, 2
WWD0032	2	2
WWD0040	1, 2	1, 2
WWD0046	3	3
WWD1012	2	2
WWS0042	2	2
WWS0048	1, 2	1, 2

Terms and Conditions: The above-described fill, void or cavity material, used to fill the remaining voids in wall assemblies with the above-described fire protection rating is accepted with the following conditions:

1. Electrical trays, cables, mechanical piping or ductwork passing through the assembly, be installed in accordance with the manufacturer's application instruction.
2. Suitable support angles and fasteners are required for respective assemblies shall be provided in accordance with manufacturer's recommendations.
3. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance September 25, 2008

Examined By Sun Derkinder