

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 101-05-E

Report of Material and Equipment Acceptance Division

Manufacturer – Aspen Industries, Inc., 480 Club Drive, Bensville, IL 60106.

Trade Name – Aspen Industries.

Product – Gas fired vented decorative fireplace appliance.

Pertinent Code Section(s) – 27-800, RS 14-2 (ANSI Z223).

Prescribed Test(s) - RS 14-6 (ANSI Z21.50).

Laboratories – CSA International.

Test Reports – No. 1477123, dated December 15, 2004.

Description – Gas fired decorative fireplace appliance design to provide supplemental heating and to enhance the aesthetics of a room. All of the below units are equipped with electric ignition.

Model “Royal”; type: Insert; 28,000 BTU/H Valve at High and 19,000 BTU/H valve at low. For use with natural gas.

Model “Royal ZC”; type: Recessed; 21,500 BTU/H Valve at High and 19,000 BTU/H valve at low. For use with natural gas.

Recommendation - That the above described gas fired vented appliance be accepted for decorative heating operation on natural gas only, for indoor installation only with combustible air and required ventilation air provided. Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag permanently affixed to the units and suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 4/27/05

Examined by Superior