

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46549CO1	05A0364CO1	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Newtown Creek WPCP 31E Greepoint Avenue Brooklyn NY	Approved	\$0.00
Carry over from September 14, 2005 meeting.						
46646CO	05A0479CO	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	Mersereau Pumping Station Mersereau Avenue Staten Island NY	Approved	\$650.00
Carry over from September 14, 2005 meeting.						
46665CO	05A0444CO	Associated Electrical Contrs of NY, Inc. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	184-10 Jamaica Avenue West Hollis NY	Approved	\$0.00
Carry over from September 14, 2005 meeting.						
46669CO	05A0445CO	Matros Automated Electl Constn Corp. 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	80 Broad Street New York NY	Approved	\$0.00
Carry over from September 14, 2005 meeting.						
46688	05A0485	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	One Bryant Park New York NY	Approved	\$650.00
1) Provide reduced neutral calculations. 2) Provide explanation for lack of coordination on DS-MBP-1, DS-MBP-2 3) Provide explanation for lack of coordination on 3000A SW on DS-CEMA and DS-CEMB. 4) Explain operating sequence on DS-LB to prevent connection of multiple supply feeders.						

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46689	05A0486	Konsker Electric Corp. 32-15 36th Avenue Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	King Harbor Medical Center 2000 East Gun Hill Road Bronx NY	Approved	\$650.00
Verify if cables ar Con-Ed or not.						
46690	05A0487	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Albert Einstein College of Med. 1301 Morris Park Avenue Bronx NY	Approved	\$650.00
1) Lower fuse on generator from 3200 to next lower size. 2) Coordination Study. 3) TVSS service rated disconnect.						
46691	05A0488	Robert Garcia Electrical Contracting Corp. 500 Trinity Avenue, Suite 1-B Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	216 East 99th Street New York NY	Denied	\$650.00
The drawings were not submitted in proper Advisory Board rules.						
46692	05A0489	Judd Electric, Inc. 327 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	1441 Broadway New York NY	Approved	\$650.00
46693	05A0490	Urban Power & Lighting Inc. 24-42 49th Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	330 Adams Street Brooklyn NY	Denied	\$650.00
1) Cut sheets of ATS switches were not provided. 2) The sets of conductors and conduits are not clear. 3) Service switches are not properly identified by numbers and amperage. 4)Neutrals not bonded to enclosures in the service switches. 5) Conductors feeding the fire pump are not clear. 6) Verify the 400 amp feeder to the 800 HCP panelboard. 7) The FRN fuses do not coordinate with the BPS fuses in switchboard MSB-SB-AW-B. 8) The feeders from the generator to the 1600 amp panelboard are undersized.						

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46694	05A0491	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Apple Bank 2112 Broadway New York NY	Denied	\$650.00
<p>1) The full load amperage of the fire pump was not provided. 2) They fire pump switch was not properly identified. 3) The neutral in the fire pump service switch is not bonded to the enclosure. 4)The fuse types in the new switchboards were not provided. 5) The 600 amp fuse in the MDP switchboard does not coordinate with the 800 amp fuse. 6) There are more than 6 services switches, special permission is required.</p>						
46695	05A0492	Falcon Electrical Contracting Corp. 159 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Home Depot 27-50 Veterans Road West Staten Island NY	Approved	\$650.00
46696	05A0493	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	245 West 29th Street New York NY	Approved	\$650.00
46697	05A0494	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Pathmark 42-02 Northern Boulevard Long Island City NY	Approved	\$650.00
46698	05A0495	A.J. Ianni Electrical Contractor 1402 B Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	51 Junius Street Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46699	05A0496	Energy Concepts Engineering, P.C. 3445 Winton Place, Suite 102 Rochester NY 14623	Requested approval for the electric service equipment proposed to be installed	Silvercrest Nursing Home 144-45 87th Avenue Queens NY	Approved	\$650.00
1) Remove neutral ground on utility side of Y-Y XFMR. 2) Provide method of tripping induction generators when 4000A ATS goes to emergency. 3) Provide warning sign that fuses may be energize by backfeed on 1200A BPS. 4) Locate life safety ATS outside service room. 5) Provide full submission of co-gen units.						
46700	05A0497	Dooley Electric Company, Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Hospital of Queens 56-45 Main Street Flushing NY	Approved	\$650.00
46701	05A0498	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	543 West 110th Street New York NY	Approved	\$650.00
46702	05A0499	Pabst Electric Company Incorporated 45-48 51st Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	160 Water Street New York NY	Approved	\$650.00
46703	05A0500	R.S. Covello 51-20 35th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2205 Richmond Ave.-Bldg. 'A' Staten Island NY	Approved	\$650.00
Confirm cable taps connects to both sets of supply feeders.						

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46704	05A0501	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	10 Barclay Street New York NY	Approved	\$650.00
46705	05A0502	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral NY 11011	Requested approval for the electric service equipment proposed to be installed	AT & T/Cingular 58-12 Queens Boulevard Maspeth NY	Approved	\$650.00
46706	05A0503	Dooley Electric Co., Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	St. Barnabas Hospital 183 Street & Third Avenue Bronx NY	Approved	\$650.00
46707	05A0504	Thorn Electric Inc. 322 East 117th Street New York NY 10035	Requested approval for the electric service equipment proposed to be installed	James Madison High School 3787 Bedford Avenue Brooklyn NY	Approved	\$650.00
46708	05A0505	I. & R. Electr Contrg and Repair Serv. Inc 149 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	175 East Broadway Brooklyn NY	Ok, but	\$650.00

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46709	05A0506	Dynamic Electric Service Inc. 14-17 110th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	419 Park Avenue South New York NY	Approved	\$650.00
46710	05A0507	Alco Electric, LLC 5790 Broadway Bronx NY 10463	Requested approval for the electric service equipment proposed to be installed	180-190 72nd Street Brooklyn NY	Approved	\$650.00
46711	05A0508	Alco Electric, LLC 5790 Broadway Bronx NY 10463	Requested approval for the electric service equipment proposed to be installed	181-191 73rd Street Brooklyn NY	Approved	\$650.00
46712	05A0509	Stonehill Electric Corp. 33-00 Northern Blvd.-Lobby Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	15 West 37th Street New York NY	Approved	\$650.00
46713	05A0510	Vintage Electric Corp. 4620 Flatlands Avenue Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	400 West 55th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46714	05A0511	Hester Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	132-03 Sanford Avenue Flushing NY	Approved	\$650.00
46715	05A0512	R. Gunzer Inc. 36-08 34th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	76 Madison Avenue New York NY	Approved	\$650.00
46716	05A0513	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	390 5th Avenue New York NY	Approved	\$650.00
46717	05A0514	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	75 Broad Street New York NY	Approved	\$650.00
46718	05A0515	SecureCom Electric 22-26 College Point Blvd. College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	239 Central Park West New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46719	05A0516	PJZ Maintenance Corp. 151-01 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	2511 49th Avenue Long Island City NY	Approved	\$650.00
46720	05A0517	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	2488 Grand Concourse Bronx NY	Approved	\$650.00
46721	05A0518	Gessin Electrical Contractors, Inc. 791 East 139th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	82 Beaver Street New York NY	Approved	\$650.00
46722	05A0519	RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Seward High School 350 Grand Street New York NY	Approved	\$650.00
Confirm "safe" access to distribution panel.						
46723	05A0520	H & L Electric Inc. 41-11 28th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Schinder Elevator 620 12th Avenue New York NY	Approved	\$650.00
1) Bond neutral in fire pump service switch and 400 amp service switch transfer switch. 2) DP-3 switch board change 400 tr fuses to AZD's.						

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46724	05A0521	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	UNsFederal Credit Union 24-01 44th Road Long Island City NY	Approved	\$650.00
1) Service conductors undersized. 2) Confirm coordination between service switch and second fuse. 3) Indicate alternate supply for emergency switchboard.						
46725	05A0522	H & L Electric Inc. 41-11 28th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Harlem Center 317 Lenox Avenue New York NY	Approved	\$650.00
46726	05A0523	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	CCNY Student Housing Facility 401 West 130th Street New York NY	Approved	\$650.00
Provide glastic barrier.						
46727	05A0524	A.T. Baker Electrical Consulting, Inc. P.O. Box 226 Glen Head NY 11545	Requested approval for the electric service equipment proposed to be installed	110 E. 59th Street New York NY	Approved	\$650.00
46728	05A0525	Al-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	Trump Megu Restaurant 845 1st Avenue New York NY	Approved	\$650.00
Feeder to MDP-ME-GU undersized.						

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46729	05A0526	I.S.M. Electric, Inc. 512 73rd Street Brooklyn NY 11209	Requested approval for the electric service equipment proposed to be installed	Victoria Towers 133-38 Sanford Avenue Flushing NY	Approved	\$650.00
46730	05A0527	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	One Bryant Park New York NY	Ok, but	\$650.00
1) Provide chiller and fire pump information. 2) Provide calculations for reduced neutrals on bus ducts. 3) Indicate size of load feeders on ATS-BB#2. 4) Clarify # of conduits for cogen feeders. 5) Identify function of ss# 4 on SS-P5. 6) Confirm adequacy of SC rating on ESS-7 based on current available from utility and generators . 7) Indicate installation method for FP wiring (MI, RHH, encasement.						
46731	05A0528	Ostroff Electric, Inc. 102-14 159th Road Howard Beach NY 11414	Requested approval for the electric service equipment proposed to be installed	Buck Residence 135 West 70th Street-9F New York NY	Ok, but	\$650.00
Change 200 amp fuses A2D's						
46732	--	Ramdeens Electrical Contracting Corp. 132-10A Liberty Avenue Richmond Hill NY 11419	Requesting permission to install Schedule 80 PVC conduit for a standpipe in a corrosive area Far Rockaway, Queens	Far Rockaway NY	Approved	\$0.00
46733	--	D Alco Electrical, Inc. 119-19 14th Road College Point NY 11356	Requesting permission to install Schedule 80 PVC for a standpipe in a corrosive area, Far Rockaway, Queens.	117-03 Rockaway Beach Blvd. Rockaway Park NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46734	--	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requesting permission to install a building service in a vaulted area where some of the equipment will not have a front clearance of 36 inches.	209 East 2nd Street New York NY	Approved	\$0.00
46735	----	Peter Maychak Electric Co. Inc. 195-43 Jamaica Avenue Hollis NY 11423	Requesting permission to install a new service replacement with a front clearance of less than 36" in a building where the service area is the only common space.	229 East 5th Street New York NY	Denied	\$0.00
Section 110.26(1) (c) of the 2002 National Electrical Code requires a front clearance of at least 3 feet in front of the service equipment.						
46736	-----	Ostroff Electric Inc. 102-14 159th Road Howard Beach NY 11414	Requesting permission to replace a circuit breaker panel that will be mounted 7 feet off of the finished floor.	15 West 12th Street-Apt. 3G New York NY	Approved	\$0.00
46737	---	Discover Electric Co., Inc. 58-10 58th Place Maspeth NY 11378	Requesting permission to leave as installed service, meters and disconnect switches mounted outdoors under a overhang that will feed 7 buildings.	128,130,132,134,136&138 Bch 92nd Rockaway NY	Approved	\$0.00
with the stipulation that the guard-rail is installed in such a way that it can be removed to access the electrical equipment if needed.						
46738	-----	ECS Electrical Contracting Services, Inc. 351 Kent Avenue Brooklyn NY 11211	Requesting permission due to lack of space inside of the existing service room to use a second service room. Providing signage at each room indicating where the other service is located.	J & R Music World 34 Park Row New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 12, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46739	-----	e Mc Caffrey**Thomas McGovern Electl 27 East 233rd Street Bronx NY 10470	Requesting permission due to a financial hardship to leave as installed BX cable as a wiring method in a place of public assembly.	137 Ludlow Street New York NY	Approved	\$350.00
With the stipulation that all the wiring inside of the public assembly is ground fault protected.						
46740	-----	Sidney Electrical Contracting Inc. 1950 Coney Island Avenue Brooklyn NY 11223	Requesting permission to tap into an existing 500 MCM copper grounding conductor riser to ground the secondary neutral of an 45 KVA transformer on the 54th floor in a building that does not have building steel.	Platinum Partners 152 West 57th Street, 54th Floor New York NY	Approved	\$0.00
46741	-----	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested permission to use a clamp hanger mounted to the main runner of a acoustical ceiling to support 8 foot florescent strip fixtures each weighting approximately 8 lbs.	89-89 Union Turnpike Queens NY	Denied	\$0.00
Section 410.16 (C) (2) of the New York City's amendments to the 2002 NEC require that a surface or pendant type luminaire to be supported from the channel iron or the building structure.						
46742	05A0529	Steelcase Inc. 901 44th St. S.E. Grand Rapids MI 49508	Requested approval for use in New York City of your Pathwas Privacy Wall.		Approved	\$200.00