

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48785CO	08A0338CO	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Presbyterian Hospital 627 West 165th Street-B3 Level New York NY	Approved	\$0.00
Carry over from June 18, 2008 meeting. 1) Provide SEQ of OP for connection of new substation to existing EDPH-1 to prevent parallel operation w/new substation. 2) Restore bus sizes on 5KV switchgear. Job finalized March 19, 2009.						
48925CO	08A0417CO	Bestco General Maintenance Inc. 922 East 233rd Street Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	Staples 90-30 Metropolitan Avenue Forest Hills NY	Approved	\$0.00
Carry over from August 13, 2008 meeting.						
48977CO	08A0461CO	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	350 West Broadway New York NY	Approved	\$0.00
Carry over from September 17, 2008 meeting. 1) Provide short circuit calculations for circuit breaker panel. 2) Verify fuse size for circuit breaker panel. 3) Verify that a neutral conductor is feeding fire pump service switch. 4) Service entrance conductors and circuit bus is undersized. Job finalized 2/20/09.						
49018	08A0487	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	JP Morgan Chase 270 Park Avenue New York NY	Approved	\$650.00
1) Bus in Section 4 of switchboard #2 undersized. 2) Provide ground fault protection on switchboard c devices over 1000A or provide ground fault on main. 3) Clearance to switchboard #3 is not adequate. 4) Indicate front clearance at switchboard c. Job finalized 12/12/08.						
49019	08A0488	udley and Assoc. Lic. Electrical Contrs, In 6 East Clarke Place Bronx NY 10452	Requested approval for the electric service equipment proposed to be installed	170 West 233rd Street Bronx NY	Hold	\$650.00
No Drawings						

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49020	08A0489	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	420 Lexington Avenue New York NY	Approved	\$650.00
49021	08A0490	Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Grace H. Dodge High School 2474 Crotona Avenue Bronx NY	Approved	\$650.00
49022	08A0491	Techno-Volt Electric, Inc. 28-31 119th Street Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	Bronxdale Apartments 2011 Holland Avenue Bronx NY	Approved	\$650.00
49023	08A0492	Balance Electrical Contracting Corp. 37-20 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	34-24 Hunters Point Avenue Long Island City NY	Approved	\$650.00
49024	08A0493	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	345 Hudson Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49025	08A0494	OM Electric, Inc. 262 West 38th Street, Suite 603 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	600 Broadway New York NY	Approved	\$650.00
49026	08A0495	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	160 West 73rd Street New York NY	Approved	\$650.00
49027	08A0496	Takos & K Electric, Inc. 38-58 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	31-35 31st Street Astoria NY	Approved	\$650.00
49028	08A0497	C.Q. Electrical Contracting Corp. 31-19 37th Avenue Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	38-60 Review Avenue Long Island City NY	Approved	\$650.00
49029	08A0498	OHM Electrical Corp. 39-40 21st Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Citigroup Center 601 Lexington Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49030	08A0499	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	D'Agostino Hall 110 West 3rd Street New York NY	Approved	\$650.00
1) New feeder from substation to be FRE. 2) Clarify if FP feeder is new/or existing and indicate FP size. Job finalized 10/22/08.						
49031	08A0500	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Vanderbilt Hall 40 Washington Square South New York NY	Hold	\$650.00
1) Provide description for compliance w/ 250.30. 2) Provide room layout for service room w/new FP SS. 3) Confirm if ATS(4000A) is 3P or 4P.						
49032	08A0501	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Tisch Hall 40 West 4th Street New York NY	Hold	\$650.00
1) Demonstrate compliance w/ 250.30. 2) Provide blank off behind switchgear. 3) Confirm system and transformer voltage. 4) If volt 480/277 provide GFP per code. 5) Confirm if ATS is 3P or 4P.						
49033	08A0502	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Furman Hall 245 Sullivan Street New York NY	Hold	\$650.00
1) Describe compliance w/250.30. 2) Confirm if ATS is 3P or 4P.						
49034	08A0503	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Kimmel Hall 60 Washington Square South New York NY	Hold	\$650.00
1) Describe compliance w/ 250.30. 2) Provide connection detail of new 8 sets to exist 4000A switch.. 3) Block rear access to substation. 4) Confirm if ATS is 3P or 4P						

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49035	08A0504	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	44 Berry Street Brooklyn NY	Approved	\$650.00
49036	08A0505	Twins Electric Corporation 695 East 132nd Street, Suite 205 Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	601 West 115th Street New York NY	Approved	\$650.00
1) Provide series rating between service switch #4 and service switch #5 and existing panels. Ext. panels undersized for the fuse size used. 2) Provide coordination service switch #3 and tenant distribution panel. Job finalized 11/3/10.						
49037	08A0506	Judd Electric Inc. 41-41 38th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	400 East 85th Street New York NY	Approved	\$650.00
49038	08A0507	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	410 4th Avenue Brooklyn NY	Approved	\$650.00
.Correct fue types on bus duct switches. Job finalized 11/17/08.						
49039	08A0508	Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Jamaica High School 167-01 Gothic Drive Queens NY	Ok, but	\$650.00
Polaris connector cited does not accommodate 10 sets 500 KCM into 3 sets 600 KCM.						

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49040	08A0509	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Presbyterian Hospital 5141 Broadway New York NY	Hold	\$650.00
1) Drawings not per Advisory Board requirements. 2) Submit switchboard details. 3) Identify new and exist. 4) Indicate alt source to generator on singleline.						
49041	08A0510	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	184 Kent Avenue Brooklyn NY	Hold	\$650.00
1) Indicate feeder size to commercial trough. 2) Step up transformers to be delta/Y. 3) FDR to DP-L-CB undersized. 4) FDR to PP-L-CA undersized. 5) Secondary sw/fu on step up transformers are backwards. 6) Provide supplemental ground lug. 7) Y on all transformer secondaries to be grounded per code. 8) Section details in sufficient. 9) Elevations and Section too small.						
49042	08A0511	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metro PCS 212 West 22nd Street New York NY	Approved	\$650.00
1) Remove neutral bond in 200 amp disconnect switch. 2) Verify if 400 Amp service switch can be relocated. Job finalized 10/29/08.						
49043	08A0512	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Price Waterhouse Coopers 300 Madison Avenue New York NY	Approved	\$650.00
1) Verify neutral bond in existing emergency switchboard. 2) Remove neutral bond in new 1600 amp disconnect switch. Job finalized 8/28/09.						
49044	08A0513	Ronnart Electric Co. 262 Jamaica Avenue Brooklyn NY 11207	Requested approval for the electric service equipment proposed to be installed	34 West 32nd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49045	08A0514	NJS Electrical Service Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	1120 6th Avenue New York NY	Approved	\$650.00
49046	08A0515	RNH Electric Company, Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	590 Flatbush Avenue Brooklyn NY	Approved	\$650.00
49047	08A0516	Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requested approval for the electric service equipment proposed to be installed	32 Avenue of the Americas New York NY	Approved	\$650.00
49048	08A0517	Dross Electrical Contracting Inc. 9202 Avenue M Brooklyn NY 11236	Requested approval for the electric service equipment proposed to be installed	2130 Broadway New York NY	Approved	\$650.00
49049	08A0518	Iberian Electric Inc. 54 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	175 West 73rd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49050	08A0519	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	10 Barclay Street New York NY	Approved	\$650.00
49051	08A0520	Five Star Electric Corp 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	20 Pine Street New York NY	Approved	\$650.00
49052	08A0521	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	20 East 23rd Street New York NY	Approved	\$650.00
8/14/15 Swapped drawings 1 and 2, Revision 3s. 4/19/16 Swapped drawings 1 and 2-Revision 5s.						
49053	08A0522	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Boricua Village, Bldg B 514 East 163rd Street Bronx NY	Approved	\$650.00
49054	08A0523	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	795 Columbus Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49055	08A0524	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Verizon 360 Bridge Street Brooklyn NY	Approved	\$650.00
1) Verify size of fire pump service switch. 2) Sprinkler system and fire pump to be fed from line side of generator main breaker. Job finalized 6/7/10.						
49056	08A0525	Alom Electric LLC 148 22nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Russo on the Bay 162-45 Cross Bay Blvd Howard Beach NY	Approved	\$650.00
49057	08A0526	Hal Electrical Contractors, Inc. 32 East 31st Street, Suite 812 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	1825 Atlantic Avenue Brooklyn NY	Approved	\$650.00
Provide circuit breaker ratings and short circuit calculations. Job finalized April 28, 2009.						
49058	08A0527	Promax Electrical Contracting Corp. 112-08 101 Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	81 Metropolitan Oval New York NY	Approved	\$650.00
Show sets of conductors feeding 800 amp disconnect switch. Job finalized April 23, 2009.						
49059	08A0528	CND Licensed Electl Contrg & Serv. Corp 454 West 46th Street, Loft SES New York NY 10036	Requested approval for the electric service equipment proposed to be installed	3041 Broadway New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49060	08A0529	AL-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	1980 Jerome Avenue Bronx NY	Approved	\$650.00
49061	08A0530	Enterprise Electrical Systems, Inc. 40 Emerson Court Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	303 East 77th Street New York NY	Approved	\$650.00
Bond neutral to enclosure in 200 amp service switch. Job finalized 11/17/08.						
49062	08A0531	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	236 Livingston Street Brooklyn NY	Approved	\$650.00
1) Verify if trough on conduit is feeding 400 amp service switch. 2) Verify rear accessibility for switchboard section 1 and 2. 3) Service room to be mechanically ventilated. 4) Fire pump service switch to be remote from switchboard. Job finalized 11/17/08.						
49063	08A0532	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	303 East 33rd Street New York NY	Approved	\$650.00
1) Show circuit breaker sizes and curves for 1200 medical office panel. 2) Service entrance conductors feeding 4000 and 2500 amp service switches are undersized. Job finalized 12/5/08.						
49064	08A0533	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Equinox Fitness Clubs 344 Amsterdam Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49065	08A0534	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	The Faculty House-Columbia U 400 West 117th Street New York NY	Approved	\$650.00
49066	08A0535	Brandl Electric Inc. 1926 Mott Avenue Far Rockaway NY 11191	Requested approval for the electric service equipment proposed to be installed	4435 Victory Blvd. Staten Island NY	Hold	\$650.00
1) Only 1 set of drawings submitted. 2) Engineer to appear at next meeting to explain job to the Advisory Board.						
49067		Arup 155 Avenue of the Americas New York NY 10013	Requested concept approval	Columbia University 550 West 120th Street New York	Approved	\$0.00
Pending submittal of full Advisory Board drawings.						
49068		Matthew K. Bendix, P.E. 519 Eighth Avenue, 20th Floor New York NY 10018	Requesting permission to utilize Section 210.60(A) and (B) for room layouts in a dormitory where the furniture will be fixed in place	New School Dormitory 318 East 15th Street New York NY	Approved	\$0.00
49069		New Grand Electric Inc. 71-73 Allen Street #302 New York NY 10002	Requesting permission to utilize Section 518.4 of the 2008 NEC where AC cable that does not contain an insulated grounding conductor was installed as a wiring method in an assembly occupancy.	1472 Ogden Avenue Bronx NY	Approved	\$350.00

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49070		Murray Diamond, Licensed Electrician 35-05 169th Street Flushing NY 11358	Requesting permission to replace 19 defective fused disconnect switches with circuit breakers without filing full Advisory Board drawings.	91-31 175th Street Jamaica NY	Denied	\$0.00
Fuses changed to breaker requires filing it is not a 1 for 1 replacement, short circuit curves and calculations are required.						
49071		Cerrito Electric of New York, Inc. 85-45 Grand Avenue Elmhurst NY 11373	Requesting permission due to hardship to replace to leave as installed non metallic-sheathed cable as a wiring method for bathroom fixtures in a 181 unit high rise building.	1 Northside Piers Brooklyn NY	Denied	\$350.00
49072		Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requesting permission to leave as installed service equipment that is not grouped together on 48 two and three family buildings where signage will be provided at each service location indicating where the other service is located.	Spring Creek Homes-Phase 1 Brooklyn NY	Approved	\$0.00
With the stipulation that signage is provided at each service switch indicating where the other service switch is located 230-2(E).						
49073		Quantum Electric Corporation 36-24 34th Street Long Island City NY 11106	Requesting permission to extend the time limit to 10/29/09 on a prior special permission approval where the temporary service entrance conductors ran approximately 80' into a building without concrete encasement due to working out a solution with Con-Ed to provide new service takeoffs.	DHL 500 Tenth Avenue New York NY	Approved	\$0.00
49074		Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requesting permission to leave as installed a service switch for a cell site on the outside of a commercial building	3511 Victory Blvd. Staten Island NY	Approved	\$0.00
With the stipulation that signage is provided at each servcie indicating where the other service is located 230.2(E).						

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49075		Scott Electrical Service, LLC 40 Macon Street Brooklyn NY 11216	Requesting permission to leave as installed non-metallic sheathed cable as a wiring method for the residential part of a mixed use building where a, two story, 2 family structure is attached to a commercial space.	1294 Forest Avenue Staten Island NY	Approved	\$0.00
49076		Dross Electrical Contracting Inc. 9202 Avenue M Brooklyn NY 11236	Requesting permission to install a seventh service switch where one of the existing service switches provides power for a fire pump	2130 Broadway New York NY	Approved	\$0.00
49077		Stanco Systems Electrical Contracting Inc. 4061 Victory Boulevard Staten Island NY 10314	Requesting permission to leave as installed service equipment mounted on the outside of a pre-fab classroom where signage will be provided at each service indicating where the other service is located	Moore High School 80 Merrill Avenue Staten Island NY	Approved	\$350.00
49078		B & G Electrical Contractors of New York 38-22 55th Street Woodside NY 11377	Requesting permission to install concrete encased service entrance conductors in rigid non-metallic conduits where all elbows and stub-ups will be rigid steel conduits.	130 Cedar Street New York NY	Approved	\$0.00
49079		Kramer Electric, LLC 35 West 35th Street, Suite 503 New York NY 10001	Requesting permission to leave as installed in a clothing retail store AC cable that does not contain an insulated grounding conductor.	Annie Sez Store 2067 Coney Island Avenue Brooklyn NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 15, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49080		Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456	Requesting permission due to a hardship to relocate, service equipment that has a front clearance of 23 inches.	944 East 228 Street Bronx NY	Denied	\$0.00
49081		Total Electrical Construction Co., Inc. 250 Green Street Greenpoint NY 11222	Requesting permission to allow 15 existing knife switch fused panels to be retro-fitted with new circuit breaker interiors leaving the back boxes in place where the retro fitting was performed by a UL approved switchboard company	P.S. 138 251-11 Weller Avenue Queens NY	Approved	\$0.00
49082	08A0537	TPR Enterprises, LTD 644 Fayette Avenue Mamaroneck NY 10453	Requested approval for use in New York City of your Fiber Optic and LED Lighting		Hold	\$200.00
1) Cut sheets (TPR-F1-150-MH-DMX-120X, TPR-F1-150-DMX-120-X) or listing. 2) Verify type of transformer used for SMD-RGB. 3) Verify that these products will only be used for stage and studio lighting. 4) Explain color encounter cable to color encounter wash? 5) Is product listed as a complete assembly transformer and leds? 6) Verify type of transformer class ID or III. 7) Verify method of LED attachment to surfaces. 8) Soldering in the field is not acceptable.						