

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48116CO	07A0392CO	BLH Electrical Contractors, Inc. 3361C East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	245 East 54th Street New York NY	Approved	\$0.00
Carry over from August 15, 2007 meeting. Show 2nd fusing off of 400 amp service switch. Job finalized 12/17/07.						
48124CO	07A0406CO	ATJ Electrical Inc. 33-61 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	El Museo del Barrio 1230 Fifth Avenue New York NY	Approved	\$0.00
Carry over from August 15, 2007 meeting.						
48142CO	07A0421CO	High-Tech Electrical Services Corp. 36-33 23rd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	545 Madison Avenue New York NY	Approved	\$0.00
Carry over September 12, 2007 meeting.						
48147CO	07A0426CO	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	City Clerk Office Relocation 155 Worth Street New York NY	Approved	\$0.00
Carry over from September 12, 2007 meeting.						
48164CO	07A0443CO	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	The Venetian 447 Avenue P Brooklyn NY	Approved	\$0.00
Carry over from September 12, 2007 meeting. Provide mechanical ventilation in service room. Job finalized 12/28/09.						

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48166CO	07A0445CO	Knight Electrical Services Corp. 111 Eighth Avenue, Suite 526 New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Bloomberg 340 West Street New York NY	Approved	\$0.00
Carry over from September 12, 2007 meeting.						
48201	07A0462	Caruso & Sons Electrical Contractors, Inc. 1489 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Home Depot 2560 Bruckner Blvd. Bronx NY	Approved	\$650.00
1) Verify primary fuse size on 1000 KVA transformer. 2) Confirm winding configuration (delta-y) on 1000 KVA transformer and 225 KVA transformer. 4)Correct grounding on 45 KVA transformer. 5) ATS-2 to be 4-pole. 6) No coordination between 800A fu and 800A CB in Switchboard #2 and MDP-A and -B. Job finalized 11/9/07.						
48202	07A0463	Folks Electrical, Inc. 670 Broadway New York NY 10012	Requested approval for the electric service equipment proposed to be installed	135 Central Park West New York NY	Approved	\$650.00
1) Indicate fuse size and type for 2 levels of o.c. protection. 2) In existing house distribution panel replace 400A fuse to coordinate with new 800A A and BY service fuse. 3) Provide connection for supl ground conductor. 4) Front clearance inadequate for ss-#4. Job finalized 5/19/08.						
48203	07A0464	Approved Electric Corp. 3578 White Plains Rd, Suite 107 Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	IS239 Mark Twain School 2401 Neptune Avenue Brooklyn NY	Approved	\$650.00
Correct floor plan-shows 400A switch should be 200A. Job finalized 12/14/07.						
48204	07A0465	Approved Electric Corp. 3578 White Plains Rd, Suite 107 Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	Regeis Care Center 3200 Baychester Avenue Bronx NY	Approved	\$650.00
1) Provide fused disconnect switch after generator receptacle. 2) Provide supplemental ground in 200 amp service switch. Job finalized 12/14/07.						

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48205	07A0466	BRG Electric, Inc. 88-26 Winchester Blvd. Queens Village NY 11427	Requested approval for the electric service equipment proposed to be installed	52-08 Grand Avenue Maspeth NY	Approved	\$650.00
1) Neutral not bonded to enclosure in 800 amp service switch. 2) Supplemental ground not provided in 800 amp service switch. Job finalized 12/4/07.						
48206	07A0467	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Ann Taylor 1372 Broadway New York NY	Approved	\$650.00
Confirm suitability of use of bus duct cable tap box provide details. Job finalized 11/19/07.						
48207	07A0468	Uptown Electric, Inc. 128-20 14th Avenue College Point NY 11101	Requested approval for the electric service equipment proposed to be installed	New York Botanical Gardens 200th Street Bronx NY	Approved	\$650.00
? Conductor in 1--3"C PVC not derated 70% Article 310.15(B) (2) (A). Job finalized 10/30/07.						
48208	07A0469	Robco Electric Corp. 2630 Chesbrough Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Harlem River Yard Inter. Trans. Ctr. 132nd Street & St. Anns Avenue Bronx NY	Approved	\$650.00
1) Confirm 4000A primary fuse can withstand transformer in rush current. 2) Provide space for future secondary protection at step-down transformer. Job finalized 3/30/09.						
48209	07A0470	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Parking Garage @BX Term. Mkt Exterior Street & East 149th Street Bronx NY	Approved	\$650.00
1) Provide ground fault protection on 1600 amp service switch. 2) Show tap details in trough. 3) Ground wires must comply with Article 250. 4) LL-DP-G, GAR-DP show 600V fuse types. 5) No coordination 400A TRS - 1200A A4BY , 600A TRS - 1600A A4BY. Job finalized 3/21/08.						

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48210	07A0471	Judd Electric Inc. 41-41 38th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	900 West 190th Street New York NY	Approved	\$650.00
48211	07A0472	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	ABN Ambro Infrastructure 7 WTC New York NY	Approved	\$650.00
48212	07A0473	Twins Electric Corporation 460 Austin Place Bronx NY 10455	Requested approval for the electric service equipment proposed to be installed	90 Morningside Drive New York NY	Approved	\$650.00
Egress doors to swing out. Job finalized 1/11/08.						
48213	07A0474	Arc Electrical & Mechanical Contrs, Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Medgar Evers College 1638 Bedford Avenue Brooklyn NY	Hold	\$650.00
1) Fire pump service switch and emergency side switch undersized. 2) Fire alarm, load side of transformers too many switches. 4) Fire alarm 120/208 volt switch shall be a fused cutout. 5) Take off bus in SSB-1, no sizing on drawing. 6) Grounding electrode and supplemental grounds not provided on drawing. 7) Service entrance neutral not provided at fire pump service switch. Article 230.28. 8) Provide cuts of generator and generator distribution. 9) Provide coordination study for generator distribution system. 10) Inadequate front clearance for 'DSB'. 11) Verify 6'-6" to 800A switch handles in SSB-1 and -2. 12) Confirm bus is minimum 12" AFF.						
48214	07A0475	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Northrop Grumman Construction 583 Riverside Dr. New York NY	Ok, but	\$650.00
1) Request special permission for 7th service switch or connect. 2) Relocate switch to maintain existing clearance in front of existing service switches.						

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48215	07A0476	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Sprint Broadband Connection 440 West 57th Street New York NY	Approved	\$650.00
Relocate new service switch to maintain existing clearance from McDonald's meter. Job finalized 10/24/07.						
48216	07A0477	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Sprint Broadband Connection 280 Madison Avenue New York NY	Approved	\$650.00
48217	07A0478	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	333 East 91st Street New York NY	Hold	\$650.00
1) Bus undersized to 1200 amp service switch should be 1-5"x1/4". 2) Service bus bar for fire pump CT passing through other equipment. 3) Second disconnect switch at transformer not GFP - Article 215.10.						
48218	07A0479	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Yeshiva University 515 West 185th Street New York NY	Approved	\$650.00
48219	07A0480	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	Barnard College-Nexus Bldg. 3009 Broadway New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48220	07A0481	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Memorial Sloan Kettering 1275 York Avenue New York NY	Approved	\$650.00
No coordination 3000A-4000A fuse. Job finalized 11/19/10.						
48221	07A0482	Urban Power and Lighting, Inc. 227 49th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	560 Broadway a.k.a. 165 West 46th ! New York NY	Approved	\$650.00
48222	07A0483	Blasko Electrical Contractors, Inc. 36-38 35th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	47-10 32nd Place Long Island City NY	Approved	\$650.00
48223	07A0484	M & J Electrical Contractors Corp. 23-24 Steinway Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	775 Concourse Village East Bronx NY	Approved	\$650.00
48224	07A0485	Bass Electrical Corp. 10-17 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	4334 Broadway New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48225	07A0486	Reliant Electrical Contracting Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	263 West 153rd Street New York NY	Approved	\$650.00
Fire pump tap must be at POE. Job finalized 12/14/07.						
48226	07A0487	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	258-264 St. Nicholas Avenue New York NY	Approved	\$650.00
Fire pump tap must be at POE. Job finalized 12/14/07.						
48227	07A0488	CRM Electric Corporation 68 East 131st Street, 302 New York NY 10037	Requested approval for the electric service equipment proposed to be installed	45 John Street New York NY	Approved	\$650.00
48228	07A0489	Tacos & K Electric, Inc. 38-58 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	220 West 19th Street New York NY	Approved	\$650.00
48229	07A0490	Seong Jin Electric Inc. 37-12 58th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	39-05 29th Street Astoria NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48230	07A0491	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	The Waldorf Astoria 301 Park Avenue New York NY	Approved	\$650.00
1) Provide proper sized ground bus. 2) Pull box to be accessible. Job finalized 10/24/07.						
48231	07A0492	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	St. Johns University 81-50 Utopia Avenue Queens NY	Denied	\$650.00
1) Contractors name not in title block. 2) Service room door to open out with panic hardware. 3) drawing not in Advisory Board format. 4) Fuse and wires sizes not provided. 5) Tap detail is not clear. 6) Looks like tap is after 2nd fuse. 7) Drawing is not clear. 8) Existing work's one line not provided. 9) New switch installation doesn't comply with 110.26.						
48232	07A0493	Approved Electric Corp. 3578 White Plains Rd, Suite 107 Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	4901 Henry Hudson Parkway Bronx NY	Approved	\$650.00
Provide fused disconnect switch instead of receptacle at roll up generator. Job finalized 12/14/07.						
48233	07A0494	Red Wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	189-02 64th Avenue Fresh Meadows NY	Ok, but	\$650.00
1) New 200 amp service switch neutral not bonded to enclosure and supplemental ground not provided. 2) check with Con-Ed to install switch before meter. 3) Show second fusing.						
48234	07A0495	Red Wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	30-50 Whitestone Expressway Queens NY	Ok, but	\$650.00
New 800 service switch neutral not bonded to enclosure and supplemental ground not provided.						

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48235	07A0496	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Manhattan Youth 200 Chambers Street New York NY	Approved	\$650.00
48236	07A0497	Roz-A-Lite Electrical Contracting, Inc. 164 20th Street, Suite 2D Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	125 North 10th Street Brooklyn NY	Approved	\$650.00
48237	07A0498	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	St. John's University 8000 Utopia Parkway Queens NY	Approved	\$650.00
48238	07A0499	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	Commercial Building 530 West 135th Street New York NY	Approved	\$650.00
48239	07A0500	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	469 West Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48240	07A0501	Roz-A-Lite Electrical Contracting, Inc. 164 20th Street, Suite 2D Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Manhattanville Houses 3240 Broadway New York NY	Ok, but	\$650.00
1) Clarify 2-3" conduits feeding a 400 amp service switch. 2) Provide supplemental ground.						
48241	07A0502	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	PS 169 New Early Childhood Ctr 3500 Edson Avenue Bronx NY	Approved	\$0.00
1) Neutral not bonded to enclosure in service switch #3 and fire alarm fuse cut-out. 2) Remove switch to fire pump jockey pump. 3) Fire pump tap from service switchboard does not comply with 695.3A. Job finalized 2/25/08.						
48242	07A0503	Aventura Electrical Services 1412 East 31st Street Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	10 Downing Street New York NY	Approved	\$650.00
1) Service switch #3 , neutral not bonded to enclosure. 2) Show tap detail in trough. 3) Remove gas meters from service room. Job finalized 12/4/07.						
48243	07A0504	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Spring Broadband Connection 215 East 64th Street New York NY	Approved	\$650.00
48244	07A0505	G.M. Electrical Contracting Inc. 284 East 236th Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	210 West 50th Street New York NY	Approved	\$650.00
Verify that 2 sets of 3/0 are being tapped. Job finalized 10/24/07.						

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48245	07A0506	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	2108 Adam Clayton Powell Blvd. New York NY	Approved	\$650.00
48246	07A0507	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Bayridge Stop & Stor 534 63rd Street Brooklyn NY	Approved	\$650.00
48247	07A0508	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Starbucks-Empire State Bldg. 350 5th Avenue New York NY	Approved	\$650.00
48248	07A0509	Quality Electric Installation, Inc. 10-17 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	637 West 42nd Street New York NY	Approved	\$650.00
48249	07A0510	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	32 Broadway New York NY	Approved	\$650.00
Provide water main ground. Job finalized 10/24/07.						

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48250	07A0511	First Central Electrical Corp. 126-12 18th Avenue, Suite 1R College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	166 West 18th Street New York NY	Ok, but	\$650.00
Manufacturer's cut sheets do not show actual bus sizes.						
48251	07A0512	A Tech Electric Enterprise, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Halstead Property 188 East 78th Street New York NY	Approved	\$650.00
Show coordination between 2000 amp service switch and 600 amp disconnect switch. Job finalized 12/17/07.						
48252	07A0513	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Cingular Wireless 205 West 61st Street New York NY	Approved	\$650.00
48253	07A0514	BT Electrical, Inc. 85-02 67th Drive Rego Park NY 11374	Requested approval for the electric service equipment proposed to be installed	45 East 66th Street New York NY	Approved	\$650.00
48254	07A0515	AL-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	30-48 Linden Place Whitestone NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48255	07A0516	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	808 Columbus Avenue New York NY	Approved	\$650.00
48256	07A0517	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	H.S.for Health Professions 345 East 15th Street New York NY	Approved	\$650.00
48257	07A0518	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	AT & T 811 10th Avenue New York	Approved	\$650.00
48258		Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requesting permission to leave as submitted a single means of egress to a 1000 KVA service room due to having no room to install a legal exit.	Queens District 14 Salt Shed Queens NY	Hold	\$0.00
48259		Trincity Electric Inc. 1350A Flatbush Avenue Brooklyn NY 11210	Requesting permission to install overhead service conductors in Schedule 80 non metallic conduit for 4 two family buildings located in a corrosive area, Far Rockaway, Queens.	53A Bch 27th St., 155 and 155A Bc Far Rockaway NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48260		Safeway Construction Inc. 90-04 Liberty Avenue Ozone Park NY 11417	Requesting permission to install overhead service entrance conductors in Schedule 80 non metallic rigid conduit for a 14 condo located in a corrosive area, Far Rockaway, Queens	56, 158, 160, 162 and 164 Bch 97th St Far Rockaway NY	Approved	\$0.00
48261		DVL Consulting Engineers Inc. 137 Fifth Avenue New York NY 10010	Requesting permission to install concrete encased underground service entrance conductors in rigid non metallic conduit.	125 East 181st Street Bronx NY	Approved	\$0.00
48262		A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requesting permission to install underground concrete encased service entrance conductors in Schedule 80 non metallic conduit	Barnard Nexus Building 3009 Broadway New York NY	Approved	\$0.00
48263		J Star Electric, Inc. 32 East 31st Street New York NY 10016	Requesting permission to leave as installed six, 2 foot lengths of liquidtight flexible non metallic conduit that feed 6 outdoor fixtures mounted under a sidewalk bridge.	PS130 New York NY	Approved	\$0.00
48264		J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requesting permission to leave as installed service equipment for a cell site outdoors.	1027 Grand Street Brooklyn NY	Approved	\$350.00

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48265		Delta Phase Electric Corporation 978 Kent Avenue Brooklyn NY 11205	Requesting permission due to no space to install service equipment inside of the gas station attendants booth, to allow service equipment for a cell site to be installed outdoors.	5205 Hylan Boulevard Staten Island NY	Approved	\$0.00
48266		Richmond Electric Contractors Inc. 4313 Arthur Kill Road Staten Island NY	Requesting permission on a lot that is zoned as a 2 family with 2 single family buildings, to install on the outside of the front building 2 meters and one outdoor service switch that will feed the back buildings circuit breaker panel containing a main breaker.	54 Goodall Street Staten Island NY	Approved	\$0.00
48267		Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requesting permission to install underground service entrance conductors, feeders and branch circuit wiring in non metallic rigid conduit, install NEMA 3R rated service and distribution equipment outdoors using two ground rods due to no water being installed on the lot where a temporary tenants court dome will be installed	North Shore Tennis Club 34-28 214th Place Bayside NY	Approved	#Error
with the stipulation that if water is available in the club house, the water piping shall be picked up in the loop.						
48268		AEC Electrical Co., Inc. 6005 Ft. Hamilton Parkway Brooklyn NY 11219	Requesting permission to use ground rods instead of the metallic water pipe to connect the grounding electrode conductor for the service ground, due to having problems with the water main installation.	3 Grand Central Pkwy & 110-56 63rd Queens NY	Denied	\$0.00
48269		Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requesting permission to leave as installed 8 sets of 500 MCM MC cable fused at 1000 amps where the cable contains #2 equipment grounding conductor.	Atria Riverdale Project 3718-3726 Henry Hudson Parkway Riverdale NY	Hold	\$0.00
1) More info required on how the load was reduced from 3000 to 1000 amps. 2) Can loads be divided into smaller ones using more switches?						

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48270		Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requesting permission due to lack of room inside of the building to install PVC coated MC cables on the outside of the building from the roof to the basement.	333 West 86th Street New York NY	Approved	\$0.00
48271		Triangle Electric Inc. 102-04 89th Street Ozone Park NY 11416	Requesting permission on a DC elimination program where are existing fire pump branch circuit had to be partially rerouted due to the location of the new rectifier, to leave the fire pump circuit as originally installed without fire rating it.	Con Edison 374 Lexington Avenue New York NY	Approved	\$0.00
48272		Appo Electric 34-18 Northern Blvd., 4th Floor Long Island City NY 11101	Requesting permission due to a hardship to replace to leave as installed in a place of assembly AC cable that does not contain an insulated grounding conductor.	Apostolic Church 900 Prospect Avenue Bronx NY	Approved	\$0.00
with the stipulation that ground fault circuit breakers are installed on all branch circuits.						
48273	07A0519	Acuity Brands Lighting 1335 Industrial Boulevard Conyers GA 30012	Requested approval for use in New York City of your Manufactured Wiring System. Model Numbers: OC/OCD/HF-DP, OD/ODC/HF-WE, OC2/HF-EE, OSC2, OSS, OCU, OCS/HF-SC, S5CD, S5CE, S5CT, S5PT, S5JS, S5SS, S5SSC and S5DC.		Approved	\$200.00
With the stipulation that the manufacturer include in its installation instructions New York City Amendments to the 2005 NEC Article 604.1 and 604.6.						
48274	07A0520	A.L.P. Lighting Components, Inc. 1401 Blairs Bridge Road Lithia Springs GA 30122	Requested approval for use in New York City of your Fluorescent Strip Fixture with Riveted Ends, Pivot Style. Model/Series Numbers: SEP 220, 230, 240, 272 and 296.		Approved	\$200.00

ADVISORY BOARD CALENDAR

October 17, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48275	07A0521	Knoll, Inc. 1235 Water Street East Greenville NY 18041	Requested approval for use in New York City of your Daisy-Chained Fluorescent Task Lights in Office Workstations. Model/Series Numbers: "RTAT5" and "QC" Series.2		Approved	\$200.00
with the stipulation that the manufacturer must include in its installation instructions that the daisy-chained fixtures can not feed cubicle to cubicle and that the current-in cords of each adder unit is installed in such a way to protect it from physical injury.						
48276	07A0522	Bretford Manufacturing 11000 Seymour Avenue Franklin IL 60131	Requested approval for use in New York City of your TRU Conference Table		Denied	\$200.00
1) Manufacturer's installation instructions not provided. 2) Prewired assembly pictures not provided. 3) Prewired assembly and the table must be listed as a complete assembly. 4 Liquidtight flexible metal conduit is limited to 18 inches.						
48277	07A0523	Herman Miller Company 1370 Abbott Court Buffalo Grove IL 60089	Requested approval for use in New York City of your Open Grid Ceiling System.		Approved	\$200.00
With the stipulation that the manufacturer include in its installation instructions New York City Amendments to the 2005 NEC Article 604.1 and 604.6.						
48278	07A0524	Herman Miller Company 1370 Abbott Court Buffalo Grove IL 60089	Requested approval for use in New York City of your Modular Ceiling System-both 120V and 277V Listed Plenum Rated Systems.		Approved	\$200.00
With the stipulation that the manufacturer include in its installation instructions New York City Amendments to the 2005 NEC Article 604.1 and 604.6.						
48279		Dawn Electric P.O. Box 519 Central Islip NY 11722	Requesting permission to install outdoor listed service and distribution equipment outdoors and to install service entrance conductors and 22 feeders underground in Schedule 80 non metallic conduits that will provide power to 22 classroom trailers, where the installation is expected to last 3 to 4 years in a corrosive area Far Rockaway, Queens.	155 Beach 67th Street Far Rockaway NY	Approved	\$0.00