

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50816CO4	11A0286CO4	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	1717 Broadway New York NY	Approved	\$0.00
1) 100 amps service switch neutral not bonded to enclosure. 2) Equipment grounding conductor for fire alarm not shown on drawing. Job finalized 1/15/13.						
51562	12A0031CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	29-01 Borden Avenue Long Island City NY	Approved	\$0.00
Carry over from June 13, 2012 meeting. 1) No barrier at generator between f.p. sw and non life safety switches. 2) No emergency feeder shown on drawing for fire alarm. 3) Mechanical ventilation not provided for service room. 4) Grounding electrode and main bonding jumper not shown on drawing at step-up transformer. 5) Fire alarm service switch to be installed not cutout and separate grounding electrode conductor. Job finalized 1/30/13.						
51484	12A0155CO	Contact Electric Corp. 1275 43rd Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	1362 50th Street Brooklyn NY	Approved	\$0.00
Carry over from August 15, 2012 meeting. 1) Verify that both service rooms are 2 hour fire rated. 2) Neutral disconnect links on line side of bonding and grounding. 3) Confirm that 100 AIC series ratings applies to the 200 amp circuit breakers in panels A-D. Job finalized 12/17/12.						
51593	12A0166CO	AL-Lectric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	One Fulton Square 39-16 Prince Street Flushing NY	Approved	\$0.00
Carry over from August 15, 2012 meeting. Overfused/or undersized feeder. Job finalized 3/14/13.						
	12A0196CO	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	80 Centre Street New York NY	Rejected	\$0.00
Carry over from September 12, 2012 meeting. Describe fire rating method has to be an approved method since UL pulled the fire resistive cable listing. Job finalized 2/26/13. Rejected 1) Some clearances removed from room layout. 2) Drawing 3. Bus to 1600 amp switches undersized. 3) Drawing 2 show bus sizes. 12/21/16 1) Clearly identify the bus sizes for 'SSB.B' (Drawing 2) switchboard. 2) Drawing 3 in section 6 bus to 1600A spare switch undersized. 3) Drawing 4 Generator switchboard 'GSB' is 2000A rated. 4) Drawing 4 Cables from 'GSB' to 'EMDB' and 'GSB' to 'load bank' undersized. 5) Drawing 4 Remove fuse disconnect on primary side of the F.A. transformer.						

# ADVISORY BOARD CALENDAR

October 17, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51422	12A0201CO	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1633 Broadway New York NY	Approved	\$0.00
Carry over from September 12, 2012 meeting.						
51477	12A0222CO	Accurate Electric Corp. 4319 18th Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	153 West 21st Street New York NY	Approved	\$0.00
Carry over from September 12, 2012 meeting. 1) F.P. service switch neutral not provided. 2) F.P. service switch neutral not bonded to enclosure. 3) Fire alarm service switch neutral not bonded to enclosure. 4) Supplemental electrode not shown on drawing. 5) Physical not shown on drawing for SS #4 and SS# 5. 6) Verify if fire pump is listed for direct connect. 7) Remove neutral bond in fire alarm emergency switch. 8) Fire pump service entrance conductors to comply with Section 230.6. Job finalized 11/30/12. 3/24/15 Swapped drawing 1 of 1, Revision 3.						
51423	12A0230CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Columbia University 3020 Broadway New York NY	Approved	\$0.00
Carry over from September 12, 2012 meeting.						
	12A0245	Cedar Electrical Contractors, Inc. 317 Madison Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	North Side 141 East 88th Street New York NY	On Hold	\$650.00
No drawings.						
	12A0246	Cedar Electrical Contractors, Inc. 317 Madison Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	South Side 141 East 88th Street New York NY	On Hold	\$650.00
No drawings.						

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51424	12A0247	Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Cooper Union 41 Cooper Square New York NY	Approved	\$650.00
<p>1) Verify high voltage feeder fuses at switchgear. 2) Feeders at loadside of stepdown transformers undersize. 3) Buss at high voltage switchgear undersize(1-1/4"x4" fused 1200 amps). Job finalized 12/19/12. 7/16/15 Swapped Drawings 1 and 3, Revision 3s.</p>						
51504	12A0248	Hatzel & Buehler, Inc. 45 Broadway, Suite #1240 New York NY 10006	Requested approval for the electric service equipment proposed to be installed	230 Park Avenue New York NY	Approved	\$650.00
<p>1) 600 amps second fusing at 1200 amps s.s. type not shown on drawing. 2) Fire rated cable when used must be listed fire resistive cables, UL has pull out all fire resistive cables. This installation does not require fire resistive cable since fire pump and service room adjacent to each other. Job finalized 12/18/12.</p>						
51485	12A0249	M.R. Electrical Service LLC 115 Heyward Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	Building C 205 North 9th Street Brooklyn NY	Approved	\$650.00
<p>1) Grounding and ungrounded conductors size between DC SW and inverter not shown on drawing. 2) Verify that tapping at the service sw does not affect the UL listing. Job finalized 1/14/13.</p>						
51544	12A0250	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Macy's Main Store 112 Richmond Hill Rd. Staten Island NY	Approved	\$650.00
<p>1) Grounding of PV System not shown. 2) AC switch must e reversed. Job finalized 3/1/13.</p>						
51584	12A0251	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Broadway Stages 365 Kingsland Avenue Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51425	12A0252	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	441 9th Avenue New York NY	Approved	\$650.00
51638	12A0253	Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	40 West Moshulu Parkway South Bronx NY	Approved	\$650.00
Installation must comply with 705.12(D)(2). Job finalized 5/9/13.						
	12A0254	I.S.M Electric, Inc. 249 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	PS290Q 5520 Metropolitan Avenue Queens NY	On Hold	\$650.00
1) F.P. emergency feeder MI cable in 4" RGS6. 2) 800 amps feeder from service and generator to DP- ESB undersize/over fused. 3) Equipment grounding #2 with 800A feeders at service and generator to DP-ESB undersized/over fused. 4) 3000 amps feeders conductors undersize/overfused. 5) Too many conductors inside 3" EMT and 4" RGS6. 6) Use approved fire resistive cable for fire pump.						
	12A0255	Roz-A-Lite Electric 163 20th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	455 West 20th Street New York NY	On Hold	\$650.00
1) Too many conductors in 3" conduit-(1200A feeders). 2) Main grounding and supplemental electrode not shown on drawing. 3) Neutral not shown on drawing lineside fire pump s.s. 4) equipment grounding conductor lineside fire pump s.s. undersize. 5) Feeders conductors at loadside of 800 amps s.s. overfused. 6) Fuses type at meter banks not shown on drawing. 7) Feeder for firepump is not fire rated and ground is undersize. 8) Jockey pump shall not be tapped from fire pum controller.						
51557	12A0256	Top Shelf Electric Corporation 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	53 Broadway Brooklyn NY	Approved	\$650.00
1) Neutral disconnect link not shown on drawing at 1200A s.s. 2) Main water pipe and supplemental grounding electrode not shown on drawing. 3) Main bonding jumpers not shown on drawing for s.s. #2, s.s.#3, s.s.#4 and s.s. #5. 4) Provide fire rated feeder for fire pump note RHW or MI cables are not listed currently by UL. Job finalized 1/17/13. 10/29/13 Swapped Rev 2.						

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0257	Team Electric, Inc. 20 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	6 Platt Street New York NY	Pending	\$650.00
1) Barrier provided at generator between F.P. and normal load overcurrent devices. 2) Fire alarm ATS #1 not 4 pole. 3) Fire rated cable must be approved fire resistive system, MI and RHW are not currently listed by UL						
51426	12A0258	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	137 Varick Street New York NY	Approved	\$650.00
10/27/13 Swapped Rev 1.						
51523	12A0259	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Baccarat Hotel 20 West 53rd Street New York NY	Approved	\$650.00
1) Generator feeder for pump must be fire rated, MI & RHW currently not approved. 2) Transformer for fire pump must have NEMA3. 3) Provide gen size and show on single line. Job finalized 1/3/13. 8/20/15 Swapped drawings. 1 through 5, Revision 5s.						
	12A0260	L.E.A. Electric Corp. 1001 Sixth Avenue, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	1775 Grand Concourse Bronx NY	Rejected	\$650.00
1) Verify that generator is a separately derived source. 2) Verify length of tapped conductors 10' or 20' in total. 3) MI & RHM not currently approved by UL use approved fire rating method. 12/26/12 - The method of UL 2hrs fire rated enclosure not indicated on drawing.						
52064	12A0261	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Avalon West Chelsea 517 West 28th Street New York NY	Approved	\$650.00
1) Provide reduced neutral calculations(ss#2A). 2) Provide 5' in front of ss#2C. 12/20/13 job finalized. 11/20/15 Rejected 1) Service entrance for D5 "HDB-B1" show" galvanized steel conduit should show through (one line diagram show conduit not pull box). 2) Column blocking approach to distribution panel. 1/22/16 Rejected Column is blocking approach to distribution panel. 4/19/16 Swapped Drawing 1,2 and 3-Revision 3.						

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0262	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	56 Leonard Street New York NY	Pending	\$650.00
1) Fire pump conductor undersized service A. 2) Provide protection for fire pump transformer service "B" and feeder undersized. 3) Panel DP-garage overfused.						
51427	12A0263	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	510 Madison Avenue New York NY	Approved	\$650.00
51428	12A0264	Bass Electrical Corp. 10-17 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	355 Kingsland Avenue Brooklyn NY	Approved	\$650.00
51429	12A0265	Bass Electrical Corp. 10-17 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	359 Kingsland Avenue Brooklyn NY	Approved	\$650.00
51430	12A0266	A.L. Electrical Corp. 307 7th Avenue, Suite 404 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	885 Avenue of the Americas New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51431	12A0267	Broadway Electric, LLC 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	620 West 42nd Street New York NY	Approved	\$650.00
51432	12A0268	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	68 Bradhurst Street New York NY	Approved	\$650.00
51468	12A0269	A & R Electrical Maintenance, Inc. 85-45 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	El Barrio Artspace @PS109 215 East 99th Street New York NY	Approved	\$650.00
1) Fire pump service switch undersized. 2) Shift 200A retail meters and switches to provide 5' in front of s.s. currently condition 3 clearances are applicable. Job finalized 11/21/12.						
51469	12A0270	Top Shelf Electric Corporation 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	2 Rector Street New York NY	Approved	\$650.00
Provide transformer cut sheet. Job finalized 11/20/12.						
51470	12A0271	APS Electric Inc. 83-32 Parsons Blvd. Queens NY 11314	Requested approval for the electric service equipment proposed to be installed	500 4th Avenue Brooklyn NY	Approved	\$650.00
1) New equipment not shown on service room layout drawing. 2) Contractors name not on room layout drawing. 3) Fuse does not coordinate with upstream fuse. Job finalized 11/20/12.						

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51433	12A0272	Valentis Electric Inc. 32-21 58th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Mink Building 1361 Amsterdam Avenue New York NY	Approved	\$650.00
11/27/13 Already swapped Rev 1 on 8/27/13.						
51434	12A0273	A & R Electrical Maintenance, Inc. 85-45 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	345 Adams Street Brooklyn NY	Approved	\$650.00
51471	12A0274	C.Q. Electrical Contracting Corp. 31-19 37th Avenue Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	260 East 161st Street Bronx NY	Approved	\$650.00
Type 400A fuses not shown on drawing. Job finalized 11/20/12.						
51545	12A0275	Enterprise Electrical Systems, Inc. 502 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	303 East 77th Street New York NY	Approved	\$650.00
1) Max 7 - 3/0 conductors allowed in 2 1/2 conduit. 2) Conductors not derated. Job finalized 1/14/13.						
51546	12A0276	Ace Electrical Expert Corp. 40-04 73rd Street, 2nd Floor Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	12-15 Broadway Astoria NY	Approved	\$650.00
1) Fire rated conductors are not listed, explain fire rated for fire pump. 2) Fire pump equipment grounding conductor undersized. 3) Show feeder sizes to building #2. Job finalized 1/14/13.						

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51515	12A0277	Tower Electric Inc. 21-19 40th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Savoy Hotel 123-32 82nd Avenue Queens NY	Approved	\$0.00
1) Verify that generator is supplying separate switches or installation complies with 700.9(B)(5)(a). 2) Equipment grounding conductors to fire pump undersized. 3) Fire rated conductors are not listed, explain fire rated. 4) Verify that separate conduits are being installed for each set of feeders. 5) Rear of switchboard to be barriered off. 6) Conductors not derated-2 sets of 350 MCM. Job finalized 1/3/13/						
	12A0278	Cabin Electric Inc. 7214 13th Avenue Brooklyn NY 11228	Requested approval for the electric service equipment proposed to be installed	Greystone Management 7 West 22nd Street New York NY	Denied	\$650.00
1) Drawing not in Advisory Board format. 2) Standard notes not on drawing. 3) Equipment manufacturer not noted. 4) Show all clearances in service room. 5) Not reviewed.						
51547	12A0279	Roma Electric Corp. 30-75 14th Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	50-01 2nd Street Queens NY	Approved	\$650.00
1) Provide side views of switchgear. 2) Grounding of the switchboard drawing does not match manufacturers cut sheet. 3) Provide short circuit calculations and short circuit calculators at meter bank. Job finalized 1/11/13.						
	12A0280	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Dickard Widder 56-02 Maspeth Avenue Maspeth NY	Pending	\$650.00
1200 amps disconnect switch neutral to be bonded.						
51548	12A0281	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Macy's Furniture Store 312 Richmond Hill Road Staten Island NY	Approved	\$650.00
Neutral to be bonded to enclosure in 600 amp disconnect switch.						

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52335	12A0282	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	NY Genome Center 101 6th Avenue New York NY	Approved	\$650.00
1) Does emergency board feed life safety equipment? 2) Generator unprotected conductors to comply with Section 230.6. 3) Will load shedding be provided? If yes, note it on drawing. 2/12/13-New -Electrotech drawing show generator wired for 3P ATS's. See Cal. #51521. 5/12/14 Job finalized.						
51472	12A0283	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	1 Liberty Plaza New York NY	Approved	\$650.00
1) 1200 amp trip getting to be lowered for 3 sets of 400 MCM, 1005 amps. 2) 1 line generator circuit breaker does not match room layout breaker. Job finalized 11/20/12.						
51509	12A0284	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	32 Avenue of the Americas New York NY	Approved	\$650.00
Increase size of service entrance conductors to 3000 amp service switch or provide load calculations. Job finalized 12/21/12. 5/6/14 Swapped FP 2 of 2.						
51473	12A0285	D & D Electrical Construction Co., Inc. 720 5th Avenue, 10th Floor New York NY 10019	Requested approval for the electric service equipment proposed to be installed	100 West 93rd Street New York NY	Approved	\$650.00
1) Neutral bonded to enclosure at existing 3000A switchboard. 2) Fire alarm service switch to be grounded. Job finalized 11/20/12. 12/7/15 Rejected 1) (535 KCM) Provide documentation that D.O.@ cable is dual rated, provide cut sheets too. 2) 100A fuse missing in 552 SR40.02 of 2 -Revision 3. 4/19/16 Swapped Drawing 1-Revision 5 and Drawing 2-Revision 4.						
51435	12A0286	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 Fifth Avenue New York NY	Approved	\$650.00
4/16/14 Swapped A-Rev 2 and B-Rev 1						

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51436	12A0287	DeFalco Electric 32-26 Greenpoint Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	435 West 50th Street New York NY	Approved	\$650.00
12/10/13 Rev 3 was already swapped on 8/28/13.						
51437	12A0288	James F. Volpe Electl Contracting Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Chase HVAC Upgrade 177 Montague Street Brooklyn NY	Approved	\$650.00
51438	12A0289	Dolores Electrical Contracting 843 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Soul Cycle 384 Lafayette Street New York NY	Approved	\$650.00
51439	12A0290	Pinto & Teger Electric Corp. 14-14 123rd Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Verizon 435 West 50th Street New York NY	Approved	\$650.00
51440	12A0291	T & R Alarm & Electric Systems, Inc. 4175 Park Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	Lehman College 250 Bedford Blvd. West Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51474	12A0292	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	1355 First Avenue New York NY	Approved	\$650.00
1) Verify barrier at generator between elevator and optional load Article 700.9(B). 2) S.S. #5 and S.S. #6 Neutral not bonded to the enclosure. 3) Fire pump to be listed for direct connect ( service equipment). 4) Grounding electrode conductor to be terminated in fire alarm service switch. 12/18/15 Swapped Drawing A-Revision 1, Drawing B-Revision 2						
51475	12A0293	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 Fifth Avenue New York NY	Approved	\$650.00
Verify that service entrance conductors are encased I concrete. Job finalized 11/27/12 Swapped Drawing A-Revision 2, 8/18/16 Swapped drawings A-Revision 3 and Drawing C-Revision 5. No more as-built drawings. New filing required.						
51476	12A0294	A & M Electrical Service Inc. 76 Bathgate Street Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	210 Joralemon Street Brooklyn NY	Approved	\$650.00
1) Fire rated conductors are no longer listed. Was fire pump wiring existing? 2) Grounding electrode conductor to be terminated in fire alarm service switch. 3) Fire pump tap can not be made in same cabinet that contains overcurrent devices. 4) 1200 am disconnect switches to have neutral disconnect links. Job finalized 11/26/12. 4/16/14 Swapped A Rev 4 and B Rev 3.						
51478	12A0295	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Hilton-Garden Inn 45 East 33rd Street New York NY	Approved	\$650.00
1) Remove neutral bond in jockey pump disconnect switch. 2) Grounding electrode conductor to be terminated in fire alarm service switch. Job finalized 11/26/12. 8/4/16 Swapped Drawing A and B-Revision 2.						
51479	12A0296	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Educational & Cultural Trust Fund 48-40 34th Street Long Island City NY	Approved	\$650.00
1) Fire rated conductor are not listed. 2) Grounding electrode conductor to be terminated in fire alarm service switch. 3) Provide physicals of switchboard. 4) Fire pump tap cannot be taken from same cabinet that contains overcurrent protective devices. Job finalized 11/21/12.						

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51508	12A0297	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S. 287Q 110-08 Northern Blvd. Corona NY	Approved	\$650.00
1) Fire rated conductors are not listed. 2) Grounding electrode conductor to be terminated in fire alarm service switch. 3) Fire pump tap cannot be made in the same cabinet that contains overcurrent protective devices. Job finalized 12/19/12.						
51480	12A0298	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S. 51M 525 West 44th Street New York NY	Approved	\$650.00
Grounding electrode conductor to terminate in fire alarm service switch. Job finalized 11/27/12. 6/24/16 Swapped drawing. A-Revision 5 and Drawing 5-Revision 3. 12/21/16 Swapped drawing D-1102-21812-A-Revision 6.						
51441	12A0299	Jun Safety Electrical Inc. 7218 16th Avenue Brooklyn NY 11204	Requesting permission to leave as installed due to lack of space inside of the existing service room a new meter and service located on the outside wall of the service room.	60 West 39th Street New York NY	Approved	\$350.00
With the stipulation that signage is provided at each service location indicating where the other service is located.						
51442	12A0300	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to replace a defective 480 volt service switch with an exact replacement on a 1000KVA service.	Times Square Tower 7 Times Square New York NY	Approved	\$0.00
51443	12A0301	Cosentini Associates Two Pennsylvania Plaza New York NY 10121	Requesting permission to replace existing automatic transfer switches that are approaching their end of life cycles with new in existing enclosures located in existing service rooms where the retro fitting of equipment will be field evaluated by an NRTL	1515 Broadway New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51444	12A0302	AKF 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to install emergency feeders as per Section 700-9D.	299 Park Avenue New York NY	Approved	\$0.00
51445	12A0303	AKF 330 West 42nd Street, 14th Floor New York NY 10036	Requesting permission for a building constructed in the early 70's where the existing emergency system transfer switches are approaching their end of life cycles to allow the replacement of these ATS to remain in their existing locations and enclosures.	1211 Avenue of the Americas New York NY	Approved	\$0.00
With the stipulation that the retro-fitting of the new automatic transfer switch interiors installed in existing enclosures are field evaluated by Osha recognized nationally recognized testing laboratory.						
51446	12A0304	M.R. Electrical Service LLC 115 Heyward Street Brooklyn NY 11206	Requesting permission to install new service equipment in a vaulted area under the sidewalk.	135 Middleton Street Brooklyn NY	Approved	\$0.00
51447	12A0305	Litespeed Electric 135 West 29th Street New York NY 10001	Requesting permission on upgrading 3 elevators with new to run unspliced elevator feeders in the elevator shaftways where it will be a hardship to install these feeders outside of the shaftways.	215 Park Avenue South New York NY	Approved	\$0.00
51448	12A0306	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to replace an existing 5KV non Con-Edison utility loop feeder on Governors Island where the fusing , switches, duct banks and manholes are existing.	Governors Island 10 South Street New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**October 17, 2012**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0307	Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	New York Aquarium 514 Surf Avenue Brooklyn NY	On Hold	\$650.00
1) Provide main bonding jumper in switchboard and provide grounding electrode conductor to grounding electrode. 2) Physical of panelboard not provided. 3) AIC of panel is undersized. 4) Provide cutsheets and size of transformer						