

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50715CO		Shelter Electric 53-01 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	120 Schermerhorn Street Brooklyn NY	Approved	\$0.00
1) Generator neutral to be bonded to enclosure. 2) Verify feeds to emergency panel 3 or 4 wire. Job finalized 10/31/11.						
50860CO		C.M.Richey, Inc. Electrical Contractors 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	CVS 300 Park Avenue South New York NY	Hold	\$0.00
Carry over from September 14, 2011 meeting. Submittal not in Advisory Board format.						
50869CO		All American Electric Corp. 508 Lefferts Avenue Brooklyn NY 11225	Requested approval for the electric service equipment proposed to be installed	George Washington H.S. 549 Audobon Avenue New York NY	Hold	\$0.00
Carry over from September 14, 2011 meeting. 1) Verify length of tapped conductor, not over 25' to the overcurrent protective device, tap of a tap not acceptable. 2) Advisory Board rules must be followed.						
50887CO		California Pulse, Inc. 23433 Keator Road Apple Valley CA 92307	Requested approval for equipment for use in New York City of your Electric heater line for spray booths.		Approved	\$0.00
Carry over from September 14, 2011 meeting.						
50888		Pace Electrical Contractors Inc. 179-02 150th Avenue Jamaica NY 11434	Requested approval for the electric service equipment proposed to be installed	37 Warren Street New York NY	Approved	\$650.00
1) Service entrance conductors undersized. 2) Confirm clearance behind distribution section is less than 12". Job finalized 12/28/11. 5/15/14 Swapped 1 of 2 and 2 of 2 Rev 5's.						

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50889		Roz-A-Lite Electric 163 20th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	Brooklyn Brewery(Phase II) 79 North 11th Street Brooklyn NY	Approved	\$650.00
Confirm primary switches have adequate closing rating for transformer inrush current. Job finalized 11/30/11.						
50890		Ace Electl Constn Expert Corporation 40-04 73rd Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	11-15 Broadway Astoria NY	Approved	\$650.00
50891		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Gotham West Building B 530 West 45th Street New York NY	Rejected	\$650.00
Provide neutral bond in service end box. Job finalized 12/15/11. 12/1/15 Rejected. Revision 4 drawings were originally approved. New Rev 4 drawings don't show any revisions. 4/1916 Swapped drawing 1 and 2-Revision 5.						
50892		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	116 John Street New York NY	Approved	\$650.00
<p>1) Block off rear of service "B". 2) Panel "ADB-B" bus last section undersized. 3) #2 tapped conductor undersized, service "A". 4) Correct designation for FA ATS. 5) Indicate correct location for FA disconnect on 'N' side. 6) Correct feeder size on meter sockets. Job finalized 11/10/11. 9/10/13 Drawings swapped for Rev. 6. 5/28/15 Swapped 1, 2, & 3 Revision 7. With the stipulation:</p> <p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Fire rated RHH conductors are to be installed as per the manufacturer's installation instructions. 						
50893		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens West Building 2 45-45 Center Blvd. Long Island City NY	Hold	\$650.00
1) SS 7B overused for feeder. 2) SMB-4A and SMB 4-C panels do not have mains. 3) Service "A" Trans S cabinet neutrals bonded after service switches. 4) Service "A" equipment grounding conductors to fire pumps are undersized. 5) Provide calculations for reduced neutral. 6) Provide ss for DP-R. maintain code limit on max ss per take off.						

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50894		Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	World Wide Plaza 825 8th Avenue New York NY	Approved	\$650.00
50895		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	29 Flatbush Avenue Brooklyn NY	Approved	\$650.00
Provide calculations for neutral reduction. Job finalized 11/15/11.						
50896		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Gotham West Building A 550 West 45th Street New York NY	Approved	\$650.00
1) Provide wiring method on load side of service switch "3B". 2) Vertical bus load side of 1600 amp service switch undersized,. 3) Confirm coordination with meter banks. 4) Confirm adequacy of closing rating on ssw 2A for transformer inrush current. 5) Confirm serv A service conductors are cable from end box to CT. Job finalized 12/15/11.						
50897		Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	60 East 8th Street New York NY	Approved	\$650.00
50898		C.Q. Electrical Contracting Corp. 31-19 37th Avenue Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	260 East 161st Street Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50899		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Columbia University Broadway and 218th Street New York NY	Hold	\$650.00
1) General notes not on drawing. 2) Incorrect address listed in Title Block. 3) Is job being installed under the 2005 or 2008 Electrical Code? 4) Grounding and bonding not shown. 5) Class R fuse max available size is 600A. 6) Coordination information on drawing w/8 1/2"x11 sheets.						
50900		Pappas and Fodera Electl Contrs 15 Ingraham Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	Royal Waste 187-10 Jamaica Avenue Queens NY	Ok, but	\$650.00
1) Verify that service room is mechanically ventilated. 2) Confirm wiring trough does not obstruct access to new 2000A switch. 3) Confirm closing rating of 2000A switch is adequate for transformer inrush.						
50901		Broadway Electric, LLC 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	NY Hilton Hotel 1335 Sixth Avenue New York NY	Hold	\$650.00
1) Provide length of tapped conductors. 2) Provide listing documentation of Co-gen units. 3) Confirm clearance between serv D sw and ATS C. 4) Indicate new/exist on single line. 5) Coordination DP-panels sizes. 6) Co-gen units should not have N-G connection. 7) Coordination swbd to correct tap location. 8) Provide sequence of operation w/exist fuel cell.						
50902		Pappas and Fodera Electl Contrs 15 Ingraham Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	Modell's Sporting Goods 1500 Bassett Avenue Bronx NY	Approved	\$650.00
Primary switch undersized. Job finalized 3/28/12.						
50903		Quantum Electric Corporation 36-24 34th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Fibernet/Zcolo 60 Hudson Street, 19th Floor New York NY	Approved	\$650.00
1) Confirm proper GFP operating w/generator neutral not bonded @ generator. 2) Confirm all existing ATS are 3 pole. Job finalized 3/7/12..						

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50904		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	All City Leadership Secondary 321 Palmetto Street Brooklyn NY	Approved	\$650.00
Verify size of service entrance conductors to fire pump service switch. Job finalized 10/31/11						
50905		Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1412 Broadway New York NY	Approved	\$650.00
Verify that Con Ed is feeding the end box. Job finalized 2/27/12.						
50906		Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	NYU Langone Medical Ctr 240 East 38th Street New York NY	Hold	\$650.00
1) Conductors feeding emergency switches are undersized for the OVPD's. 2) Emergency fire alarm switch to be fed from line side of generator main switch. 3) How long is the tapped conductor to service Switch B? 4) Where is new emergency located? 5) Confirm EDPH will not support required life safety loads. 6) Provide plan layout for EDPH.						
50907		Alef Electric Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Zuberry Development Corp. 311 West 43rd Street New York NY	Approved	\$650.00
1) Provide detail of Polaris connectors used in pullbox. 2) Confirm coordination w/KDC breakers. Job finalized 12/5/11.						
50908		Demand Electric, Inc. 1219 Rockaway Avenue Brooklyn NY 11236	Requested approval for the electric service equipment proposed to be installed	Linden Guild Hall 3859 Third Avenue Bronx NY	Hold	\$650.00
1) Clarify section bus location in switchboard. 2) Service bus to 3 600 amp service switches undersized. 3) "Service bus to 1600 amp service switch undersized. 4) Supplemental ground not shown. 5) Feeders to "MDB" board overfused. 6) AIC not shown (meter banks). 7) Short circuit calculations not provided. 8) Neutral link not shown for 600A ss.						

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50909		erified Electrical & Technical Services, In 27 William Street, Suite 409 New York NY 10005	Requested approval for the electric service equipment proposed to be installed	341 9th Avenue New York NY	Approved	\$650.00
50910		Patriot Electric Corp. 96-06 220th Street Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	1230 3rd Avenue New York NY	Approved	\$650.00
50911		Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Dept. of Environmental Protection North River WPCP New York NY	Hold	\$650.00
1) Fused disconnect switch required for portable generator. 2) Do rear clearances of new equipment comply with Table 110.34A. 3) Provide power single line. 4) Provide OCP @G3 connection.						
50912		Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Detschue Bank 60 Wall Street New York NY	Hold	\$650.00
1) Tapped conductor undersized to EDP-C H1. 2) Verify that new equipment has rear doors. 3) Service room door to open outwards 4) Redesignate swbd ESG as "standby". 5) Add GFP to new service switch. 6) Recheck feeder size to 'E' term of ATS. 7) Show N-G bond, modify N-G strap @ TVSS and exist 4000A sw to suit. 8) New ATS to be 4 pole. 9) Correct feeder size for gen. to suit gen. Fla. 10) Indicate OCP for exist SBF.						
50913		Five Stars Electrical Contracting NY Inc. 82-31 51 Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	150 Delancey Street New York NY	Hold	\$650.00
Submittal did not contain drawings.						

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50914		A & R Electrical Maintenance, Inc. 64-14 69th Place Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	1071 Tinton Avenue Bronx NY	Approved	\$650.00
Equipment grounding conductor to fire pump undersized.. Job finalized 12/5/11.						
50915		Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	200 East 79th Street New York NY	Approved	\$650.00
Show generator on drawing. Job finalized 11/15/11. 7/31/15 Swapped Drawings 1,2 and 3-Revision 3s. 4/19/16 Swapped drawing 1,2 and 3-Revision 4s.						
50916		S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	45--60 Center Blvd. Long Island City NY	Approved	\$650.00
1) Fire pump branch circuit undersized and not fire rated on load side of service switch. 2) Fire pump service entrance conductors not derated, undersized. Job finalized 12/15/11.						
50917		FSM Electrical Corp. 36-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	54 West 13th Street New York NY	Approved	\$650.00
1) Fire pump section bus connected to neutral. 2) Special service fire pump circuit to be ran in rigid galvanized steel or intermediate conduit. Job finalized 12/15/11.						
50918		Joseph K, Blum Co., LLP 6 East 39th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	200 West 86th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50919		Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	138 West 27th Street New York NY	Approved	\$650.00
Verify if emergency feeders are being ran through the service room, if yes they must be fire rated. Job finalized 11/21/11.						
50920		P2 Electric, Inc. 416 Graham Avenue Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	240 Park Avenue South New York NY	Approved	\$650.00
50921		Taft Electric Co., Inc. 3155 College Pt. Blvd. Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	Ormonde 30 Broadway a.k.a 154 West 70th S New York NY	Ok, but	\$650.00
Verify section bus size on far left section of distribution panel.						
50922		Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	AIG 180 Maiden Lane New York NY	Hold	\$650.00
1) Drawing not submitted in Advisory Board format. 2) Line side equipment grounding conductor undersized.						
50923		Apollo Electric, Inc. 212 West 29th Street, 2nd Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Club 40/40 6 West 25th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50924		Litespeed Electric, Inc. 135 West 29th Street, Suite 301 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	NYU Stern School of Business 40 West 4th Street New York NY	Approved	\$650.00
Equipment grounding conductor undersized to fire pump. Job finalized 10/31/11.						
50925		Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Sullivan & Cromwell 125 Broad Street New York NY	Approved	\$650.00
1) Install new switches so that switches ratings don't exceed 1100 amps. 2) Was new switch installed in ASCO switchgear? Show bus sizes, grounding and bonding. 3) Verify that ATS "B" is not misidentified, normal and emergency. 4) 800 amps fuse on 600 mcm emergency side. Job finalized 11/29/11.						
50926		B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	The Strand Theater 647 Fulton Street Brooklyn NY	Approved	\$650.00
4/18/14 Swapped A-Rev 3 D-Rev 5 ok. Drawing C-Rev 4, B-Rev 6 already swapped 8/14/12.						
50927		Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Brooklyn College-James Hall 2910 Bedford Avenue Brooklyn NY	Hold	\$650.00
1) 5 feet clearance required in rear of 4160V switchgear. 2) 1 line and room layout drawing don't match medium voltage fusing. 3) Parallel conductors minimum size must be 1/0. 4) Verify wire bending radius on medium voltage cables. 5) Provide transformer cut sheet 4160.						
50928		Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Fire Pump Replacement 285 Madison Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50929		Five Stars Electrical Contracting NY Inc. 82-31 51 Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Hyatt Place 52-54 West 36th Street New York NY	Approved	\$650.00
1) Provide neutral bond in 800 amp service switch. 2) Increase the size of neutral bonding jumper.. Job finalized 12/5/11.						
50930		B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Courtlandt Crescent 383 East 162nd Street Bronx NY	Approved	\$650.00
1) Verify sizing of the fire pump service conductors and fire pump switch size. 2) Equipment grounding conductor to fire pump undersized. Job finalized 2/27/12.						
50931		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	NYU Generator Feeder 550 First Avenue New York NY	Denied	\$650.00
1) 5 sets of 500 MCM fused at 3200 amps are conductors AL or copper. 2) Clarify how many sets of conductors are running from 3200 amp switch to 3200 amp switch. 3) What is the length of the tapped conductors.						
50932		Alef Electric Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	530 Seventh Avenue New York NY	Approved	\$650.00
1) Verify if pump is limited service on fire pump. 2) Tap if for fire pump can't be made in the same enclosure that contains overcurrent protective devices. Job finalized 11/29/11.						
50933		Wesler-Cohen Associates Consulting Engs 740 Broadway Amityville NY 11701	Requested approval for the electric service equipment proposed to be installed	Staten Island Stapleton Marine 9 FDNY Staten Island NY	Hold	\$650.00
Submittal not in Advisory Board format.						

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50934	-	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	1560 Broadway New York NY	Approved	\$650.00
50935	-	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	487 Keap Street Brooklyn NY	Hold	\$650.00
<p>1) 1600 amp switchboard undersized for 3-600 amp service switches. 2) Service entrance conductors to service switchboard undersized, 1800 amps of copper required. 3) Neutral disconnect link to be installed on load side of all bonding and grounding. 3) Provide short circuit calculations showing 10 KAIC circuit breakers are acceptable. 4) Service entrance end box bus misidentified as 2000 should be 2800 amps by the size of the bus in the end box.</p>						
50936	-	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mout Sinai School of Medicine 1470 Madison Avenue New York NY	Hold	\$650.00
<p>1) Describe equipment in front of switchboard. 2) 3 feet needed on sides of switchboards. 3) Show clearances in back of switchboard Table 110.26(A) Condition 3. 4) Provide approved continued drawing 50565 one line for emergency side fusing. 5) Show conductors off of emergency side ATS #9 and panel "EDP-ELB" panel. 6) Provide ground fault indication for emergency switchboard. 7) Neutral disconnect link in emergency board bonded to enclosure on load side of link. 8) Show fire pump utility feed for all fire pumps. 9) Provide physicals for all new distribution boards. 10) Vertical bus in ASCO board not provided.</p>						
50937	-	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	250 West 55th Street New York NY	Rejected	\$650.00
<p>1) Service room door to open outwards. 2) Load side of fire pump circuits to be fire rated. 3) Load side of fire pump #3 equipment grounding conductor undersized. 4) Emergency fire pump branch circuits not fire rated. 11/18/14 Swap Rejected Equipment grounding conductor undersized for revised. 12/17/15 Swapped drawing FP-Revision 5; AB-1-Revision 4; AB-2-Revision 3 and AB-3-Revision 3. 10/28/16 Rejected. Drawings were revised several times before latest revisions and were not identified on the drawings. Fire rated conductors to be installed as per UL 25A, conduit cannot be used for fire rated conductors, new submittal required.</p>						
50938	-	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to omit disconnecting means for emergency system feeders where the generator is located in a remote building	Mt. Sinai 10 East 102nd Street New York NY	Approved	\$0.00
<p>With the stipulation that approval from other jurisdictions may apply. Code: 225.32 and 225.34(B).</p>						

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50939		New York City Housing Authority 90 Church Street New York NY 10007	Requesting permission for 34 buildings under going elevator upgrades to allow new unspliced elevator feeders to be run inside of the levator shaftway.	Bland, Low, Wyckoff Gdns etc, See comments for list of addresses Various boro	Approved	\$0.00
40-25 and 40-05 College Pt. Blvd., 133-20, 133-40 and 133-50 Roosevelt Ave., Queens; 70, 60, 50, 40, 30, 20 and 10 Paladino Ave., 2370, 2360, 2369, 2375, 2385, 2395 and 2405 First Ave., 2390 and 2400 Second Ave., 350 East 124th St.,Manahttan; 180 Powell St, 131 and 157 Belmont Ave., 365 Sackman St., 130 Third Ave., 185 Nevins St., 272 Wyckoff St., and 447 Kingsborough 4th Walk, Brooklyn; 90, 80 Paladino Ave., 505 and 445 East 120th St., Manhattan. Code: 620.37(c)(1).						
50940		Laser Lite Electrical, Inc. 40 Gaton Street Staten Island NY 10309	Requesting permission to leave as installed service equipment installed on the outside of a building where one service provides power to a commercial space and the other service provides power to an apartment where there wasn't any indoor space available to install the equipment. Permanent signage will be installed at each service indicating where the other service is located.	2109 Victory Boulevard Staten Island NY	Approved	\$0.00
Code 230.70(A)(1)						
50941		Perfection Electric LLC 29-07 119th Street Flushing NY 11354	Requesting permission to install service equipment outdoors in a Nema 4 weatherproof cabinet that will provide power to a free standing electric sign.	Whitestone Lanes Bowling Alley 30-05 Whitestone Expressway Flushing NY	Approved	\$0.00
50942		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to omit the laundry area receptacle outlet in 327 apartments where there is no space inside the laundry closet to install the receptacle.	29 Flatbush Avenue Brooklyn NY	Denied	\$0.00
With the stipulation that the required laundry receptacle is installed on a wall outside closet to the laundry area. Code: 210.11(c)(2) and 210.52(F).						
50943		Kenneth Fisk Electric Corporation 72-02 Cooper Avenue Glendale NY 11385	Requesting permission to install rigid non metallic conduit on the outside of a one family building to power a second floor air conditioner.	144-23 68th Road Kew Gardens NY	Approved	\$0.00
Code: 225.10.						

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50944		Kallen & Lemelson Consulting Engs, LLP 520 Eighth Avenue, 17th Floor New York NY 10018	Requesting permission to install rigid nonmetallic conduit and PVC coated rigid metallic conduit in a corrosive environment New York aquarium.	New York Aquarium Surf Avenue and West Street Brooklyn NY	Approved	\$0.00
Code: 352.10(B) and 352.10(J)						
50945		Sterling Electric Inc. 863 Sterling Place Brooklyn NY 11216	Requesting permission to leave as installed existing (9) sets of 500MCM cables between the property line box and the service switchboard. The existing switchboard has (2) 2000A service switches both metered via one Con Ed CT cabinet. The building has subleased the 5th floor and the owner wants to meter their load separately. No additional loads will be added to the building. The existing fuses in both 2000A service switches will be 1500 each. A sign will be added to the front of the service indicating 1500A max fuse size for both service switches. The new service switch will be 400A. Existing service conductors are rated for 3,420 amps and the sum of the service switch fuses will be 3,400 amps.	Try Whitefield School 17 Hinsdale Street Brooklyn NY	Hold	\$0.00
Provide load letter from Con Edison. Code: 230.42(A)(2).						
50946		Samson Electric Corp. 498 7th Avenue, Bsmt New York NY 10018	Requesting permission to install a 2500 amp service switch with a front clearance of 48 inches to eliminate an excessive run of service entrance conductors in a 1000 KVA service room	World Wide Plaza 825 8th Avenue New York NY	Approved	\$0.00
Code: 230.64(B)(1)						

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50947		AKF Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to add a battery system with an AC inverter which will interconnect with primary power source by means of dedicated ATS' that will provide power to operate the fire alarm system 24 hours in standby mode followed by 45 minutes in full alarm in an existing 10 story class E (old code) office building where the owner wishes to provide emergency operation of the FA system in the event of a power failure.	49 East 52nd Street New York NY	Approved	\$0.00

With the stipulation that approval from other jurisdictions may apply.

50948		Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requesting permission to leave as installed due to a hardship to replace, AC cable that does not contain an insulated equipment grounding conductor as a wiring method in a place of assembly	601 East 156th Street Bronx NY	Approved	\$350.00
-------	--	--	---	-----------------------------------	----------	----------

50949		W.M. Sanfardino Electric, LTD 1303 Blondell Avenue Bronx NY 10461	Requesting permission due to lack of space inside the commercial building to install new service equipment on the outside of the building and not group it together with existing service equipment where signage will be provided at both service locations indicating where the other services are located.	2270 Kimball Street Brooklyn NY	Approved	\$0.00
-------	--	---	---	------------------------------------	----------	--------

Code: 230.71(A)(1) and 230.72(A).

50950		Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requesting permission due to lack of space inside of the electrical service room to locate a new 800 amp service approximately 60 feet away to a new electrical service room on the second floor	2276 12th Avenue New York NY	Approved	\$0.00
-------	--	---	--	---------------------------------	----------	--------

Code: 230.70(A)(1).

ADVISORY BOARD CALENDAR

October 19, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50951		Sprayline Manufacturing Company 10110 Geenleaf Avenue Santa Fe Springs CA 90670	Requested approval for equipment for use in New York City of your Spraybooth Product Line		Approved	\$200.00
50952		Cable Management Solutions, Inc. 291 Skip Lane Bay Shore NY 11706	Requested approval for equipment for use in New York City of your UL 183 Manufactured Wiring Device. Model/Series Numbers: CM 707 Series.		Denied	\$200.00
Article 604 wiring systems are prohibited for under floor installations See, 2008 NYC Amendment 604.1(A)(3).						
50953		Skanska 85 St. Nicholas Terrace New York NY 10031	Requesting Concept Approval of the electrical room layout	CUNY/ASRC 85 St. Nicholas Terrace New York NY	Approved	\$0.00
With the recommendation that two additional doors are installed at the center of the front and back of the customer distribution switchgear.						