

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

**MEA 107-00-E
Report of Material and Equipment Acceptance Division**

Manufacturer– Rheem Manufacturing Company, 2600 Gunter Park Drive East, Montgomery, Alabama 36109.

Trade Name – General Electric.

Product – Gas fired hot water heaters.

Pertinent Code Section(s) – 27-800, P107.26, RS 14-2 (ANSI Z223.1).

Prescribed Tests–RS 14-6 (ANSI Z21.10.1).

Laboratory –Canadian Standard Association.

Test Report(s) – 10-(31E, 31F, 58A, 58B, 58C, 59C, -22M), 112628-29.

Description – Gas fired, automatic storage, water heaters, designed for residential installation. Unit comprises a glass-lined storage tank with foam insulation, aluminized steel main burner, adjustable thermostat with temperature limiting control and gas pressure regulator, and draft hood. Water heaters are hydrostatically pressure tested for 150 psi working pressure. Units with model numbers, storage capacities and input heating ratings are listed below:

Model No.	Storage Capacity Gallon	Input Heating Rating BTUH
GG40S6A	40	28,000
GG30S6A	30	26,000
GG50T6A	50	36,000
GG40T6A	40	38,000
HG40T1A	40	30,000
GG30T6A	30	32,000
HG30T1A	30	27,000
GG75T6A	75	75,000
PG50T9A	50	40,000
SG50T12A	50	40,000
GG50T6EA	50	40,000
PG40T9A	40	40,000
SG40T12A	40	40,000
GG40T6EA	40	40,000
PG40S9B	40	40,000

Notes: Units may be installed in combustible flooring. Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Recommendation - That the above described residential water heaters, be accepted, when fired by natural gas only, under the following conditions:

1. Automatic ASME listed temperature and pressure relief valve, properly sized for heater and MEA accepted, and operating temperature limit control, shall be furnished for heater installation.
2. Heaters shall not be installed in any enclosed space with a volume of less than 100 cubic feet.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.
5. Water heaters shall not be operated until installation is approved for such operation by the Gas Company and the model has been approved by the Gas Appliance Approval Committee of the New York City Department of Health.

AUG 24 2000

Final Acceptance _____

Examined By S Derkhdam