

ADVISORY BOARD CALENDAR

November 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48217CO	07A0478CO	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	333 East 91st Street New York NY	Approved	\$0.00
Carry over from October 17, 2007 meeting.						
48280	07A0525	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	SUNY Downstate 760 Parkside Avenue Brooklyn NY	Approved	\$650.00
48281	07A0526	Infinity Electrical Contractors, Inc. 22-10A 35th Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	20 Maiden Lane New York NY	Hold	\$650.00
No Drawings.						
48282	07A0527	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	270 Park Avenue New York NY	Approved	\$650.00
1) Verify bus size not provided on new MSCB #38 and MSS #16'. 2) Ground fault protection not provided on 2 new 1600 amp 277/480 disconnect switches load side unknown. 3) Identify intent of "future" on new utility switchboard and new emergency switchboard. 4) Confirm 4-pole on existing ATS's. Job finalized 12/4/07.						
48283	07A0528	High-Tech Electrical Services Corp. 36-33 23rd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Evolution 104 West 40th Street, 18th Floor New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48284	07A0529	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	40 East 66th Street New York NY	Approved	\$650.00
48285	07A0530	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	85 West Broadway New York NY	Approved	\$650.00
48286	07A0531	Olympic Electrical Wiring Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	75 Smith Street Brooklyn NY	Approved	\$650.00
48287	07A0532	Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	74 DeKalb Avenue Brooklyn NY	Approved	\$650.00
48288	07A0533	On Demand Electrical Services Inc. 725 East 135th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	545 West 45th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48289	07A0534	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Bronx Terminal Mkt-Bldg. "B" East 149th Street Bronx NY	Approved	\$650.00
1) Provide short circuit current at POE. 2) Show support ground lug. Job finalized 12/4/07.						
48290	07A0535	Eric & Ng Electrical, Inc. 155 Suffolk Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	235 Canal Street New York NY	Approved	\$650.00
48291	07A0536	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	63 West 35th Street New York NY	Approved	\$650.00
48292	07A0537	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	20 West 37th Street New York NY	Approved	\$650.00
48293	07A0538	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Gary Plastics 1341 Ryawa Avenue Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48294	07A0539	Lestev Electric Corp. 325 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	711 Seagirt Boulevard (Blvd. A) Far Rockaway NY	Approved	\$650.00
48295	07A0540	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Disney/New Amsterdam Theatre 214 West 42nd Street New York NY	Approved	\$650.00
48296	07A0541	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University Data Ctr 1130 St. Nicholas Avenue New York NY	Approved	\$650.00
48297	07A0542	AARCO Electrical Contractors 5902 Avenue N Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	75 Worth Street New York NY	Approved	\$0.00
48298	07A0543	Christopher Jon Electrical, Inc. 108 Frost Street Brooklyn NY 10014	Requested approval for the electric service equipment proposed to be installed	414-418 West 14th Street New York NY	Approved	\$650.00
Load side bus on 3000A service switch is undersized. Job finalized 01/11/08.						

ADVISORY BOARD CALENDAR

November 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48299	07A0544	Broadway Electric 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Isabella 410 West 13th Street New York NY	Approved	\$650.00
Neutral bonded to enclosure on load side of neutral link in 1200 amp service switch, load side 3 sets of 500 MCM fused at 1200 amps undersized. Job finalized 12/17/07.						
48300	07A0545	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYPH 523 East 70th Street New York NY	Hold	\$650.00
Have engineer/contractor appear at next available meeting.						
48301	07A0546	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Yeshiva University 2520 Amsterdam Avenue-1st Floor New York NY	Approved	\$650.00
5' clearance needed in front of new service switch. Job finalized 12/4/07.						
48302	07A0547	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metropolitan Television Alliscane 500 19th Street Brooklyn NY	Hold	\$650.00
1) Verify that there is no tap of a tap feeding the existing 400 and 200 amp disconnect switches. 2) One line diagram does not match room layout. 3) Is service room ventilated.						
48303	07A0548	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	PS 59M 213 East 63rd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48304	07A0549	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Hunters View 48-15 11th Street Queens NY	Approved	\$650.00
1) Block off back of distribution Board "B". 2) Change 600 amp fuse to A2D in distribution Board B. Job finalized 12/4/07.						
48305	07A0550	Michael Schondorf, Inc. 545 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	224 12th Avenue New York NY	Approved	\$650.00
1) Bus feeding two 1200 amp service switches is undersized. 2) Fire pump service switch is undersized should be 1200. 3) Show bus size off load of 2500 amp service switch. 4) Fire pump conductors undersized. Job finalized 12/4/07.						
48306	07A0551	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1760 Third Avenue New York NY	Approved	\$650.00
1) Bus feeding two 1200 amp service switches is undersized. 2) Fire pump service switch is undersized should be 1200. 3) Show bus size off load of 2500 amp service switch. 4) Fire pump conductors undersized. Job finalized 12/4/07.						
48307	07A0552	lennium Maint. & Electrical Contractors, I 201 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Lincoln Center 132 West 65th Street New York NY	Approved	\$650.00
1) Change 600 amp fuses in DP-C to A4BY's. 2) Change bus duct fuses to A2KS. Job finalized 12/17/07.						
48308	07A0553	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	122 West Street Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48309	07A0554	G.S.H. Electric Inc. 491 East 166 Street Bronx NY 10456	Requested approval for the electric service equipment proposed to be installed	Jefferson High School 400 Pennsylvania Avenue Brooklyn NY	Approved	\$650.00
48310	07A0555	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens West Building #7 4-76 47th Avenue Long Island City NY	Approved	\$650.00
48311	07A0556	Power Tech Electric Corp. 245 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	200 West 57th Street New York NY	Approved	\$650.00
48312	07A0557	P.J. Dempsey & Co. Electrical Contrs Inc. 151-45 6th Road Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	545 West 45th Street New York NY	Approved	\$650.00
Tap of a tap not allowed, disconnect one set in tap box. Job finalized 12/17/07.						
48313	07A0558	Hy-Lee Electric Co. Inc. 11-52 44th Drive Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Gertz Mall 162-10 Jamaica Avenue Jamaica NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48314	07A0559	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Dare to Dream Tour 350 Fifth Avenue New York NY	Approved	\$650.00
1) Conductors must comply with tap rules for new disconnect switches. 2) Show selectivity between new panel and serve switch. Job finalized 3/27/08.						
48315	07A0560	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Commerce Bank 1873 Broadway New York NY	Hold	\$650.00
1) Drawing not in Advisory Board format. 2) Show tap detail inside of existing trough. 3) Load side of disconnects feeding line side of same switches. 4) Bonding and grounding not shown on drawing.						
48316	07A0561	Dooley Electric Co., Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Lasdon House 404-420 East 70th Street New York NY	Approved	\$650.00
48317	07A0562	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New York Hospital Queens 56-45 Main Street Queens NY	Hold	\$650.00
1) Show conductor and conduit sizes and types. 2) Equipment must ground fault protected. 3) Clarify size and amount of conductors on load side of medium voltage switch. 4) Show clearance detail between 5KV switch and transformer and show elevation. 5) Neutrals bonded after service switches in MSDPH-B. 6) Designer must appear at next meeting when drawings are corrected.						
48318	07A0563	A.L. Electrical Corp. 307 7th Avenue, Suite 404 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	4433 Victory Boulevard, 1st Floor Staten Island NY	Hold	\$650.00
1) Show 2000 amp MDP panel how circuit breaker is attached to existing service substation SST-1. 2) E11, Page 12 of 16 show manufacturer & build details and room layout with clearance details. 3) E-13 show manufacturer detail of MDP. 4) Provide room layout. 5) Designer to appear at next meeting when drawings are corrected.						

ADVISORY BOARD CALENDAR

November 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48319	07A0564	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	101 Ludlow Street New York NY	Denied	\$650.00
1) 7 foot clearance needed between 1600 and 3000 amp service switches. 2) Fire pump circuits normal and emergency not fire rated. 3) No neutral bond in 1600 amp service switch. 4) Bonding, grounding and neutral disconnect link not in 3000 amp switch section. 5) Provide cut sheets. 6) Fire pump service switch must be separated 12" from switchboard. 7) Tap lengths not provided.						
48320		Village Electric 187-20 Baisley Blvd. St. Albans NY 11412	Requesting permission to install overhead service entrance conductors in Schedule 80 non metallic conduit for a 2 family building located in a corrosive area, Far Rockaway, Queens	125 Beach 4th Street Far Rockaway NY	Approved	\$0.00
48321		Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requesting permission to install underground concrete encased service lateral conductors in either Schedule 40 non metallic conduit, fiberglass reinforced epoxy conduit or concrete ducts that will provide power to a building.	Central Park Police Precint 830 5th Avenue at 86th Street New York NY	Approved	\$0.00
With the stipulation that one of the wiring methods listed above be installed.						
48322		Doshi Consultants 66-15 Wetherole Street, Suite #B17 Rego Park NY 11374	Requesting permission to tap power for the fire alarm cut-out from the line side of the tenants main distribution panel where the new fire alarm panel will have battery back up.	Chrysler Building 405 Lexington Avenue New York NY	Approved	\$0.00
With the stipulation that the installation complies with Section RS 17-3 of the New York City Building Code and the installation is subject to other jurisdictions.						
48323		Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requested permission to not group together service equipment in a building where a new service is being installed to provide power for one receptacle outlet, signage will be provided at each service indicating where the other service is located	3276 Layton Avenue Bronx NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48324		Sanitation Bureau of Building Maintenance 52-35 58th Street Woodside ny 11377	Requesting permission to leave as installed a service switch mounted outside of the building due to lack of space inside of the building	1 Muldoon Avenue Staten Island NY	Approved	\$0.00
48325		C & S Engineers, Inc. 499 Col. Eileen Collins Blvd. Syracuse NY 13212	Requesting permission to leave the door to the electrical service room to swing in instead of swinging out due to the door swinging out into public egress space in a building being electrically upgraded.	2185 Bathgate Avenue Bronx NY	Denied	\$0.00
48326		Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval for the installation of a Solar photovoltaic system where the solar modules will be custom made and field evaluated, to connect the grounding electrode for the PV system to the 4th floor ground bus and waive Section 690.64(B)(2) for this installation.	41 Cooper Square New York NY	Approved	#Error
48327		altPower, Inc. 125 Maiden Lane, Suite 307 New York NY 10038	Requesting permission due to the photovoltaic system being installed prior to the adoption of 2005 NEC to waive requirements of 690.1 on a job where the 2.4 kw system will be paid for by the senior class of 2006, all equipment is listed.	Dalton School 108 East 89th Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 14, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48328		Sambar Electric Corp. 314 Nelson Avenue Staten Island NY 10308	Requesting permission on a job where the DOB permit states "construct 2nd floor and associated interior renovations, 2 stories, 1 building," to install 2 new meters on Building A and feed Building B located in rear of Building A	340 Wilson Avenue Staten Island NY	Hold	\$0.00