

ADVISORY BOARD CALENDAR

November 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0312	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	175 Water Street New York NY	On Hold	\$650.00
1) All new or temporary wiring to be bubbled, are generators existing or new. 2) How long will the temp wiring be in service prior to service equipment replacement. 3) How are temp conductors run, overhead, on floor, or cable trays. 4) Free air ratings to comply with electrical code.						
	12A0125CO	Enterprise Electrical Systems, Inc. 40 Emerson Court Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	291 Union Street Brooklyn NY	Denied	\$0.00
Carry over from July 18, 2012 meeting. 1) Type of fuses in meter banks not shown. 2) The type of circuit breakers in panel PPRZ not shown. 3) The circuit breakers in the main panel are not adequate for available short circuit current, cut sheet not submitted. 4) Coordination curves not provided. 5) Equipment grounding conductors undersized.						
	12A0197CO	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Middle College H.S. 4535 Van Dam Street Queens NY	On Hold	\$0.00
Carry over from September 12, 2012 meeting. 1) Panel MDSB2A to have main overcurrent protective devices 408.36 and items 3,6, and 8 not addressed. 2) MDSB-2A does not comply with 10' tap rule.						
	12A0314	Innovative Electrical Services 3346 Provost Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	Amerigroup 14 Wall Street New York NY	Pending	\$650.00
1) Length of tap not shown on drawing. 2) Verify the number of conduits being installed. 3) Verify address of project, drawing and application. 4) Reduce fuse size to 3500A or increase cable to 4000A.						
	12A0327	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Target Store 2873 Richmond Avenue Staten Island NY	On Hold	\$650.00
1) Equipment grounding conductors for fire alarm system undersized. 2) Indicate what is new and existing on drawings. 3) Provide physical separation at gen board between em and non-life safety loads. 4) Use NYC approved switches for fire alarm service switches. 5) Min service switch size is 60A for 3 phase. 6) Min #10 ground for fire alarm power circuits.						

ADVISORY BOARD CALENDAR

November 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	10A0478CO	Universal Electric Corporation 168 Georgetown Road Canonsburg PA 15317	Requesting approval for use in New York City of you Starline Track Busway and Starline Plug-in Raceway Model/Series Numbers: B400, B400N, B400G, B400NG and Accessories & SB20, SB20G, SB40. SB40G, SB60, SB60G and Accessories.		On Hold	\$0.00
Carry over from December 22, 2010 meeting. Not Reviewed.						
	12A0321	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	JPMC 1 Chase Manhattan Plaza New York NY	On Hold	\$650.00
1) Provide cut sheets of reactor. 2) Short circuit study not provided. 3) Feeder schedule to be on single line drawings.						
50880CO	12A0308	Arc Electrical & Mechanical Contrs Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Newtown Creek Water Pollution 329 Greenpoint Avenue Brooklyn NY	Denied	\$0.00
Carry over from September 14, 2011 meeting. Submittal not in Advisory Board format.						
51450	12A0311	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Brookfield Properties 245 Park Avenue New York NY	Rejected	\$650.00
2/13/17 - Show 2nd fuse for new 600 a sw						
51451	12A0313	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	Skirball Building 540 1st Avenue New York NY	Approved	\$650.00
7/15/14 AB50-01-Rev 1 amd SB50-01-Rev 1. 9/29/14 Swapped AB50-01, Rev 2 and SB50-01, Rev 2.						

ADVISORY BOARD CALENDAR

November 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51452	12A0315	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU School of Medicine 550 1st Avenue New York NY	Approved	\$650.00
51453	12A0316	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Charleston Enterprises LLC 2720 Veterans Road West Staten Island NY	Approved	\$650.00
51454	12A0319	Euro Electrical Contracting Inc. 4601 White Plains Road Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	Center for Jewish History 15 West 16th Street New York NY	Approved	\$650.00
3/25/14 Swapped Revision 1.						
51455	12A0320	A.L. Electrical Corp. 307 7th Avenue, Suite 404 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	120 Riverside Blvd New York NY	Approved	\$650.00
51456	12A0323	Small Electrical Construction, Inc. ashing Avenue, Unit 338, Bldg #3, Suite # Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	Verizon 140 West Street New York NY	Approved	\$650.00
12/20/13 Swapped Revision 1.						

ADVISORY BOARD CALENDAR

November 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51457	12A0324	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	2889 Richmond Avenue Staten Island NY	Approved	\$650.00
11/27/13 Swapped C-Rev 1, D-Rev 2.						
51458	12A0325	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Park West H.S.(M) 525 West 50th Street New York NY	Approved	\$650.00
11/27/13 Swapped C-Rev 1, D-Rev 2.						
51459	12A0326	Mar-Kam Electrical Contracting Inc. 153 32nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	30-02 48th Avenue Queens NY	Approved	\$650.00
11/27/13 Swapped C-Rev 1, D-Rev 2.						
51481	12A0309	Tribeca Electrical Corp. 107-05 Jamaica Avenue Richmond Hills NY 11418	Requested approval for the electric service equipment proposed to be installed	136 East 76th Street New York NY	Approved	\$650.00
1) Provide load calculations showing that service switches are properly sized or provide full copper to line side of service switches. 2) Provide ampere rating of house panel. 3) Service entrance conductors to new 1200 amp service switch undersized. 4) Show tap detail out of 800 amp service switch. Job finalized 11/30/12. 11/22/13 Dwg Swapped Rev 2						
51482	12A0322	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	JPMC-Temporary Service 1 Chase Manhattan Plaza New York NY	Approved	\$650.00
Feeders to switchboard 1 + 2 are overfused. Job finalized 11/28/12.						

ADVISORY BOARD CALENDAR

November 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51486	12A0310	PS & E Electrical Contractors, Inc. 112-08 Springfield Boulevard Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	200 West Tremont Avenue Bronx NY	Approved	\$650.00
Show all clearances in the service room. Job finalized 12/14/12.						
51506	12A0317	Foster Electrical Service, Inc. 1325 Foster Avenue Brooklyn NY 11230	Requested approval for the electric service equipment proposed to be installed	DCD Marketing 73 Wortman Avenue Brooklyn NY	Approved	\$650.00
1) Specify what type of industrial processing to demonstrate shut down will introduce hazards. 2) Provide alarm only GFI if note #11 is verified. 3) Verify 750KVA is low in-rush current or size secondary trans sw accordingly. 4) Verify 750KVA is DOE compliance. Job finalized 12/26/12.						
51507	12A0329	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	1 Prospect Park West Brooklyn NY	Approved	\$650.00
1) Provide size of equipment grounding conductors. 2) Provide cut sheet of co-gen unit showing its listing. Job finalized 12/20/12.						
51513	12A0330	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Bronx Zoo-Wild Asia 2300 Southern Blvd Bronx NY	Approved	\$650.00
1) Show clearances for E-E, F-F. 2) Install personnel door at each end of switchboard. 12/27/12.						
51554	12A0328	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	5-11 47th Avenue Long Island City NY	Approved	\$650.00
Short circuit calculations not provided at RD retail panel for 22K breakers. Job finalized 1/17/13.						

ADVISORY BOARD CALENDAR

November 14, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51563	12A0194CO	Verified Electl & Technical Services, Inc. 27 William Street, Suite 409 New York NY 10005	Requested approval for the electric service equipment proposed to be installed	1441 Broadway New York NY	Approved	\$0.00
Carry over from September 12, 2012 meeting. Main bonding jumper still not indicated. Job finalized 1/30/13.						
51662	12A0087CO	D & D Electric Contracting Corp. 720 Fifth Avenue, 10th Floor New York NY 10019	Requested approval for the electric service equipment proposed to be installed	237 West 54th Street New York NY	Rejected	\$650.00
Carry over from July 18, 2012 meeting. Provide documentation showing that the transformer can be installed against the walls. Job finalized 5/17/13. 5/16/14 Rejected 3 Revised drawings marked revision 6's when revisions appear to be made on page 1 of 3. No comments were made on pages 2, & 3 of 3. 6/23/14 Swapped drawing 1 of 3, Revision 6. Drawings 2 of 3 and 3 of 3 not swapped due to no revisions stated in the title block 12/19/14 Swap rejected. New submittal required. Room layout not changed. 1 Line to busy with prior change's to follow Rev 7 changes, changes not even hi lighted.						
51782	12A0318	Queue Electrical Contractors, Inc. 58-38 59th Street Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	3861 Nostrand Avenue Brooklyn NY	Approved	\$650.00
Verify TDP-2 has 2 bus @ 1/4 x3" cu. 7/29/13 job finalized						